

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9806220249 DOC. DATE: 98/06/15 NOTARIZED: NO DOCKET #
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251
 AUTH. NAME: AUTHOR AFFILIATION
 HOVEY, R.J. Florida Power & Light Co.
 RECIP. NAME: RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Informs that util proceeding w/design & will commence
 implementation of fire barrier upgrades for fire zones. Util
 will aggressively pursue implemetation of Thermo-Lag fire
 barrier upgrades to complete no later than 991231.

DISTRIBUTION CODE: A029D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: Generic Letter 92-008 Thermo-Lag 330 Fire Barrier

NOTES:

| RECIPIENT ID CODE/NAME | COPIES LTTR ENCL | RECIPIENT ID CODE/NAME | COPIES LTTR ENCL |
|----------------------------------|---------------------|---------------------------|---------------------|
| PD2-3 LA | 1 0 | PD2-3 PD | 1 1 |
| JABBOUR, K | 1 1 | | |
| INTERNAL: <u>FILE CENTER, 01</u> | 1 1 | NRR/DE/EELB | 1 1 |
| NRR/DRPW/PD3-1 | 1 1 | NRR/DSSA/SPLB | 1 1 |
| NRR/KUGLER, A | 1 1 | RGN2 FILE | 1 1 |
| EXTERNAL: NOAC | 1 1 | NRC PDR | 1 1 |

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T

NOTE TO ALL "RIDS" RECIPIENTS:
 PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS
 OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL
 DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 11 ENCL 0



JUN 15 1998

L-98-151

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D. C. 20555

Subject: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Fire Rating of Raceway Fire Barriers in the
Outdoor Fire Area Excluding the Turbine Building

By letter L-96-318 dated December 12, 1996, Florida Power & Light Company (FPL) submitted a request for exemption from the requirements for raceway fire barriers in outdoor fire areas excluding the Turbine Building at Turkey Point Units 3 and 4. This letter also stated that an implementation plan would be provided to the NRC within 120 days of NRC approval of the exemption request.

By letter dated February 24, 1998, the NRC granted the FPL request for exemption for Fire Zones 47, 54, 113, 114, 115, 116, 118, 119, 120 and 143. Although the request for Fire Zone 106R was denied based on a horizontal distance of 10 feet separation, Fire Zone 106R is included in this implementation plan for protection of exposed cables required for safe shutdown. Accordingly, FPL is proceeding with the design and will commence implementation of the fire barrier upgrades for these fire zones. FPL will aggressively pursue implementation of these Thermo-Lag fire barrier upgrades to complete no later than December 31, 1999, in Fire Zones 47, 54, 106R, 113, 114, 115, 116, 118, 119, 120 and 143.

Should there be any questions, please contact us.

Very truly yours,

R. J. Hovey
Vice President
Turkey Point Plant

OIH

cc: Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant

AD 291 10

9806220249 980615
PDR ADDCK 05000250
P PDR

