

# CATEGORY 1

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9807140041 DOC.DATE: 98/06/30 NOTARIZED: NO DOCKET #  
FACIL:50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250  
50-351 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251  
AUTH.NAME AUTHOR AFFILIATION  
MOWREY,C.L. Florida Power & Light Co.  
HOVEY,R.J. Florida Power & Light Co.  
RECIP.NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating repts for June 1998 for Turkey Point,Units  
3 & 4.W/980709 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 9  
TITLE: Monthly Operating Report (per Tech Specs)

### NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-3 PD	1 1	JABBOUR,K	1 1
INTERNAL:	AEOD/SPD/RRAB	1 1	FILE CENTER OT	1 1
	OC/DBA/PAD	1 1	RGN2	1 1
EXTERNAL:	LITCO BRYCE,J H	1 1	NOAC	1 1
	NRC PDR	1 1		

C  
A  
T  
E  
G  
O  
R  
Y  
  
1  
  
D  
O  
C  
U  
M  
E  
N  
T

### NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS  
OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL  
DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 9 ENCL 9





JUL 09 1998


L-98-187  
10 CFR §50.36

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D. C. 20555

Re: Turkey Point Units 3 and 4  
Docket Nos. 50-250 and 50-251  
Monthly Operating Report

In accordance with the requirements of Turkey Point Units 3 and 4 Technical Specification 6.9.1.5, and the guidance of Generic Letter 97-02, attached are the June 1998 Operating Status and Summary of Operating Experience Reports for Turkey Point Units 3 and 4.

Very truly yours,

  
R. J. Hovey  
Vice President  
Turkey Point Plant

CLM

Attachments

cc: Regional Administrator, Region II, USNRC  
Senior Resident Inspector, USNRC, Turkey Point Plant

100086

IE241

9807140041 980630  
PDR ADDCK 05000250  
R PDR

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-250  
UNIT: Turkey Point #3  
DATE: July 6, 1998  
COMPLETED BY: C. L. Mowrey  
TELEPHONE: (305) 246-6204

REPORT MONTH June 1998

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
6/1/98	701
6/2/98	699
6/3/98	698
6/4/98	692
6/5/98	694
6/6/98	693
6/7/98	692
6/8/98	692
6/9/98	699
6/10/98	702
6/11/98	698
6/12/98	694
6/13/98	693
6/14/98	695
6/15/98	696
6/16/98	694
6/17/98	691
6/18/98	691
6/19/98	690
6/20/98	690
6/21/98	688
6/22/98	689
6/23/98	694
6/24/98	695
6/25/98	693
6/26/98	693
6/27/98	699
6/28/98	695
6/29/98	698
6/30/98	697

DOCKET NO. 50-250  
UNIT NAME TURKEY POINT UNIT 3  
DATE July 6, 1998  
COMPLETED BY C. L. Mowrey  
TELEPHONE (305) 246-6204

REPORTING PERIOD June, 1998  
(Month/Year)

1. Design Electrical Rating (MWe-Net)\_\_\_\_\_ 720  
2. Maximum Dependable Capacity (MWe-Net)\_\_\_\_\_ 693

	<u>MONTH</u>	<u>-YTD-</u>	<u>CUMULATIVE</u>
3. Number of Hours Reactor Was Critical_____	720.0	4262.5	157380.3
4. Number of Hours Generator Was On Line_____	720.0	4253.8	155212.7
5. Unit Reserve Shutdown Hours_____	0.0	0.0	121.8
6. Net Electrical Energy (MWH)_____	499976.0	3014357.0	99426913.0



SUMMARY OF OPERATING EXPERIENCE

DOCKET NO.	<u>50-250</u>
UNIT:	<u>Turkey Point #3</u>
DATE:	<u>July 6, 1998</u>
COMPLETED BY:	<u>C. L. Mowrey</u>
TELEPHONE:	<u>(305) 246-6204</u>

REPORT MONTH June 1998

Unit 3 operated at essentially 100% power for the entire month of June.

# UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-250  
 UNIT NAME: Turkey Point #3  
 DATE: July 6, 1998  
 COMPLETED BY: C. L. Mowrey  
 TELEPHONE: (305) 246-6204

REPORT MONTH June 1998

No.	Date	Type <sup>1</sup>	Duration (Hours)	Reason <sup>2</sup>	Method of Shutting Down Reactor <sup>3</sup>	Cause & Corrective Action Comments
N/A	N/A	N/A	N/A	N/A	N/A	N/A

1

F - Forced  
S - Scheduled

2

Reason  
 A - Equipment Failure  
 B - Maintenance or Test  
 C - Refueling  
 D - Regulatory restriction  
 E - Operator Training &  
 License Examination  
 F - Administrative  
 G - Operational Error (Explain)  
 H - Other (Explain)

3

Method 1 - Manual  
 2 - Manual Scram  
 3 - Automatic Scram  
 4 - Continued  
 5 - Load Reduction  
 9 - Other (Explain)

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-251  
UNIT: Turkey Point #4  
DATE: July 6, 1998  
COMPLETED BY: C. L. Mowrey  
TELEPHONE: (305) 246-6204

REPORT MONTH June 1998

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
6/1/98	696
6/2/98	694
6/3/98	693
6/4/98	688
6/5/98	690
6/6/98	689
6/7/98	688
6/8/98	688
6/9/98	695
6/10/98	698
6/11/98	693
6/12/98	689
6/13/98	322
6/14/98	340
6/15/98	670
6/16/98	692
6/17/98	693
6/18/98	692
6/19/98	693
6/20/98	694
6/21/98	691
6/22/98	691
6/23/98	697
6/24/98	698
6/25/98	695
6/26/98	695
6/27/98	702
6/28/98	698
6/29/98	701
6/30/98	699

# OPERATING DATA REPORT

DOCKET NO. 50-251  
 UNIT NAME TURKEY POINT UNIT 4  
 DATE July 6, 1998  
 COMPLETED BY C. L. Mowrey  
 TELEPHONE (305) 246-6204

REPORTING PERIOD June, 1998  
 (Month/Year)

1. Design Electrical Rating (MWe-Net)\_\_\_\_\_ 720
2. Maximum Dependable Capacity (MWe-Net)\_\_\_\_\_ 693

	<u>MONTH</u>	<u>-YTD-</u>	<u>CUMULATIVE</u>
3. Number of Hours Reactor Was Critical_____	720.0	4343.0	153650.5
4. Number of Hours Generator Was On Line_____	720.0	4343.0	149319.5
5. Unit Reserve Shutdown Hours_____	0.0	0.0	577.2
6. Net Electrical Energy (MWH)_____	481525.0	3072614.0	96564251.0

# UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-251  
 UNIT NAME: Turkey Point #4  
 DATE: July 6, 1998  
 COMPLETED BY: C. L. Mowrey  
 TELEPHONE: (305) 246-6204

REPORT MONTH June 1998

No.	Date	Type <sup>1</sup>	Duration (Hours)	Reason <sup>2</sup>	Method of Shutting Down Reactor <sup>3</sup>	Cause & Corrective Action to Prevent Recurrence
1066	6/13/98	S	0.0	B	5	Turbine valve testing

1

F - Forced  
 S - Scheduled

2

Reason  
 A - Equipment Failure  
 B - Maintenance or Test  
 C - Refueling  
 D - Regulatory restriction  
 E - Operator Training &  
 License Examination  
 F - Administrative  
 G - Operational Error (Explain)  
 H - Other (Explain)

3

Method  
 1 - Manual  
 2 - Manual Scram  
 3 - Automatic Scram  
 4 - Continued  
 5 - Load Reduction  
 9 - Other (Explain)

## SUMMARY OF OPERATING EXPERIENCE

DOCKET NO.	<u>50-251</u>
UNIT:	<u>Turkey Point #4</u>
DATE:	<u>July 6, 1998</u>
COMPLETE BY:	<u>C. L. Mowrey</u>
TELEPHONE:	<u>(305)246-6204</u>

REPORT MONTH June 1998

Unit 4 operated at essentially 100% power until June 13, when power was reduced to 40% for turbine valve testing. Power was restored to 100% on June 15, and Unit 4 stayed at essentially 100% power for the remainder of the month.

