

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9808140158 DOC.DATE: 98/07/31 NOTARIZED: NO DOCKET #
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251
 AUTH.NAME AUTHOR AFFILIATION
 MOWREY, C.R. Florida Power & Light Co.
 HOVEY, R.J. Florida Power & Light Co.
 RECIP.NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating repts for July 1998 for Turkey Point, Units 3 & 4. W/980810 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 9
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-3 PD	1 1	JABBOUR, K	1 1
INTERNAL:	AEOD/SPD/RRAB	1 1	FILE CENTER 01	1 1
	OC/DBA/PAD	1 1	RGN2	1 1
EXTERNAL:	LITCO BRYCE, J H	1 1	NOAC	1 1
	NRC PDR	1 1		

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T

NOTE TO ALL "RIDS" RECIPIENTS:
 PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS
 OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL
 DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 9 ENCL 9



AUG 10 1998

L-98-206
10 CFR §50.36

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Monthly Operating Report

In accordance with the requirements of Turkey Point Units 3 and 4 Technical Specification 6.9.1.5, and the guidance of Generic Letter 97-02, attached are the July 1998 Operating Status and Summary of Operating Experience Reports for Turkey Point Units 3 and 4.

Very truly yours,

R. J. Hovey
Vice President
Turkey Point Plant

CLM

Attachments

cc: Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant

IE24'1

9808140158 980731
PDR ADOCK 05000250
R PDR



140006

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-250
UNIT: Turkey Point #3
DATE: August 3, 1998
COMPLETED BY: C. L. Mowrey
TELEPHONE: (305) 246-6204

REPORT MONTH July 1998

DAY	AVERAGE DAILY POWER LEVEL (Mwe-Net)
7/1/98	692
7/2/98	689
7/3/98	689
7/4/98	688
7/5/98	693
7/6/98	689
7/7/98	689
7/8/98	690
7/9/98	688
7/10/98	687
7/11/98	693
7/12/98	697
7/13/98	699
7/14/98	702
7/15/98	702
7/16/98	696
7/17/98	689
7/18/98	688
7/19/98	689
7/20/98	691
7/21/98	695
7/22/98	624
7/23/98	374
7/24/98	688
7/25/98	695
7/26/98	695
7/27/98	691
7/28/98	690
7/29/98	689
7/30/98	691
7/31/98	691

DOCKET NO. 50-250
UNIT NAME TURKEY POINT UNIT 3
DATE August 3, 1998
COMPLETED BY C. L. Mowrey
TELEPHONE (305) 246-6204

REPORTING PERIOD July, 1998
(Month/Year)

1. Design Electrical Rating (MWe-Net)_____ 720
2. Maximum Dependable Capacity (MWe-Net)_____ 693

	<u>MONTH</u>	<u>-YTD-</u>	<u>CUMULATIVE</u>
3. Number of Hours Reactor Was Critical_____	744.0	5006.5	158124.3
4. Number of Hours Generator Was On Line_____	744.0	4997.8	155956.7
5. Unit Reserve Shutdown Hours_____	0.0	0.0	121.8
6. Net Electrical Energy (MWH)_____	505418.0	3519775.0	99932331.0

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-250
 UNIT NAME: Turkey Point #3
 DATE: August 3, 1998
 COMPLETED BY: C. L. Mowrey
 TELEPHONE: (305) 246-6204

REPORT MONTH July 1998

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Cause & Corrective Action Comments
1067	7/22/98	S	0.0	B	5	Turbine Plant Cooling Water: heat exchanger cleaning, pump bearing replacement

1

F - Forced
 S - Scheduled

2

Reason
 A - Equipment Failure
 B - Maintenance or Test
 C - Refueling
 D - Regulatory restriction
 E - Operator Training &
 License Examination
 F - Administrative
 G - Operational Error (Explain)
 H - Other (Explain)

3

Method 1 - Manual
 2 - Manual Scram
 3 - Automatic Scram
 4 - Continued
 5 - Load Reduction
 9 - Other (Explain)

SUMMARY OF OPERATING EXPERIENCE

DOCKET NO.	<u>50-250</u>
UNIT:	<u>Turkey Point #3</u>
DATE:	<u>August 3, 1998</u>
COMPLETED BY:	<u>C. L. Mowrey</u>
TELEPHONE:	<u>(305) 246-6204</u>

REPORT MONTH July 1998

Unit 3 operated at essentially 100% power until July 22, when power was reduced to 30% to clean a Turbine Plant Cooling Water (TPCW) heat exchanger, and to replace a bearing on a TPCW pump (due to high vibration). Power was returned to 100% on July 24, and stayed at approximately 100% for the remainder of the month.

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-251
UNIT: Turkey Point #4
DATE: August 3, 1998
COMPLETED BY: C. L. Mowrey
TELEPHONE: (305) 246-6204

REPORT MONTH July 1998

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
7/1/98	695
7/2/98	693
7/3/98	692
7/4/98	693
7/5/98	697
7/6/98	693
7/7/98	693
7/8/98	693
7/9/98	690
7/10/98	690
7/11/98	696
7/12/98	698
7/13/98	701
7/14/98	703
7/15/98	704
7/16/98	698
7/17/98	692
7/18/98	691
7/19/98	691
7/20/98	692
7/21/98	697
7/22/98	699
7/23/98	698
7/24/98	697
7/25/98	697
7/26/98	697
7/27/98	693
7/28/98	692
7/29/98	691
7/30/98	692
7/31/98	693



11

OPERATING DATA REPORT

DOCKET NO. 50-251
UNIT NAME TURKEY POINT UNIT 4
DATE August 3, 1998
COMPLETED BY C. L. Mowrey
TELEPHONE (305) 246-6204

REPORTING PERIOD July, 1998
(Month/Year)

1. Design Electrical Rating (MWe-Net)_____ 720
2. Maximum Dependable Capacity (MWe-Net)_____ 693

	<u>MONTH</u>	<u>-YTD-</u>	<u>CUMULATIVE</u>
3. Number of Hours Reactor Was Critical_____	744.0	5087.0	154394.5
4. Number of Hours Generator Was On Line_____	744.0	5087.0	150063.5
5. Unit Reserve Shutdown Hours_____	0.0	0.0	577.2
6. Net Electrical Energy (MWH)_____	516966.0	3589580.0	97081217.0

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-251
 UNIT NAME: Turkey Point #4
 DATE: August 3, 1998
 COMPLETED BY: C. L. Mowrey
 TELEPHONE: (305) 246-6204

REPORT MONTH July 1998

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Cause & Corrective Action to Prevent Recurrence
N/A	N/A	N/A	N/A	N/A	N/A	N/A

1

F - Forced
 S - Scheduled

2

Reason
 A - Equipment Failure
 B - Maintenance or Test
 C - Refueling
 D - Regulatory restriction
 E - Operator Training &
 License Examination
 F - Administrative
 G - Operational Error (Explain)
 H - Other (Explain)

3

Method
 1 - Manual
 2 - Manual Scram
 3 - Automatic Scram
 4 - Continued
 5 - Load Reduction
 9 - Other (Explain)

SUMMARY OF OPERATING EXPERIENCE

DOCKET NO.	<u>50-251</u>
UNIT:	<u>Turkey Point #4</u>
DATE:	<u>August 3, 1998</u>
COMPLETE BY:	<u>C. L. Mowrey</u>
TELEPHONE:	<u>(305)246-6204</u>

REPORT MONTH July 1998

Unit 4 operated at essentially 100% for the entire month.