

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

.. ACCESSION NBR: 9811200095 DOC.DATE: 98/10/31 NOTARIZED: NO DOCKET #
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251
 AUTH.NAME AUTHOR AFFILIATION
 MOWREY, C.L. Florida Power & Light Co.
 HOVEY, R.J. Florida Power & Light Co.
 RECIP.NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating repts for Oct 1998 for Turkey Point, Units 3 & 4. With 981112 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 9
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-3 PD	1 1	JABBOUR, K	1 1
INTERNAL:	AEOD/SPD/RRAB	1 1	<u>FILE CENTER 01</u>	1 1
	OC/DBA/PAD	1 1	RGN2	1 1
EXTERNAL:	LITCO BRYCE, J H.	1 1	NOAC	1 1
	NRC PDR	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 9 ENCL 9

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T



NOV 12 1998

L-98-281
10 CFR §50.36

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Monthly Operating Report

In accordance with the requirements of Turkey Point Units 3 and 4 Technical Specification 6.9.1.5, and the guidance of Generic Letter 97-02, attached are the October 1998 Operating Data Report and Summary of Operating Experience for Turkey Point Units 3 and 4.

Very truly yours,

R. J. Hovey
Vice President
Turkey Point Plant

CLM

Attachments

cc: Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant

IE241

9811200095 981031
PDR ADOCK 05000250
R PDR

200006

1953

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-250
UNIT: Turkey Point #3
DATE: November 5, 1998
COMPLETED BY: C. L. Mowrey
TELEPHONE: (305) 246-6204

REPORT MONTH October 1998

DAY	AVERAGE DAILY POWER LEVEL (Mwe-Net)
10/1/98	0
10/2/98	0
10/3/98	0
10/4/98	0
10/5/98	0
10/6/98	0
10/7/98	0
10/8/98	0
10/9/98	0
10/10/98	0
10/11/98	0
10/12/98	0
10/13/98	0
10/14/98	0
10/15/98	0
10/16/98	0
10/17/98	0
10/18/98	0
10/19/98	0
10/20/98	0
10/21/98	0
10/22/98	0
10/23/98	0
10/24/98	0
10/25/98	0
10/26/98	0
10/27/98	0
10/28/98	0
10/29/98	118
10/30/98	250
10/31/98	298

OPERATING DATA REPORT

DOCKET NO. 50-250
UNIT NAME TURKEY POINT UNIT 3
DATE November 5, 1998
COMPLETED BY C. L. Mowrey
TELEPHONE (305) 246-6204

REPORTING PERIOD October, 1998
(Month/Year)

1. Design Electrical Rating (MWe-Net)_____ 720
2. Maximum Dependable Capacity (MWe-Net)_____ 693

	<u>MONTH</u>	<u>-YTD-</u>	<u>CUMULATIVE</u>
3. Number of Hours Reactor Was Critical_____	97.7	6328.2	159446.0
4. Number of Hours Generator Was On Line_____	72.9	6294.7	157253.6
5. Unit Reserve Shutdown Hours_____	0.0	0.0	121.8
6. Net Electrical Energy (MWH)_____	12866.0	4360947.0	100773503.0

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-250
 UNIT NAME: Turkey Point #3
 DATE: November 5, 1998
 COMPLETED BY: C. L. Mowrey
 TELEPHONE: (305) 246-6204

REPORT MONTH October 1998

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Cause & Corrective Action Comments
19980001	9/21/98	S	601.0	C	1,3	Shut down for refueling, tripped automatically at 8% power due to Intermediate Range N35 misadjustment (NOTE: this entry was included in last month's report. The refueling outage extended into this month, so the duration has been changed to reflect the outage hours incurred in October.)
19980004	10/26/98	F	70.0	H	4	Outage extension due to Hurricane Georges.
19980003	10/29/98	S	1.1	B	4	Turbine overspeed test following refueling outage.

1

F - Forced
 S - Scheduled

2

Reason
 A - Equipment Failure
 B - Maintenance or Test
 C - Refueling
 D - Regulatory restriction
 E - Operator Training & License Examination
 F - Administrative
 G - Operational Error (Explain)
 H - Other (Explain)

3

Method 1 - Manual
 2 - Manual Scram
 3 - Automatic Scram
 4 - Continued
 5 - Load Reduction
 9 - Other (Explain)

SUMMARY OF OPERATING EXPERIENCE

DOCKET NO.	<u>50-250</u>
UNIT:	<u>Turkey Point #3</u>
DATE:	<u>November 5, 1998</u>
COMPLETED BY:	<u>C. L. Mowrey</u>
TELEPHONE:	<u>(305) 246-6204</u>

REPORT MONTH October 1998

Unit 3 was shut down for a refueling outage for most of October. The unit's return to power operations was delayed by about 70 hours by Hurricane Georges (see LER 250/98-005). The unit was restarted on October 27, and placed on line on October 28. Early on October 29, the unit was taken back off line to perform a turbine overspeed test, and placed back on line later that day. Power was slowly increased, and finished the month at approximately 49% reactor power.

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-251
UNIT: Turkey Point #4
DATE: November 5, 1998
COMPLETED BY: C. L. Mowrey
TELEPHONE: (305) 246-6204

REPORT MONTH October 1998

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
10/1/98	705
10/2/98	703
10/3/98	701
10/4/98	700
10/5/98	700
10/6/98	702
10/7/98	704
10/8/98	702
10/9/98	698
10/10/98	701
10/11/98	701
10/12/98	700
10/13/98	701
10/14/98	705
10/15/98	711
10/16/98	712
10/17/98	715
10/18/98	716
10/19/98	715
10/20/98	709
10/21/98	705
10/22/98	703
10/23/98	714
10/24/98	725
10/25/98	726
10/26/98	723
10/27/98	723
10/28/98	720
10/29/98	720
10/30/98	719
10/31/98	716

OPERATING DATA REPORT

DOCKET NO. 50-251
UNIT NAME TURKEY POINT UNIT 4
DATE November 5, 1998
COMPLETED BY C. L. Mowrey
TELEPHONE (305) 246-6204

REPORTING PERIOD October, 1998
(Month/Year)

1. Design Electrical Rating (MWe-Net)_____ 720
2. Maximum Dependable Capacity (MWe-Net)_____ 693

	<u>MONTH</u>	<u>-YTD-</u>	<u>CUMULATIVE</u>
3. Number of Hours Reactor Was Critical_____	745.0	7296.0	156603.5
4. Number of Hours Generator Was On Line_____	745.0	7296.0	152272.5
5. Unit Reserve Shutdown Hours_____	0.0	0.0	577.2
6. Net Electrical Energy (MWH)_____	528565.0	5131628.0	98623265.0

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-251
UNIT NAME: Turkey Point #4
DATE: November 5, 1998
COMPLETED BY: C. L. Mowrey
TELEPHONE: (305) 246-6204

REPORT MONTH October 1998

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Cause & Corrective Action to Prevent Recurrence
N/A	N/A	N/A	N/A	N/A	N/A	N/A

1

F - Forced
S - Scheduled

2

Reason
A - Equipment Failure
B - Maintenance or Test
C - Refueling
D - Regulatory restriction
E - Operator Training &
License Examination
F - Administrative
G - Operational Error (Explain)
H - Other (Explain)

3

Method
1 - Manual
2 - Manual Scram
3 - Automatic Scram
4 - Continued
5 - Load Reduction
9 - Other (Explain)

SUMMARY OF OPERATING EXPERIENCE

DOCKET NO.	<u>50-251</u>
UNIT:	<u>Turkey Point #4</u>
DATE:	<u>November 5, 1998</u>
COMPLETE BY:	<u>C. L. Mowrey</u>
TELEPHONE:	<u>(305)246-6204</u>

REPORT MONTH October 1998

Unit 4 operated at essentially 100% for the entire month of October, 1998.