

# CATEGORY 1

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9902220174 DOC.DATE: 99/01/31 NOTARIZED: NO DOCKET #  
FACIL:50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250  
50-251.Turkey Point Plant, Unit 4, Florida Power and Light C 05000251  
AUTH.NAME AUTHOR AFFILIATION  
SHUKLA,G.S. Florida Power & Light Co.  
HOVEY,R.J. Florida Power & Light Co.  
RECIP.NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating repts for Jan 1999 for Turkey Point, Units  
3 & 4. With 990211 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 9  
TITLE: Monthly Operating Report (per Tech Specs)

### NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-3 PD	1 1	JABBOUR, K	1 1
INTERNAL:	AEOD/SPD/RRAB	1 1	FILE CENTER 01	1 1
	OC/DBA/PAD	1 1	RGN2	1 1
EXTERNAL:	LITCO BRYCE, J H	1 1	NOAC	1 1
	NRC PDR	1 1		

**MICROFILMED**

NOTE TO ALL "RIDS" RECIPIENTS:  
PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS  
OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL  
DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 9 ENCL 9



FEB 11 1999

L-99-033  
10 CFR 50.36

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D. C. 20555

Re: Turkey Point Units 3 and 4  
Docket Nos. 50-250 and 50-251  
Monthly Operating Report

In accordance with the requirements of Turkey Point Units 3 and 4 Technical Specification 6.9.1.5, and the guidance of Generic Letter 97-02, attached are the January, 1999 Operating Data Report and Summary of Operating Experience for Turkey Point Units 3 and 4.

Very truly yours,

R. J. Hovey  
Vice President  
Turkey Point Plant

GSS

Attachments

cc: Regional Administrator, Region II, USNRC  
Senior Resident Inspector, USNRC, Turkey Point Plant

190116

9902220174 990131  
PDR ADDCK 05000250  
R PDR

1/1  
IE24



AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-250  
UNIT: Turkey Point #3  
DATE: February 4, 1999  
COMPLETED BY: G. S. Shukla  
TELEPHONE: (305) 246-6047

REPORT MONTH January, 1999

DAY	AVERAGE DAILY POWER LEVEL (Mwe-Net)
1/1/99	729
1/2/99	727
1/3/99	725
1/4/99	728
1/5/99	738
1/6/99	742
1/7/99	740
1/8/99	735
1/9/99	731
1/10/99	727
1/11/99	735
1/12/99	737
1/13/99	733
1/14/99	729
1/15/99	726
1/16/99	724
1/17/99	720
1/18/99	718
1/19/99	716
1/20/99	715
1/21/99	712
1/22/99	717
1/23/99	720
1/24/99	722
1/25/99	729
1/26/99	729
1/27/99	728
1/28/99	726
1/29/99	725
1/30/99	722
1/31/99	720

## OPERATING DATA REPORT

DOCKET NO. 50-250  
UNIT NAME TURKEY POINT UNIT 3  
DATE February 4, 1999  
COMPLETED BY G. S. Shukla  
TELEPHONE (305) 246-6047

REPORTING PERIOD January, 1999  
(Month/Year)

1. Design Electrical Rating (MWe-Net)\_\_\_\_\_ 720  
2. Maximum Dependable Capacity (MWe-Net)\_\_\_\_\_ 693

	<u>MONTH</u>	<u>-YTD-</u>	<u>CUMULATIVE</u>
3. Number of Hours Reactor Was Critical_____	744.0	744.0	161654.0
4. Number of Hours Generator Was On Line_____	744.0	744.0	159461.6
5. Unit Reserve Shutdown Hours_____	0.0	0.0	121.8
6. Net Electrical Energy (MWH)_____	540584.0	540584.0	102361443.0

# UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-250  
 UNIT NAME: Turkey Point #3  
 DATE: February 4, 1999  
 COMPLETED BY: G. S. Shukla  
 TELEPHONE: (305) 246-6047

REPORT MONTH January, 1999

No.	Date	Type <sup>1</sup>	Duration (Hours)	Reason <sup>2</sup>	Method of Shutting Down Reactor <sup>3</sup>	Cause & Corrective Action Comments
N/A	N/A	N/A	N/A	N/A	N/A	N/A

1

F - Forced  
S - Scheduled

2

Reason  
 A - Equipment Failure  
 B - Maintenance or Test  
 C - Refueling  
 D - Regulatory restriction  
 E - Operator Training &  
 License Examination  
 F - Administrative  
 G - Operational Error (Explain)  
 H - Other (Explain)

3

Method  
 1 - Manual  
 2 - Manual Scram  
 3 - Automatic Scram  
 4 - Continued  
 5 - Load Reduction  
 9 - Other (Explain)

SUMMARY OF OPERATING EXPERIENCE

DOCKET NO.	<u>50-250</u>
UNIT:	<u>Turkey Point #3</u>
DATE:	<u>February 4, 1999</u>
COMPLETED BY:	<u>G. S. Shukla</u>
TELEPHONE:	<u>(305) 246-6047</u>

REPORT MONTH January, 1999

Unit 3 operated at essentially 100% for the entire month of January, 1999.

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-251  
UNIT: Turkey Point #4  
DATE: February 4, 1999  
COMPLETED BY: G. S. Shukla  
TELEPHONE: (305) 246-6047

REPORT MONTH January, 1999

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1/1/99	726
1/2/99	723
1/3/99	722
1/4/99	725
1/5/99	734
1/6/99	735
1/7/99	733
1/8/99	730
1/9/99	725
1/10/99	723
1/11/99	730
1/12/99	732
1/13/99	730
1/14/99	660
1/15/99	720
1/16/99	719
1/17/99	717
1/18/99	716
1/19/99	715
1/20/99	714
1/21/99	714
1/22/99	717
1/23/99	720
1/24/99	721
1/25/99	726
1/26/99	728
1/27/99	726
1/28/99	725
1/29/99	724
1/30/99	720
1/31/99	720



## OPERATING DATA REPORT

DOCKET NO. 50-251  
UNIT NAME TURKEY POINT UNIT 4  
DATE February 4, 1999  
COMPLETED BY G. S. Shukla  
TELEPHONE (305) 246-6047

REPORTING PERIOD January, 1999  
(Month/Year)

1. Design Electrical Rating (MWe-Net)\_\_\_\_\_ 720  
2. Maximum Dependable Capacity (MWe-Net)\_\_\_\_\_ 693

	<u>MONTH</u>	<u>-YTD-</u>	<u>CUMULATIVE</u>
3. Number of Hours Reactor Was Critical_____	744.0	744.0	158811.5
4. Number of Hours Generator Was On Line_____	744.0	744.0	154480.5
5. Unit Reserve Shutdown Hours_____	0.0	0.0	577.2
6. Net Electrical Energy (MWH)_____	536896.0	536896.0	100209994.0

## UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-251  
 UNIT NAME: Turkey Point #4  
 DATE: February 4, 1999  
 COMPLETED BY: G. S. Shukla  
 TELEPHONE: (305) 246-6047

REPORT MONTH January, 1999

No.	Date	Type <sup>1</sup>	Duration (Hours)	Reason <sup>2</sup>	Method of Shutting Down Reactor <sup>3</sup>	Cause & Corrective Action to Prevent Recurrence
19990001	01/14/1999	S	0.0	B	5	Turbine Valve Test

1

F - Forced  
S - Scheduled

2

Reason  
A - Equipment Failure  
B - Maintenance or Test  
C - Refueling  
D - Regulatory restriction  
E - Operator Training &  
License Examination  
F - Administrative  
G - Operational Error (Explain)  
H - Other (Explain)

3

Method  
1 - Manual  
2 - Manual Scram  
3 - Automatic Scram  
4 - Continued  
5 - Load Reduction  
9 - Other (Explain)

## SUMMARY OF OPERATING EXPERIENCE

DOCKET NO.	<u>50-251</u>
UNIT:	<u>Turkey Point #4</u>
DATE:	<u>February 4, 1999</u>
COMPLETE BY:	<u>G. S. Shukla</u>
TELEPHONE:	<u>(305)246-6047</u>

### REPORT MONTH January, 1999

Unit 4 operated essentially at 100% in the beginning of the month of January, 1999. On January 14, 1999 the power was reduced to 65% to perform the Turbine Valve Test. Unit 4 resumed 100% power the same day and stayed essentially at 100% for rest of the month of January, 1999.

