

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9903240195 DOC.DATE: 99/02/28 NOTARIZED: NO DOCKET #
FACIL:50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251
AUTH.NAME AUTHOR AFFILIATION
SHUKLA,G.S. Florida Power & Light Co.
HOVEY,R.J. Florida Power & Light Co.
RECIP.NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating repts for Feb 1999 for Turkey Point
Nuclear Power Plant, Units 3 & 4. With 990315 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 9
TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-3 PD	1 1	JABBOUR, K	1 1
INTERNAL:	AEOD/SPD/RRAB	1 1	FILE CENTER 01	1 1
	OC/DBA/PAD	1 1	RGN2	1 1
EXTERNAL:	LMITCO MARSHALL	1 1	NOAC	1 1
	NRC PDR	1 1		

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 9 ENCL 9



MAR 15 1999

L-99-063
10 CFR 50.36

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Monthly Operating Report

In accordance with the requirements of Turkey Point Units 3 and 4 Technical Specification 6.9.1.5, and the guidance of Generic Letter 97-02, attached are the February, 1999, Operating Data Report and Summary of Operating Experience for Turkey Point Units 3 and 4.

Very truly yours,

R. J. Hovey
Vice President
Turkey Point Plant

GSS

Attachments

cc: Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant

IE241

240053

9903240195 990228
PDR ADOCK 05000250
R PDR

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-250
UNIT: Turkey Point #3
DATE: March 4, 1999
COMPLETED BY: G. S. Shukla
TELEPHONE: (305) 246-6047

REPORT MONTH February, 1999

DAY	AVERAGE DAILY POWER LEVEL (Mwe-Net)
2/1/99	722
2/2/99	378
2/3/99	667
2/4/99	712
2/5/99	716
2/6/99	718
2/7/99	719
2/8/99	717
2/9/99	713
2/10/99	712
2/11/99	715
2/12/99	718
2/13/99	719
2/14/99	730
2/15/99	734
2/16/99	730
2/17/99	728
2/18/99	726
2/19/99	723
2/20/99	722
2/21/99	725
2/22/99	733
2/23/99	735
2/24/99	733
2/25/99	727
2/26/99	730
2/27/99	727
2/28/99	724

OPERATING DATA REPORT

DOCKET NO. 50-250
UNIT NAME TURKEY POINT UNIT 3
DATE March 4, 1999
COMPLETED BY G. S. Shukla
TELEPHONE (305) 246-6047

REPORTING PERIOD February, 1999
(Month/Year)

1. Design Electrical Rating (MWe-Net)_____ 720
2. Maximum Dependable Capacity (MWe-Net)_____ 693

	<u>MONTH</u>	<u>-YTD-</u>	<u>CUMULATIVE</u>
3. Number of Hours Reactor Was Critical_____	672.0	1416.0	162326.0
4. Number of Hours Generator Was On Line_____	672.0	1416.0	160133.6
5. Unit Reserve Shutdown Hours_____	0.0	0.0	121.8
6. Net Electrical Energy (MWH)_____	476413.0	1016997.0	102837856.0

SUMMARY OF OPERATING EXPERIENCE

DOCKET NO.	<u>50-250</u>
UNIT:	<u>Turkey Point #3</u>
DATE:	<u>March 4, 1999</u>
COMPLETED BY:	<u>G. S. Shukla</u>
TELEPHONE:	<u>(305) 246-6047</u>

REPORT MONTH February, 1999

Unit 3 operated at essentially 100% for the entire month of February, 1999, except for a scheduled power reduction to 40% on February 2, 1999 for performing a turbine valve test.

UNIT SHUTDOWNS

DOCKET NO. 50-250
UNIT NAME: Turkey Point #3
DATE: March 4, 1999
COMPLETED BY: G. S. Shukla
TELEPHONE: (305) 246-6047

REPORT MONTH February, 1999

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Cause & Corrective Action Comments
N/A	N/A	N/A	N/A	N/A	N/A	N/A

1

F - Forced
S - Scheduled

2

Reason
A - Equipment Failure
B - Maintenance or Test
C - Refueling
D - Regulatory restriction
E - Operator Training &
License Examination
F - Administrative
G - Operational Error (Explain)
H - Other (Explain)

3

Method
1 - Manual
2 - Manual Scram
3 - Automatic Scram
4 - Continuation
5 - Other (Explain)

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-251
UNIT: Turkey Point #4
DATE: March 4, 1999
COMPLETED BY: G. S. Shukla
TELEPHONE: (305) 246-6047

REPORT MONTH February, 1999

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
2/1/99	721
2/2/99	722
2/3/99	719
2/4/99	715
2/5/99	713
2/6/99	713
2/7/99	714
2/8/99	712
2/9/99	708
2/10/99	710
2/11/99	711
2/12/99	714
2/13/99	714
2/14/99	727
2/15/99	730
2/16/99	728
2/17/99	726
2/18/99	723
2/19/99	721
2/20/99	720
2/21/99	723
2/22/99	732
2/23/99	733
2/24/99	731
2/25/99	726
2/26/99	728
2/27/99	724
2/28/99	721

OPERATING DATA REPORT

DOCKET NO. 50-251
UNIT NAME TURKEY POINT UNIT 4
DATE March 4, 1999
COMPLETED BY G. S. Shukla
TELEPHONE (305) 246-6047

REPORTING PERIOD February, 1999
(Month/Year)

1. Design Electrical Rating (MWe-Net)_____ 720
2. Maximum Dependable Capacity (MWe-Net)_____ 693

	<u>MONTH</u>	<u>-YTD-</u>	<u>CUMULATIVE</u>
3. Number of Hours Reactor Was Critical_____	672.0	1416.0	159483.5
4. Number of Hours Generator Was On Line_____	672.0	1416.0	155152.5
5. Unit Reserve Shutdown Hours_____	0.0	0.0	577.2
6. Net Electrical Energy (MWH)_____	484252.0	1021148.0	100694246.0

UNIT SHUTDOWNS

DOCKET NO. 50-251
UNIT NAME: Turkey Point #4
DATE: March 4, 1999
COMPLETED BY: G. S. Shukla
TELEPHONE: (305) 246-6047

REPORT MONTH February, 1999

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Cause & Corrective Action Comments
N/A	N/A	N/A	N/A	N/A	N/A	N/A

1

F - Forced
S - Scheduled

2

Reason
A - Equipment Failure
B - Maintenance or Test
C - Refueling
D - Regulatory restriction
E - Operator Training &
License Examination
F - Administrative
G - Operational Error (Explain)
H - Other (Explain)

3

Method
1 - Manual
2 - Manual Scram
3 - Automatic Scram
4 - Continued
5 - Other (Explain)

SUMMARY OF OPERATING EXPERIENCE

DOCKET NO.	<u>50-251</u>
UNIT:	<u>Turkey Point #4</u>
DATE:	<u>March 4, 1999</u>
COMPLETE BY:	<u>G. S. Shukla</u>
TELEPHONE:	<u>(305)246-6047</u>

REPORT MONTH February, 1999

Unit 4 operated at essentially 100% for the entire month of February, 1999.



11