

# CATEGORY 1

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9903260351    DOC DATE: 99/03/19    NOTARIZED: NO    DOCKET #  
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C    05000250  
       50-251 Turkey Point Plant, Unit 4, Florida Power and Light C    05000251  
 AUTH. NAME: \_\_\_\_\_    AUTHOR AFFILIATION:  
 HOVEY, R.J.    Florida Power & Light Co.  
 RECIP. NAME: \_\_\_\_\_    RECIPIENT AFFILIATION:  
                   Records Management Branch (Document Control Desk)

SUBJECT: Forwards "Annual Radioactive Effluent Release Rpt for  
           980101-981231," IAW TS 6.9.1.4 & 10CFR50.36a(a)(2). Encl  
           2 contains rev 7 to "ODCM."

DISTRIBUTION CODE: IE48D    COPIES RECEIVED: LTR 1 ENCL 1    SIZE: 2+38  
 TITLE: 50.36a(a)(2) Semiannual Effluent Release Reports

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-3 LA	1 1	PD2-3 PD	1 1
	JABBOUR, K	1 1		
INTERNAL:	FILE CENTER 01	1 1	NRR/DRPM/PERB/A	1 1
	NRR/DSSA/SPLB	1 1	RGN2 DRS/RSB	1 1
	RGN2 FILE	1 1		
EXTERNAL:	NRC PDR	1 1		

MICROFILMED

NOTE TO ALL "RIDS" RECIPIENTS:  
 PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS  
 OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL  
 DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR    9    ENCL    9

C  
A  
T  
E  
G  
O  
R  
Y  
  
1  
  
D  
O  
C  
U  
M  
E  
N  
T



FPL

MAR 19 1999

L-99-069

10 CFR 50.36a(a)(2)

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D.C. 20555

Re: Turkey Point Units 3 and 4  
Docket Nos. 50-250 and 50-251  
Annual Radioactive Effluent Release Report

Attached is the Radioactive Effluent Release Report for the period of January 1, 1998, through December 31, 1998, for Turkey Point Units 3 and 4, as required by Technical Specification 6.9.1.4 and 10 CFR 50.36a (a)(2).

Should there be any questions or comments regarding this information, please contact us.

Very truly yours,

R. J. Hovey  
Vice President  
Turkey Point Plant

DRL

Attachment

cc: Regional Administrator, Region II, USNRC  
Senior Resident Inspector, USNRC, Turkey Point Plant

TE481/

9903260351 990319  
PDR ADOCK 05000250  
R PDR

200

200

200

200

200

TURKEY POINT PLANT  
UNITS 3 AND 4

ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT

Executive Summary

Liquid effluent releases at Turkey Point did not exceed the concentrations specified in 10 CFR 20, Appendix B, Table II, Column 2. The limits for dissolved and entrained noble gases were not exceeded.

The dose or dose commitment limits per reactor to a member of the public from liquid effluents were not exceeded.

Dose rate limits due to radioactive materials in the gaseous effluents were not exceeded.

The dose limits per reactor to a member of the public due to I-131, I-133, tritium, and particulates with half-lives greater than 8 days were not exceeded.

All liquid and airborne discharges to the environment were analyzed in accordance with the Technical Specifications and Regulatory Guide 1.21.

There were no unplanned liquid releases for either unit during this period.

There were no unplanned gas releases for either unit during this period.

Visitor dose limits were calculated and included in this report for both adult and children at the Satellite School.

