

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9904220223 DOC.DATE: 99/03/31 NOTARIZED: NO DOCKET #
 FACIL:50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251
 AUTH.NAME AUTHOR AFFILIATION
 SHUKLA,G.S. Florida Power & Light Co.
 HOVEY,R.J. Florida Power & Light Co.
 RECIP.NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating repts for Mar 1999 for Turkey Point,Units
 3 & 4.With 990414 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 9
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	LPD2-2 PD	1 1	JABBOUR,K	1 1
INTERNAL:	AEOD/SPD/RRAB	1 1	<u>FILE CENTER 01</u>	1 1
	OC/DBA/PAD	1 1	RGN2	1 1
EXTERNAL:	LMITCO MARSHALL	1 1	NOAC	1 1
	NRC PDR	1 1		



NOTE TO ALL "RIDS" RECIPIENTS:
 PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS
 OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL
 DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 9 ENCL 9

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T



APR 14 1999

L-99-087
10 CFR 50.36

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Monthly Operating Report

In accordance with the requirements of Turkey Point Units 3 and 4 Technical Specification 6.9.1.5, and the guidance of Generic Letter 97-02, attached are the March, 1999, Operating Data Report and Summary of Operating Experience for Turkey Point Units 3 and 4.

Very truly yours,

R. J. Hovey
Vice President
Turkey Point Plant

GSS

Attachments

cc: Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant

11
11
IE24

9904220223 990331
PDR ADOCK 05000250
R PDR



100-100000

100-100000

100-100000

100-100000

100-100000

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-250
UNIT: Turkey Point #3
DATE: April 5, 1999
COMPLETED BY: G. S. Shukla
TELEPHONE: (305) 246-6047

REPORT MONTH March, 1999

DAY	AVERAGE DAILY POWER LEVEL (Mwe-Net)
3/1/99	725
3/2/99	729
3/3/99	728
3/4/99	730
3/5/99	730
3/6/99	729
3/7/99	727
3/8/99	719
3/9/99	730
3/10/99	722
3/11/99	721
3/12/99	720
3/13/99	714
3/14/99	719
3/15/99	725
3/16/99	731
3/17/99	731
3/18/99	728
3/19/99	725
3/20/99	724
3/21/99	722
3/22/99	718
3/23/99	723
3/24/99	718
3/25/99	715
3/26/99	718
3/27/99	712
3/28/99	715
3/29/99	717
3/30/99	720
3/31/99	722

OPERATING DATA REPORT

DOCKET NO. 50-250
UNIT NAME TURKEY POINT UNIT 3
DATE April 5, 1999
COMPLETED BY G. S. Shukla
TELEPHONE (305) 246-6047

REPORTING PERIOD March, 1999
(Month/Year)

1. Design Electrical Rating (MWe-Net)_____ 720
2. Maximum Dependable Capacity (MWe-Net)_____ 693

	<u>MONTH</u>	<u>-YTD-</u>	<u>CUMULATIVE</u>
3. Number of Hours Reactor Was Critical_____	744.0	2160.0	163070.0
4. Number of Hours Generator Was On Line_____	744.0	2160.0	160877.6
5. Unit Reserve Shutdown Hours_____	0.0	0.0	121.8
6. Net Electrical Energy (MWH)_____	537849.0	1554846.0	103375705.0

SUMMARY OF OPERATING EXPERIENCE

DOCKET NO.	<u>50-250</u>
UNIT:	<u>Turkey Point #3</u>
DATE:	<u>April 5, 1999</u>
COMPLETED BY:	<u>G. S. Shukla</u>
TELEPHONE:	<u>(305) 246-6047</u>

REPORT MONTH March, 1999

Unit 3 operated at essentially 100% for the entire month of March, 1999.

UNIT SHUTDOWNS

DOCKET NO. 50-250
UNIT NAME: Turkey Point #3
DATE: April 5, 1999
COMPLETED BY: G. S. Shukla
TELEPHONE: (305) 246-6047

REPORT MONTH March, 1999

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Cause & Corrective Action Comments
N/A	N/A	N/A	N/A	N/A	N/A	N/A

1

F - Forced
S - Scheduled

2

Reason
A - Equipment Failure
B - Maintenance or Test
C - Refueling
D - Regulatory restriction
E - Operator Training &
License Examination
F - Administrative
G - Operational Error (Explain)
H - Other (Explain)

3

Method
1 - Manual
2 - Manual Scram
3 - Automatic Scram
4 - Continuation
5 - Other (Explain)

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-251
UNIT: Turkey Point #4
DATE: April 5, 1999
COMPLETED BY: G. S. Shukla
TELEPHONE: (305) 246-6047

REPORT MONTH March, 1999

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
3/1/99	721
3/2/99	723
3/3/99	722
3/4/99	724
3/5/99	727
3/6/99	724
3/7/99	721
3/8/99	715
3/9/99	705
3/10/99	701
3/11/99	695
3/12/99	690
3/13/99	324
3/14/99	292
3/15/99	0
3/16/99	0
3/17/99	0
3/18/99	0
3/19/99	0
3/20/99	0
3/21/99	0
3/22/99	0
3/23/99	0
3/24/99	0
3/25/99	0
3/26/99	0
3/27/99	0
3/28/99	0
3/29/99	0
3/30/99	0
3/31/99	0



OPERATING DATA REPORT

DOCKET NO. 50-251
UNIT NAME TURKEY POINT UNIT 4
DATE April 5, 1999
COMPLETED BY G. S. Shukla
TELEPHONE (305) 246-6047

REPORTING PERIOD March, 1999
(Month/Year)

1. Design Electrical Rating (MWe-Net)_____ 720
2. Maximum Dependable Capacity (MWe-Net)_____ 693

	<u>MONTH</u>	<u>-YTD-</u>	<u>CUMULATIVE</u>
3. Number of Hours Reactor Was Critical_____	336.0	1752.0	159819.5
4. Number of Hours Generator Was On Line_____	336.0	1752.0	155488.5
5. Unit Reserve Shutdown Hours_____	0.0	0.0	577.2
6. Net Electrical Energy (MWH)_____	218998.0	1240146.0	100913244.0

UNIT SHUTDOWNS

DOCKET NO. 50-251
UNIT NAME: Turkey Point #4
DATE: April 5, 1999
COMPLETED BY: G. S. Shukla
TELEPHONE: (305) 246-6047

REPORT MONTH March, 1999

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Cause & Corrective Action Comments
1999 0005	3/15/99	S	408.0	C	1	Shut down for refueling.

1

F - Forced
S - Scheduled

2

Reason
A - Equipment Failure
B - Maintenance or Test
C - Refueling
D - Regulatory restriction
E - Operator Training &
License Examination
F - Administrative
G - Operational Error (Explain)
H - Other (Explain)

3

Method
1 - Manual
2 - Manual Scram
3 - Automatic Scram
4 - Continued
5 - Other (Explain)

SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50-251
UNIT: Turkey Point #4
DATE: April 5, 1999
COMPLETE BY: G. S. Shukla
TELEPHONE: (305)246-6047

REPORT MONTH March, 1999

Unit 4 operated at essentially 100% reactor power until March 10, 1999. Then power was lowered in preparation for a refueling outage which started on March 15, 1999. The unit remained shut down for refueling for the remainder of the month, and is expected to restart on or about April 8, 1999.

1945

