

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9906210188      DOC.DATE: 99/05/31      NOTARIZED: NO      DOCKET #  
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C      05000250  
       50-251 Turkey Point Plant, Unit 4, Florida Power and Light C      05000251  
 AUTH.NAME      AUTHOR AFFILIATION  
 SHUKLA, G.S.      Florida Power & Light Co.  
 HOVEY, R.J.      Florida Power & Light Co.  
 RECIP.NAME      RECIPIENT AFFILIATION

SUBJECT: Monthly operating repts for May 1999 for Turkey Point, Units 3 & 4. With 990609 ltr.

DISTRIBUTION CODE: IE24D      COPIES RECEIVED: LTR 1 ENCL 1      SIZE: 10  
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	LPD2-2 PD	1 1	JABBOUR, K	1 1
INTERNAL:	AEOD/SPD/RRAB	1 1	<u>FILE CENTER 01</u>	1 1
	OC/DBA/PAD	1 1	RGN2	1 1
EXTERNAL:	LMITCO MARSHALL	1 1	NOAC	1 1
	NRC PDR	1 1		

MICROFILMED

NOTE TO ALL "RIDS" RECIPIENTS:  
 PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS  
 OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL  
 DESK (DCD) ON EXTENSION 415-2083

C  
A  
T  
E  
G  
O  
R  
Y  
  
1  
  
D  
O  
C  
U  
M  
E  
N  
T





JUN 9 1999

L-99-134  
10 CFR 50.36

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D. C. 20555

Re: Turkey Point Units 3 and 4  
Docket Nos. 50-250 and 50-251  
Monthly Operating Report - May, 1999

In accordance with the requirements of Turkey Point Units 3 and 4 Technical Specification 6.9.1.5, and the guidance of Generic Letter 97-02, attached are the May, 1999, Operating Data Report and Summary of Operating Experience for Turkey Point Units 3 and 4.

Very truly yours,



R. J. Hovey  
Vice President  
Turkey Point Plant

1/1

GSS

Je24

Attachments

cc: Regional Administrator, Region II, USNRC  
Senior Resident Inspector, USNRC, Turkey Point Plant

9906210188 990531  
PDR ADOCK 05000250  
R PDR



# AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-250  
UNIT: Turkey Point #3  
DATE: June 3, 1999  
COMPLETED BY: G. S. Shukla  
TELEPHONE: (305) 246-6047

REPORT MONTH May, 1999

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
5/1/99	713
5/2/99	720
5/3/99	716
5/4/99	707
5/5/99	704
5/6/99	704
5/7/99	704
5/8/99	222
5/9/99	400
5/10/99	673
5/11/99	707
5/12/99	711
5/13/99	712
5/14/99	707
5/15/99	706
5/16/99	706
5/17/99	707
5/18/99	706
5/19/99	708
5/20/99	706
5/21/99	707
5/22/99	710
5/23/99	710
5/24/99	707
5/25/99	708
5/26/99	703
5/27/99	698
5/28/99	697
5/29/99	700
5/30/99	706
5/31/99	710

## OPERATING DATA REPORT

DOCKET NO. 50-250  
UNIT NAME TURKEY POINT UNIT 3  
DATE June 3, 1999  
COMPLETED BY G. S. Shukla  
TELEPHONE (305) 246-6047

REPORTING PERIOD May, 1999  
(Month/Year)

1. Design Electrical Rating (MWe-Net)\_\_\_\_\_ 720  
2. Maximum Dependable Capacity (MWe-Net)\_\_\_\_\_ 693

	<u>MONTH</u>	<u>-YTD-</u>	<u>CUMULATIVE</u>
3. Number of Hours Reactor Was Critical_____	744.0	3623.0	164533.0
4. Number of Hours Generator Was On Line_____	744.0	3623.0	162340.6
5. Unit Reserve Shutdown Hours_____	0.0	0.0	121.8
6. Net Electrical Energy (MWH)_____	506266.0	2571089.0	104391948.0

## UNIT SHUTDOWNS

DOCKET NO. 50-250  
UNIT NAME: Turkey Point #3  
DATE: June 3, 1999  
COMPLETED BY: G. S. Shukla  
TELEPHONE: (305) 246-6047

REPORT MONTH May, 1999

No.	Date	Type <sup>1</sup>	Duration (Hours)	Reason <sup>2</sup>	Method of Shutting Down Reactor <sup>3</sup>	Cause & Corrective Action Comments
N/A	N/A	N/A	N/A	N/A	N/A	N/A

1

F - Forced  
S - Scheduled

2

Reason  
A - Equipment Failure  
B - Maintenance or Test  
C - Refueling  
D - Regulatory restriction  
E - Operator Training &  
License Examination  
F - Administrative  
G - Operational Error (Explain)  
H - Other (Explain)

3

Method  
1 - Manual  
2 - Manual Scram  
3 - Automatic Scram  
4 - Continuation  
5 - Other (Explain)

## SUMMARY OF OPERATING EXPERIENCE

DOCKET NO.	<u>50-250</u>
UNIT:	<u>Turkey Point #3</u>
DATE:	<u>June 3, 1999</u>
COMPLETED BY:	<u>G. S. Shukla</u>
TELEPHONE:	<u>(305) 246-6047</u>

REPORT MONTH May, 1999

Unit 3 operated at essentially 100% for the entire month of May, 1999, except between May 8 - 9, 1999, when power was reduced to perform Turbine Valve Test and maintenance work on the Turbine Plant Cooling Water Heat Exchanger.



AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-251  
UNIT: Turkey Point #4  
DATE: June 3, 1999  
COMPLETED BY: G. S. Shukla  
TELEPHONE: (305) 246-6047

REPORT MONTH May, 1999

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
5/1/99	713
5/2/99	722
5/3/99	718
5/4/99	710
5/5/99	707
5/6/99	706
5/7/99	706
5/8/99	705
5/9/99	704
5/10/99	707
5/11/99	706
5/12/99	710
5/13/99	711
5/14/99	704
5/15/99	703
5/16/99	701
5/17/99	703
5/18/99	704
5/19/99	704
5/20/99	701
5/21/99	702
5/22/99	706
5/23/99	706
5/24/99	702
5/25/99	703
5/26/99	699
5/27/99	696
5/28/99	693
5/29/99	697
5/30/99	702
5/31/99	707

## OPERATING DATA REPORT

DOCKET NO. 50-251  
UNIT NAME TURKEY POINT UNIT 4  
DATE June 3, 1999  
COMPLETED BY G. S. Shukla  
TELEPHONE (305) 246-6047

REPORTING PERIOD May, 1999  
(Month/Year)

1. Design Electrical Rating (MWe-Net)\_\_\_\_\_ 720  
2. Maximum Dependable Capacity (MWe-Net)\_\_\_\_\_ 693

	<u>MONTH</u>	<u>-YTD-</u>	<u>CUMULATIVE</u>
3. Number of Hours Reactor Was Critical_____	744.0	3069.7	161137.2
4. Number of Hours Generator Was On Line_____	744.0	3048.8	156785.3
5. Unit Reserve Shutdown Hours_____	0.0	0.0	577.2
6. Net Electrical Energy (MWH)_____	524551	2134577	101807675

## UNIT SHUTDOWNS

DOCKET NO. 50-251  
 UNIT NAME: Turkey Point #4  
 DATE: June 3, 1999  
 COMPLETED BY: G. S. Shukla  
 TELEPHONE: (305) 246-6047

REPORT MONTH May, 1999

No.	Date	Type <sup>1</sup>	Duration (Hours)	Reason <sup>2</sup>	Method of Shutting Down Reactor <sup>3</sup>	Cause & Corrective Action Comments
N/A	N/A	N/A	N/A	N/A	N/A	N/A

1

F - Forced  
S - Scheduled

2

Reason  
 A - Equipment Failure  
 B - Maintenance or Test  
 C - Refueling  
 D - Regulatory restriction  
 E - Operator Training &  
     License Examination  
 F - Administrative  
 G - Operational Error (Explain)  
 H - Other (Explain)

3

Method  
 1 - Manual  
 2 - Manual Scram  
 3 - Automatic Scram  
 4 - Continued  
 5 - Other (Explain)

SUMMARY OF OPERATING EXPERIENCE

DOCKET NO.	<u>50-251</u>
UNIT:	<u>Turkey Point #4</u>
DATE:	<u>June 3, 1999</u>
COMPLETE BY:	<u>G. S. Shukla</u>
TELEPHONE:	<u>(305)246-6047</u>

REPORT MONTH May, 1999

Unit 4 operated at essentially 100% for the entire month of May, 1999.