

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9907210125 DOC. DATE: 99/06/30 NOTARIZED: NO DOCKET #
 FACIL: 50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
 50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251
 AUTH. NAME AUTHOR AFFILIATION
 SHUKLA, G.S. Florida Power & Light Co.
 HOVEY, R.J. Florida Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating repts for June 1999 for Turkey Point, Units 3 & 4. With 990713 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 9
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	JABBOUR, K	1 1		
INTERNAL:	FILE CENTER 01	1 1	OC/DBA/PAD	1 1
	RES/DRAA/OERAB	1 1	RGN2	1 1
EXTERNAL:	LMITCO MARSHALL	1 1	NOAC	1 1
	NRC PDR	1 1		

MICROFILMED

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 8 ENCL 8

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T



JUL 13 1999

L-99-163
10 CFR 50.36

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Monthly Operating Report - June, 1999

In accordance with the requirements of Turkey Point Units 3 and 4 Technical Specification 6.9.1.5, and the guidance of Generic Letter 97-02, attached are the June, 1999, Operating Data Report and Summary of Operating Experience for Turkey Point Units 3 and 4.

Very truly yours,

R. J. Hovey
Vice President
Turkey Point Plant

GSS

Attachments

cc: Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant

210004

9907210125 990630
PDR ADDCK 05000250
R PDR

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-250
UNIT: Turkey Point #3
DATE: July 7, 1999
COMPLETED BY: G. S. Shukla
TELEPHONE: (305) 246-6047

REPORT MONTH June, 1999

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
6/1/99	713
6/2/99	714
6/3/99	711
6/4/99	707
6/5/99	704
6/6/99	707
6/7/99	707
6/8/99	704
6/9/99	703
6/10/99	700
6/11/99	700
6/12/99	704
6/13/99	706
6/14/99	702
6/15/99	699
6/16/99	699
6/17/99	698
6/18/99	700
6/19/99	708
6/20/99	710
6/21/99	700
6/22/99	695
6/23/99	326
6/24/99	0
6/25/99	520
6/26/99	697
6/27/99	702
6/28/99	701
6/29/99	701
6/30/99	705

OPERATING DATA REPORT

DOCKET NO. 50-250
UNIT NAME TURKEY POINT UNIT 3
DATE July 7, 1999
COMPLETED BY G. S. Shukla
TELEPHONE (305) 246-6047

REPORTING PERIOD June, 1999
(Month/Year)

1. Design Electrical Rating (MWe-Net)_____ 720
2. Maximum Dependable Capacity (MWe-Net)_____ 693

	<u>MONTH</u>	<u>-YTD-</u>	<u>CUMULATIVE</u>
3. Number of Hours Reactor Was Critical_____	693.6	4316.6	165226.6
4. Number of Hours Generator Was On Line_____	687.3	4310.3	163027.9
5. Unit Reserve Shutdown Hours_____	0.0	0.0	121.8
6. Net Electrical Energy (MWH)_____	476209.0	3047298.0	104868157.0

SUMMARY OF OPERATING EXPERIENCE

DOCKET NO.	<u>50-250</u>
UNIT:	<u>Turkey Point #3</u>
DATE:	<u>July 7, 1999</u>
COMPLETED BY:	<u>G. S. Shukla</u>
TELEPHONE:	<u>(305) 246-6047</u>

REPORT MONTH June, 1999

Unit 3 operated at essentially 100% for the month of June, 1999, except between June 23 - 24, 1999. The reactor was manually tripped on June 23, 1999 after receiving rod drop indication. The reactor was started up on June 24, 1999, and achieved 100% power on June 25, 1999.

A Licensee Event Report (No. 1999-001-00) is being prepared for submittal to the NRC.

UNIT SHUTDOWNS

DOCKET NO. 50-250
UNIT NAME: Turkey Point #3
DATE: July 7, 1999
COMPLETED BY: G. S. Shukla
TELEPHONE: (305) 246-6047

REPORT MONTH June, 1999

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Cause & Corrective Action Comments
19990018	6/23/99	F	32.7	A	2	<p>The cause of the rod drop, that required manual reactor trip, was failure of a Stationary Gripper circuit card in the Rod Control System. The card failure was due to fracture of a solder terminal post. Failure of the card caused the group 1 rods in Shutdown Bank B to be released by their Stationary Gripper Coils, allowing the rods to drop into the core.</p> <p>Corrective actions included inspections and repairs of Stationary Gripper circuit cards and Post Maintenance Testing.</p> <p>A Licensee Event Report (No. 1999-001-00) is being prepared for submittal to the NRC.</p>

1

F - Forced
S - Scheduled

2

Reason
A - Equipment Failure
B - Maintenance or Test
C - Refueling
D - Regulatory restriction
E - Operator Training &
License Examination
F - Administrative
G - Operational Error (Explain)
H - Other (Explain)

3

Method
1 - Manual
2 - Manual Scram
3 - Automatic Scram
4 - Continuation
5 - Other (Explain)

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-251
UNIT: Turkey Point #4
DATE: July 7, 1999
COMPLETED BY: G. S. Shukla
TELEPHONE: (305) 246-6047

REPORT MONTH June, 1999

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
6/1/99	711
6/2/99	711
6/3/99	706
6/4/99	705
6/5/99	705
6/6/99	707
6/7/99	705
6/8/99	704
6/9/99	703
6/10/99	699
6/11/99	701
6/12/99	704
6/13/99	705
6/14/99	703
6/15/99	700
6/16/99	700
6/17/99	698
6/18/99	700
6/19/99	708
6/20/99	711
6/21/99	700
6/22/99	694
6/23/99	689
6/24/99	701
6/25/99	700
6/26/99	701
6/27/99	703
6/28/99	699
6/29/99	700
6/30/99	703

OPERATING DATA REPORT

DOCKET NO. 50-251
UNIT NAME TURKEY POINT UNIT 4
DATE July 7, 1999
COMPLETED BY G. S. Shukla
TELEPHONE (305) 246-6047

REPORTING PERIOD June, 1999
(Month/Year)

1. Design Electrical Rating (MWe-Net)_____ 720
2. Maximum Dependable Capacity (MWe-Net)_____ 693

	<u>MONTH</u>	<u>-YTD-</u>	<u>CUMULATIVE</u>
3. Number of Hours Reactor Was Critical_____	720.0	3789.7	161857.2
4. Number of Hours Generator Was On Line_____	720.0	3768.8	157505.3
5. Unit Reserve Shutdown Hours_____	0.0	0.0	577.2
6. Net Electrical Energy (MWH)_____	505757	2640334	102313432

UNIT SHUTDOWNS

DOCKET NO. 50-251
 UNIT NAME: Turkey Point #4
 DATE: July 7, 1999
 COMPLETED BY: G. S. Shukla
 TELEPHONE: (305) 246-6047

REPORT MONTH June, 1999

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Cause & Corrective Action Comments
N/A	N/A	N/A	N/A	N/A	N/A	N/A

1

F - Forced
S - Scheduled

2

Reason
 A - Equipment Failure
 B - Maintenance or Test
 C - Refueling
 D - Regulatory restriction
 E - Operator Training &
 License Examination
 F - Administrative
 G - Operational Error (Explain)
 H - Other (Explain)

3

Method
 1 - Manual
 2 - Manual Scram
 3 - Automatic Scram
 4 - Continued
 5 - Other (Explain)

SUMMARY OF OPERATING EXPERIENCE

DOCKET NO.	<u>50-251</u>
UNIT:	<u>Turkey Point #4</u>
DATE:	<u>July 7, 1999</u>
COMPLETE BY:	<u>G. S. Shukla</u>
TELEPHONE:	<u>(305)246-6047</u>

REPORT MONTH June, 1999

Unit 4 operated at essentially 100% for the entire month of June, 1999.

