

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9908310219 DOC.DATE: 99/08/23 NOTARIZED: NO DOCKET #
FACIL:50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251
AUTH.NAME AUTHOR AFFILIATION
HOVEY,R.J. Florida Power & Light Co.
RECIP.NAME RECIPIENT AFFILIATION
Records Management Branch (Document Control Desk)

SUBJECT: Informs that FPL has completed review of info listed in reactor vessel integrity database, version 2 & found listed discrepancies, re closure of GL 92-01, rev 1, suppl 1, "Reactor Vessel Structural Integrity."

DISTRIBUTION CODE: A028D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
TITLE: Generic Letter 92-01, Rev 1, Suppl 1 Responses (Reactor Vessel Struct

NOTES:

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
JABBOUR, K	1 1		
INTERNAL: FILE CENTER 01	1 1	NUDOCS-ABSTRACT	1 1
OGC/RP	1 0	RES/DET/MEB	1 1
EXTERNAL: NOAC	1 1	NRC PDR	1 1

MICROFILMED

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 7 ENCL 0



FPL

AUG 23 1999

L-99-174

10 CFR 50, Appendix G

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555-0001

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Closure of Generic Letter 92-01, Revision 1,
Supplement 1, "Reactor Vessel Structural Integrity"

On July 8, 1999, the NRC issued "Closure of TAC Nos. MA0579 and MA0580 - Response to the Requests for Additional Information to Generic Letter 92-01, Revision 1, Supplement 1, 'Reactor Vessel Integrity,' for the Turkey Point Plant, Units 3 and 4." The NRC letter requested that Florida Power and Light Co. (FPL) review and verify the accuracy of the information listed in the Reactor Vessel Integrity Database (RVID), Version 2, for Turkey Point Units 3 and 4. FPL has completed its review of the information listed in the RVID, Version 2, for Turkey Point Units 3 and 4 and found the following discrepancies:

1. The End of Life (EOL) dates for the Turkey Point units are not correct. The EOL for Unit 3 is July 19, 2012. The EOL date for Unit 4 is April 10, 2013.
2. The wall thickness for the beltline is 7.75 inches for both units.

Should there be any questions, please contact us.

Very truly yours,

R. J. Hovey
Vice President
Turkey Point Plant

OIH

cc: Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant

9908310219 990823
PDR ADOCK 05000250
P PDR

A0281/0

2000

1000

1000

1000

1000

1000

1000

1000