

December 19, 2017
L-17-373

Department of Environmental Protection
Bureau of Water Quality Management
Attention: DMR Clerk
400 Waterfront Drive
Pittsburgh, PA 15222

SUBJECT:

Beaver Valley Power Station Discharge Monitoring Report (NPDES) Permit No. PA0025615

Enclosed is the November 2017 NPDES Discharge Monitoring Report (DMR) for FirstEnergy Nuclear Operating Company (FENOC), Beaver Valley Power Station (BVPS), in accordance with the requirements of the Permit. Attachment 1 to this letter is supplemental monitoring data for Outfall 001 (dissolved oxygen). Attachment 2 is the explanation of NODI codes. Attachment 3 is the twice in one month per year analysis for Chromium and Zinc required on Outfalls 001, 004 and 012 as required by NPDES Permit Part C.19.

On November 18, 2017 at 0908 hours, FirstEnergy's BETA Lab contacted BVPS chemistry to confirm that a sample taken November 9, 2017 from Outfall 012, Emergency Response Facility HVAC blowdown, analyzed high for zinc. The result, 1.6 ppm, exceeds the daily maximum limit of 1.5 ppm established in our permit. A sample obtained on the previous day, November 8, 2017 was analyzed to have a zinc concentration of 0.5 ppm. Chemistry personnel contacted the BVPS control room at 0947 to inform them of the result and request the maintenance logs be evaluated for completed work during the time. A 24-hour notification was delivered via phone call and email on November 18, 2017 at 1652 hours.

FENOC takes such noncompliance incidents very seriously. An investigation into the cause of the elevated zinc has begun. Personnel immediately resampled Outfall 012 discharge on November 18, 2017 to evaluate if normal plant conditions had been restored. The sample taken November 18, 2017 at 1045 hours contained a zinc concentration of 0.269 ppm.

IE25
NRR

A potential cause of the elevated zinc is the higher than normal volume of domestic water being used by the plant around the time frame of the November 9, 2017 sample. This may have resulted in the transport of sediment in the domestic water supply lines from the Midland Water Authority to the plant. Investigation into the source of the elevated zinc level will be completed through our corrective action process.

Included with this report are two Supplemental Laboratory Accreditation Forms for analyses performed to support permit requirements as required by 25 Pa. Code § 252.

Should you have any questions regarding the attached and enclosed documents, please direct them to Ms. Kelsy McKee, at 724-682-4218.

Sincerely,



John J. Grabnar
General Plant Manager

Attachment(s):

1. Weekly Dissolved Oxygen Monitoring Results at Outfall 001
2. Explanation of NODI Codes
3. Annual Zn and Cr Monitoring Results

Enclosure(s)

- A. Discharge Monitoring Report
- B. Supplemental Laboratory Accreditation Form
- C. Non-Compliance Reporting Form

cc: Document Control Desk US NRC (NOTE: No new US NRC commitments are contained in this letter.)
US Environmental Protection Agency
Ms. Amanda Schmidt, PA DEP/Bureau of Water Quality Management

ATTACHMENT 1

Weekly Dissolved Oxygen Monitoring Results at Outfall 001

The following supplemental dissolved oxygen monitoring data for Outfall 001 is provided as agreed.

SAMPLE DATE	SAMPLE TIME	VALUE	UNITS
11/02/17	09:00:00 AM	7.00	mg/L
11/08/17	10:10:00 AM	7.00	mg/L
11/12/17	10:20:00 AM	7.00	mg/L
11/20/17	09:00:00 AM	7.00	mg/L
11/29/17	10:42:00 AM	7.00	Mg/L

- Attachment 1 END -

Discharge Monitoring Report Attachment for NPDES Permit No. PA0025615 L-17-373
FirstEnergy Nuclear Operating Company (FENOC)
Beaver Valley Power Station

ATTACHMENT 2

Explanation of NODI Codes

SAMPLE	SAMPLE PARAMETER	DOMI CODE	COMMENT
001A	Nitrogen	GG	Wet lay-up not done during month
001A	Hydrazine	GG	Wet lay-up not done during month
001A	CT-1	GG	Product not used
010A	CT-1	GG	Product not used
101A	Nitrogen	GG	Wet lay-up not done during month
101A	Hydrazine	GG	Wet lay-up not done during month

- Attachment 2 END -

ATTACHMENT 3

Permit Part C.19 Chromium & Zinc Monitoring Outfalls 001, 004, and 012

Permit Part C.19 requires monitoring for chromium and zinc at Outfalls 001, 004, and 012 twice per year in the same month.

Outfall 001	SAMPLE DATE	SAMPLE TIME	VALUE	MEASURE UNITS
Chromium	11/08/17	1210	<0.01	mg/L
Zinc	11/08/17	1210	0.037	mg/L
Chromium	11/09/17	1235	<0.01	mg/L
Zinc	11/09/17	1235	0.113	mg/L

Outfall 004	SAMPLE DATE	SAMPLE TIME	VALUE	MEASURE UNITS
Chromium	11/07/17	1130	<0.01	mg/L
Zinc	11/07/17	1130	0.068	mg/L
Chromium	11/08/17	1220	<0.01	mg/L
Zinc	11/08/17	1220	0.043	mg/L

Outfall 012	SAMPLE DATE	SAMPLE TIME	VALUE	MEASURE UNITS
Chromium	11/08/17	1115	0.01	mg/L
Zinc	11/08/17	1115	0.5530	mg/L
Chromium	11/09/17	1100	0.03	mg/L
Zinc	11/09/17	1100	1.6400	mg/L
Chromium	11/18/17	1045	<0.01	mg/L
Zinc	11/18/17	1045	0.2690	mg/L

- Attachment 3 END -

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 1

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615	001A
PERMIT NUMBER	DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
UNITS 1&2 COOLG. TOWER BLWDN
External Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2017	TO	11/ 30/ 2017

No Discharge

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	8.0	N/A	8.5	SU	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	SU		Weekly	GRAB
Nitrogen, ammonia total (as N)	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	GG	GG	mg/L	0	DIS / C	GRAB
00610 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon MO AVG	Req. Mon DAILY MX	mg/L		Weekly	GRAB
CLAMTROL CT-1, TOTAL WATER	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	GG	GG	mg/L	0	DIS / C	24 HR COMP
04251 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	0 MO AVG	0 DAILY MX	mg/L		When Discharging	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	27.6	34.1	MGD	N/A	N/A	N/A	N/A	-	DAILY	CONT
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MX	MGD	*****	*****	*****	N/A		Daily	CONTIN
Chlorine, total residual	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.02	<0.02	mg/L	0	1 / 7	GRAB
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	.5 AVERAGE	1.25 MAXIMUM	mg/L		Weekly	GRAB
Chlorine, free available	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.03	0.25	mg/L	0	Continuous	RCORDR
50064 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	.2 AVERAGE	.5 MAXIMUM	mg/L		Continuous	RCORDR
Hydrazine	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	GG	GG	mg/L	0	1 / 7	GRAB
81313 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	0 MO AVG	0 DAILY MX	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
John J. Grabnar, General Plant Manager		724	682-7773	12/ 15/ 2017
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		MM/DD/YYYY
		AREA Code	NUMBER	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

HYDRAZINE / AMMONIA MONITORING APPLY DURING PERIODS OF WET LAYUP. REPORT DAILY MAXIMUM FOR BETZ DT-1 WHEN DISCHARGING. THE LIMIT IS 35 MG/L AS A DAILY MAX.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 2

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

002A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)

FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004


INTAKE SCREEN BACKWASH
External Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM 11/ 01/ 2017		TO 11/ 30/ 2017	

No Discharge

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.006	0.046	MGD	N/A	N/A	N/A	N/A	0	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE
John J. Grabnar, General Plant Manager			724	682-7773	12/ 15/ 2017
TYPED OR PRINTED			AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

• PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 3

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615	003A
PERMIT NUMBER	DISCHARGE NUMBER


DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
003
External Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		TO	MM/DD/YYYY
FROM	11/ 01/ 2017		11/ 30/ 2017

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.173	0.414	MGD	N/A	N/A	N/A	N/A	-	30 / 30	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	N/A		Twice Per Month	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	<small>I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.</small>	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE
John J. Grabnar, General Plant Manager			724	682-7773	12/ 15/ 2017
			AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

THE FLOWS FOR OUTFALLS 103, 203, 303, AND 403 ARE TO BE TOTALED AND REPORTED AS THE 003 FLOW.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 4

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

004A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
UNIT ONE COOLG TOWER OVERFLOW
External Outfall

FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2017	TO	11/ 30/ 2017

No Discharge

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	8.1	N/A	8.1	pH	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	SU		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	2.57	7.71	MGD	N/A	N/A	N/A	N/A	-	1 / 7	MEAS
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req Mon MO AVG	Req Mon DAILY MX	MGD	*****	*****	*****	N/A		Weekly	MEASRD
Chlorine, total residual	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	0.1	0.12	mg/L	0	1 / 7	GRAB
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	0.5 MO AVG	1.25 INST MAX	mg/L		Weekly	GRAB
Chlorine, free available	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	0.1	0.10	mg/L	0	1 / 7	GRAB
50064 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	0.2 AVERAGE	0.5 MAXIMUM	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
John J. Grabnar, General Plant Manager		724	682-7773	12/ 15/ 2017
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 5

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615	006A
PERMIT NUMBER	DISCHARGE NUMBER


DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
AUX. INTAKE SCREEN BACKWASH
External Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD				
MM/DD/YYYY			MM/DD/YYYY	
FROM	11/ 01/ 2017	TO	11/ 30/ 2017	

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.002	0.016	MGD	N/A	N/A	N/A	N/A	0	1 / 7	EST
50050 1'0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO.AVG	Req. Mon DAILY.MX	MGD	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE	
John J. Grabnar, General Plant Manager			724	682-7773	12/ 15/ 2017	
			AREA Code	NUMBER	MM/DD/YYYY	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 6

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615	007A
PERMIT NUMBER	DISCHARGE NUMBER


DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
AUX. INTAKE SYSTEM
External Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2017	TO	11/ 30/ 2017

No Discharge ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	SU		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****			Weekly	GRAB
Chlorine, total residual	SAMPLE MEASUREMENT										
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	5 MO AVG	1.25 INST MAX	mg/L		Weekly	GRAB
Chlorine, free available	SAMPLE MEASUREMENT										
50064 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	2 AVERAGE	5 MAXIMUM	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE
John J. Grabnar, General Plant Manager			724	682-7773	12/ 15/ 2017
			AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

MONITORING FOR FLOW, FREE AVAILABLE CHLORINE, AND TOTAL RESIDUAL CHLORINE ARE REQUIRED ONLY DURING THOSE PERIODS OF DISCHARGE FROM THE ALTERNATE FLOW PATH OF THE REACTOR PLANT RIVER WATER SYSTEM.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 7

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

008A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
UNIT 1 COOLING TOWER PUMPHOUSE
External Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2017	TO	11/ 30/ 2017

No Discharge



PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	SU		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	100 DAILY MX	mg/L		Twice Per Month	GRAB
Oil & grease	SAMPLE MEASUREMENT										
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	15 MO AVG	20 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Reg. Mon. MO AVG	Reg. Mon. DAILY MX	MGD	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
John J. Grabnar, General Plant Manager		724	682-7773	12/ 15/ 2017
TYPED OR PRINTED		AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 8

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

010A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
UNIT 2 COOLING WATER
External Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2017	TO	11/ 30/ 2017

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.7	N/A	8.0	SU	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	SU		Weekly	GRAB
CLAMTROL CT-1, TOTAL WATER	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	GG	GG	mg/L	0	DIC / C	24 HR COMP
04251 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	0 MO AVG	0 INST MAX	mg/L		When Discharging	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	2.8	2.9	MGD	N/A	N/A	N/A	N/A	0	1 / 7	MEAS
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	N/A		Weekly	MEASRD
Chlorine, total residual	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.06	0.09	mg/L	0	1 / 7	GRAB
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	5 MO AVG	1.25 INST MAX	mg/L		Weekly	GRAB
Chlorine, free available	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.02	<0.02	mg/L	0	1 / 7	GRAB
50064 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	2 AVERAGE	5 MAXIMUM	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
John J. Grabnar, General Plant Manager		724	682-7773	12/ 15/ 2017
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

REPORT THE DAILY MAXIMUM FOR BETZ DT-1 WHEN DISCHARGING (24 HR. COMP.): MG/L. (THE LIMIT IS 35 MG/L AS A DAILY MAX)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 9

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

011A
DISCHARGE NUMBER


DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
DIESEL GEN & TURBINE DRAINS
External Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY			MM/DD/YYYY
FROM 11/ 01/ 2017		TO	11/ 30/ 2017

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.004	0.004	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
John J. Grabnar, General Plant Manager				12/ 15/ 2017
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		
		AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 10

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

012A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)

FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

BLOWDOWN FROM THE HVAC UNIT
External Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2017	TO	11/ 30/ 2017

No Discharge

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	8.2	N/A	8.3	SU	pH	3 / 30	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	SU		Once Per Month	GRAB
Copper, total (as Cu)	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	0.2643	0.4900	mg/L	0	3 / 30	GRAB
01042 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice Per Month	GRAB
Zinc, total (as Zn)	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	0.8	1.6	mg/L	1	3 / 30	GRAB
01092 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	1.5 MO AVG	1.5 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	<0.001	<0.001	MGD	N/A	N/A	N/A	N/A	-	1 / 30	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	N/A		Once Per Month	ESTIMA
Solids, total dissolved	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	651	816	mg/L	0	3 / 30	GRAB
70295 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice Per Month	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE	
John J. Grabnar, General Plant Manager		724 682-7773		12/ 15/ 2017	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code	NUMBER
					MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
High volume of Domestic water utilized by the plant resulted in zinc daily max exceedance.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 11

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

013A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
OUTFALL 013
External Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY			MM/DD/YYYY
FROM	11/ 01/ 2017	TO	11/ 30/ 2017

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.1	N/A	7.6	SU	1	0 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	SU		Weekly	GRAB
Cyanide, total (as CN)	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.01	<0.01	mg/L	0	2 / 30	24 HR COMP
00720 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice Per Month	COMP24
Copper, total (as Cu)	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.0148	0.0196	mg/L	0	2 / 30	24 HR COMP
01042 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice Per Month	COMP24
Chlorobenzene	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.005	<0.005	mg/L	0	1 / 30	24 HR COMP
34301 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice Per Month	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.002	0.002	MGD	N/A	N/A	N/A	N/A	0	2 / 30	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	N/A		Twice Per Month	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
John J. Grabnar, General Plant Manager		724	682-7773	12/ 15/ 2017
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 12

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615	101A
PERMIT NUMBER	DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
101 CHEMICAL WASTE TREATMENT
Internal Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		TO	MM/DD/YYYY
FROM	11/ 01/ 2017		11/ 30/ 2017

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	6.2	N/A	8.6	pH	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<4	5	mg/L	0	1 / 7	2 HR COMP
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	COMP-2
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5	<5	mg/L	0	1 / 7	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Nitrogen, ammonia total (as N)	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	GG	GG	mg/L	GG	1 / 7	
00610 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon MO AVG	Req. Mon DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.008	0.008	MGD	N/A	N/A	N/A	N/A	-	4 / 4	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MX	MGD	*****	*****	*****	N/A		DAILY	CONTIN
Hydrazine	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	GG	GG	mg/L	GG	GG GG	
81313 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon MO AVG	Req. Mon DAILY MX	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
John J. Grabnar, General Plant Manager		724	682-7773	12/ 15/ 2017
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

HYDRAZINE AND AMMONIA MONITORING TO APPLY DURING PERIODS OF WET LAYUP. SAMPLES SHALL BE TAKEN AT THE DISCHARGE FROM THE CHEMICAL WASTE SUMP PRIOR TO MIXING WITH ANY OTHER WATER. Flow measurements recorded on days of manual discharge. Discharge events were estimated based on sump volume.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 13

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615	102A
PERMIT NUMBER	DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
102 INTAKE SCREEN HOUSE
Internal Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		TO	MM/DD/YYYY
11/	01/	2017	11/ 30/ 2017

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.7	N/A	7.8	SU	0	2 / 30	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	SU		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	29	29	mg/L	0	2 / 30	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Twice Per Month	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5	<5	mg/L	0	2 / 30	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	<0.001	<0.001	MGD	N/A	N/A	N/A	N/A	0	2 / 30	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	N/A		Twice Per Month	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE	
John J. Grabnar, General Plant Manager		724	682-7773	12/ 15/ 2017	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code	NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT THE DISCHARGE OF COLLECTED PUMP BEARING LEAKAGE PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 14

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615	103A
PERMIT NUMBER	DISCHARGE NUMBER


DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
SLUDGE SETTLING BASIN
Internal Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2017	TO	11/ 30/ 2017

No Discharge

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.6	N/A	7.7	SU	0	2 / 30	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	SU		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<4	4	mg/L	0	2 / 30	24 HR COMP
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Twice Per Month	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.154	0.358	MGD	N/A	N/A	N/A	N/A	-	30 / 30	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Reg. Mon. MO AVG	Reg. Mon. DAILY MX	MGD	*****	*****	*****	N/A		Twice Per Month	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE
TYPED OR PRINTED			724 682-7773	12/ 15/ 2017	
			AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT THE OVERFLOW FROM THE BASIN PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 15

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

111A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
111 DIESEL GENERATOR BLDG
Internal Outfall

FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2017	TO	11/ 30/ 2017

No Discharge

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.4	N/A	7.8	SU	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<4	<4	mg/L	0	1 / 7	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5	<5	mg/L	0	1 / 7	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.002	0.002	MGD	N/A	N/A	N/A	N/A	0	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
John J. Grabnar, General Plant Manager		724	682-7773	12/ 15/ 2017
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 16

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615	113A
PERMIT NUMBER	DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
UNIT 2 SEWAGE TMT PLANT
Internal Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		TO	MM/DD/YYYY
FROM	11/ 01/ 2017	TO	11/ 30/ 2017

No Discharge ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	SU		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	60 DAILY MX	mg/L		Twice Per Month	COMP-8
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	043 MO AVG	Req Mon DAILY MX	MGD	*****	*****	*****	N/A		Weekly	MEASRD
Chlorine, total residual	SAMPLE MEASUREMENT										
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	1.4 MO AVG	3.3 INST MAX	mg/L		Twice Per Month	GRAB
Coliform, fecal general	SAMPLE MEASUREMENT										
74055 1 1 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	200 MO GEOMIN	*****	#/100mL		Twice Per Month	GRAB
BOD, carbonaceous, 05 day 20 C	SAMPLE MEASUREMENT										
80082 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	25 MO AVG	50 DAILY MX	mg/L		Twice Per Month	COMP-8

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
John J. Grabnar, General Plant Manager		724	682-7773	12/ 15/ 2017
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT OVERFLOW FROM THE CHLORINE CONTACT TANK PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 17

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615	203A
PERMIT NUMBER	DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
MAIN SEWAGE TMT PLANT
Internal Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2017	TO	11/ 30/ 2017

No Discharge ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	SU		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	60 DAILY MX	mg/L		Twice Per Month	COMP-8
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	023 MO AVG	Req Mon DAILY MX	MGD	*****	*****	*****			Weekly	MEASRD
Chlorine, total residual	SAMPLE MEASUREMENT										
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	1.4 MO AVG	3.3 INST MAX	mg/L		Twice Per Month	GRAB
Coliform, fecal general	SAMPLE MEASUREMENT										
74055 1 1 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	200 MO GEOMN	*****	#/100mL		Twice Per Month	GRAB
BOD, carbonaceous, 05 day 20 C	SAMPLE MEASUREMENT										
80082 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	25 MO AVG	50 DAILY MX	mg/L		Twice Per Month	COMP-8

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE	
John J. Grabnar, General Plant Manager		724 682-7773		12/ 15/ 2017	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code	NUMBER
					MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT OVERFLOW FROM THE CHLORINE CONTACT TANK PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 18

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

211A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
211 TURBINE BLDG
Internal Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2017	TO	11/ 30/ 2017

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.2	N/A	8.5	SU	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<4	<4	mg/L	0	1 / 7	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5	<5	mg/L	0	1 / 7	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.002	0.002	MGD	N/A	N/A	N/A		0	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Reg. Mon MO AVG	Reg. Mon DAILY MX	MGD	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
John J. Grabnar, General Plant Manager		724	682-7773	12/ 15/ 2017
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 19

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615	213A
PERMIT NUMBER	DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
UNIT 2 COOL TOWER PUMPHOUSE
Internal Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2017	TO	11/ 30/ 2017

No Discharge ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	SU		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	100 DAILY MX	mg/L		Twice Per Month	GRAB
Oil & grease	SAMPLE MEASUREMENT										
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	15 MO AVG	20 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req Mon MO AVG	Req Mon DAILY MX	MGD	*****	*****	*****			Weekly	ESTIMA
Chlorine, total residual	SAMPLE MEASUREMENT										
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	5 MO AVG	1.25 INST MAX	mg/L		Twice Per Month	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE	
John J. Grabnar, General Plant Manager		724	682-7773	12/ 15/ 2017	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code	NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT DISCHARGE FROM THE PUMP HOUSE PRIOR TO MIXING WITH ANY OTHER WATER. NOTE: THE MONITORING OF THIS DISCHARGE IS NOT REQUIRED WHEN EFFLUENT FROM UNIT NO. 2 COOLING TOWER PUMP HOUSE FLOOR & EQUIPMENT DRAINS IS BEING RECYCLED TO THE UNIT NO. 2 WATER RECIRCULATION SYSTEM.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

* PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 20

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615	301A
PERMIT NUMBER	DISCHARGE NUMBER


DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
UNIT 2 AUX BOILER BLOWDOWN
Internal Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2017	TO	11/ 30/ 2017

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<4	<4	mg/L	0	2 / 30	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Twice Per Month	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5	<5	mg/L	0	2 / 30	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	<0.001	<0.001	MGD	N/A	N/A	N/A	N/A	0	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MX	MGD	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		TELEPHONE		DATE
John J. Grabnar, General Plant Manager			724	682-7773	12/ 15/ 2017
			TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT THE DISCHARGE OF BOILER BLOWN DOWN PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 21

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615	303A
PERMIT NUMBER	DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
UNIT 1 OIL WATER SEPARATOR
Internal Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2017	TO	11/ 30/ 2017

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.2	N/A	7.5	pH	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<7	11	mg/L	0	1 / 7	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5	<5	mg/L	0	1 / 7	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.019	0.056	MGD	N/A	N/A	N/A	N/A	0	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Reg. Mon. MO AVG	Reg. Mon. DAILY MX	MGD	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
John J. Grabnar, General Plant Manager		724	682-7773	12/ 15/ 2017
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 22

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615	313A
PERMIT NUMBER	DISCHARGE NUMBER


DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
313 TURBINE BLDG DRAIN
Internal Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
11/ 01/ 2017	11/ 30/ 2017

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.1	N/A	7.6	SU	1	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<4	9	mg/L	0	1 / 1	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5	<5	mg/L	0	1 / 7	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.002	0.002	MGD	N/A	N/A	N/A	N/A	0	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MX	MGD	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE
John J. Grabnar, General Plant Manager			724 682-7773	12/ 15/ 2017	
TYPED OR PRINTED			AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 23

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615	401A
PERMIT NUMBER	DISCHARGE NUMBER


DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
CHEM.FEED AREA OF AUX BOILERS
Internal Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		TO	MM/DD/YYYY
11/ 01/ 2017			11/ 30/ 2017

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	8.8	N/A	9.0	SU	0	2 / 30	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	Req. Mon. MAXIMUM	SU		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<4	<4	mg/L	0	2 / 30	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Twice Per Month	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5	<5	mg/L	0	2 / 30	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	<0.001	<0.001	MGD	N/A	N/A	N/A	N/A	0	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		TELEPHONE		DATE
John J. Grabnar, General Plant Manager			724 682-7773	12/ 15/ 2017	
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
SAMPLES SHALL BE TAKEN AT CHEMICAL FEED AREA DRAINS PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 24

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

403A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
CONDENSATE BLOWDOWN & RIVR WAT
Internal Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2017	TO	11/ 30/ 2017

No Discharge



PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease	SAMPLE MEASUREMENT										
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Nitrogen, ammonia total (as N)	SAMPLE MEASUREMENT										
00610 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Weekly	GRAB
CLAMTROL CT-1, TOTAL WATER	SAMPLE MEASUREMENT										
04251 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	0 MO AVG	0 DAILY MX	mg/L		When Discharging	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****			Weekly	ESTIMA
Chlorine, total residual	SAMPLE MEASUREMENT										
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	5 MO AVG	0 INST MAX	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
John J. Grabnar, General Plant Manager		724	682-7773	12/ 15/ 2017
		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER
TYPED OR PRINTED				

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

HYDRAZINE AND AMMONIA MONITORING TO APPLY DURING PERIODS OF WET LAYUP. REPORT THE DAILY MAXIMUM FOR BETZ DT-1 WHEN DISCHARGING (24 HR. COMP.):
(THE LIMIT IS 35 MG/L AS A DAILY MAX.) SAMPLES SHALL BE TAKEN AT MP 403 PRIOR TO MIXING WITH ANY OTHER WATER.

MG/L.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 25

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615	403A
PERMIT NUMBER	DISCHARGE NUMBER


DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
CONDENSATE BLOWDOWN & RIVR WAT
Internal Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		TO	MM/DD/YYYY
FROM	11/ 01/ 2017		11/ 30/ 2017

No Discharge ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Hydrazine	SAMPLE MEASUREMENT										
81313 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	0 MO AVG	0 DAILY MX	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		TELEPHONE		DATE
John J. Grabnar, General Plant Manager			724	682-7773	12/ 15/ 2017
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

HYDRAZINE AND AMMONIA MONITORING TO APPLY DURING PERIODS OF WET LAYUP. REPORT THE DAILY MAXIMUM FOR BETZ DT-1 WHEN DISCHARGING (24 HR. COMP.):
LIMIT IS 35 MG/L AS A DAILY MAX.) SAMPLES SHALL BE TAKEN AT MP 403 PRIOR TO MIXING WITH ANY OTHER WATER.

MG/L. (THE

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 26

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615	413A
PERMIT NUMBER	DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
BULK FUEL STORAGE DRAIN
Internal Outfall


ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2017	TO	11/ 30/ 2017

No Discharge



PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT					N/A					
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease	SAMPLE MEASUREMENT										
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE	
John J. Grabnar, General Plant Manager			724	682-7773	12/ 15/ 2017	
			AREA Code	NUMBER	MM/DD/YYYY	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
SAMPLES SHALL BE TAKEN AT DISCHARGE FROM OWS #24 PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 27

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

501A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
UNIT 1 GENRTR BLWDWN FILT BW
Internal Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2017	TO	11/ 30/ 2017

No Discharge



PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Solids, total suspended	SAMPLE MEASUREMENT									/	
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT									/	
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****			Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
John J. Grabnar, General Plant Manager		724	682-7773	12/ 15/ 2017
TYPED OR PRINTED		AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
SAMPLES SHALL BE TAKEN AT INTERNAL MP 501 PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 1

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615	001A
PERMIT NUMBER	DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
UNITS 1&2 COOLG. TOWER BLWDN
External Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2017	TO	11/ 30/ 2017

No Discharge

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	8.0	N/A	8.5	SU	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	SU		Weekly	GRAB
Nitrogen, ammonia total (as N)	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	GG	GG	mg/L	0	DIS / C	GRAB
00610 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Weekly	GRAB
CLAMTROL CT-1, TOTAL WATER	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	GG	GG	mg/L	0	DIS / C	24 HR COMP
04251 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	0 MO AVG	0 DAILY MX	mg/L		When Discharging	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	27.6	34.1	MGD	N/A	N/A	N/A	N/A	-	DAILY	CONT
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	N/A		Daily	CONTIN
Chlorine, total residual	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.02	<0.02	mg/L	0	1 / 7	GRAB
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	5 AVERAGE	1.25 MAXIMUM	mg/L		Weekly	GRAB
Chlorine, free available	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.03	0.25	mg/L	0	Continuous	RCORDR
50064 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	2 AVERAGE	5 MAXIMUM	mg/L		Continuous	RCORDR
Hydrazine	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	GG	GG	mg/L	0	1 / 7	GRAB
81313 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	0 MO AVG	0 DAILY MX	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
John J. Grabnar, General Plant Manager		724	682-7773	12/ 15/ 2017
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

HYDRAZINE / AMMONIA MONITORING APPLY DURING PERIODS OF WET LAYUP. REPORT DAILY MAXIMUM FOR BETZ DT-1 WHEN DISCHARGING. THE LIMIT IS 35 MG/L AS A DAILY MAX.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 2

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615	002A
PERMIT NUMBER	DISCHARGE NUMBER


DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
INTAKE SCREEN BACKWASH
External Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2017	TO	11/ 30/ 2017

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.006	0.046	MGD	N/A	N/A	N/A	N/A	0	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE
John J. Grabnar, General Plant Manager			724	682-7773	12/ 15/ 2017
TYPED OR PRINTED			AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 3

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615	003A
PERMIT NUMBER	DISCHARGE NUMBER


DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
003
External Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2017	TO	11/ 30/ 2017

No Discharge

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.173	0.414	MGD	N/A	N/A	N/A	N/A	-	30 / 30	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	N/A		Twice Per Month	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		TELEPHONE		DATE
John J. Grabnar, General Plant Manager			724	682-7773	12/ 15/ 2017
TYPED OR PRINTED			SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
THE FLOWS FOR OUTFALLS 103, 203, 303, AND 403 ARE TO BE TOTALED AND REPORTED AS THE 003 FLOW.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 4

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615	004A
PERMIT NUMBER	DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
UNIT ONE COOLG TOWER OVERFLOW
External Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2017	TO	11/ 30/ 2017

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	8.1	N/A	8.1	pH	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	SU		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	2.57	7.71	MGD	N/A	N/A	N/A	N/A	-	1 / 7	MEAS
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Reg. Mon. MO AVG	Reg. Mon. DAILY MX	MGD	*****	*****	*****	N/A		Weekly	MEASRD
Chlorine, total residual	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	0.1	0.12	mg/L	0	1 / 7	GRAB
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	0.5 MO AVG	1.25 INST MAX	mg/L		Weekly	GRAB
Chlorine, free available	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	0.1	0.10	mg/L	0	1 / 7	GRAB
50064 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	0.2 AVERAGE	0.5 MAXIMUM	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE	
John J. Grabnar, General Plant Manager		724 682-7773		12/ 15/ 2017	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code	NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)**

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 5

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615	006A
PERMIT NUMBER	DISCHARGE NUMBER


DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
AUX. INTAKE SCREEN BACKWASH
External Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2017	TO	11/ 30/ 2017

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.002	0.016	MGD	N/A	N/A	N/A	N/A	0	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	<small>I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.</small>	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE	
John J. Grabnar, General Plant Manager TYPED OR PRINTED			724	682-7773	12/ 15/ 2017	
			AREA Code	NUMBER	MM/DD/YYYY	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)**

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 6

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

007A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
AUX. INTAKE SYSTEM
External Outfall

FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2017	TO	11/ 30/ 2017

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

No Discharge ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	SU		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY-MX	MGD	*****	*****	*****			Weekly	GRAB
Chlorine, total residual	SAMPLE MEASUREMENT										
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	5 MO AVG	1.25 INST MAX	mg/L		Weekly	GRAB
Chlorine, free available	SAMPLE MEASUREMENT										
50064 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	2 AVERAGE	5 MAXIMUM	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
John J. Grabnar, General Plant Manager		724	682-7773	12/ 15/ 2017
TYPED OR PRINTED		AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

MONITORING FOR FLOW, FREE AVAILABLE CHLORINE, AND TOTAL RESIDUAL CHLORINE ARE REQUIRED ONLY DURING THOSE PERIODS OF DISCHARGE FROM THE ALTERNATE FLOW PATH OF THE REACTOR PLANT RIVER WATER SYSTEM.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 7

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615	008A
PERMIT NUMBER	DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
UNIT 1 COOLING TOWER PUMPHOUSE
External Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY			MM/DD/YYYY
FROM	11/ 01/ 2017	TO	11/ 30/ 2017

No Discharge ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	SU		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	100 DAILY MX	mg/L		Twice Per Month	GRAB
Oil & grease	SAMPLE MEASUREMENT										
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	15 MO AVG	20 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MX	MGD	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
John J. Grabnar, General Plant Manager		724	682-7773	12/ 15/ 2017
TYPED OR PRINTED		AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 8

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615	010A
PERMIT NUMBER	DISCHARGE NUMBER


DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
UNIT 2 COOLING WATER
External Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		TO	MM/DD/YYYY
FROM 11/ 01/ 2017			11/ 30/ 2017

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.7	N/A	8.0	SU	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	SU		Weekly	GRAB
CLAMTROL CT-1, TOTAL WATER	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	GG	GG	mg/L	0	DIC / C	24 HR COMP
04251 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	0 MO AVG	0 INST MAX	mg/L		When Discharging	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	2.8	2.9	MGD	N/A	N/A	N/A	N/A	0	1 / 7	MEAS
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	N/A		Weekly	MEASRD
Chlorine, total residual	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.06	0.09	mg/L	0	1 / 7	GRAB
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	5 MO AVG	1.25 INST MAX	mg/L		Weekly	GRAB
Chlorine, free available	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.02	<0.02	mg/L	0	1 / 7	GRAB
50064 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	2 AVERAGE	5 MAXIMUM	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE
John J. Grabnar, General Plant Manager			724 682-7773	12/ 15/ 2017	
TYPED OR PRINTED			AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

REPORT THE DAILY MAXIMUM FOR BETZ DT-1 WHEN DISCHARGING (24 HR. COMP.): MG/L. (THE LIMIT IS 35 MG/L AS A DAILY MAX)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 9

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

011A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
DIESEL GEN & TURBINE DRAINS
External Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2017	TO	11/ 30/ 2017

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.004	0.004	MGD	N/A	N/A	N/A	N/A	-	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Reg. Mon. MO AVG	Reg. Mon. DAILY MX	MGD	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
John J. Grabnar, General Plant Manager		724	682-7773	12/ 15/ 2017
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		MM/DD/YYYY
		AREA Code	NUMBER	

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 10

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615	012A
PERMIT NUMBER	DISCHARGE NUMBER


DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
BLOWDOWN FROM THE HVAC UNIT
External Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2017	TO	11/ 30/ 2017

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	8.2	N/A	8.3	SU	pH	3 / 30	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	SU		Once Per Month	GRAB
Copper, total (as Cu)	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	0.2643	0.4900	mg/L	0	3 / 30	GRAB
01042 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice Per Month	GRAB
Zinc, total (as Zn)	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	0.8	1.6	mg/L	1	3 / 30	GRAB
01092 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	1.5 MO AVG	1.5 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	<0.001	<0.001	MGD	N/A	N/A	N/A	N/A	-	1 / 30	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	N/A		Once Per Month	ESTIMA
Solids, total dissolved	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	651	816	mg/L	0	3 / 30	GRAB
70295 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice Per Month	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER John J. Grabnar, General Plant Manager TYPED OR PRINTED	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE
			724	682-7773	12/ 15/ 2017
			AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

High volume of Domestic water utilized by the plant resulted in zinc daily max exceedance.

**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)**

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 11

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615	013A
PERMIT NUMBER	DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
OUTFALL 013
External Outfall

FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2017	TO	11/ 30/ 2017

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.1	N/A	7.6	SU	1	0 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	SU		Weekly	GRAB
Cyanide, total (as CN)	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.01	<0.01	mg/L	0	2 / 30	24 HR COMP
00720 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice Per Month	COMP24
Copper, total (as Cu)	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.0148	0.0196	mg/L	0	2 / 30	24 HR COMP
01042 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice Per Month	COMP24
Chlorobenzene	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<0.005	<0.005	mg/L	0	1 / 30	24 HR COMP
34301 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice Per Month	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.002	0.002	MGD	N/A	N/A	N/A	N/A	0	2 / 30	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	N/A		Twice Per Month	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
John J. Grabnar, General Plant Manager		724	682-7773	12/ 15/ 2017
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 12

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615	101A
PERMIT NUMBER	DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
101 CHEMICAL WASTE TREATMENT
Internal Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2017	TO	11/ 30/ 2017

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	6.2	N/A	8.6	pH	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<4	5	mg/L	0	1 / 7	2 HR COMP
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	COMP-2
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5	<5	mg/L	0	1 / 7	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Nitrogen, ammonia total (as N)	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	GG	GG	mg/L	GG	1 / 7	
00610 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.008	0.008	MGD	N/A	N/A	N/A	N/A	-	4 / 4	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	N/A		DAILY	CONTIN
Hydrazine	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	GG	GG	mg/L	GG	GG GG	
81313 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
John J. Grabnar, General Plant Manager		724	682-7773	12/ 15/ 2017
		AREA Code		NUMBER
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

HYDRAZINE AND AMMONIA MONITORING TO APPLY DURING PERIODS OF WET LAYUP. SAMPLES SHALL BE TAKEN AT THE DISCHARGE FROM THE CHEMICAL WASTE SUMP PRIOR TO MIXING WITH ANY OTHER WATER. Flow measurements recorded on days of manual discharge. Discharge events were estimated based on sump volume.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 13

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

102A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
102 INTAKE SCREEN HOUSE
Internal Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2017	TO	11/ 30/ 2017

No Discharge

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.7	N/A	7.8	SU	0	2 / 30	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	SU		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	29	29	mg/L	0	2 / 30	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Twice Per Month	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5	<5	mg/L	0	2 / 30	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	<0.001	<0.001	MGD	N/A	N/A	N/A	N/A	0	2 / 30	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	N/A		Twice Per Month	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE	
John J. Grabnar, General Plant Manager			724 682-7773		12/ 15/ 2017	
TYPED OR PRINTED			SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code	NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT THE DISCHARGE OF COLLECTED PUMP BEARING LEAKAGE PRIOR TO MIXING WITH ANY OTHER WATER.

**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)**

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 14

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615	103A
PERMIT NUMBER	DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
SLUDGE SETTLING BASIN
Internal Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2017	TO	11/ 30/ 2017

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.6	N/A	7.7	SU	0	2 / 30	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	SU		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<4	4	mg/L	0	2 / 30	24 HR COMP
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Twice Per Month	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.154	0.358	MGD	N/A	N/A	N/A	N/A	-	30 / 30	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	N/A		Twice Per Month	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
John J. Grabnar, General Plant Manager		724 682-7773		12/ 15/ 2017
		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		MM/DD/YYYY
TYPED OR PRINTED			AREA Code	NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT THE OVERFLOW FROM THE BASIN PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 15

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615	111A
PERMIT NUMBER	DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
111 DIESEL GENERATOR BLDG
Internal Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD					
MM/DD/YYYY			TO	MM/DD/YYYY	
11/	01/	2017		11/	30/ 2017

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.4	N/A	7.8	SU	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<4	<4	mg/L	0	1 / 7	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5	<5	mg/L	0	1 / 7	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.002	0.002	MGD	N/A	N/A	N/A	N/A	0	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
John J. Grabnar, General Plant Manager		724	682-7773	12/ 15/ 2017
TYPED OR PRINTED		AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 16

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

113A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
UNIT 2 SEWAGE TMT PLANT
Internal Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2017	TO	11/ 30/ 2017

No Discharge ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	SU		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	60 DAILY MX	mg/L		Twice Per Month	COMP-8
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	.043 MO AVG	Req. Mon DAILY MX	MGD	*****	*****	*****	N/A		Weekly	MEASRD
Chlorine, total residual	SAMPLE MEASUREMENT										
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	1.4 MO AVG	3.3 INST MAX	mg/L		Twice Per Month	GRAB
Coliform, fecal general	SAMPLE MEASUREMENT										
74055 1 1 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	200 MO GEOMN	*****	#/100mL		Twice Per Month	GRAB
BOD, carbonaceous, 05 day 20 C	SAMPLE MEASUREMENT										
80082 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	25 MO AVG	50 DAILY MX	mg/L		Twice Per Month	COMP-8

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE	
John J. Grabnar, General Plant Manager		724 682-7773		12/ 15/ 2017	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code	NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT OVERFLOW FROM THE CHLORINE CONTACT TANK PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 17

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615	203A
PERMIT NUMBER	DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
MAIN SEWAGE TMT PLANT
Internal Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD				
MM/DD/YYYY			MM/DD/YYYY	
FROM 11/ 01/ 2017		TO	11/ 30/ 2017	

No Discharge ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	SU		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	60 DAILY MX	mg/L		Twice Per Month	COMP-8
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	023 MO AVG	Reg. Mon. DAILY MX	MGD	*****	*****	*****			Weekly	MEASRD
Chlorine, total residual	SAMPLE MEASUREMENT										
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	1.4 MO AVG	3.3 INST MAX	mg/L		Twice Per Month	GRAB
Coliform, fecal general	SAMPLE MEASUREMENT										
74055 1 1 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	200 MO GEOMN	*****	#/100mL		Twice Per Month	GRAB
BOD, carbonaceous, 05 day 20 C	SAMPLE MEASUREMENT										
80082 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	25 MO AVG	50 DAILY MX	mg/L		Twice Per Month	COMP-8

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
John J. Grabnar, General Plant Manager		724	682-7773	12/ 15/ 2017
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		MM/DD/YYYY
		AREA Code	NUMBER	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT OVERFLOW FROM THE CHLORINE CONTACT TANK PRIOR TO MIXING WITH ANY OTHER WATER.

**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)**

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 18

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615	211A
PERMIT NUMBER	DISCHARGE NUMBER


DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
211 TURBINE BLDG
Internal Outfall

MONITORING PERIOD				
MM/DD/YYYY			MM/DD/YYYY	
FROM 11/ 01/ 2017		TO	11/ 30/ 2017	

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.2	N/A	8.5	SU	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<4	<4	mg/L	0	1 / 7	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5	<5	mg/L	0	1 / 7	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.002	0.002	MGD	N/A	N/A	N/A		0	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MX	MGD	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		TELEPHONE		DATE
John J. Grabnar, General Plant Manager			724 682-7773		12/ 15/ 2017
			SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

* PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 19

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615	213A
PERMIT NUMBER	DISCHARGE NUMBER


DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
UNIT 2 COOL TOWER PUMPHOUSE
Internal Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2017	TO	11/ 30/ 2017

No Discharge ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	SU		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	100 DAILY MX	mg/L		Twice Per Month	GRAB
Oil & grease	SAMPLE MEASUREMENT										
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	15 MO AVG	20 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****			Weekly	ESTIMA
Chlorine, total residual	SAMPLE MEASUREMENT										
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	5 MO AVG	1.25 INST MAX	mg/L		Twice Per Month	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE	DATE
John J. Grabnar, General Plant Manager			724 682-7773	12/ 15/ 2017
TYPED OR PRINTED			AREA Code	NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT DISCHARGE FROM THE PUMP HOUSE PRIOR TO MIXING WITH ANY OTHER WATER. NOTE: THE MONITORING OF THIS DISCHARGE IS NOT REQUIRED WHEN EFFLUENT FROM UNIT NO. 2 COOLING TOWER PUMP HOUSE FLOOR & EQUIPMENT DRAINS IS BEING RECYCLED TO THE UNIT NO. 2 WATER RECIRCULATION SYSTEM.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 20

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

301A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
UNIT 2 AUX BOILER BLOWDOWN
Internal Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY			MM/DD/YYYY
FROM 11/ 01/ 2017		TO	11/ 30/ 2017

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<4	<4	mg/L	0	2 / 30	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Twice Per Month	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5	<5	mg/L	0	2 / 30	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	<0.001	<0.001	MGD	N/A	N/A	N/A	N/A	0	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Reg Mon MO AVG	Reg Mon DAILY MX	MGD	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE	
John J. Grabnar, General Plant Manager		724	682-7773	12/ 15/ 2017	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code	NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT THE DISCHARGE OF BOILER BLOWN DOWN PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 21

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615	303A
PERMIT NUMBER	DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
UNIT 1 OIL WATER SEPARATOR
Internal Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
FROM 11/ 01/ 2017	TO 11/ 30/ 2017

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.2	N/A	7.5	pH	0	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<7	11	mg/L	0	1 / 7	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5	<5	mg/L	0	1 / 7	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.019	0.056	MGD	N/A	N/A	N/A	N/A	0	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon DAILY MX	MGD	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER John J. Grabnar, General Plant Manager TYPED OR PRINTED	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE 724 682-7773	DATE 12/ 15/ 2017
		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 22

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

313A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
313 TURBINE BLDG DRAIN
Internal Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD
MM/DD/YYYY MM/DD/YYYY
FROM 11/ 01/ 2017 TO 11/ 30/ 2017

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	7.1	N/A	7.6	SU	1	1 / 7	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<4	9	mg/L	0	1 / 1	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5	<5	mg/L	0	1 / 7	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.002	0.002	MGD	N/A	N/A	N/A	N/A	0	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req: Mon MO AVG	Req: Mon DAILY MX	MGD	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
John J. Grabnar, General Plant Manager		724	682-7773	12/ 15/ 2017
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

Page 23

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615	401A
PERMIT NUMBER	DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
CHEM.FEED AREA OF AUX BOILERS
Internal Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2017	TO	11/ 30/ 2017

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT	N/A	N/A	N/A	8.8	N/A	9.0	SU	0	2 / 30	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	8 MINIMUM	*****	Req. Mon. MAXIMUM	SU		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<4	<4	mg/L	0	2 / 30	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Twice Per Month	GRAB
Oil & grease	SAMPLE MEASUREMENT	N/A	N/A	N/A	N/A	<5	<5	mg/L	0	2 / 30	GRAB
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Twice Per Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	<0.001	<0.001	MGD	N/A	N/A	N/A	N/A	0	1 / 7	EST
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
John J. Grabnar, General Plant Manager		724	682-7773	12/ 15/ 2017
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

SAMPLES SHALL BE TAKEN AT CHEMICAL FEED AREA DRAINS PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 24

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615
PERMIT NUMBER

403A
DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)

FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

CONDENSATE BLOWDOWN & RIVR WAT
Internal Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2017	TO	11/ 30/ 2017

No Discharge



PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT										
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		6 MINIMUM	*****	9 MAXIMUM	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease	SAMPLE MEASUREMENT										
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Nitrogen, ammonia total (as N)	SAMPLE MEASUREMENT										
00610 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Weekly	GRAB
CLAMTROL CT-1, TOTAL WATER	SAMPLE MEASUREMENT										
04251 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	0 MO AVG	0 DAILY MX	mg/L		When Discharging	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****			Weekly	ESTIMA
Chlorine, total residual	SAMPLE MEASUREMENT										
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	5 MO AVG	0 INST MAX	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
John J. Grabnar, General Plant Manager		724	682-7773	12/ 15/ 2017
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

HYDRAZINE AND AMMONIA MONITORING TO APPLY DURING PERIODS OF WET LAYUP. REPORT THE DAILY MAXIMUM FOR BETZ DT-1 WHEN DISCHARGING (24 HR. COMP.):
(THE LIMIT IS 35 MG/L AS A DAILY MAX.) SAMPLES SHALL BE TAKEN AT MP 403 PRIOR TO MIXING WITH ANY OTHER WATER.

MG/L.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 25

PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615	403A
PERMIT NUMBER	DISCHARGE NUMBER


DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
CONDENSATE BLOWDOWN & RIVR WAT
Internal Outfall

ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2017	TO	11/ 30/ 2017

No Discharge ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Hydrazine	SAMPLE MEASUREMENT										
81313 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****		*****	0 MO AVG	0 DAILY MX	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE
John J. Grabnar, General Plant Manager			724	682-7773	12/ 15/ 2017
TYPED OR PRINTED			AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

HYDRAZINE AND AMMONIA MONITORING TO APPLY DURING PERIODS OF WET LAYUP. REPORT THE DAILY MAXIMUM FOR BETZ DT-1 WHEN DISCHARGING (24 HR. COMP.):
LIMIT IS 35 MG/L AS A DAILY MAX.) SAMPLES SHALL BE TAKEN AT MP 403 PRIOR TO MIXING WITH ANY OTHER WATER.

MG/L. (THE

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 26

* PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615	413A
PERMIT NUMBER	DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
BULK FUEL STORAGE DRAIN
Internal Outfall


ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2017	TO	11/ 30/ 2017

No Discharge



PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
pH	SAMPLE MEASUREMENT					N/A					
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	6 MINIMUM	*****	9 MAXIMUM	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT										
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Oil & grease	SAMPLE MEASUREMENT										
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	N/A	*****	15 MO AVG	20 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT										
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	N/A		Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE
John J. Grabnar, General Plant Manager			724	682-7773	12/ 15/ 2017
TYPED OR PRINTED			AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
SAMPLES SHALL BE TAKEN AT DISCHARGE FROM OWS #24 PRIOR TO MIXING WITH ANY OTHER WATER.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

Page 27

*PERMITTEE NAME/ADDRESS (include Facility Name/Location if Different)

NAME: FIRST ENERGY NUCLEAR OPERATING
ADDRESS: PA ROUTE 168
SHIPPINGPORT, PA 150770004
FACILITY: BEAVER VALLEY POWER STATION
LOCATION: PA ROUTE 168
SHIPPINGPORT, PA 150770004

PA0025615	501A
PERMIT NUMBER	DISCHARGE NUMBER

DMR MAILING ZIP CODE: 150770004
MAJOR
(SUBR05)
UNIT 1 GENRTR BLWDWN FILT BW
Internal Outfall


ATTN: JOHN J GRABNAR/GENERAL PLANT MANAGER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	11/ 01/ 2017	TO	11/ 30/ 2017

No Discharge



PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Solids, total suspended 00530 1 0 Effluent Gross	SAMPLE MEASUREMENT									/	
	PERMIT REQUIREMENT	*****	*****		*****	30 MO AVG	100 DAILY MX	mg/L		Weekly	GRAB
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT									/	
	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****			Weekly	ESTIMA

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		TELEPHONE		DATE
John J. Grabnar, General Plant Manager			724	682-7773	12/ 15/ 2017
			TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
SAMPLES SHALL BE TAKEN AT INTERNAL MP 501 PRIOR TO MIXING WITH ANY OTHER WATER.



pennsylvania
DEPARTMENT OF ENVIRONMENTAL PROTECTION

COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF WATER STANDARDS AND FACILITY REGULATION

SUPPLEMENTAL LABORATORY ACCREDITATION FORM¹

Permittee Name: <u>FirstEnergy Nuclear Operating Company</u>							
Address: <u>P.O. Box 4</u>							
<u>Shippingport, PA 15077</u>							
<u>Beaver Valley Power Station</u>							
PERMIT NUMBER				MONITORING PERIOD Year/Month/Day			
PA0025615				2017	11	01	TO 2017 11 30
PARAMETER	ANALYSIS METHOD	LAB NAME	LAB ID NUMBER²				
Total Residual Chlorine	SM 4500-CL G [20 th]	Beaver Valley Power Station	04-2742				
Free Available Chlorine	SM 4500-CL G [20 th]	Beaver Valley Power Station	04-2742				
pH	SM 4500-H+ B [20 th]	Beaver Valley Power Station	04-2742				
Temperature	SM 2550 B [20 th]	Beaver Valley Power Station	04-2742				
Flow	NA	Beaver Valley Power Station	04-2742				
Total Suspended Solids (TSS)	SM 2540 D [20 th]	Beaver Valley Power Station	04-2742				
Quaternary Amine Compounds	Photometric Determination ½-CHM-ANA-4.23H	Beaver Valley Power Station	04-2742				
Bentonite Detoxicant	Estimated using feed rate and discharge flow rate per NPDES Permit PA0025645	Beaver Valley Power Station	04-2742				
Hydrazine	ASTM D1385-01	Beaver Valley Power Station	04-2742				

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibly of fine and imprisonment for knowing violations.

Name/Title Principal Executive Officer

John J. Grabnar
General Plant Manager

Phone: 724-682-7773

Date:

12/15/17

Signature of Principal Executive Officer or Authorized Agent

[Signature]

¹ Submit this form with the first Discharge Monitoring Report (DMR), Annual Report or Recordkeeping and Reporting Form, where sample results are submitted to the Department for compliance purposes. You do not need to send this form to the Department again UNLESS there has been a change to the lab or method of analysis.

² For parameter(s) covered under accreditation-by-rule, submit the lab's registration number in lieu of an accreditation number.



pennsylvania
DEPARTMENT OF ENVIRONMENTAL PROTECTION

COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF WATER STANDARDS AND FACILITY REGULATION

SUPPLEMENTAL LABORATORY ACCREDITATION FORM¹

Permittee Name: <u>FirstEnergy Nuclear Operating Company</u>							
Address: <u>P.O. Box 4</u>							
<u>Shippingport, PA 15077</u>							
<u>Beaver Valley Power Station</u>							
PERMIT NUMBER				MONITORING PERIOD Year/Month/Day			
PA0025615				2017	11	01	TO 2017 11 30
PARAMETER	ANALYSIS METHOD	LAB NAME	LAB ID NUMBER²				
Zinc	EPA 200.7 Rev 4.4	FirstEnergy Corp-Beta Lab	68-01120				
Copper	EPA 200.7 Rev 4.4	FirstEnergy Corp-Beta Lab	68-01120				
Iron	EPA 200.7 Rev 4.4	FirstEnergy Corp-Beta Lab	68-01120				
Chromium	EPA 200.7 Rev 4.4	FirstEnergy Corp-Beta Lab	68-01120				
Ammonia	SM 4500 NH3 F	FirstEnergy Corp-Beta Lab	68-01120				
Cyanide	SM 4500-CN E [18th]	FirstEnergy Corp-Beta Lab	68-01120				
Chlorobenzene	EPA 624	Test American-Canton Lab	68-00340				
Oil and Grease	EPA 1664 Rev A	FirstEnergy Corp-Beta Lab	68-01120				
Oil and Grease	EPA 1664 Rev A	PACE Analytical Services	65-00282				
Total Dissolved Solids	SM 2540 C *	FirstEnergy Corp-Beta Lab	68-01120				
Total Suspended Solids	SM 2540 D *	FirstEnergy Corp-Beta Lab	68-01120				
* 2012 EPA Method Update Rule (MUR) no longer cites Standard Method editions							

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Name/Title Principal Executive Officer

Phone: 724-682-7773

Signature of Principal Executive Officer or Authorized Agent

John J. Grabnar
General Plant Manager

Date:

12/15/17

[Signature]

¹ Submit this form with the first Discharge Monitoring Report (DMR), Annual Report or Recordkeeping and Reporting Form, where sample results are submitted to the Department for compliance purposes. You do not need to send this form to the Department again UNLESS there has been a change to the lab or method of analysis.

² For parameter(s) covered under accreditation-by-rule, submit the lab's registration number in lieu of an accreditation number.

NON-COMPLIANCE REPORTING FORM

Use this supplemental form to report all permit violations and any other non-compliance that may endanger health or the environment, in accordance with your permit. Complete all sections that apply. If you are reporting violations of permit limits, monitoring requirements or schedules that do not pose an immediate threat to health or the environment, you may attach this form to the Discharge Monitoring Report (DMR). **Title 25, Pa. Code §§ 91.33 and 91.34 (regarding incidents causing or threatening pollution and activities utilizing pollutants, respectively), in part requires immediate notification by telephone to the Department of pollution incidents, remediation, and may require an additional report on the incident or plan of pollution prevention measures.** If you are reporting other non-compliance events, and the reporting deadline does not coincide with your submission of the DMR, it should be submitted separately to the Department by the reporting deadline set forth in the permit. See instructions for more information.

Facility Name: FirstEnergy Beaver Valley Power Station Month: November Year: 2017
 Municipality: Shippingport Borough County: Beaver Permit No.: PA0025615

☒ **Violations of Permit Effluent Limitations***

Date	Parameter	Permit Limit	Units	Statistical Code	Result	Units	Cause of Violation	Corrective Action Taken
11/09/2017	Zinc	1.5	ppm	MAX	1.6	ppm	Higher than normal volume of domestic water potentially stirred sediment in the domestic water line	Reduced water usage. Resampled 11/18/2017; Results satisfactory at 0.269ppm.

☐ **Sanitary Sewer Overflows and Other Unauthorized Discharges***

Event Date	Substance Discharged	Location	Volume (gals)	Duration (hrs)	Receiving Waters	Impact on Waters	Cause of Discharge	Date DEP Notified

☐ **Other Permit Violations***


- ☐ Sample collection less frequent than required
- ☐ Sample type not in compliance with permit
- ☐ Violation of permit schedule
- ☐ Other
- ☐ Other

Explain _____
 Explain _____
 Explain _____
 Explain _____
 Explain _____

***If the space provided is not sufficient to record all information, please attach additional sheets.**

I certify under penalty of law that this document was prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. See 18 Pa. C.S. § 4904 (relating to unsworn falsification).

Prepared By: John J. Grabnar
 Title: General Plant Manager

Signature: 
 Date: 12/15/17