



December 27, 2017

10 CFR 50.90
Docket No. 50-443
SBK-L-17216

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

Seabrook Station

Withdrawal of License Amendment Request 17-05, Deletion of Operator Action and Change to the Current Licensing Bases for Fire Protection

References:

1. NextEra Energy Seabrook, LLC letter SBK-L-17160, "License Amendment Request 17-05, Deletion of Operator Action and Request for Exemption from Section III.G.2.b of 10 CFR 50 Appendix R," October 10, 2017 (ML17283A398)
2. NRC letter, "Seabrook Station, Unit No. 1 – Supplemental Information Needed for Acceptance of Requested Licensing Action Re: Amendment to Delete Operator Action and Request for Exemption (EPID L-2017-LLA-0352 and EPID L-2017-LLE-0028)" November 29, 2017 (ML17332A341)
3. NextEra Energy Seabrook, LLC letter SBK-L-17202, "Response to Seabrook Station, Unit No. 1 – Supplemental Information Needed for Acceptance of Requested Licensing Action Re: Amendment to Delete Operator Action and Request for Exemption," December 14, 2017 (ML17348A865)

In Reference 1, NextEra Energy Seabrook, LLC (NextEra) submitted a license amendment request (LAR) to delete an operator action in the Seabrook Station current licensing basis and request exemption from the cable separation and automatic fire suppression requirements in Appendix R, Section III.G.2.b. In Reference 2, the NRC identified that supplemental information would be required for acceptance of the request for processing. In Reference 3, NextEra provided a response to the request for supplemental information.

Based upon subsequent discussion with the staff, NextEra hereby withdraws the license amendment, including supplemental information. NextEra will review its authority to make these changes under 10 CFR 50.48, Fire Protection, and Condition 2.F of the Seabrook Facility Operating License.

Should you have any questions regarding this information, please contact Kenneth J. Browne, Licensing Manager, at (603) 773-7932.

Sincerely,

NextEra Energy Seabrook, LLC



Christopher Domingos
Plant General Manager
NextEra Energy Seabrook, LLC

cc

D. Dorman, NRC Region I Administrator
J. Poole, NRC Project Manager
P. Cataldo, NRC Senior Resident Inspector

Mr. Perry Plummer
Director Homeland Security and Emergency Management
New Hampshire Department of Safety
Division of Homeland Security and Emergency Management
Bureau of Emergency Management
33 Hazen Drive
Concord, NH 03305
perry.plummer@dos.nh.gov

Mr. John Giarrusso, Jr., Nuclear Preparedness Manager
The Commonwealth of Massachusetts
Emergency Management Agency
400 Worcester Road
Framingham, MA 01702-5399
John.Giarrusso@massmail.state.ma.us