

# NOTARIZED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

SESSION NBR:8811300410 DOC.DATE: 88/11/23 NOTARIZED: NO DOCKET #  
 FACIL:50-400 Shearon Harris Nuclear Power Plant, Unit 1, Carolina 05000400  
 AUTH.NAME AUTHOR AFFILIATION  
 WATSON,R.A. Carolina Power & Light Co.  
 RECIP.NAME RECIPIENT AFFILIATION  
 Document Control Branch (Document Control Desk)

SUBJECT: Responds to NRC 881025 ltr re deviations noted in Insp Rept  
 50-400/88-29.

DISTRIBUTION CODE: IE01D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 3  
 TITLE: General (50 Dkt)-Insp Rept/Notice of Violation Response

NOTES:Application for permit renewal filed. 05000400

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PD2-1 PD	1 1	BUCKLEY,B	1 1
INTERNAL: ACRS	2 2	AEOD	1 1
DEDRO	1 1	NRR MORISSEAU,D	1 1
NRR/DLPQ/PEB 11	1 1	NRR/DLPQ/QAB 10	1 1
NRR/DOEA DIR 11	1 1	NRR/DREP/EPB 10	1 1
NRR/DREP/RPB 10	2 2	NRR/DRIS DIR 9A	1 1
NRR/PMAS/ILRB12	1 1	NUDOCS-ABSTRACT	1 1
OE LIEBERMAN,J	1 1	OGC/HDS1	1 1
REG FILE 02	1 1	RGN2 FILE 01	1 1
INTERNAL: LPDR	1 1	NRC PDR	1 1
NSIC	1 1	RESL MARTIN,D	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 24 ENCL 24

R  
I  
D  
S  
/  
A  
D  
S  
/  
A  
D  
S  
/  
A  
D  
S



3021

Carolina Power & Light Company

NOV 23 1988

HARRIS NUCLEAR PROJECT  
P. O. Box 165  
New Hill, North Carolina 27562

File Number: SHF/10-13510E  
Letter Number: HO-880236 (O)

NRC-651

Document Control Desk  
United States Nuclear Regulatory Commission  
Washington, DC 20555

SHEARON HARRIS NUCLEAR POWER PLANT  
DOCKET NO. 50-400  
LICENSE NO. NPF-63  
REPLY TO A NOTICE OF DEVIATION

Gentlemen:

In reference to your letter of October 25, 1988, referring to I.E. Report RII: 50-400/88-29, the attached is Carolina Power & Light Company's reply to the deviation identified in the enclosure.

It is considered that the actions taken are satisfactory for resolution of this matter.

Thank you for your consideration in this matter.

Very truly yours,

*CSHinnant for*

R. A. Watson  
Vice President  
Harris Nuclear Project

MGW:crc

Attachment

cc: Messrs. W. H. Bradford (NRC-SHNPP)  
B. C. Buckley (NRC)  
M. L. Ernst (NRC)

8811300410 881123  
PDR ADOCK 05000400  
Q PDC

MEM/HO-8802360/1/OS1

*TEO*  
*11*



Reported Deviation:

Shearon Harris Nuclear Power Plant (SHNPP) FSAR, Section 1.8 - Conformance to NRC Regulatory Guides states: "...SHNPP complies with IEEE Standard 338-1977, Reg. Guide 1.118."

IEEE Standard 338-1977 requires, in part, that a test program be implemented that produces objective data for evaluating (assessing) the performance and availability of the component being tested, and that the data be trended to allow for the detection of degradation and indication of incipient failures.

Contrary to the above, on September 1, 1988, 27 of 50 Maintenance Surveillance Tests that were reviewed contained as found data that was outside of its allowable range. The licensee did not have a program to evaluate the out-of-range readings, nor was there a program to trend instrument drift as required by the above.

Reason for the Deviation:

CP&L agrees that a formal program to comply with the evaluation and trending requirements for instrumentation calibration was not in place at the time of the inspection. However, CP&L disagrees that the 27 items noted required evaluation under such a program.

This is best explained by the definitions used in instrument calibrations. The following definitions are provided to clarify this:

1. Allowable Range: The tolerance used in calibration procedures (less than or equal to the allowable limit).
2. Allowable Limit: The tolerance specified in the design set point document.
3. Allowable Value: The Tech. Spec. value which a set point must trip before to remain within Westinghouse set point margin allowances.
4. Tech. Spec. Limit: Total allowance as defined in Tech. Spec.

Twenty-seven out of fifty Maintenance Surveillance test calibration procedures, "as found" values, were found outside of the "allowable range" but not outside the "allowable value". The Westinghouse set point study addresses instrument drift and this basis is incorporated in the set point document. From the set point listed in the Technical Specification the "allowable value" has been established. In the majority of the cases, SHNPP intentionally made tolerance bands or "allowable range" more conservative than the "allowable limit" which reduces the possibility of exceeding the "allowable limits" or Technical Specification "allowable value." Due to this fact, we do not trend those devices that are outside of the "allowable range."



Notwithstanding the lack of a formal program, when instruments were found outside of the "allowable value," in particular, two separate episodes of Pressurizer Pressure Transmitter drift, the situation was evaluated.

Corrective Steps Taken and Results Achieved:

Since the twenty-seven as found values identified were outside of the "allowable range" but not outside of the "allowable value" trending was not performed.

Corrective Steps Taken to Avoid Further Deviations:

The existing program will be modified to "evaluate" and "trend" those devices found out of the "allowable value" criteria. These program changes are projected to be completed by March 1, 1989.

In the interim, instructions will be issued to appropriate maintenance personnel requiring that when readings exceed the "allowable value," maintenance engineering is to be notified to perform an evaluation. This action will be completed by December 2, 1988.

Date When Corrective Action will be Completed:

Corrective action is projected to be complete by March 1, 1989.

