

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8902070068 DOC. DATE: 88/12/31 NOTARIZED: NO DOCKET #
 FACIL: 50-400 Shearon Harris Nuclear Power Plant, Unit 1, Carolina 05000400
 AUTH. NAME AUTHOR AFFILIATION
 WATSON, R.A. Carolina Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Annual rept of individuals receiving exposures greater than 100 mrem/yr & associated manrem exposure for 1988.

DISTRIBUTION CODE: IE56D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4
 TITLE: 20.407 Annual Personnel Monitoring Rpt/Annual Rad Exposure Rpt by Fun

NOTES: Application for permit renewal filed. 05000400

	RECIPIENT		COPIES			RECIPIENT		COPIES		
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL	
	PD2-1 LA		1	0		PD2-1 PD		5	5	
	BECKER, D		1	0						
INTERNAL:	ACRS		6	6		AEOD/DSP/TPAB		1	1	
	NMSS/IMSB 6H3		1	1		NRR/DOEA/EAB 11		1	1	
	NRR/DREP/RPB 10		2	2		NUDOCS-ABSTRACT		1	1	
	REG FILE 02		1	1		RES BROOKS, B		2	2	
	RGN2 01		1	1						
EXTERNAL:	LPDR		1	1		NRC PDR		1	1	
	NSIC		1	1						

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 26 ENCL 24

R
I
D
S
/
A
D
D
S

m/94
90



Carolina Power & Light Company

HARRIS NUCLEAR PROJECT
P. O. Box 165
New Hill, North Carolina 27562

FEB 01 1989

File Number: SHF/10-135010I
Letter Number: HO-890011 (0)

Document Control Desk
United States Nuclear Regulatory Commission
Washington, DC 20555

SHEARON HARRIS NUCLEAR POWER PLANT
DOCKET NO. 50-400
LICENSE NO. NPF-63
ANNUAL OPERATING REPORT

Gentlemen:

In accordance with Technical Specification 6.9.1.2 for the Shearon Harris Nuclear Power Plant, Unit No. 1, Carolina Power and Light Company herewith submits the annual report of (a) individuals receiving exposures greater than 100 mrem/yr and their associated manrem exposure according to work and job functions, (b) primary coolant iodine spikes, and (c) challenges to the pressurizer power-operated relief valves (PORVs) and primary safety valves for 1988.

Very truly yours,

CSHinnant FOR

R. A. Watson
Vice President
Harris Nuclear Project

8902070068 881231
PDR ADDCK 05000400
R PNU

MGW:dj

Enclosure

cc: Messrs. W. H. Bradford (NRC-SHNPP)
M. L. Ernst (NRC-R11)
J. M. Taylor (NRC)

MEM/HO-3900110/1/OS1

IE56
11

RIMS II
NUMBER OF PERSONNEL AND MAN-REM BY WORK AND JOB FUNCTION, 1988
HARRIS PLANT

WORK AND JOB FUNCTION	NUMBER OF PERSONNEL > 100 MREM			TOTAL MAN-REM		
	STAT	UTIL	CNTR	STAT	UTIL	CNTR
REACTOR OPERATIONS AND SURVEILLANCE						
MAINTENANCE PERSONNEL	4	0	5	1.201	0.040	4.614
OPERATING PERSONNEL	33	1	11	10.420	0.128	5.598
HEALTH PHYSICS PERSONNEL	19	0	40	7.134	0.060	13.003
SUPERVISORY PERSONNEL	0	0	0	0.087	0.025	0.020
ENGINEERING PERSONNEL	0	0	1	0.452	0.120	0.360
ROUTINE MAINTENANCE						
MAINTENANCE PERSONNEL	27	9	48	7.976	2.297	15.288
OPERATING PERSONNEL	0	0	1	0.027	0.000	0.495
HEALTH PHYSICS PERSONNEL	0	0	6	0.362	0.011	2.356
SUPERVISORY PERSONNEL	0	0	0	0.000	0.000	0.000
ENGINEERING PERSONNEL	4	1	2	1.331	0.297	1.846
INSERVICE INSPECTION						
MAINTENANCE PERSONNEL	10	1	10	3.740	0.389	4.403
OPERATING PERSONNEL	0	0	0	0.109	0.000	0.095
HEALTH PHYSICS PERSONNEL	22	0	23	5.657	0.080	7.232
SUPERVISORY PERSONNEL	0	1	0	0.060	0.125	0.000
ENGINEERING PERSONNEL	19	1	26	6.883	0.647	16.482
SPECIAL MAINTENANCE						
MAINTENANCE PERSONNEL	27	11	101	10.256	3.332	49.636
OPERATING PERSONNEL	0	0	2	0.243	0.000	0.805
HEALTH PHYSICS PERSONNEL	9	0	26	3.533	0.061	7.097
SUPERVISORY PERSONNEL	0	0	0	0.000	0.000	0.090
ENGINEERING PERSONNEL	13	4	84	4.626	1.061	42.386
WASTE PROCESSING						
MAINTENANCE PERSONNEL	0	0	0	0.000	0.000	0.315
OPERATING PERSONNEL	0	0	0	0.000	0.000	0.000
HEALTH PHYSICS PERSONNEL	2	0	0	1.345	0.000	0.110
SUPERVISORY PERSONNEL	0	0	0	0.000	0.000	0.000
ENGINEERING PERSONNEL	0	0	0	0.000	0.000	0.032
REFUELING						
MAINTENANCE PERSONNEL	0	0	0	0.210	0.065	0.070
OPERATING PERSONNEL	0	0	0	0.172	0.005	0.000
HEALTH PHYSICS PERSONNEL	0	0	0	0.100	0.000	0.175
SUPERVISORY PERSONNEL	0	0	0	0.000	0.000	0.000
ENGINEERING PERSONNEL	0	0	0	0.160	0.058	0.815
TOTAL						
MAINTENANCE PERSONNEL	68	21	164	23.383	6.123	74.326
OPERATING PERSONNEL	33	1	14	10.971	0.133	6.993
HEALTH PHYSICS PERSONNEL	52	0	95	18.131	0.212	29.973
SUPERVISORY PERSONNEL	0	1	0	0.147	0.150	0.110
ENGINEERING PERSONNEL	36	6	113	13.452	2.183	61.921
GRAND TOTAL	189	29	386	66.084	8.801	173.323

Notes: (1) Dose based on pocket dosimeters
(2) Stat = Harris Plant staff
Util = CP&L non-Harris personnel
Cntr = Contractor

1988 ANNUAL REPORT - PRIMARY COOLANT IODINE SPIKES

During 1987, the primary coolant did not exceed 1.0 $\mu\text{Ci}/\text{gram}$ dose equivalent I-131 or $> 100/\text{E}/\mu\text{Ci}/\text{gram}$ dose as set forth in Technical Specification 3.4.8.

1988 ANNUAL REPORT - PRIMARY SAFETY AND RELIEF VALVE CHALLENGES

On October 20, 1988, pressurizer power operated relief valve (PORV) 1-PCV-444B lifted and released approximately 28 gallons of reactor coolant to the Pressurizer Relief Tank. The PORV was immediately reshut. Actual system pressure was not the initiating factor for this event based on normal pressure readings observed through protection channels prior to the PORV lifting. The cause of the event was determined to be due to Radio Frequency Interference from a portable radio used by Operations personnel inside containment at the time of the event. Operations personnel were instructed to use the phone system for future communications. Subsequently, no similar incidents have been observed.

