

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9812160080 DOC.DATE: 98/11/30 NOTARIZED: NO DOCKET #
FACIL:50-250 Turkey Point Plant, Unit 3, Florida Power and Light C 05000250
50-251 Turkey Point Plant, Unit 4, Florida Power and Light C 05000251
AUTH.NAME : AUTHOR AFFILIATION
MOWREY,C.L. Florida Power & Light Co.
HOVEY,R.J. Florida Power & Light Co.
RECIP.NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating repts for Nov 1998 for Turkey Point, Units
3 & 4. With 981209 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 9
TITLE: Monthly Operating Report (per Tech Specs)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-3 PD	1 1	JABBOUR, K	1 1
INTERNAL:	AEOD/SPD/RRAB	1 1	FILE CENTER 01	1 1
	OC/DBA/PAD	1 1	RGN2	1 1
EXTERNAL:	LITCO BRYCE, J H	1 1	NOAC	1 1
	NRC PDR	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083.

TOTAL NUMBER OF COPIES REQUIRED: LTTR 9 ENCL 9



FPL

DEC 09 1998

L-98-297

10 CFR §50.36

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Monthly Operating Report

In accordance with the requirements of Turkey Point Units 3 and 4 Technical Specification 6.9.1.5, and the guidance of Generic Letter 97-02, attached are the November 1998 Operating Data Report and Summary of Operating Experience for Turkey Point Units 3 and 4.

Very truly yours,

R. J. Hovey
Vice President
Turkey Point Plant

CLM

Attachments

cc: Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, Turkey Point Plant

9812140080 981130
PDR ADOCK 05000250
R PDR

1000-

11
I E24

1943

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-250
UNIT: Turkey Point #3
DATE: December 2, 1998
COMPLETED BY: C. L. Mowrey
TELEPHONE: (305) 246-6204

REPORT MONTH November 1998

DAY	AVERAGE DAILY POWER LEVEL (Mwe-Net)
11/1/98	409
11/2/98	679
11/3/98	712
11/4/98	716
11/5/98	722
11/6/98	729
11/7/98	730
11/8/98	728
11/9/98	725
11/10/98	720
11/11/98	722
11/12/98	721
11/13/98	722
11/14/98	722
11/15/98	720
11/16/98	716
11/17/98	717
11/18/98	712
11/19/98	711
11/20/98	712
11/21/98	711
11/22/98	714
11/23/98	719
11/24/98	718
11/25/98	719
11/26/98	719
11/27/98	718
11/28/98	722
11/29/98	724
11/30/98	723

OPERATING DATA REPORT

DOCKET NO. 50-250
UNIT NAME TURKEY POINT UNIT 3
DATE December 2, 1998
COMPLETED BY C. L. Mowrey
TELEPHONE (305) 246-6204

REPORTING PERIOD November, 1998
(Month/Year)

1. Design Electrical Rating (MWe-Net)_____ 720
2. Maximum Dependable Capacity (MWe-Net)_____ 693

	<u>MONTH</u>	<u>-YTD-</u>	<u>CUMULATIVE</u>
3. Number of Hours Reactor Was Critical_____	720.0	7048.2	160166.0
4. Number of Hours Generator Was On Line_____	720.0	7014.7	157973.6
5. Unit Reserve Shutdown Hours_____	0.0	0.0	121.8
6. Net Electrical Energy (MWH)_____	509570.0	4870517.0	101283073.0

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-250
 UNIT NAME: Turkey Point #3
 DATE: December 2, 1998
 COMPLETED BY: C. L. Mowrey
 TELEPHONE: (305) 246-6204

REPORT MONTH November 1998

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Cause & Corrective Action Comments
N/A	N/A	N/A	N/A	N/A	N/A	N/A

1

F - Forced
S - Scheduled

2

Reason
 A - Equipment Failure
 B - Maintenance or Test
 C - Refueling
 D - Regulatory restriction
 E - Operator Training &
 License Examination
 F - Administrative
 G - Operational Error (Explain)
 H - Other (Explain)

3

Method 1 - Manual
 2 - Manual Scram
 3 - Automatic Scram
 4 - Continued
 5 - Load Reduction
 9 - Other (Explain)



10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

SUMMARY OF OPERATING EXPERIENCE

DOCKET NO.	<u>50-250</u>
UNIT:	<u>Turkey Point #3</u>
DATE:	<u>December 2, 1998</u>
COMPLETED BY:	<u>C. L. Mowrey</u>
TELEPHONE:	<u>(305) 246-6204</u>

REPORT MONTH November 1998

Unit 3 started the month at approximately 49% reactor power, ramping up after the Cycle 17 refueling outage. Unit 3 achieved 100% power on November 2, 1998, and stayed at about 100% power for the remainder of the month.

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-251
UNIT: Turkey Point #4
DATE: December 2, 1998
COMPLETED BY: C. L. Mowrey
TELEPHONE: (305) 246-6204

REPORT MONTH November 1998

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
11/1/98	713
11/2/98	710
11/3/98	711
11/4/98	712
11/5/98	718
11/6/98	725
11/7/98	728
11/8/98	726
11/9/98	724
11/10/98	722
11/11/98	720
11/12/98	717
11/13/98	717
11/14/98	718
11/15/98	715
11/16/98	711
11/17/98	712
11/18/98	708
11/19/98	707
11/20/98	706
11/21/98	706
11/22/98	709
11/23/98	713
11/24/98	712
11/25/98	714
11/26/98	714
11/27/98	713
11/28/98	717
11/29/98	719
11/30/98	718

OPERATING DATA REPORT

DOCKET NO. 50-251
UNIT NAME TURKEY POINT UNIT 4
DATE December 2, 1998
COMPLETED BY C. L. Mowrey
TELEPHONE (305) 246-6204

REPORTING PERIOD November, 1998
(Month/Year)

1. Design Electrical Rating (MWe-Net)_____ 720
2. Maximum Dependable Capacity (MWe-Net)_____ 693

	<u>MONTH</u>	<u>-YTD-</u>	<u>CUMULATIVE</u>
3. Number of Hours Reactor Was Critical_____	720.0	8016.0	157323.5
4. Number of Hours Generator Was On Line_____	720.0	8016.0	152992.5
5. Unit Reserve Shutdown Hours_____	0.0	0.0	577.2
6. Net Electrical Energy (MWH)_____	514873.0	5646501.0	99138138.0

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-251
UNIT NAME: Turkey Point #4
DATE: December 2, 1998
COMPLETED BY: C. L. Mowrey
TELEPHONE: (305) 246-6204

REPORT MONTH November 1998

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Cause & Corrective Action to Prevent Recurrence
N/A	N/A	N/A	N/A	N/A	N/A	N/A

1

F - Forced
S - Scheduled

2

Reason
A - Equipment Failure
B - Maintenance or Test
C - Refueling
D - Regulatory restriction
E - Operator Training &
License Examination
F - Administrative
G - Operational Error (Explain)
H - Other (Explain)

3

Method
1 - Manual
2 - Manual Scram
3 - Automatic Scram
4 - Continued
5 - Load Reduction
9 - Other (Explain)

SUMMARY OF OPERATING EXPERIENCE

DOCKET NO.	<u>50-251</u>
UNIT:	<u>Turkey Point #4</u>
DATE:	<u>December 2, 1998</u>
COMPLETE BY:	<u>C. L. Mowrey</u>
TELEPHONE:	<u>(305)246-6204</u>

REPORT MONTH November 1998

Unit 4 operated at essentially 100% for the entire month of November, 1998.