

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9802030015 DOC.DATE: 98/01/27 NOTARIZED: NO DOCKET #
 FACIL: 50-400 Shearon Harris Nuclear Power Plant, Unit 1, Carolina 05000400
 AUTH.NAME AUTHOR AFFILIATION
 ROBINSON, W.R. Carolina Power & Light Co. *See Rpt.*
 RECIP.NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards Rev 0 to Procedure HNP-ISI-002, "Shearon Harris Nuclear Power Plant, ISI Program Plan, 2nd Interval." Plan describes exams & schedules for performing ASME Code insps of Class 1, 2 & 3 components & supports.

DISTRIBUTION CODE: A047D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3 + 650
 TITLE: OR Submittal: Inservice/Testing/Relief from ASME Code - GL-89-04


NOTES: Application for permit renewal filed. 05000400

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PD2-1 LA	1 1	PD2-1 PD	1 1
FLANDERS, S	1 1		
INTERNAL: ACRS	1 1	AEOD/SPD/RAB	1 1
<u>FILE CENTER 01</u>	1 1	NRR/DE/EMEB	1 1
NUDOCS-ABSTRACT	1 1	OGC/HDS2	1 0
RES/DET/EIB	1 1	RES/DET/EMMEB	1 1
EXTERNAL: LITCO ANDERSON	1 1	NOAC	1 1
NRC PDR	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:
 PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 13

MAZ



Carolina Power & Light Company
PO Box 165
New Hill NC 27562

William R. Robinson
Vice President
Harris Nuclear Plant

SERIAL: HNP-98-010
10 CFR 50.55a

JAN 27 1998

United States Nuclear Regulatory Commission
ATTENTION: Document Control Desk
Washington, DC 20555

SHEARON HARRIS NUCLEAR POWER PLANT
DOCKET NO. 50-400/LICENSE NO. NPF-63
INSERVICE INSPECTION PROGRAM PLAN - SECOND TEN-YEAR INTERVAL

Dear Sir or Madam:

In accordance with 10 CFR 50.55a(g)(5)(i), Carolina Power & Light Company (CP&L) hereby submits the Harris Nuclear Plant (HNP) Inservice Inspection (ISI) Program Plan for the second ten-year inspection interval. The second ten-year interval will be in effect from February 2, 1998 through and including May 1, 2007. The ISI Program Plan has been prepared in accordance with the requirements of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code, Section XI, of the 1989 Edition, as required by 10 CFR 50.55a(g)(4)(ii). The Plan describes the examinations and schedules for performing ASME Code inspections of Class 1, 2, and 3 components and supports.

Section 7 of the enclosed ISI Program Plan includes 19 relief requests which require NRC approval. The following eight (8) relief requests are submitted for NRC approval pursuant to 10 CFR 50.55a(g)(6)(i) due to the impracticality of conformance with the Code: 2R1-003, 2R1-004, 2R1-006, 2R1-008, 2R1-011, 2R2-001, 2R2-003, and 2R2-005. The following 10 relief requests are submitted for NRC approval pursuant to 10 CFR 50.55a(a)(3)(ii) due to hardship or unusual difficulty created by compliance with the Code, without a compensating increase in the level of quality and safety: 2R1-009, 2R1-010, 2R2-006, 2R3-002, 2RG-003, 2RG-004, 2RG-005, 2RG-006, 2RG-007, and 2RG-008. Relief request 2R2-007 is submitted for NRC approval pursuant to 10 CFR 50.55a(a)(3)(i) based on the determination that the proposed alternative examination provides an acceptable level of quality and safety.

In addition, Section 7 of the Plan includes two (2) relief requests which have been approved by the NRC. Relief request 2RG-001 is a general relief request for the application of ASME Code Case N-416-1 to Class 1, 2 and 3 pressure tests following repair and replacements. Relief request 2RG-002 is a general relief request for the application of ASME Code Case N-498-1 to Class 3 hydrostatic tests. The NRC approved the HNP use of Code Cases N-416-1 and N-498-1 by letters dated November 29, 1995 and September 6, 1996, respectively.

9802030015 980127
PDR ADOCK 05000400
G PDR



Questions regarding this matter may be referred to Mr. J. H. Eads at (919) 362-2646.

Sincerely,



AEC/aec

Enclosure

c: Mr. J. B. Brady (NRC Senior Resident Inspector, HNP)
Mr. L. A. Reyes (NRC Regional Administrator, Region II)
Mr. S. C. Flanders (NRR Project Manager, HNP)
Mr. E. B. Dayton (Authorized Nuclear Inservice Inspector)
Mr. J. M. Given, Jr. (North Carolina Department of Labor)

bc: (w/o enclosure)

Ms. D. B. Alexander

Mr. T. C. Bell

Mr. H. K. Chernoff (RNP)

Mr. B. H. Clark

Mr. G. W. Davis

Mr. J. W. Donahue

Mr. W. J. Dorman (BNP)

Mr. W. J. Hindman

Mr. W. D. Johnson

Mr. R. M. Krich

(w/o enclosure)

Ms. W. C. Langston (PE&RAS File)

Mr. C. W. Martin (BNP)

Mr. R. D. Martin

Mr. P. M. Odom (RNP)

Mr. W. S. Orser

Mr. R. F. Saunders

Mr. D. L. Tibbitts

Mr. C. A. VanDenburgh

Nuclear Records

Licensing File (w/ enclosure)

File: H-X-0710

Carolina Power and Light Company

Harris Nuclear Power Plant

ISI Program Plan

2nd Interval

50-400
9802030015
1/27/98

Class 3 Integrally-Welded Attachments
Numbering System
for Harris Nuclear Plant

HNP is applying Code Case N-509 only to Class 3 as stated in Relief Request 2R3-002. Per the Code Case, all Class 3 integrally-welded attachments are assigned to Category D-A. A 10% sample by system, as required by the Code Case, has been selected for examination.



Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY D-A
ITEM NO. D1.10

SYSTEMS IN SUPPORT OF REACTOR SHUTDOWN FUNCTION
PRESSURE RETAINING COMPONENTS

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
SEE SECTION 9	/						

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	D-A	INTEGRAL ATTACHMENTS FOR CLASS 3 VESSELS, PIPING, PUMPS, AND VALVES					
ITEM NO.	D1.20	INTEGRALLY-WELDED ATTACHMENTS ON CLASS 3 PIPING					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER	AF-H-0082I(2)	AFW PUMPS RECIRC HDR TO CST	AF	3		VT-1	
HANGER	AF-H-0092I(4)	AFW PUMPS RECIRC HDR TO CST	AF	3		VT-1	
HANGER	AF-H-0190I(2)	AFW PUMPS A&B DISCH TO VALVE AF-73	AF	3		VT-1	
HANGER	AF-H-0197I(2)	AFW PUMPS A&B DISCH TO VALVE AF-73	AF	3	2-1-08	VT-1	
HANGER	AF-H-0204I(2)	AFW PUMP A OUTLET TO DISCH HDR	AF	3		VT-1	
HANGER	AF-H-0209I(4)	AFW PUMP A OUTLET TO DISCH HDR	AF	3		VT-1	
HANGER	AF-H-0228I(4)	DNSTRM OF VALVE AF-42	AF	3		VT-1	
HANGER	AF-H-0246I(4)	AFW PUMP 1X-SAB DISCH TO VALVE AF-148	AF	3		VT-1	
HANGER	AF-H-0258I(2)	AFW PUMP 1X-SAB DISCH TO VALVE AF-136	AF	3		VT-1	
HANGER	AF-H-0266I(4)	AFW PUMP 1X-SAB DISCH TO VALVE AF-136	AF	3	2-1-09	VT-1	
HANGER	AF-H-0270I(4)	AFW PUMP 1X-SAB DISCH TO VALVE AF-142	AF	3		VT-1	
HANGER	AF-H-0278I(2)	AFW PUMP 1X-SAB DISCH TO VALVE AF-142	AF	3		VT-1	
HANGER	CC-H-0093I(2)	BETWEEN VALVES CC-95 AND CC-99	CC	3		VT-1	
HANGER	CC-H-0095I(4)	BETWEEN VALVE CC-99 AND LINE 3CC20-11SN	CC	3		VT-1	
HANGER	CC-H-0102I(4)	UPSTREAM OF VALVE CC-259	CC	3		VT-1	
HANGER	CC-H-0107I(4)	RHR HX A INLET	CC	3		VT-1	
HANGER	CC-H-0114I(4)	BETWEEN VALVE CC-99 AND LINE 3CC20-11SN	CC	3		VT-1	
HANGER	CC-H-0289I(4)	CCW HDR TO RCP	CC	3		VT-1	
HANGER	CC-H-0292I(2)	CCW HDR TO RCP	CC	3		VT-1	
HANGER	CC-H-0304I(2)	HDR CONN TO EX LTDN HX & RCDT HX	CC	3	2-2-11	VT-1	
HANGER	CC-H-0313I(2)	FP HX 1&4A-SA OUTLET	CC	3		VT-1	
HANGER	CC-H-0330I(3)	RETURN HDR FROM HXs	CC	3		VT-1	
HANGER	CC-H-0351I(2)	HDR TO HXs	CC	3		VT-1	
HANGER	CC-H-0355I(1)	HDR TO HXs	CC	3		VT-1	
HANGER	CC-H-0367I(3)	HDR TO CCS SFP HX UNIT 4	CC	3		VT-1	
HANGER	CC-H-0369I(2)	CCW HDR TO RCP	CC	3		VT-1	
HANGER	CC-H-0370I(2)	CCW HDR TO RCP	CC	3		VT-1	
HANGER	CC-H-0374I(1)	BETWEEN VALVES CC-109 AND CC-113	CC	3		VT-1	
HANGER	CC-H-0376I(2)	BETWEEN VALVES CC-109 AND CC-113	CC	3		VT-1	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY D-A		INTEGRAL ATTACHMENTS FOR CLASS 3 VESSELS, PIPING, PUMPS, AND VALVES				
ITEM NO. D1.20		INTEGRALLY-WELDED ATTACHMENTS ON CLASS 3 PIPING				
Component	Description	System	Class	Outage	Exam Type	Relief Request
HANGER CC-H-0392I(2)	UPSTRM OF VALVE CC-156	CC	3		VT-1	
HANGER CC-H-0394I(4)	UPSTRM OF VALVE CC-156	CC	3	2-3-13	VT-1	
HANGER CC-H-0402I(4)	RHR HX B INLET	CC	3		VT-1	
HANGER CC-H-0406I(2)	RHR HX B INLET	CC	3		VT-1	
HANGER CC-H-0414I(8)	HDR TO CCS SFP HX UNIT 4	CC	3		VT-1	
HANGER CC-H-0416I(2)	HDR TO CCS SFP HX UNIT 4	CC	3		VT-1	
HANGER CC-H-0427I(4)	TO RETURN HDR FROM RCDT HX & EX LTDN HX	CC	3		VT-1	
HANGER CC-H-0438I(4)	TO RETURN HDR FROM RCDT HX & EX LTDN HX	CC	3		VT-1	
HANGER CC-H-0443I(2)	TO RETURN HDR FROM RCDT HX & EX LTDN HX	CC	3		VT-1	
HANGER CC-H-0444I(1)	TO RETURN HDR FROM RCDT HX & EX LTDN HX	CC	3		VT-1	
HANGER CC-H-0458I(1)	HDR TO HXs	CC	3		VT-1	
HANGER CC-H-0461I(2)	HDR TO HXs	CC	3		VT-1	
HANGER CC-H-0466I(2)	HDR TO HXs	CC	3		VT-1	
HANGER CC-H-0473I(4)	RETURN HDR TO CC PUMP A SUCTION	CC	3		VT-1	
HANGER CC-H-0483I(4)	PUMP A SUCTION CONN TO CC PUMP C SUCTION	CC	3	2-3-13	VT-1	
HANGER CC-H-0496I(2)	RHR HX B INLET	CC	3		VT-1	
HANGER CC-H-0497I(4)	RHR HX B INLET	CC	3		VT-1	
HANGER CC-H-0499I(1)	RHR HX B INLET	CC	3		VT-1	
HANGER CC-H-0503I(1)	RHR HX B INLET	CC	3		VT-1	
HANGER CC-H-0505I(2)	RHR HX B INLET	CC	3		VT-1	
HANGER CC-H-0512I(2)	RETURN HDR TO CC PUMP B SUCTION	CC	3		VT-1	
HANGER CC-H-0536I(4)	RECYCLE EVAP COND INLET	CC	3		VT-1	
HANGER CC-H-0541I(4)	RECYCLE EVAP COND INLET	CC	3		VT-1	
HANGER CC-H-0546I(4)	RECYCLE EVAP COND INLET	CC	3		VT-1	
HANGER CC-H-0570I(2)	LTDN HX OUTLET TO RETURN HDR	CC	3		VT-1	
HANGER CC-H-0682I(4)	LTDN HX INLET FROM HDR	CC	3		VT-1	
HANGER CC-H-0794I(4)	RECYCLE EVAP COND (CVCS) OUTLET TO RETURN HDR	CC	3		VT-1	
HANGER CC-H-0877I(1)	RETURN HDR TO CC PUMP A SUCTION	CC	3	2-2-10	VT-1	
HANGER CC-H-0882I(2)	BETWEEN VALVES CC-27 AND CC-128	CC	3	2-3-13	VT-1	

Carolina Power and Light Company

Harris Nuclear Power Plant - Unit 1

ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY D-A
ITEM NO. D1.20

INTEGRAL ATTACHMENTS FOR CLASS 3 VESSELS, PIPING, PUMPS, AND VALVES

INTEGRALLY-WELDED ATTACHMENTS ON CLASS 3 PIPING

Component	Description	System	Class	Outage	Exam Type	Relief Request
HANGER CC-H-0892I(2)	CC PUMP A SUCTION TO CC PUMP C SUCTION	CC	3	2-1-09	VT-1	
HANGER CC-H-0906I(4)	RHR HX A OUTLET	CC	3	2-2-10	VT-1	
HANGER CC-H-0908I(2)	RHR HX A OUTLET	CC	3	2-1-09	VT-1	
HANGER CC-H-0909I(2)	RHR HX A OUTLET	CC	3	2-2-11	VT-1	
HANGER CC-H-0911I(4)	RHR HX A OUTLET	CC	3	2-3-13	VT-1	
HANGER CC-H-0913I(2)	RHR HX A OUTLET	CC	3	2-3-13	VT-1	
HANGER CC-H-0919I(2)	RHR HX A OUTLET	CC	3	2-3-13	VT-1	
HANGER CC-H-0932I(2)	CC PUMP B DISCH TO CC HX B	CC	3	2-1-09	VT-1	
HANGER CC-H-0935I(2)	CC PUMP B DISCH TO CC HX B	CC	3	2-1-08	VT-1	
HANGER CC-H-0938I(1)	CC PUMP B DISCH TO CC HX B	CC	3		VT-1	
HANGER CC-H-0939I(1)	CC PUMP B DISCH TO CC HX B	CC	3		VT-1	
HANGER CC-H-0941I(2)	CC PUMP C DISCH TO CC PUMPS A&B DISCH	CC	3		VT-1	
HANGER CC-H-0945I(2)	CC PUMP A DISCH TO CC HX A	CC	3		VT-1	
HANGER CC-H-0950I(1)	CC PUMP A DISCH TO CC HX A	CC	3		VT-1	
HANGER CC-H-1346I(8)	TO CCS SFP HX UNIT 4	CC	3		VT-1	
HANGER CC-H-1351I(8)	TO CCS SFP HX UNIT 4	CC	3		VT-1	
HANGER CC-H-1594I(2)	CC PUMP B DISCH TO CC HX B	CC	3		VT-1	
HANGER CC-H-1801I(2)	CC PUMP C DISCH TO CC PUMPS A&B DISCH	CC	3		VT-1	
HANGER CC-H-1802I(2)	CC PUMP A DISCH TO CC HX A	CC	3		VT-1	
HANGER CC-H-1838I(2)	HDR TO HXs	CC	3		VT-1	
HANGER CC-H-1999I(2)	FP HX 1&4A OUTLET	CC	3	2-3-13	VT-1	
HANGER CE-H-0007I(2)	COND FROM CST TO AF PUMPS SUCTION	CC	3	2-1-09	VT-1	
HANGER CE-H-0022I(4)	COND FROM CST TO AF PUMPS SUCTION	CC	3		VT-1	
HANGER CE-H-0025I(4)	COND FROM CST TO AF PUMPS SUCTION	CC	3		VT-1	
HANGER CH-H-1467I(2)	ESSENTIAL SERVICE CH FOR MAIN	CH	3	2-2-10	VT-1	
HANGER CH-H-1581I(3)	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-1	
HANGER CH-H-1734I(2)	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-1	
HANGER CS-H-2862I(4)	RCP C SEAL INJ AT CONT PENE M-11	CS	2	2-1-08	VT-1	
HANGER CX-H-0361I(2)	ESSENTIAL SER CX FOR PUMP SUCTION	CX	3	2-2-10	VT-1	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY D-A		INTEGRAL ATTACHMENTS FOR CLASS 3 VESSELS, PIPING, PUMPS, AND VALVES				
ITEM NO. D1.20		INTEGRALLY-WELDED ATTACHMENTS ON CLASS 3 PIPING				
Component	Description	System	Class	Outage	Exam Type	Relief Request
HANGER CX-H-1524I(1)	ESSENTIAL SER CX FOR PUMP DISCH	CX	3		VT-1	
HANGER CX-H-1741I(3)	ESSENTIAL SER CX FOR MAIN	CX	3		VT-1	
HANGER CX-H-1808I(2)	ESSENTIAL SER CX FOR MAIN	CX	3		VT-1	
HANGER EA-H-0170I(2)	INTAKE AIR TO D/G A	EA	3		VT-1	
HANGER EA-H-0178I(2)	INTAKE AIR TO D/G A	EA	3		VT-1	
HANGER EA-H-0186I(2)	INTAKE AIR TO D/G B	EA	3	2-3-13	VT-1	
HANGER EA-H-0194I(2)	INTAKE AIR TO D/G B	EA	3		VT-1	
HANGER MS-H-0171I(2)	S/G B OUTLET TO TURB DRIVEN AFW PUMP	MS	3		VT-1	
HANGER MS-H-0172I(8)	S/G B OUTLET TO TURB DRIVEN AFW PUMP	MS	3	2-3-13	VT-1	
HANGER MS-H-0197I(2)	STM SUPPLY TO TURB DRIVEN AFW PUMP	MS	3		VT-1	
HANGER MS-H-0202I(2)	STM SUPPLY TO TURB DRIVEN AFW PUMP	MS	3		VT-1	
HANGER MS-H-0410I(2)	MS DRAIN HDR INLET TO CONDENSER	MS	3		VT-1	
HANGER MS-H-0415I(2)	MS DRAIN HDR INLET TO CONDENSER	MS	3		VT-1	
HANGER MS-H-0418I(4)	MS DRAIN HDR INLET TO CONDENSER	MS	3	2-1-09	VT-1	
HANGER MS-H-0420I(4)	MS DRAIN HDR INLET TO CONDENSER	MS	3		VT-1	
HANGER MS-H-1388I(2)	VENT ON AFW PUMP TURB 1X-NNS	MS	3		VT-1	
HANGER MS-H-1393I(4)	VENT ON AFW PUMP TURB 1X-NNS	MS	3		VT-1	
HANGER MS-H-1394I(2)	VENT ON AFW PUMP TURB 1X-NNS	MS	3		VT-1	
HANGER SF-H-0438I(2)	NFP DISCH TO 1&4B PUMP SUCTION	SF	SE		VT-1	
HANGER SF-H-0453I(8)	SFP 1&4B PUMP SUCTION	SF	SE		VT-1	
HANGER SF-H-0498I(8)	COMMON TO UNITS 1&4	SF	SE		VT-1	
HANGER SF-H-0507I(8)	COMMON TO UNITS 1&4	SF	SE		VT-1	
HANGER SF-H-0884I(4)	COMMON TO UNITS 1&4	SF	SE		VT-1	
HANGER SF-H-0886I(4)	COMMON TO UNITS 1&4	SF	SE		VT-1	
HANGER SF-H-0888I(4)	COMMON TO UNITS 1&4	SF	SE		VT-1	
HANGER SF-H-0896I(4)	COMMON TO UNITS 1&4	SF	SE		VT-1	
HANGER SF-H-0899I(4)	COMMON TO UNITS 1&4	SF	SE		VT-1	
HANGER SF-H-0904I(4)	COMMON TO UNITS 1&4	SF	SE		VT-1	
HANGER SF-H-0906I(4)	COMMON TO UNITS 1&4	SF	SE		VT-1	



Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY D-A		INTEGRAL ATTACHMENTS FOR CLASS 3 VESSELS, PIPING, PUMPS, AND VALVES				
ITEM NO. D1.20		INTEGRALLY-WELDED ATTACHMENTS ON CLASS 3 PIPING				
Component	Description	System	Class	Outage	Exam Type	Relief Request
HANGER SF-H-0908I(4)	COMMON TO UNITS 1&4	SF	SE		VT-1	
HANGER SF-H-0912I(4)	COMMON TO UNITS 1&4	SF	SE		VT-1	
HANGER SF-H-0916I(4)	COMMON TO UNITS 1&4	SF	SE		VT-1	
HANGER SF-H-0918I(8)	COMMON TO UNITS 1&4	SF	SE		VT-1	
HANGER SF-H-0919I(4)	COMMON TO UNITS 1&4	SF	SE		VT-1	
HANGER SF-H-0921I(2)	COMMON TO UNITS 1&4	SF	SE		VT-1	
HANGER SF-H-1305I(8)	SFP PUMP 1&4A DISCH	SF	SE		VT-1	
HANGER SW-H-0036I(2)	SW SUPPLY TO CONT FAN COOLER AH-3	SW	3		VT-1	
HANGER SW-H-0042I(4)	SW BOOSTER PUMP A BY-PASS	SW	3		VT-1	
HANGER SW-H-0056I(4)	SW RETURN FROM CONT FAN COOLERS TO SW RETURN HDR A	SW	3	2-2-10	VT-1	
HANGER SW-H-0063I(1)	SW SUPPLY TO CONT FAN COOLER AH-2	SW	3		VT-1	
HANGER SW-H-0064I(2)	SW SUPPLY TO CONT FAN COOLER AH-2	SW	3		VT-1	
HANGER SW-H-0072I(2)	SW SUPPLY TO CONT FAN COOLER AH-2	SW	3		VT-1	
HANGER SW-H-0073I(4)	SW SUPPLY TO CONT FAN COOLER AH-2	SW	3		VT-1	
HANGER SW-H-0102I(4)	SW RETURN FROM CONT FAN COOLER AH-1 TO SW RETURN HDR	SW	3		VT-1	
HANGER SW-H-0106I(4)	SW RETURN FROM CONT FAN COOLER AH-1 TO SW RETURN HDR	SW	3		VT-1	
HANGER SW-H-0111I(4)	SW RETURN FROM CONT FAN COOLER AH-1 TO SW RETURN HDR	SW	3		VT-1	
HANGER SW-H-0114I(4)	SW RETURN FROM CONT FAN COOLER AH-4	SW	3		VT-1	
HANGER SW-H-0115I(2)	SW RETURN FROM CONT FAN COOLER AH-4	SW	3		VT-1	
HANGER SW-H-0419I(2)	FROM SW SUPPLY HDR B TO DG B COOLING	SW	3		VT-1	
HANGER SW-H-0440I(4)	SW SUPPLY HDR A	SW	3		VT-1	
HANGER SW-H-0449I(2)	SW SUPPLY HDR A	SW	3	2-1-09	VT-1	
HANGER SW-H-0492I(3)	SW BOOSTER PUMP B BY-PASS	SW	3		VT-1	
HANGER SW-H-0493I(4)	SW BOOSTER PUMP B BY-PASS	SW	3		VT-1	
HANGER SW-H-0507I(2)	SW BOOSTER PUMP A BY-PASS	SW	3		VT-1	
HANGER SW-H-0515I(2)	SW BOOSTER PUMP A DISCH HDR	SW	3		VT-1	
HANGER SW-H-0558I(2)	SW FROM RETURN HDR B TO CIRC WATER DISCH	SW	3		VT-1	
HANGER SW-H-0620I(2)	SW BOOSTER PUMP B HDR TO CONT FAN COOLER AH-1	SW	3		VT-1	
HANGER SW-H-0798I(2)	SW SUPPLY HDR B FROM SW PUMP DISCH	SW	3		VT-1	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY D-A		INTEGRAL ATTACHMENTS FOR CLASS 3 VESSELS, PIPING, PUMPS, AND VALVES					
ITEM NO. D1.20		INTEGRALLY-WELDED ATTACHMENTS ON CLASS 3 PIPING					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER	SW-H-1227I(1)	TO AFW PUMP A SUCTION	SW	3	2-2-10	VT-1	
HANGER	SW-H-1236I(2)	TO RAB HVAC CHILLER A	SW	3		VT-1	
HANGER	SW-H-1242I(1)	TO RAB HVAC CHILLER A	SW	3		VT-1	
HANGER	SW-H-1243I(2)	SW TO AFW PUMPS BACK-UP LINES	SW	3		VT-1	
HANGER	SW-H-1258I(2)	FROM SW SUPPLY HDR TO AFW PUMP 1X BACK-UP LINE	SW	3		VT-1	
HANGER	SW-H-1289I(4)	FROM SW SUPPLY HDR B TO CCW HX B	SW	3		VT-1	
HANGER	SW-H-1290I(2)	FROM SW SUPPLY HDR B TO CCW HX B	SW	3		VT-1	
HANGER	SW-H-1300I(2)	TO AFW PUMPS BACK-UP LINES	SW	3		VT-1	
HANGER	SW-H-1306I(2)	TO AFW PUMP B SUCTION	SW	3		VT-1	
HANGER	SW-H-1310I(2)	TO AFW PUMP B SUCTION	SW	3	2-2-10	VT-1	
HANGER	SW-H-1343I(2)	SW RETURN HDR A TO NORM SW DISCH HDR	SW	3		VT-1	
HANGER	SW-H-1422I(4)	SW RETURN FROM CONT FAN COOLERS TO SW RETURN HDR A	SW	3		VT-1	
HANGER	SW-H-1451I(2)	FROM RAB HVAC CHILLER A TO RETURN HDR A	SW	3		VT-1	
HANGER	SW-H-1502I(3)	FROM RAB HVAC CHILLER B TO RETURN HDR B	SW	3		VT-1	
HANGER	SW-H-1603I(4)	SW FROM CCW HX B TO RETURN HDR B	SW	3		VT-1	
HANGER	SW-H-1677I(2)	SW RETURN FROM CONT FAN COOLERS TO SW RETURN HDR A	SW	3		VT-1	
HANGER	SW-H-1738I(2)	SW RETURN FROM CONT FAN COOLERS TO SW RETURN HDR B	SW	3		VT-1	
HANGER	SW-H-1739I(4)	SW RETURN FROM CONT FAN COOLERS TO SW RETURN HDR B	SW	3		VT-1	
HANGER	SW-H-1742I(1)	SW RETURN FROM CONT FAN COOLER AH-4	SW	3		VT-1	
HANGER	SW-H-1871I(2)	SW FROM RETURN HDR B TO CIRC WATER DISCH	SW	3	2-3-13	VT-1	
HANGER	SW-H-1872I(3)	TO RAB HVAC CHILLER B	SW	3		VT-1	
HANGER	SW-H-2080I(2)	SW RETURN FROM DG A COOLING TO SW RETURN HDR A	SW	3		VT-1	
HANGER	SW-H-2100I(4)	TO RAB HVAC CHILLER B	SW	3		VT-1	
HANGER	SW-H-2107I(2)	SW FOR HVAC ESW CHILLER WC-2B RECIRC LOOP - PUMP P-7B D	SW	3		VT-1	
HANGER	SW-H-2123I(2)	TO RAB HVAC CHILLER A	SW	3		VT-1	
HANGER	SW-H-2131I(2)	SW FOR HVAC ESW CHILLER WC-2A RECIRC LOOP - PUMP P-7A D	SW	3		VT-1	
HANGER	SW-H-2132I(2)	SW FOR HVAC ESW CHILLER WC-2A RECIRC LOOP - PUMP P-7A D	SW	3		VT-1	
HANGER	SW-H-2144I(2)	SW FOR HVAC ESW CHILLER WC-2A RECIRC LOOP - PUMP P-7A S	SW	3	2-3-13	VT-1	
HANGER	SW-H-2177I(2)	FROM SW SUPPLY HDR B TO DG B COOLING	SW	3		VT-1	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY D-A		INTEGRAL ATTACHMENTS FOR CLASS 3 VESSELS, PIPING, PUMPS, AND VALVES				
ITEM NO. D1.20		INTEGRALLY-WELDED ATTACHMENTS ON CLASS 3 PIPING				
Component	Description	System	Class	Outage	Exam Type	Relief Request
HANGER SW-H-2297I(4)	SW RETURN FROM CONT FAN COOLER AH-1 TO SW RETURN HDR	SW	3		VT-1	
HANGER SW-H-2302I(4)	SW RETURN HDR B TO NORM SW DISCH HDR	SW	3		VT-1	
HANGER SW-H-2334I(2)	FROM RAB HVAC CHILLER A TO RETURN HDR A	SW	3		VT-1	
HANGER SW-H-2667I(2)	SW SUPPLY HDR B FROM SW PUMP DISCH	SW	3		VT-1	
HANGER SW-H-2749I(2)	SW RETURN FROM DG A COOLING TO SW RETURN HDR A	SW	3		VT-1	
HANGER SW-H-2800I(2)	AFW PUMP 1X-SAB SUCTION	SW	3		VT-1	
HANGER SW-H-2911I(4)	NSW PUMP A DISCH TO HDR	SW	3		VT-1	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY D-A
ITEM NO. D1.30

SYSTEMS IN SUPPORT OF REACTOR SHUTDOWN FUNCTION
INTEGRAL ATTACHMENT - MECHANICAL AND HYRAULIC SNUBBERS

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
NONE	/						

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY D-A SYSTEMS IN SUPPORT OF REACTOR SHUTDOWN FUNCTION
ITEM NO. D1.40 INTEGRAL ATTACHMENT - SPRING TYPE SUPPORTS

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
NONE	/						

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY D-A SYSTEMS IN SUPPORT OF REACTOR SHUTDOWN FUNCTION
ITEM NO. D1.50 INTEGRAL ATTACHMENT - CONSTANT LOAD TYPE SUPPORTS

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
NONE	/						

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY D-A SYSTEMS IN SUPPORT OF REACTOR SHUTDOWN FUNCTION
ITEM NO. D1.60 INTEGRAL ATTACHMENT - SHOCK ABSORBERS

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
NONE	/						

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY D-B SYSTEMS IN SUPPORT OF ECCS, CHR, AC, AND RHR
ITEM NO. D2.10 PRESSURE RETAINING COMPONENTS

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
SEE SECTION 9	/						



Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY D-B SYSTEMS IN SUPPORT OF ECCS, CHR, AC, AND RHR
ITEM NO. D2.20 INTEGRAL ATTACHMENT - COMPONENT SUPPORTS AND ATTACHMENTS

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
NONE	/						

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY D-B SYSTEMS IN SUPPORT OF ECCS, CHR, AC, AND RHR
ITEM NO. D2.30 INTEGRAL ATTACHMENT - MECHANICAL AND HYDRAULIC SNUBBERS

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
NONE	/						

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY D-B SYSTEMS IN SUPPORT OF ECCS, CHR, AC, AND RHR
ITEM NO. D2.40 INTEGRAL ATTACHMENT - SPRING TYPE SUPPORTS

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
NONE	/						

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY D-B SYSTEMS IN SUPPORT OF ECCS, CHR, AC, AND RHR
ITEM NO. D2.50 INTEGRAL ATTACHMENT - CONSTANT LOAD TYPE SUPPORTS

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
NONE	/						



Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY D-B SYSTEMS IN SUPPORT OF ECCS, CHR, AC, AND RHR
ITEM NO. D2.60 INTEGRAL ATTACHMENT - SHOCK ABSORBERS

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
NONE	/						

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY D-C SYSTEMS IN SUPPORT OF RHR FROM SPENT FUEL STORAGE POOL

ITEM NO. D3.10 PRESSURE RETAINING COMPONENTS

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
SEE SECTION 9	/						

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY D-C
ITEM NO. D3.20

SYSTEMS IN SUPPORT OF RHR FROM SPENT FUEL STORAGE POOL
INTEGRAL ATTACHMENT - COMPONENT SUPPORTS AND RESTRAINTS

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
NONE	/						

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY D-C
ITEM NO. D3.30

SYSTEMS IN SUPPORT OF RHR FROM SPENT FUEL STORAGE POOL
INTEGRAL ATTACHMENT - MECHANICAL AND HYDRAULIC SNUBBERS

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
NONE	/						

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY D-C SYSTEMS IN SUPPORT OF RHR FROM SPENT FUEL STORAGE POOL
ITEM NO. D3.40 INTEGRAL ATTACHMENT - SPRING TYPE SUPPORTS

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
NONE	/						

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY D-C
ITEM NO. D3.50

SYSTEMS IN SUPPORT OF RHR FROM SPENT FUEL STORAGE POOL
INTEGRAL ATTACHMENT - CONSTANT LOAD TYPE SUPPORTS

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
NONE	/						

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY D-C SYSTEMS IN SUPPORT OF RHR FROM SPENT FUEL STORAGE POOL

ITEM NO. D3.60 INTEGRAL ATTACHMENT - SHOCK ABSORBERS

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
NONE	/						

Component Supports (Hangers)
Item Numbering System
for Harris Nuclear Plant

Item Numbers are as assigned in Code Case N-491 and are summarized as follows:

<u>Item No.</u>	<u>Support Types Examined</u>	<u>Extent of Examination</u>
F1.10	Class 1 Piping Supports	25% of Class 1
F1.20	Class 2 Piping Supports	15% of Class 2
F1.30	Class 3 Piping Supports	10% of Class 3
F1.40	Supports Other Than Piping (Class 1, 2, 3, and MC)	100% of <u>one</u> of the multiple components

To this Code-supplied numbering system, except for F1.40, HNP has added the following "component support designators":

		Type Abbreviations
A	Anchor	AN
B	Box	BX
C	Constant Support	CS
H	Hydraulic Snubber	PM
R	Rigid	RI
S	Snubber	SN
V	Variable (Spring Can)	SP

An example of the numbering system:

"F1.20V" denotes a Class 2 hanger that is of a variable spring design.

HNP has applied the percentages above to each system, item number, and component support designator.

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS						
ITEM NO. F1.10B		CLASS 1 HANGER - BOX						
Component		Description	System	Class	Outage	Exam Type	Relief Request	
HANGER	RC-H-0033	LOOP 2 CL OUTLET TO RCS PZR SPRAY	RC	1	2-1-09	VT-3		
HANGER	RC-H-0058	LOOP 1 CL OUTLET TO RCS PZR SPRAY	RC	1		VT-3		
HANGER	RC-H-0074	LOOP 2 CL OUTLET TO RCS PZR SPRAY	RC	1		VT-3		
HANGER	RC-H-0084	LOOP 1 CL OUTLET TO RCS PZR SPRAY	RC	1		VT-3		
HANGER	RC-H-0099	LOOP 1 CL OUTLET TO RCS PZR SPRAY	RC	1	2-1-09	VT-3		
HANGER	RC-H-0242	PZR PORV INLET	RC	1		VT-3		
HANGER	RC-H-0446	LOOP 2 CL OUTLET TO RCS PZR SPRAY	RC	1		VT-3		
HANGER	RH-H-0120	RCS LOOP 3 HL TO RHR PUMP SUCTION	RH	1		VT-3		
HANGER	RH-H-0122	RCS LOOP 3 HL TO RHR PUMP SUCTION	RH	1		VT-3		
HANGER	RH-H-0151	RCS LOOP 1 HL TO RHR PUMP SUCTION	RH	1	2-2-10	VT-3		
HANGER	RH-H-0365	RCS LOOP 3 HL TO RHR PUMP SUCTION	RH	1		VT-3		
HANGER	SI-H-0352	BIT OUTLET TO RCS LOOP 2 CL	SI	1	2-1-08	VT-3		
HANGER	SI-H-0354	BIT OUTLET TO RCS LOOP 2 CL	SI	1		VT-3		
HANGER	SI-H-0356	BIT OUTLET TO RCS LOOP 2 CL	SI	1		VT-3		
HANGER	SI-H-0362	BIT OUTLET TO RCS LOOP 2 CL	SI	1		VT-3		
HANGER	SI-H-0364	BIT OUTLET TO RCS LOOP 2 CL	SI	1		VT-3		
HANGER	SI-H-0366	BIT OUTLET TO RCS LOOP 2 CL	SI	1	2-1-09	VT-3		
HANGER	SI-H-0368	BIT OUTLET TO RCS LOOP 2 CL	SI	1		VT-3		
HANGER	SI-H-0370	BIT OUTLET TO RCS LOOP 2 CL	SI	1		VT-3		
HANGER	SI-H-0434	BIT OUTLET TO RCS LOOP 1 CL	SI	1	2-2-11	VT-3		
HANGER	SI-H-0439	BIT OUTLET TO RCS LOOP 1 CL	SI	1		VT-3		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A CLASS 1,2, AND 3 COMPONENT SUPPORTS
ITEM NO. F1.10C CLASS 1 HANGER - CONSTANT SUPPORT

Component	Description	System	Class	Outage	Exam Type	Relief Request
HANGER RC-H-0057	SPRAY LINE HDR TO PZR SPRAY NOZZLE	RC	1	2-1-09	VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO. F1.10R		CLASS 1 HANGER - RIGID					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER CS-H-2870		RCP C SEAL INJ FROM VALVE CS-430 TO PUMP	CS	1	2-2-10	VT-3	
HANGER CS-H-2889		RCP B SEAL INJ FROM VALVE CS-389 TO PUMP	CS	1		VT-3	
HANGER CS-H-2890		RCP B SEAL INJ FROM VALVE CS-389 TO PUMP	CS	1		VT-3	
HANGER CS-H-2956		RCP A SEAL INJ FROM VALVE CS-348 TO PUMP	CS	1		VT-3	
HANGER CS-H-2957		RCP A SEAL INJ FROM VALVE CS-348 TO PUMP	CS	1	2-1-08	VT-3	
HANGER CS-H-2958		RCP A SEAL INJ FROM VALVE CS-348 TO PUMP	CS	1		VT-3	
HANGER CS-H-2961		RCP A SEAL INJ FROM VALVE CS-348 TO PUMP	CS	1		VT-3	
HANGER CS-H-3243		PZR SPRAY LINE FROM LINE 2CS2-119SN	CS	1	2-3-13	VT-3	
HANGER CS-H-3622		RCP A SEAL INJ FROM VALVE CS-348 TO PUMP	CS	1		VT-3	
HANGER RC-H-0001		PZR SURGE LINE FROM LOOP 2 HL TO PZR	RC	1		VT-3	
HANGER RC-H-0004		PZR SURGE LINE FROM LOOP 2 HL TO PZR	RC	1	2-3-13	VT-3	
HANGER RC-H-0040		LOOP 2 CL OUTLET TO RCS PZR SPRAY	RC	1		VT-3	
HANGER RC-H-0047		LOOP 1 CL OUTLET TO RCS PZR SPRAY	RC	1		VT-3	
HANGER RC-H-0055		SPRAY LINE HDR TO PZR SPRAY NOZZLE	RC	1		VT-3	
HANGER RC-H-0056		SPRAY LINE HDR TO PZR SPRAY NOZZLE	RC	1		VT-3	
HANGER RC-H-0078		LOOP 2 CL OUTLET TO RCS PZR SPRAY	RC	1		VT-3	
HANGER RC-H-0081		LOOP 2 CL OUTLET TO RCS PZR SPRAY	RC	1	2-1-08	VT-3	
HANGER RC-H-0098		LOOP 1 CL OUTLET TO RCS PZR SPRAY	RC	1		VT-3	
HANGER RC-H-0240		PZR DISCH TO PORV	RC	1		VT-3	
HANGER RC-H-0245		PZR PORV INLET	RC	1	2-3-13	VT-3	
HANGER RC-H-0411		PZR SURGE LINE FROM LOOP 2 HL TO PZR	RC	1		VT-3	
HANGER RH-H-0115		RCS LOOP 3 HL TO RHR PUMP SUCTION	RH	1		VT-3	
HANGER RH-H-0124		RCS LOOP 3 HL TO RHR PUMP SUCTION	RH	1	2-2-11	VT-3	
HANGER RH-H-0125		RCS LOOP 3 HL TO RHR PUMP SUCTION	RH	1		VT-3	
HANGER RH-H-0143		RCS LOOP 1 HL TO RHR PUMP SUCTION	RH	1		VT-3	
HANGER RH-H-0149		RCS LOOP 1 HL TO RHR PUMP SUCTION	RH	1	2-2-10	VT-3	
HANGER RH-H-0150		RCS LOOP 1 HL TO RHR PUMP SUCTION	RH	1		VT-3	
HANGER RH-H-0152		RCS LOOP 1 HL TO RHR PUMP SUCTION	RH	1		VT-3	
HANGER RH-H-0153		RCS LOOP 1 HL TO RHR PUMP SUCTION	RH	1	2-2-10	VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.10R	CLASS 1 HANGER - RIGID					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER	RH-H-0154	RCS LOOP 1 HL TO RHR PUMP SUCTION	RH	1		VT-3	
HANGER	SI-H-0117	ACCUM A INJ LINE TO RCS CL LOOP 1	SI	1	2-3-13	VT-3	
HANGER	SI-H-0120	ACCUM A INJ LINE TO RCS CL LOOP 1	SI	1		VT-3	
HANGER	SI-H-0134	ACCUM B INJ LINE TO RCS CL LOOP 2	SI	1		VT-3	
HANGER	SI-H-0136	ACCUM B INJ LINE TO RCS CL LOOP 2	SI	1		VT-3	
HANGER	SI-H-0145	SIS RES HX TO RCS LOOP 3 CL	SI	1		VT-3	
HANGER	SI-H-0147	SIS RES HX TO RCS LOOP 3 CL	SI	1	2-2-11	VT-3	
HANGER	SI-H-0170	SIS RES HX TO RCS HL LOOP 1	SI	1		VT-3	
HANGER	SI-H-0173	SIS RES HX TO RCS HL LOOP 1	SI	1		VT-3	
HANGER	SI-H-0176	SIS RES HX TO RCS HL LOOP 1	SI	1	2-1-09	VT-3	
HANGER	SI-H-0184	SIS RES HX TO RCS HL LOOP 2	SI	1		VT-3	
HANGER	SI-H-0186	SIS RES HX TO RCS HL LOOP 2	SI	1		VT-3	
HANGER	SI-H-0229	SIS RES HX TO RCS CL LOOP 1	SI	1		VT-3	
HANGER	SI-H-0262	SIS RES HX TO RCS CL LOOP 2	SI	1	2-1-08	VT-3	
HANGER	SI-H-0265	SIS RES HX TO RCS CL LOOP 2	SI	1		VT-3	
HANGER	SI-H-0277	ACCUM TK C INJ LINE TO RCS CL LOOP 3	SI	1		VT-3	
HANGER	SI-H-0315	HIGH HEAD INJ TO RCS HL LOOP 3	SI	1		VT-3	
HANGER	SI-H-0317	HIGH HEAD INJ TO RCS HL LOOP 3	SI	1	2-3-13	VT-3	
HANGER	SI-H-0320	HIGH HEAD INJ TO RCS HL LOOP 3	SI	1		VT-3	
HANGER	SI-H-0322	HIGH HEAD INJ TO RCS HL LOOP 3	SI	1		VT-3	
HANGER	SI-H-0323	HIGH HEAD INJ TO RCS HL LOOP 3	SI	1		VT-3	
HANGER	SI-H-0325	HIGH HEAD INJ TO RCS HL LOOP 3	SI	1	2-3-13	VT-3	
HANGER	SI-H-0327	HIGH HEAD INJ TO RCS HL LOOP 3	SI	1		VT-3	
HANGER	SI-H-0350	BIT OUTLET TO RCS LOOP 2 CL	SI	1		VT-3	
HANGER	SI-H-0351	BIT OUTLET TO RCS LOOP 2 CL	SI	1		VT-3	
HANGER	SI-H-0358	BIT OUTLET TO RCS LOOP 2 CL	SI	1	2-1-08	VT-3	
HANGER	SI-H-0360	BIT OUTLET TO RCS LOOP 2 CL	SI	1		VT-3	
HANGER	SI-H-0424	BIT OUTLET TO RCS LOOP 1 CL	SI	1		VT-3	
HANGER	SI-H-0425	BIT OUTLET TO RCS LOOP 1 CL	SI	1		VT-3	



Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1

ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.10R	CLASS 1 HANGER - RIGID					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER SI-H-0426		BIT OUTLET TO RCS LOOP 1 CL	SI	1	2-2-11	VT-3	
HANGER SI-H-0429		BIT OUTLET TO RCS LOOP 1 CL	SI	1		VT-3	
HANGER SI-H-0431		BIT OUTLET TO RCS LOOP 1 CL	SI	1		VT-3	
HANGER SI-H-0432		BIT OUTLET TO RCS LOOP 1 CL	SI	1		VT-3	
HANGER SI-H-0433		BIT OUTLET TO RCS LOOP 1 CL	SI	1	2-2-10	VT-3	
HANGER SI-H-0436		BIT OUTLET TO RCS LOOP 1 CL	SI	1		VT-3	
HANGER SI-H-0438		BIT OUTLET TO RCS LOOP 1 CL	SI	1		VT-3	
HANGER SI-H-0497		BIT OUTLET TO RCS LOOP 3 CL	SI	1		VT-3	
HANGER SI-H-0941		HIGH HEAD INJ TO RCS LOOP 2 CL	SI	1	2-2-10	VT-3	
HANGER SI-H-0962		SIS RES HX TO RCS LOOP 1 CL	SI	1		VT-3	
HANGER SI-H-1201		SIS RES HX TO RCS LOOP 2 CL	SI	1		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A ITEM NO. F1.10S		CLASS 1,2, AND 3 COMPONENT SUPPORTS CLASS 1 HANGER - SNUBBER						
Component		Description	System	Class	Outage	Exam Type	Relief Request	
HANGER CS-H-0398		NORM LTDN FROM RCS ADJACENT TO VALVE CS-1	CS	1		VT-3		
HANGER CS-H-0399		NORM LTDN FROM RCS ADJACENT TO VALVE CS-1	CS	1		VT-3		
HANGER CS-H-2871		RCP C SEAL INJ FROM VALVE CS-430 TO PUMP	CS	1	2-2-11	VT-3		
HANGER CS-H-2962		RCP A SEAL INJ FROM VALVE CS-348 TO PUMP	CS	1		VT-3		
HANGER CS-H-3208		NORM LTDN FROM RCS TO VALVE CS-2	CS	1		VT-3		
HANGER CS-H-3242		PZR SPRAY LINE FROM LINE 2CS2-119SN	CS	1	2-3-13	VT-3		
HANGER CS-H-4418		NORM LTDN FROM RCS TO VALVE CS-2	CS	1		VT-3		
HANGER CS-H-4430		NORM LTDN FROM RCS TO VALVE CS-2	CS	1		VT-3		
HANGER RC-H-0002		PZR SURGE LINE FROM LOOP 2 HL TO PZR	RC	1	2-3-13	VT-3		
HANGER RC-H-0006		PZR SURGE LINE FROM LOOP 2 HL TO PZR	RC	1		VT-3		
HANGER RC-H-0037		LOOP 2 CL OUTLET TO RCS PZR SPRAY	RC	1		VT-3		
HANGER RC-H-0038		LOOP 2 CL OUTLET TO RCS PZR SPRAY	RC	1		VT-3		
HANGER RC-H-0042		LOOP 2 CL OUTLET TO RCS PZR SPRAY	RC	1	2-2-10	VT-3		
HANGER RC-H-0046		LOOP 1 CL OUTLET TO RCS PZR SPRAY	RC	1		VT-3		
HANGER RC-H-0048		HDR TO PZR SPRAY NOZZLE	RC	1		VT-3		
HANGER RC-H-0049		HDR TO PZR SPRAY NOZZLE	RC	1		VT-3		
HANGER RC-H-0053		HDR TO PZR SPRAY NOZZLE	RC	1	2-2-11	VT-3		
HANGER RC-H-0054		HDR TO PZR SPRAY NOZZLE	RC	1		VT-3		
HANGER RC-H-0059		LOOP 1 CL OUTLET TO RCS PZR SPRAY	RC	1		VT-3		
HANGER RC-H-0064		LOOP 1 CL OUTLET TO RCS PZR SPRAY	RC	1		VT-3		
HANGER RC-H-0065		LOOP 1 CL OUTLET TO RCS PZR SPRAY	RC	1	2-2-10	VT-3		
HANGER RC-H-0067		LOOP 2 CL OUTLET TO RCS PZR SPRAY	RC	1		VT-3		
HANGER RC-H-0068		LOOP 2 CL OUTLET TO RCS PZR SPRAY	RC	1		VT-3		
HANGER RC-H-0069		LOOP 2 CL OUTLET TO RCS PZR SPRAY	RC	1		VT-3		
HANGER RC-H-0070		LOOP 2 CL OUTLET TO RCS PZR SPRAY	RC	1	2-1-09	VT-3		
HANGER RC-H-0073		LOOP 2 CL OUTLET TO RCS PZR SPRAY	RC	1		VT-3		
HANGER RC-H-0075		LOOP 2 CL OUTLET TO RCS PZR SPRAY	RC	1		VT-3		
HANGER RC-H-0077		LOOP 2 CL OUTLET TO RCS PZR SPRAY	RC	1		VT-3		
HANGER RC-H-0080		LOOP 2 CL OUTLET TO RCS PZR SPRAY	RC	1	2-1-08	VT-3		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.10S	CLASS 1 HANGER - SNUBBER					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER	RC-H-0082	LOOP 2 CL OUTLET TO RCS PZR SPRAY	RC	1		VT-3	
HANGER	RC-H-0083	LOOP 2 CL OUTLET TO RCS PZR SPRAY	RC	1		VT-3	
HANGER	RC-H-0087	LOOP 1 CL OUTLET TO RCS PZR SPRAY	RC	1		VT-3	
HANGER	RC-H-0088	LOOP 1 CL OUTLET TO RCS PZR SPRAY	RC	1	2-3-13	VT-3	
HANGER	RC-H-0089	LOOP 1 CL OUTLET TO RCS PZR SPRAY	RC	1		VT-3	
HANGER	RC-H-0090	LOOP 1 CL OUTLET TO RCS PZR SPRAY	RC	1		VT-3	
HANGER	RC-H-0092	LOOP 1 CL OUTLET TO RCS PZR SPRAY	RC	1		VT-3	
HANGER	RC-H-0093	LOOP 1 CL OUTLET TO RCS PZR SPRAY	RC	1	2-1-09	VT-3	
HANGER	RC-H-0095	LOOP 1 CL OUTLET TO RCS PZR SPRAY	RC	1		VT-3	
HANGER	RC-H-0096	LOOP 1 CL OUTLET TO RCS PZR SPRAY	RC	1		VT-3	
HANGER	RC-H-0100	LOOP 1 CL OUTLET TO RCS PZR SPRAY	RC	1		VT-3	
HANGER	RC-H-0220	PZR DISCH TO PORV	RC	1	2-3-13	VT-3	
HANGER	RC-H-0221	PZR DISCH TO PORV	RC	1		VT-3	
HANGER	RC-H-0222	PZR DISCH TO PORV	RC	1		VT-3	
HANGER	RC-H-0224	PZR DISCH TO PORV	RC	1	2-3-13	VT-3	
HANGER	RC-H-0225	PZR DISCH TO PORV	RC	1		VT-3	
HANGER	RC-H-0228	PZR PORV INLET	RC	1		VT-3	
HANGER	RC-H-0229	PZR PORV INLET	RC	1		VT-3	
HANGER	RC-H-0230	PZR PORV INLET	RC	1	2-3-13	VT-3	
HANGER	RC-H-0231	PZR PORV INLET	RC	1		VT-3	
HANGER	RC-H-0236	PZR PORV INLET	RC	1		VT-3	
HANGER	RC-H-0238	PZR PORV INLET	RC	1		VT-3	
HANGER	RC-H-0239	PZR PORV INLET	RC	1	2-3-13	VT-3	
HANGER	RC-H-0244	PZR PORV INLET	RC	1		VT-3	
HANGER	RC-H-0246	PZR PORV INLET	RC	1		VT-3	
HANGER	RC-H-0412	PZR SURGE LINE FROM LOOP 2 HL TO PZR	RC	1		VT-3	
HANGER	RC-H-0444	LOOP 2 CL OUTLET TO RCS PZR SPRAY	RC	1	2-1-08	VT-3	
HANGER	RC-H-0447	SPRAY LINE HDR TO PZR SPRAY HDR	RC	1		VT-3	
HANGER	RC-H-0486	PZR PORV INLET	RC	1		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.10S	CLASS 1 HANGER - SNUBBER					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER RC-H-0487		PZR PORV INLET	RC	1		VT-3	
HANGER RC-H-0491		PZR DISCH TO CODE SAFETY VALVE	RC	1	2-3-13	VT-3	
HANGER RC-H-0494		PZR DISCH TO CODE SAFETY VALVE	RC	1		VT-3	
HANGER RC-H-0640		LOOP 1 CL OUTLET TO RCS PZR SPRAY	RC	1		VT-3	
HANGER RC-H-0664		PZR DISCH TO CODE SAFETY VALVE	RC	1		VT-3	
HANGER RC-H-0665		PZR DISCH TO CODE SAFETY VALVE	RC	1	2-3-12	VT-3	
HANGER RC-H-0666		PZR DISCH TO CODE SAFETY VALVE	RC	1		VT-3	
HANGER RC-H-0667		PZR DISCH TO CODE SAFETY VALVE	RC	1		VT-3	
HANGER RC-H-0920		LOOP 3 X-OVER LEG TO WPS RCDT PUMP	RC	1		VT-3	
HANGER RH-H-0113		RCS LOOP 3 HL TO RHR PUMP SUCTION	RH	1	2-2-10	VT-3	
HANGER RH-H-0116		RCS LOOP 3 HL TO RHR PUMP SUCTION	RH	1		VT-3	
HANGER RH-H-0118		RCS LOOP 3 HL TO RHR PUMP SUCTION	RH	1		VT-3	
HANGER RH-H-0119		RCS LOOP 3 HL TO RHR PUMP SUCTION	RH	1		VT-3	
HANGER RH-H-0141		RCS LOOP 1 HL TO RHR PUMP SUCTION	RH	1	2-2-10	VT-3	
HANGER RH-H-0142		RCS LOOP 1 HL TO RHR PUMP SUCTION	RH	1		VT-3	
HANGER RH-H-0144		RCS LOOP 1 HL TO RHR PUMP SUCTION	RH	1		VT-3	
HANGER RH-H-0145		RCS LOOP 1 HL TO RHR PUMP SUCTION	RH	1		VT-3	
HANGER RH-H-0146		RCS LOOP 1 HL TO RHR PUMP SUCTION	RH	1		VT-3	
HANGER RH-H-0364		RCS LOOP 3 HL TO RHR PUMP SUCTION	RH	1	2-2-11	VT-3	
HANGER SI-H-0118		ACCUM A INJ LINE TO RCS CL LOOP 1	SI	1	2-3-13	VT-3	
HANGER SI-H-0119		ACCUM A INJ LINE TO RCS CL LOOP 1	SI	1		VT-3	
HANGER SI-H-0122		ACCUM A INJ LINE TO RCS CL LOOP 1	SI	1		VT-3	
HANGER SI-H-0133		ACCUM B INJ LINE TO RCS CL LOOP 2	SI	1		VT-3	
HANGER SI-H-0141		SIS RES HX TO RCS LOOP 3 CL	SI	1	2-2-11	VT-3	
HANGER SI-H-0142		SIS RES HX TO RCS LOOP 3 CL	SI	1		VT-3	
HANGER SI-H-0144		SIS RES HX TO RCS LOOP 3 CL	SI	1		VT-3	
HANGER SI-H-0146		SIS RES HX TO RCS LOOP 3 CL	SI	1		VT-3	
HANGER SI-H-0148		SIS RES HX TO RCS LOOP 3 CL	SI	1	2-2-10	VT-3	
HANGER SI-H-0149		SIS RES HX TO RCS LOOP 3 CL	SI	1		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.10S	CLASS 1 HANGER - SNUBBER					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER	SI-H-0168	SIS RES HX TO RCS HL LOOP 1	SI	1		VT-3	
HANGER	SI-H-0169	SIS RES HX TO RCS HL LOOP 1	SI	1		VT-3	
HANGER	SI-H-0171	SIS RES HX TO RCS HL LOOP 1	SI	1	2-1-08	VT-3	
HANGER	SI-H-0172	SIS RES HX TO RCS HL LOOP 1	SI	1		VT-3	
HANGER	SI-H-0174	SIS RES HX TO RCS HL LOOP 1	SI	1		VT-3	
HANGER	SI-H-0175	SIS RES HX TO RCS HL LOOP 1	SI	1		VT-3	
HANGER	SI-H-0177	SIS RES HX TO RCS HL LOOP 1	SI	1	2-1-08	VT-3	
HANGER	SI-H-0185	SIS RES HX TO RCS HL LOOP 2	SI	1		VT-3	
HANGER	SI-H-0187	SIS RES HX TO RCS HL LOOP 2	SI	1		VT-3	
HANGER	SI-H-0188	SIS RES HX TO RCS HL LOOP 2	SI	1		VT-3	
HANGER	SI-H-0190	SIS RES HX TO RCS HL LOOP 2	SI	1	2-3-13	VT-3	
HANGER	SI-H-0192	SIS RES HX TO RCS HL LOOP 2	SI	1		VT-3	
HANGER	SI-H-0230	SIS RES HX TO RCS CL LOOP 1	SI	1		VT-3	
HANGER	SI-H-0233	SIS RES HX TO RCS CL LOOP 1	SI	1		VT-3	
HANGER	SI-H-0266	SIS RES HX TO RCS CL LOOP 2	SI	1	2-1-08	VT-3	
HANGER	SI-H-0275	ACCUM TK C INJ LINE TO RCS CL LOOP 3	SI	1		VT-3	
HANGER	SI-H-0279	ACCUM TK C INJ LINE TO RCS CL LOOP 3	SI	1		VT-3	
HANGER	SI-H-0318	HIGH HEAD INJ TO RCS HL LOOP 3	SI	1	2-3-13	VT-3	
HANGER	SI-H-0321	HIGH HEAD INJ TO RCS HL LOOP 3	SI	1		VT-3	
HANGER	SI-H-0324	HIGH HEAD INJ TO RCS HL LOOP 3	SI	1	2-3-13	VT-3	
HANGER	SI-H-0326	HIGH HEAD INJ TO RCS HL LOOP 3	SI	1		VT-3	
HANGER	SI-H-0357	BIT OUTLET TO RCS LOOP 2 CL	SI	1		VT-3	
HANGER	SI-H-0359	BIT OUTLET TO RCS LOOP 2 CL	SI	1		VT-3	
HANGER	SI-H-0361	BIT OUTLET TO RCS LOOP 2 CL	SI	1		VT-3	
HANGER	SI-H-0373	BIT OUTLET TO RCS LOOP 2 CL	SI	1		VT-3	
HANGER	SI-H-0375	BIT OUTLET TO RCS LOOP 2 CL	SI	1		VT-3	
HANGER	SI-H-0376	BIT OUTLET TO RCS LOOP 2 CL	SI	1		VT-3	
HANGER	SI-H-0428	BIT OUTLET TO RCS LOOP 1 CL	SI	1	2-2-11	VT-3	
HANGER	SI-H-0430	BIT OUTLET TO RCS LOOP 1 CL	SI	1		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1

ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A ITEM NO. F1.10S		CLASS 1,2, AND 3 COMPONENT SUPPORTS CLASS 1 HANGER - SNUBBER						
Component	Description	System	Class	Outage	Exam Type	Relief Request		
HANGER SI-H-0437	BIT OUTLET TO RCS LOOP 1 CL	SI	1		VT-3			
HANGER SI-H-0440	BIT OUTLET TO RCS LOOP 1 CL	SI	1	2-2-10	VT-3			
HANGER SI-H-0498	BIT OUTLET TO RCS LOOP 3 CL	SI	1		VT-3			
HANGER SI-H-0499	BIT OUTLET TO RCS LOOP 3 CL	SI	1		VT-3			
HANGER SI-H-0500	BIT OUTLET TO RCS LOOP 3 CL	SI	1		VT-3			
HANGER SI-H-0501	BIT OUTLET TO RCS LOOP 3 CL	SI	1	2-3-13	VT-3			
HANGER SI-H-0502	BIT OUTLET TO RCS LOOP 3 CL	SI	1		VT-3			
HANGER SI-H-0503	BIT OUTLET TO RCS LOOP 3 CL	SI	1		VT-3			
HANGER SI-H-0504	BIT OUTLET TO RCS LOOP 3 CL	SI	1		VT-3			
HANGER SI-H-0506	BIT OUTLET TO RCS LOOP 3 CL	SI	1	2-3-13	VT-3			
HANGER SI-H-0507	BIT OUTLET TO RCS LOOP 3 CL	SI	1		VT-3			
HANGER SI-H-0508	BIT OUTLET TO RCS LOOP 3 CL	SI	1		VT-3			
HANGER SI-H-0599	HIGH HEAD INJ TO RCS LOOP 1 CL	SI	1		VT-3			
HANGER SI-H-0942	HIGH HEAD INJ TO RCS LOOP 2 CL	SI	1	2-2-11	VT-3			
HANGER SI-H-0959	SIS RES HX TO RCS LOOP 1 CL	SI	1		VT-3			
HANGER SI-H-0960	SIS RES HX TO RCS LOOP 1 CL	SI	1		VT-3			
HANGER SI-H-0961	SIS RES HX TO RCS LOOP 1 CL	SI	1		VT-3			
HANGER SI-H-0982	SIS RES HX TO RCS LOOP 2 CL	SI	1	2-2-10	VT-3			
HANGER SI-H-0983	SIS RES HX TO RCS LOOP 2 CL	SI	1		VT-3			
HANGER SI-H-0989	ACCUM B INJ LINE TO RCS CL LOOP 2	SI	1		VT-3			
HANGER SI-H-1023	SIS RES HX TO RCS HL LOOP 2	SI	1		VT-3			
HANGER SI-H-1025	SIS RES HX TO RCS HL LOOP 2	SI	1	2-3-13	VT-3			
HANGER SI-H-1036	SIS RES HX TO RCS LOOP 2 CL	SI	1		VT-3			
HANGER SI-H-1092	BIT OUTLET TO RCS LOOP 3 CL	SI	1		VT-3			
HANGER SI-H-1193	SIS RES HX TO RCS LOOP 2 CL	SI	1		VT-3			

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO. F1.10V		CLASS 1 HANGER - VARIABLE (SPRING CAN)					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER	CS-H-2891	RCP B SEAL INJ FROM VALVE CS-389 TO PUMP	CS	1	2-3-13	VT-3	
HANGER	RC-H-0008	PZR SURGE LINE FROM LOOP 2 HL TO PZR	RC	1		VT-3	
HANGER	RC-H-0036	LOOP 2 CL OUTLET TO RCS PZR SPRAY	RC	1		VT-3	
HANGER	RC-H-0041	LOOP 2 CL OUTLET TO RCS PZR SPRAY	RC	1	2-1-09	VT-3	
HANGER	RC-H-0052	HDR TO PZR SPRAY NOZZLE	RC	1		VT-3	
HANGER	RC-H-0061	LOOP 1 CL OUTLET TO RCS PZR SPRAY	RC	1	2-1-08	VT-3	
HANGER	RC-H-0071	LOOP 2 CL OUTLET TO RCS PZR SPRAY	RC	1		VT-3	
HANGER	RC-H-0072	LOOP 2 CL OUTLET TO RCS PZR SPRAY	RC	1		VT-3	
HANGER	RC-H-0076	LOOP 2 CL OUTLET TO RCS PZR SPRAY	RC	1		VT-3	
HANGER	RC-H-0079	LOOP 2 CL OUTLET TO RCS PZR SPRAY	RC	1	2-1-08	VT-3	
HANGER	RC-H-0086	LOOP 1 CL OUTLET TO RCS PZR SPRAY	RC	1		VT-3	
HANGER	RC-H-0091	LOOP 1 CL OUTLET TO RCS PZR SPRAY	RC	1		VT-3	
HANGER	RC-H-0094	LOOP 1 CL OUTLET TO RCS PZR SPRAY	RC	1		VT-3	
HANGER	RC-H-0199	PZR DISCH TO SAFETY RV	RC	1	2-3-13	VT-3	
HANGER	RC-H-0209	PZR DISCH TO SAFETY VALVE	RC	1		VT-3	
HANGER	RC-H-0214	PZR DISCH TO SAFETY VALVE	RC	1		VT-3	
HANGER	RC-H-0219	PZR DISCH TO PORV	RC	1		VT-3	
HANGER	RC-H-0223	PZR DISCH TO PORV	RC	1		VT-3	
HANGER	RC-H-0226	PZR DISCH TO PORV	RC	1	2-3-13	VT-3	
HANGER	RC-H-0227	PZR PORV INLET	RC	1		VT-3	
HANGER	RC-H-0237	PZR PORV INLET	RC	1		VT-3	
HANGER	RC-H-0243	PZR PORV INLET	RC	1		VT-3	
HANGER	RC-H-0272	LOOP 1 X-OVER LEG TO CVCS NORM LTDN	RC	1	2-2-11	VT-3	
HANGER	RC-H-0445	LOOP 1 CL OUTLET TO RCS PZR SPRAY	RC	1		VT-3	
HANGER	RC-H-0862	LOOP 1 CL OUTLET TO RCS PZR SPRAY	RC	1		VT-3	
HANGER	RH-H-0112	RCS LOOP 3 HL TO RHR PUMP SUCTION	RH	1	2-2-11	VT-3	
HANGER	RH-H-0140	RCS LOOP 1 HL TO RHR PUMP SUCTION	RH	1		VT-3	
HANGER	SI-H-0121	ACCUM A INJ LINE TO RCS CL LOOP 1	SI	1		VT-3	
HANGER	SI-H-0189	SIS RES HX TO RCS HL LOOP 2	SI	1	2-3-13	VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO. F1.10V		CLASS 1 HANGER - VARIABLE (SPRING CAN)					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER	SI-H-0191	SIS RES HX TO RCS HL LOOP 2	SI	1		VT-3	
HANGER	SI-H-0228	SIS RES HX TO RCS CL LOOP 1	SI	1		VT-3	
HANGER	SI-H-0231	SIS RES HX TO RCS CL LOOP 1	SI	1	2-3-13	VT-3	
HANGER	SI-H-0260	SIS RES HX TO RCS CL LOOP 2	SI	1		VT-3	
HANGER	SI-H-0372	BIT OUTLET TO RCS LOOP 2 CL	SI	1		VT-3	
HANGER	SI-H-0427	BIT OUTLET TO RCS LOOP 1 CL	SI	1	2-2-10	VT-3	
HANGER	SI-H-0509	BIT OUTLET TO RCS LOOP 3 CL	SI	1		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.20A	CLASS 2 HANGER - ANCHOR					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER	CS-H-0001	RWST CONN TO CHARGING PUMP A SUCTION	CS	2		VT-3	
HANGER	CS-H-0018	CHARGING PUMPS SUCTION HDR	CS	2	2-2-10	VT-3	
HANGER	CS-H-0023	VCT OUTLET HDR AT CHARGING PUMPS SUCTION	CS	2		VT-3	
HANGER	CS-H-0725	EXCESS LTDN DELAY HDR	CS	2		VT-3	
HANGER	CT-H-0228	PORTION FROM VALVE CT-26 TO CT PUMP A SUCTION	CT	2		VT-3	
HANGER	CT-H-0242	LINE TO SIS RHR HX	CT	2	2-2-11	VT-3	
HANGER	CT-H-0249	CVCS CHARGING PUMPS CONN	CT	2		VT-3	
HANGER	CT-H-0320	PUMP B DISCH TO CONT SPRAY RING HDR	CT	2		VT-3	
HANGER	CT-H-0341	PUMP A DISCH TO CONT SPRAY RING HDR	CT	2		VT-3	
HANGER	RH-H-0013	RHR HX B OUTLET FOR VALVE RH-66	RH	2		VT-3	
HANGER	RH-H-0078	RHR HX A OUTLET	RH	2	2-1-09	VT-3	
HANGER	SI-H-0016	SIS LOW HEAD INJ TO RCS HL	SI	2		VT-3	
HANGER	SI-H-0044	SIS LOW HEAD INJ TO RCS HL	SI	2	2-1-09	VT-3	
HANGER	SI-H-1284	SUCTION LINE TO RHR PUMP B FROM CONT SUMP B	SI	2		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS						
ITEM NO. F1.20B		CLASS 2 HANGER - BOX						
Component	Description	System	Class	Outage	Exam Type	Relief Request		
HANGER AF-H-0155	AFW PUMP 1X-SAB OUTLET TO DISCH HDR	AF	2	2-2-11	VT-3			
HANGER AF-H-0485	FROM FP B VALVE AF-81 TO S/G	AF	2		VT-3			
HANGER BD-H-0079	S/G B BLDWN TO ISO VALVE BD-30	BD	2		VT-3			
HANGER BD-H-0498	S/G A BLDWN TO ISO VALVE BD-11	BD	2	2-1-09	VT-3			
HANGER CS-H-0002	RWST CONN TO CHARGING PUMP A SUCTION	CS	2		VT-3			
HANGER CS-H-0003	RHRS CONN TO CHARGING PUMP SUCTION	CS	2	2-1-09	VT-3			
HANGER CS-H-0004	RHRS CONN TO CHARGING PUMP SUCTION	CS	2		VT-3			
HANGER CS-H-0006	RHRS CONN TO CHARGING PUMP SUCTION	CS	2		VT-3			
HANGER CS-H-0011	VCT OUTLET HDR AT CHARGING PUMPS SUCTION	CS	2		VT-3			
HANGER CS-H-0015	VCT OUTLET HDR TO CHARGING PUMPS SUCTION	CS	2		VT-3			
HANGER CS-H-0016	VCT OUTLET HDR TO CHARGING PUMPS SUCTION	CS	2		VT-3			
HANGER CS-H-0019	FROM HDR TO CHARGING PUMP C SUCTION	CS	2		VT-3			
HANGER CS-H-0021	VCT OUTLET HDR AT CHARGING PUMPS SUCTION	CS	2		VT-3			
HANGER CS-H-0031	RWST CONN TO CHARGING PUMP C SUCTION	CS	2		VT-3			
HANGER CS-H-0033	RWST CONN TO CHARGING PUMP C SUCTION	CS	2		VT-3			
HANGER CS-H-0035	RWST CONN TO CHARGING PUMP A SUCTION	CS	2	2-1-08	VT-3			
HANGER CS-H-0036	CHARGING PUMPS SUCTION HDR	CS	2		VT-3			
HANGER CS-H-0037	CHARGING PUMPS SUCTION HDR	CS	2		VT-3			
HANGER CS-H-0236	VCT OUTLET HDR AT CHARGING PUMPS SUCTION	CS	2		VT-3			
HANGER CS-H-0726	EXCESS LTDN DELAY HDR	CS	2		VT-3			
HANGER CS-H-0863	FROM HDR TO CHARGING PUMP A SUCTION	CS	2		VT-3			
HANGER CS-H-2793	RHRS CONN TO CHARGING PUMP SUCTION	CS	2		VT-3			
HANGER CS-H-2855	RCP C SEAL INJ AT CONT PENE M-11	CS	2	2-3-13	VT-3			
HANGER CS-H-2859	RCP C SEAL INJ AT CONT PENE M-11	CS	2		VT-3			
HANGER CT-H-0093	PUMP A DISCH TO SPRAY RING HDR	CT	2	2-1-08	VT-3			
HANGER CT-H-0100	PUMP B DISCH TO SPRAY RING HDR	CT	2		VT-3			
HANGER CT-H-0222	PORTION FROM VALVE CT-26 TO CT PUMP A SUCTION	CT	2		VT-3			
HANGER CT-H-0233	PORTION FROM VALVE CT-26 TO CT PUMP A SUCTION	CT	2		VT-3			
HANGER CT-H-0281	INLET TO CT PUMP B SUCTION	CT	2		VT-3			

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO. F1.20B		CLASS 2 HANGER - BOX					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER	CT-H-0283	INLET TO CT PUMP B SUCTION	CT	2		VT-3	
HANGER	CT-H-0287	PORTION FROM VALVE CT-26 TO CT PUMP A SUCTION	CT	2	2-1-09	VT-3	
HANGER	CT-H-0306	PUMP B DISCH TO CONT SPRAY RING HDR	CT	2		VT-3	
HANGER	CT-H-0313	PUMP B DISCH TO CONT SPRAY RING HDR	CT	2		VT-3	
HANGER	CT-H-0316	PUMP B DISCH TO CONT SPRAY RING HDR	CT	2		VT-3	
HANGER	CT-H-0339	PUMP A DISCH TO CONT SPRAY RING HDR	CT	2		VT-3	
HANGER	CT-H-0342	PUMP A DISCH TO CONT SPRAY RING HDR	CT	2		VT-3	
HANGER	CT-H-0362	CVCS CHARGING PUMP CONN	CT	2	2-1-08	VT-3	
HANGER	CT-H-0796	PUMP B DISCH TO CONT SPRAY RING HDR	CT	2		VT-3	
HANGER	MS-H-0068	FROM PENE M-2 TO ISO VALVE MS-82	MS	2		VT-3	
HANGER	MS-H-0168	S/G B OUTLET TO TURB DRIVEN AFW PUMP	MS	2		VT-3	
HANGER	RH-H-0012	RHR HX B OUTLET FOR VALVE RH-66	RH	2	2-3-13	VT-3	
HANGER	RH-H-0017	RCS LOOP 1 HL TO RHR PUMP SUCTION	RH	2		VT-3	
HANGER	RH-H-0019	RCS LOOP 1 HL TO RHR PUMP SUCTION	RH	2		VT-3	
HANGER	RH-H-0022	RCS LOOP 1 HL TO RHR PUMP SUCTION	RH	2		VT-3	
HANGER	RH-H-0047	RCS LOOP 3 HL TO RHR PUMP SUCTION	RH	2		VT-3	
HANGER	RH-H-0049	RCS LOOP 3 HL TO RHR PUMP SUCTION	RH	2		VT-3	
HANGER	RH-H-0066	RHR HX A OUTLET	RH	2	2-1-09	VT-3	
HANGER	RH-H-0171	RHR PUMP A DISCH TO RHR HX A	RH	2		VT-3	
HANGER	SI-H-0029	SUCTION LINE TO RHR PUMP A FROM CONT SUMP A	SI	2		VT-3	
HANGER	SI-H-0045	SIS LOW HEAD INJ TO RCS HL	SI	2	2-1-09	VT-3	
HANGER	SI-H-0046	SIS LOW HEAD INJ TO RCS HL	SI	2		VT-3	
HANGER	SI-H-0047	SIS LOW HEAD INJ TO RCS HL	SI	2		VT-3	
HANGER	SI-H-0052	SUCTION LINE TO RHR PUMP B FROM CONT SUMP B	SI	2		VT-3	
HANGER	SI-H-0165	SIS RES HX TO RCS HL LOOP 1	SI	2	2-3-13	VT-3	
HANGER	SI-H-0183	SIS RES HX TO RCS HL LOOP 2	SI	2		VT-3	
HANGER	SI-H-0240	SIS LOW HEAD INJ TO RCS CL FROM RHR PUMP A	SI	2		VT-3	
HANGER	SI-H-0242	SIS LOW HEAD INJ TO RCS CL FROM RHR PUMP A	SI	2		VT-3	
HANGER	SI-H-0244	SIS LOW HEAD INJ TO RCS CL FROM RHR PUMP A	SI	2		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1

ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS						
ITEM NO. F1.20B		CLASS 2 HANGER - BOX						
Component		Description	System	Class	Outage	Exam Type	Relief Request	
HANGER SI-H-0246		SIS LOW HEAD INJ TO RCS CL FROM RHR PUMP A	SI	2		VT-3		
HANGER SI-H-0255		X-CONN BETWEEN LOW HEAD INJ BRANCH LINES	SI	2		VT-3		
HANGER SI-H-0274		ACCUM TK C INJ LINE TO RCS CL LOOP 3	SI	2	2-3-13	VT-3		
HANGER SI-H-1031		LOW HEAD INJ TO RCS CL FROM RHR PUMP B	SI	2		VT-3		
HANGER SI-H-1197		LOW HEAD INJ TO RCS CL FROM RHR PUMP B	SI	2		VT-3		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO. F1.20H		CLASS 2 HANGER - HYDRAULIC SNUBBERS					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER	MS-H-0034	FROM PENE M-3 TO ISO VALVE MS-80	MS	2		VT-3	
HANGER	MS-H-0041	FROM PENE M-2 TO ISO VALVE MS-82	MS	2		VT-3	
HANGER	MS-H-0049	FROM PENE M-1 TO ISO VALVE MS-84	MS	2		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.20R	CLASS 2 HANGER - RIGID					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER	AF-H-0285	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER	AF-H-0287	FROM FP B VALVE AF-64 TO S/G	AF	2	2-1-09	VT-3	
HANGER	AF-H-0288	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER	AF-H-0289	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER	AF-H-0290	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER	AF-H-0291	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER	AF-H-0292	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER	AF-H-0293	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER	AF-H-0294	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER	AF-H-0295	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER	AF-H-0297	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER	AF-H-0306	FROM FP B VALVE AF-102 TO S/G	AF	2	2-1-09	VT-3	
HANGER	AF-H-0308	FROM FP B VALVE AF-102 TO S/G	AF	2		VT-3	
HANGER	AF-H-0309	FROM FP B VALVE AF-102 TO S/G	AF	2		VT-3	
HANGER	AF-H-0310	FROM FP B VALVE AF-102 TO S/G	AF	2		VT-3	
HANGER	AF-H-0316	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER	AF-H-0318	FROM FP B VALVE AF-64 TO S/G	AF	2	2-1-08	VT-3	
HANGER	AF-H-0319	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER	AF-H-0321	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER	AF-H-0322	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER	AF-H-0323	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER	AF-H-0324	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER	AF-H-0325	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER	AF-H-0329	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER	AF-H-0330	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER	AF-H-0331	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER	AF-H-0332	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER	AF-H-0344	FROM FP B VALVE AF-102 TO S/G	AF	2	2-1-09	VT-3	
HANGER	AF-H-0347	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.20R	CLASS 2 HANGER - RIGID					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER AF-H-0388		FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER AF-H-0389		FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER AF-H-0470		FROM FP B VALVE AF-102 TO S/G	AF	2		VT-3	
HANGER AF-H-0486		FROM FP B VALVE AF-81 TO S/G	AF	2	2-1-08	VT-3	
HANGER AF-H-0487		FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER AF-H-0489		FROM FP B VALVE AF-102 TO S/G	AF	2		VT-3	
HANGER AF-H-0490		FROM FP B VALVE AF-81 TO S/G	AF	2		VT-3	
HANGER AF-H-0491		FROM FP B VALVE AF-64 TO S/G	AF	2	2-3-12	VT-3	
HANGER BD-H-0010		S/G C BLDWN TO ISO VALVE BD-49	BD	2		VT-3	
HANGER BD-H-0012		S/G C BLDWN TO ISO VALVE BD-49	BD	2	2-1-09	VT-3	
HANGER BD-H-0013		S/G C BLDWN TO ISO VALVE BD-49	BD	2		VT-3	
HANGER BD-H-0025		S/G A BLDWN TO ISO VALVE BD-11	BD	2		VT-3	
HANGER BD-H-0028		S/G A BLDWN TO ISO VALVE BD-11	BD	2		VT-3	
HANGER BD-H-0030		S/G A BLDWN TO ISO VALVE BD-11	BD	2		VT-3	
HANGER BD-H-0032		S/G A BLDWN TO ISO VALVE BD-11	BD	2		VT-3	
HANGER BD-H-0034		S/G A BLDWN TO ISO VALVE BD-11	BD	2	2-1-08	VT-3	
HANGER BD-H-0072		S/G B BLDWN TO ISO VALVE BD-30	BD	2		VT-3	
HANGER BD-H-0075		S/G B BLDWN TO ISO VALVE BD-30	BD	2		VT-3	
HANGER BD-H-0076		S/G B BLDWN TO ISO VALVE BD-30	BD	2		VT-3	
HANGER BD-H-0099		S/G A BLDWN TO ISO VALVE BD-11	BD	2		VT-3	
HANGER BD-H-0166		S/G C BLDWN TO ISO VALVE BD-49	BD	2		VT-3	
HANGER BD-H-0167		S/G C BLDWN TO ISO VALVE BD-49	BD	2	2-1-08	VT-3	
HANGER BD-H-0208		S/G B BLDWN TO ISO VALVE BD-30	BD	2		VT-3	
HANGER BD-H-0368		S/G C BLDWN TO ISO VALVE BD-49	BD	2		VT-3	
HANGER CS-H-0014		VCT OUTLET HDR TO CHARGING PUMPS SUCTION	CS	2		VT-3	
HANGER CS-H-0024		FROM HDR TO CHARGING PUMP A SUCTION	CS	2	2-2-10	VT-3	
HANGER CS-H-0027		RHRS CONN TO CHARGING PUMP SUCTION	CS	2		VT-3	
HANGER CS-H-0029		RHRS CONN TO CHARGING PUMP SUCTION	CS	2	2-2-10	VT-3	
HANGER CS-H-0030		RHRS CONN TO CHARGING PUMP SUCTION	CS	2		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO. F1.20R		CLASS 2 HANGER - RIGID					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER	CS-H-0038	CHARGING PUMPS SUCTION HDR	CS	2		VT-3	
HANGER	CS-H-0235	VCT OUTLET HDR AT CHARGING PUMPS SUCTION	CS	2		VT-3	
HANGER	CS-H-1425	RCP B SEAL INJ AT CONT PENE M-10	CS	2		VT-3	
HANGER	CS-H-1426	RCP B SEAL INJ AT CONT PENE M-10	CS	2		VT-3	
HANGER	CS-H-1427	RCP B SEAL INJ AT CONT PENE M-10	CS	2		VT-3	
HANGER	CS-H-2603	RCP A SEAL INJ AT CONT PENE M-9	CS	2	2-3-13	VT-3	
HANGER	CS-H-2604	RCP A SEAL INJ AT CONT PENE M-9	CS	2		VT-3	
HANGER	CS-H-2605	RCP A SEAL INJ AT CONT PENE M-9	CS	2		VT-3	
HANGER	CS-H-2817	RCP C SEAL INJ AT CONT PENE M-11	CS	2		VT-3	
HANGER	CS-H-2819	RCP C SEAL INJ AT CONT PENE M-11	CS	2		VT-3	
HANGER	CS-H-2820	RCP C SEAL INJ AT CONT PENE M-11	CS	2	2-3-13	VT-3	
HANGER	CS-H-2846	RCP C SEAL INJ AT CONT PENE M-11	CS	2		VT-3	
HANGER	CS-H-2847	RCP C SEAL INJ AT CONT PENE M-11	CS	2		VT-3	
HANGER	CS-H-2849	RCP C SEAL INJ AT CONT PENE M-11	CS	2		VT-3	
HANGER	CS-H-2850	RCP C SEAL INJ AT CONT PENE M-11	CS	2		VT-3	
HANGER	CS-H-2851	RCP C SEAL INJ AT CONT PENE M-11	CS	2		VT-3	
HANGER	CS-H-2852	RCP C SEAL INJ AT CONT PENE M-11	CS	2		VT-3	
HANGER	CS-H-2853	RCP C SEAL INJ AT CONT PENE M-11	CS	2	2-3-13	VT-3	
HANGER	CS-H-2856	RCP C SEAL INJ AT CONT PENE M-11	CS	2		VT-3	
HANGER	CS-H-2857	RCP C SEAL INJ AT CONT PENE M-11	CS	2		VT-3	
HANGER	CS-H-2860	RCP C SEAL INJ AT CONT PENE M-11	CS	2		VT-3	
HANGER	CS-H-2861	RCP C SEAL INJ AT CONT PENE M-11	CS	2		VT-3	
HANGER	CS-H-2862	RCP C SEAL INJ AT CONT PENE M-11	CS	2		VT-3	
HANGER	CS-H-2863	RCP C SEAL INJ AT CONT PENE M-11	CS	2		VT-3	
HANGER	CS-H-2864	RCP C SEAL INJ AT CONT PENE M-11	CS	2		VT-3	
HANGER	CS-H-2865	RCP C SEAL INJ AT CONT PENE M-11	CS	2		VT-3	
HANGER	CS-H-2867	RCP C SEAL INJ AT CONT PENE M-11	CS	2		VT-3	
HANGER	CS-H-2874	RCP B SEAL INJ AT CONT PENE M-10	CS	2		VT-3	
HANGER	CS-H-2875	RCP B SEAL INJ AT CONT PENE M-10	CS	2		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.20R	CLASS 2 HANGER - RIGID					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER	CS-H-2876	RCP B SEAL INJ AT CONT PENE M-10	CS	2		VT-3	
HANGER	CS-H-2878	RCP B SEAL INJ AT CONT PENE M-10	CS	2		VT-3	
HANGER	CS-H-2879	RCP B SEAL INJ AT CONT PENE M-10	CS	2		VT-3	
HANGER	CS-H-2880	RCP B SEAL INJ AT CONT PENE M-10	CS	2	2-3-13	VT-3	
HANGER	CS-H-2881	RCP B SEAL INJ AT CONT PENE M-10	CS	2		VT-3	
HANGER	CS-H-2882	RCP B SEAL INJ AT CONT PENE M-10	CS	2		VT-3	
HANGER	CS-H-2945	RCP A SEAL INJ AT CONT PENE M-9	CS	2		VT-3	
HANGER	CS-H-2946	RCP A SEAL INJ AT CONT PENE M-9	CS	2		VT-3	
HANGER	CS-H-2947	RCP A SEAL INJ AT CONT PENE M-9	CS	2		VT-3	
HANGER	CS-H-2948	RCP A SEAL INJ AT CONT PENE M-9	CS	2	2-3-13	VT-3	
HANGER	CS-H-3192	NORM LTDN FROM LTDN ORIFICES TO LTDN HX	CS	2		VT-3	
HANGER	CS-H-3193	NORM LTDN FROM LTDN ORIFICES TO LTDN HX	CS	2		VT-3	
HANGER	CS-H-3261	NORM LTDN FROM LTDN ORIFICES TO LTDN HX	CS	2		VT-3	
HANGER	CS-H-3343	FROM HDR TO CHARGING PUMP C SUCTION	CS	2		VT-3	
HANGER	CS-H-3559	RHRS CONN TO CHARGING PUMP SUCTION	CS	2		VT-3	
HANGER	CS-H-4519	NORM LTDN FROM LTDN ORIFICES TO LTDN HX	CS	2	2-2-11	VT-3	
HANGER	CT-H-0092	PUMP A DISCH TO SPRAY RING HDR	CT	2		VT-3	
HANGER	CT-H-0094	PUMP A DISCH TO SPRAY RING HDR	CT	2	2-1-08	VT-3	
HANGER	CT-H-0095	PUMP A DISCH TO SPRAY RING HDR	CT	2		VT-3	
HANGER	CT-H-0096	PUMP A DISCH TO SPRAY RING HDR	CT	2		VT-3	
HANGER	CT-H-0097	PUMP B DISCH TO SPRAY RING HDR	CT	2		VT-3	
HANGER	CT-H-0098	PUMP B DISCH TO SPRAY RING HDR	CT	2		VT-3	
HANGER	CT-H-0099	PUMP B DISCH TO SPRAY RING HDR	CT	2		VT-3	
HANGER	CT-H-0101	PUMP B DISCH TO SPRAY RING HDR	CT	2		VT-3	
HANGER	CT-H-0219	PORT FROM VALVE CT-26 TO CT PUMP A SUCTION	CT	2	2-2-10	VT-3	
HANGER	CT-H-0224	PORTION FROM VALVE CT-26 TO CT PUMP A SUCTION	CT	2		VT-3	
HANGER	CT-H-0226	PORTION FROM VALVE CT-26 TO CT PUMP A SUCTION	CT	2		VT-3	
HANGER	CT-H-0227	PORTION FROM VALVE CT-26 TO CT PUMP A SUCTION	CT	2		VT-3	
HANGER	CT-H-0239	PART OF LINE FROM CONT SUMP TO VALVE CT-105	CT	2		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.20R	CLASS 2 HANGER - RIGID					
Component	Description		System	Class	Outage	Exam Type	Relief Request
HANGER	CT-H-0251	CVCS CHARGING PUMPS CONN	CT	2		VT-3	
HANGER	CT-H-0275	INLET TO CT PUMP B SUCTION	CT	2		VT-3	
HANGER	CT-H-0276	INLET TO CT PUMP B SUCTION	CT	2		VT-3	
HANGER	CT-H-0277	INLET TO CT PUMP B SUCTION	CT	2		VT-3	
HANGER	CT-H-0278	INLET TO CT PUMP B SUCTION	CT	2		VT-3	
HANGER	CT-H-0280	INLET TO CT PUMP B SUCTION	CT	2		VT-3	
HANGER	CT-H-0282	INLET TO CT PUMP B SUCTION	CT	2	2-1-09	VT-3	
HANGER	CT-H-0295	FROM CONT SUMP (PENE M-50) TO VALVE CT-102	CT	2		VT-3	
HANGER	CT-H-0304	PUMP B DISCH TO CONT SPRAY RING HDR	CT	2		VT-3	
HANGER	CT-H-0309	PUMP B DISCH TO CONT SPRAY RING HDR	CT	2		VT-3	
HANGER	CT-H-0310	PUMP B DISCH TO CONT SPRAY RING HDR	CT	2		VT-3	
HANGER	CT-H-0312	PUMP B DISCH TO CONT SPRAY RING HDR	CT	2		VT-3	
HANGER	CT-H-0317	PUMP B DISCH TO CONT SPRAY RING HDR	CT	2	2-1-08	VT-3	
HANGER	CT-H-0318	PUMP B DISCH TO CONT SPRAY RING HDR	CT	2		VT-3	
HANGER	CT-H-0319	PUMP B DISCH TO CONT SPRAY RING HDR	CT	2		VT-3	
HANGER	CT-H-0325	PUMP B DISCH TO CONT SPRAY RING HDR	CT	2		VT-3	
HANGER	CT-H-0331	PUMP A DISCH TO CONT SPRAY RING HDR	CT	2		VT-3	
HANGER	CT-H-0332	PUMP A DISCH TO CONT SPRAY RING HDR	CT	2		VT-3	
HANGER	CT-H-0338	PUMP A DISCH TO CONT SPRAY RING HDR	CT	2		VT-3	
HANGER	CT-H-0344	PUMP A DISCH TO CONT SPRAY RING HDR	CT	2	2-1-09	VT-3	
HANGER	CT-H-0345	PUMP A DISCH TO CONT SPRAY RING HDR	CT	2		VT-3	
HANGER	CT-H-0346	PUMP A DISCH TO CONT SPRAY RING HDR	CT	2		VT-3	
HANGER	CT-H-0349	PUMP A DISCH TO CONT SPRAY RING HDR	CT	2		VT-3	
HANGER	CT-H-0351	PUMP A DISCH TO CONT SPRAY RING HDR	CT	2		VT-3	
HANGER	CT-H-0352	PUMP A DISCH TO CONT SPRAY RING HDR	CT	2		VT-3	
HANGER	CT-H-0353	PUMP A DISCH TO CONT SPRAY RING HDR	CT	2		VT-3	
HANGER	CT-H-0818	FROM VALVE CT-26 TO CT PUMP A SUCTION	CT	2		VT-3	
HANGER	CT-H-0819	FROM VALVE CT-26 TO CT PUMP A SUCTION	CT	2	2-2-10	VT-3	
HANGER	CT-H-0886	INLET TO CT PUMP B SUCTION	CT	2		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO. F1.20R		CLASS 2 HANGER - RIGID					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER	CT-H-0887	INLET TO CT PUMP B SUCTION	CT	2		VT-3	
HANGER	CT-H-0891	PUMP B DISCH TO CONT SPRAY RING HDR	CT	2		VT-3	
HANGER	CT-H-0892	PUMP B DISCH TO CONT SPRAY RING HDR	CT	2		VT-3	
HANGER	CT-H-0895	INLET TO CT PUMP B SUCTION	CT	2	2-1-09	VT-3	
HANGER	FW-H-0102	FROM PENE M-4 TO S/G A	FW	2	2-3-13	VT-3	
HANGER	FW-H-0104	FROM PENE M-4 TO S/G A	FW	2		VT-3	
HANGER	FW-H-0107	FROM PENE M-4 TO S/G A	FW	2		VT-3	
HANGER	FW-H-0109	FROM PENE M-4 TO S/G A	FW	2		VT-3	
HANGER	FW-H-0112	FROM PENE M-5 TO S/G B	FW	2		VT-3	
HANGER	FW-H-0119	FROM PENE M-6 TO S/G C	FW	2		VT-3	
HANGER	FW-H-0121	FROM PENE M-6 TO S/G C	FW	2		VT-3	
HANGER	FW-H-0124	FROM PENE M-6 TO S/G C	FW	2		VT-3	
HANGER	FW-H-0128	FROM PENE M-6 TO S/G C	FW	2	2-1-08	VT-3	
HANGER	FW-H-0130	FROM PENE M-6 TO S/G C	FW	2		VT-3	
HANGER	FW-H-0188	FROM PENE M-5 TO S/G B	FW	2		VT-3	
HANGER	FW-H-0209	FROM PENE M-4 TO S/G A	FW	2		VT-3	
HANGER	FW-H-0216	FROM PENE M-6 TO S/G C	FW	2		VT-3	
HANGER	FW-H-0489	FROM FPBV AF-81 TO S/G	FW	2		VT-3	
HANGER	FW-H-0490	FROM FPBV AF-81 TO S/G	FW	2		VT-3	
HANGER	FW-H-0514	FROM VALVE FW-159 TO PENE M-4	FW	2	2-2-11	VT-3	
HANGER	FW-H-0517	FROM VALVE FW-277 TO PENE M-5	FW	2		VT-3	
HANGER	FW-H-0520	FROM VALVE FW-217 TO PENE M-6	FW	2		VT-3	
HANGER	MS-H-0009	S/G A OUTLET TO PENE M-3	MS	2		VT-3	
HANGER	MS-H-0011	S/G A OUTLET TO PENE M-3	MS	2		VT-3	
HANGER	MS-H-0017	S/G A OUTLET TO PENE M-3	MS	2		VT-3	
HANGER	MS-H-0029	S/G C OUTLET TO PENE M-1	MS	2		VT-3	
HANGER	MS-H-0031	S/G C OUTLET TO PENE M-1	MS	2		VT-3	
HANGER	MS-H-0036	FROM PENE M-3 TO ISO VALVE MS-80	MS	2		VT-3	
HANGER	MS-H-0043	FROM PENE M-2 TO ISO VALVE MS-82	MS	2		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.20R	CLASS 2 HANGER - RIGID					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER MS-H-0051		FROM PENE M-1 TO ISO VALVE MS-84	MS	2		VT-3	
HANGER MS-H-0067		FROM PENE M-3 TO ISO VALVE MS-80	MS	2		VT-3	
HANGER MS-H-0069		FROM PENE M-1 TO ISO VALVE MS-84	MS	2		VT-3	
HANGER MS-H-0077		S/G A OUTLET CONN UPSTRM OF VALVE MS-58	MS	2		VT-3	
HANGER MS-H-0085		S/G B OUTLET CONN UPSTRM OF VALVE MS-60	MS	2		VT-3	
HANGER MS-H-0093		S/G C OUTLET CONN UPSTRM OF VALVE MS-62	MS	2		VT-3	
HANGER MS-H-0174		S/G C OUTLET TO TURB DRIVEN AFW PUMP	MS	2		VT-3	
HANGER RH-H-0006		RHR HX A OUTLET FOR VALVE RH-20	RH	2	2-1-09	VT-3	
HANGER RH-H-0015		RCS LOOP 1 HL TO RHR PUMP SUCTION	RH	2		VT-3	
HANGER RH-H-0016		RCS LOOP 1 HL TO RHR PUMP SUCTION	RH	2		VT-3	
HANGER RH-H-0018		RCS LOOP 1 HL TO RHR PUMP SUCTION	RH	2		VT-3	
HANGER RH-H-0021		RCS LOOP 1 HL TO RHR PUMP SUCTION	RH	2		VT-3	
HANGER RH-H-0024		RCS LOOP 1 HL TO RHR PUMP SUCTION	RH	2		VT-3	
HANGER RH-H-0031		RHR PUMP A DISCH TO RHR HX A	RH	2	2-1-08	VT-3	
HANGER RH-H-0032		RHR PUMP A DISCH TO RHR HX A	RH	2		VT-3	
HANGER RH-H-0034		RHR PUMP A DISCH TO RHR HX A	RH	2		VT-3	
HANGER RH-H-0035		RHR PUMP A DISCH TO RHR HX A	RH	2		VT-3	
HANGER RH-H-0041		RCS LOOP 3 HL TO RHR PUMP SUCTION	RH	2		VT-3	
HANGER RH-H-0043		RCS LOOP 3 HL TO RHR PUMP SUCTION	RH	2		VT-3	
HANGER RH-H-0046		RCS LOOP 3 HL TO RHR PUMP SUCTION	RH	2		VT-3	
HANGER RH-H-0051		RCS LOOP 3 HL TO RHR PUMP SUCTION	RH	2		VT-3	
HANGER RH-H-0052		RCS LOOP 3 HL TO RHR PUMP SUCTION	RH	2		VT-3	
HANGER RH-H-0059		RHR PUMP B DISCH TO RHR HX B	RH	2	2-2-10	VT-3	
HANGER RH-H-0060		RCS LOOP 3 HL TO RHR PUMP SUCTION	RH	2		VT-3	
HANGER RH-H-0061		RCS LOOP 3 HL TO RHR PUMP SUCTION	RH	2		VT-3	
HANGER RH-H-0064		RHR PUMP B DISCH TO RHR HX B	RH	2		VT-3	
HANGER RH-H-0068		RHR HX A OUTLET	RH	2		VT-3	
HANGER RH-H-0069		RHR HX A OUTLET	RH	2		VT-3	
HANGER RH-H-0074		RHR HX A OUTLET	RH	2		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS						
ITEM NO. F1.20R		CLASS 2 HANGER - RIGID						
Component	Description	System	Class	Outage	Exam Type	Relief Request		
HANGER RH-H-0075	RHR HX A OUTLET	RH	2		VT-3			
HANGER RH-H-0080	RHR HX A OUTLET	RH	2	2-1-08	VT-3			
HANGER RH-H-0081	RHR HX A OUTLET	RH	2		VT-3			
HANGER RH-H-0082	RHR PUMP A DISCH TO RHR HX A	RH	2		VT-3			
HANGER RH-H-0087	RHR HX A DISCH BY-PASS	RH	2	2-1-09	VT-3			
HANGER RH-H-0098	RHR HX B OUTLET	RH	2		VT-3			
HANGER RH-H-0099	RHR HX B OUTLET	RH	2		VT-3			
HANGER RH-H-0100	RHR HX B OUTLET	RH	2		VT-3			
HANGER RH-H-0104	RHR HX B OUTLET	RH	2		VT-3			
HANGER RH-H-0128	RHR PUMP A DISCH TO RHR HX A	RH	2		VT-3			
HANGER RH-H-0156	RHR PUMP B DISCH TO RHR HX B	RH	2		VT-3			
HANGER RH-H-0159	RHR PUMP B DISCH TO RHR HX B	RH	2	2-2-10	VT-3			
HANGER RH-H-0170	RHR PUMP A DISCH TO RHR HX A	RH	2		VT-3			
HANGER RH-H-0174	RHR HX A OUTLET	RH	2		VT-3			
HANGER RH-H-0175	RHR HX A OUTLET	RH	2		VT-3			
HANGER RH-H-0184	RHR HX B OUTLET	RH	2		VT-3			
HANGER RH-H-0185	RHR HX B OUTLET	RH	2	2-3-13	VT-3			
HANGER RH-H-0187	RCS LOOP 1 HL TO RHR PUMP SUCTION	RH	2		VT-3			
HANGER RH-H-0244	RHR HX A DISCH BY-PASS	RH	2		VT-3			
HANGER RH-H-0266	LOW HEAD INJ TO RCS CL FROM RHR PUMP B	RH	2		VT-3			
HANGER RH-H-0267	RHR HX A OUTLET	RH	2		VT-3			
HANGER RH-H-0291	RHR PUMP B DISCH TO RHR HX B	RH	2		VT-3			
HANGER RH-H-0313	RH HX B OUTLET	RH	2		VT-3			
HANGER RH-H-0315	LOW HEAD INJ TO RCS CL FROM RHR PUMP B	RH	2	2-2-11	VT-3			
HANGER RH-H-0352	RCS LOOP 3 HL TO RHR PUMP SUCTION	RH	2		VT-3			
HANGER RH-H-0354	RHR HX A OUTLET	RH	2		VT-3			
HANGER RH-H-0376	RHR PUMP B DISCH TO RHR HX B	RH	2		VT-3			
HANGER RH-H-0750R	RHR PUMP A DISCH TO RHR HX A	RH	2		VT-3			
HANGER RH-H-0751R	RHR PUMP A DISCH TO RHR HX A	RH	2		VT-3			

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.20R	CLASS 2 HANGER - RIGID					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER	SI-H-0008	LOW HEAD INJ TO RCS CL FROM RHR PUMP B	SI	2	2-2-11	VT-3	
HANGER	SI-H-0010	LOW HEAD INJ X-CONN TO RCS HL FROM RHR PUMP B	SI	2		VT-3	
HANGER	SI-H-0012	LOW HEAD INJ X-CONN TO RCS HL FROM RHR PUMP B	SI	2		VT-3	
HANGER	SI-H-0013	LOW HEAD INJ X-CONN TO RCS HL FROM RHR PUMP B	SI	2		VT-3	
HANGER	SI-H-0014	SIS LOW HEAD INJ TO RCS HL	SI	2		VT-3	
HANGER	SI-H-0015	SIS LOW HEAD INJ TO RCS HL	SI	2		VT-3	
HANGER	SI-H-0017	LOW HEAD INJ TO RCS CL FROM RHR PUMP B	SI	2		VT-3	
HANGER	SI-H-0018	LOW HEAD INJ TO RCS CL FROM RHR PUMP B	SI	2		VT-3	
HANGER	SI-H-0025	SIS LOW HEAD INJ TO RCS HL	SI	2	2-1-08	VT-3	
HANGER	SI-H-0027	RWST OUTLET TO RHR PUMP A SUCTION	SI	2		VT-3	
HANGER	SI-H-0031	SUCTION LINE TO RHR PUMP A FROM CONT SUMP A	SI	2		VT-3	
HANGER	SI-H-0034	SUCTION LINE TO RHR PUMP A FROM CONT SUMP A	SI	2		VT-3	
HANGER	SI-H-0036	SIS LOW HEAD INJ TO RCS HL	SI	2		VT-3	
HANGER	SI-H-0039	SIS LOW HEAD INJ TO RCS HL	SI	2	2-1-08	VT-3	
HANGER	SI-H-0040	SIS LOW HEAD INJ TO RCS HL	SI	2		VT-3	
HANGER	SI-H-0042	SIS LOW HEAD INJ TO RCS HL	SI	2		VT-3	
HANGER	SI-H-0043	SIS LOW HEAD INJ TO RCS HL	SI	2		VT-3	
HANGER	SI-H-0054	SUCTION LINE TO RHR PUMP B FROM CONT SUMP B	SI	2		VT-3	
HANGER	SI-H-0055	SUCTION LINE TO RHR PUMP B FROM CONT SUMP B	SI	2		VT-3	
HANGER	SI-H-0056	LOW HEAD INJ TO RCS CL FROM RHR PUMP A	SI	2		VT-3	
HANGER	SI-H-0057	LOW HEAD INJ TO RCS CL FROM RHR PUMP A	SI	2	2-1-09	VT-3	
HANGER	SI-H-0059	LOW HEAD INJ TO RCS CL FROM RHR PUMP A	SI	2		VT-3	
HANGER	SI-H-0111	ACCUM A INJ LINE TO RCS CL LOOP 1	SI	2		VT-3	
HANGER	SI-H-0112	ACCUM A INJ LINE TO RCS CL LOOP 1	SI	2		VT-3	
HANGER	SI-H-0113	ACCUM A INJ LINE TO RCS CL LOOP 1	SI	2		VT-3	
HANGER	SI-H-0115	ACCUM A INJ LINE TO RCS CL LOOP 1	SI	2		VT-3	
HANGER	SI-H-0126	ACCUM B INJ LINE TO RCS CL LOOP 2	SI	2		VT-3	
HANGER	SI-H-0128	ACCUM B INJ LINE TO RCS CL LOOP 2	SI	2	2-2-11	VT-3	
HANGER	SI-H-0129	ACCUM B INJ LINE TO RCS CL LOOP 2	SI	2		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A ITEM NO. F1.20R		CLASS 1,2, AND 3 COMPONENT SUPPORTS CLASS 2 HANGER - RIGID						
Component	Description	System	Class	Outage	Exam Type	Relief Request		
HANGER SI-H-0130	ACCUM B INJ LINE TO RCS CL LOOP 2	SI	2		VT-3			
HANGER SI-H-0132	ACCUM B INJ LINE TO RCS CL LOOP 2	SI	2		VT-3			
HANGER SI-H-0150	LOW HEAD INJ TO RCS CL FROM RHR PUMP B	SI	2		VT-3			
HANGER SI-H-0155	LOW HEAD INJ TO RCS CL FROM RHR PUMP B	SI	2		VT-3			
HANGER SI-H-0159	SIS LOW HEAD INJ TO RCS HL	SI	2		VT-3			
HANGER SI-H-0160	SIS LOW HEAD INJ TO RCS HL	SI	2		VT-3			
HANGER SI-H-0161	SIS RES HX TO RCS HL LOOP 1	SI	2		VT-3			
HANGER SI-H-0163	SIS RES HX TO RCS HL LOOP 1	SI	2		VT-3			
HANGER SI-H-0166	SIS RES HX TO RCS HL LOOP 1	SI	2	2-3-13	VT-3			
HANGER SI-H-0179	SIS RES HX TO RCS HL LOOP 2	SI	2		VT-3			
HANGER SI-H-0234	SIS LOW HEAD INJ TO RCS CL FROM RHR PUMP A	SI	2		VT-3			
HANGER SI-H-0248	X-CONN BETWEEN LOW HEAD INJ BRANCH LINES	SI	2		VT-3			
HANGER SI-H-0250	X-CONN BETWEEN LOW HEAD INJ BRANCH LINES	SI	2	2-1-08	VT-3			
HANGER SI-H-0253	X-CONN BETWEEN LOW HEAD INJ BRANCH LINES	SI	2		VT-3			
HANGER SI-H-0269	ACCUM TK C INJ LINE TO RCS CL LOOP 3	SI	2		VT-3			
HANGER SI-H-0417	SIS LOW HEAD INJ TO RCS HL	SI	2		VT-3			
HANGER SI-H-0420	SIS LOW HEAD INJ TO RCS HL	SI	2		VT-3			
HANGER SI-H-0882	SIS LOW HEAD INJ TO RCS HL	SI	2		VT-3			
HANGER SI-H-0891	LOW HEAD INJ TO RCS CL FROM RHR PUMP A	SI	2		VT-3			
HANGER SI-H-0980	SIS LOW HEAD INJ TO RCS CL FROM RHR PUMP A	SI	2	2-1-09	VT-3			
HANGER SI-H-0987	ACCUM B INJ LINE TO RCS CL LOOP 2	SI	2		VT-3			
HANGER SI-H-0988	ACCUM B INJ LINE TO RCS CL LOOP 2	SI	2		VT-3			
HANGER SI-H-1030	X-CONN BETWEEN LOW HEAD INJ BRANCH LINES	SI	2		VT-3			
HANGER SI-H-1186	LOW HEAD INJ TO RCS CL FROM RHR PUMP B	SI	2		VT-3			
HANGER SI-H-1200	LOW HEAD INJ TO RCS CL FROM RHR PUMP B	SI	2		VT-3			
HANGER SI-H-1285	RWST OUTLET TO RHR PUMP B	SI	2	2-2-11	VT-3			

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS				
ITEM NO. F1.20S		CLASS 2 HANGER - SNUBBER				
Component	Description	System	Class	Outage	Exam Type	Relief Request
HANGER AF-H-0286	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER AF-H-0296	FROM FP B VALVE AF-64 TO S/G	AF	2	2-1-09	VT-3	
HANGER AF-H-0298	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER AF-H-0299	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER AF-H-0300	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER AF-H-0302	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER AF-H-0303	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER AF-H-0311	FROM FP B VALVE AF-102 TO S/G	AF	2	2-2-11	VT-3	
HANGER AF-H-0312	FROM FP B VALVE AF-102 TO S/G	AF	2		VT-3	
HANGER AF-H-0313	FROM FP B VALVE AF-102 TO S/G	AF	2		VT-3	
HANGER AF-H-0314	FROM FP B VALVE AF-102 TO S/G	AF	2		VT-3	
HANGER AF-H-0317	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER AF-H-0320	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER AF-H-0326	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER AF-H-0327	FROM FP B VALVE AF-64 TO S/G	AF	2	2-1-08	VT-3	
HANGER AF-H-0328	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER AF-H-0333	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER AF-H-0334	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER AF-H-0335	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER AF-H-0336	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER AF-H-0338	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER AF-H-0339	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER AF-H-0362	FROM FP B VALVE AF-102 TO S/G	AF	2	2-1-08	VT-3	
HANGER AF-H-0363	FROM FP B VALVE AF-102 TO S/G	AF	2		VT-3	
HANGER AF-H-0364	FROM FP B VALVE AF-102 TO S/G	AF	2		VT-3	
HANGER AF-H-0365	FROM FP B VALVE AF-102 TO S/G	AF	2		VT-3	
HANGER AF-H-0366	FROM FP B VALVE AF-81 TO S/G	AF	2		VT-3	
HANGER AF-H-0367	FROM FP B VALVE AF-81 TO S/G	AF	2	2-3-13	VT-3	
HANGER AF-H-0368	FROM FP B VALVE AF-81 TO S/G	AF	2		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1

ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO. F1.20S		CLASS 2 HANGER - SNUBBER					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER	AF-H-0369	FROM FP B VALVE AF-81 TO S/G	AF	2		VT-3	
HANGER	AF-H-0390	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER	AF-H-0391	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER	AF-H-0392	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER	AF-H-0393	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER	AF-H-0466	FROM FP B VALVE AF-64 TO S/G	AF	2	2-1-08	VT-3	
HANGER	AF-H-0467	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER	AF-H-0653	FROM FP B VALVE AF-81 TO S/G	AF	2		VT-3	
HANGER	BD-H-0011	S/G C BLDWN TO ISO VALVE BD-49	BD	2		VT-3	
HANGER	BD-H-0015	S/G C BLDWN TO ISO VALVE BD-49	BD	2		VT-3	
HANGER	BD-H-0029	S/G A BLDWN TO ISO VALVE BD-11	BD	2		VT-3	
HANGER	BD-H-0031	S/G A BLDWN TO ISO VALVE BD-11	BD	2	2-1-09	VT-3	
HANGER	BD-H-0073	S/G B BLDWN TO ISO VALVE BD-30	BD	2		VT-3	
HANGER	BD-H-0074	S/G B BLDWN TO ISO VALVE BD-30	BD	2		VT-3	
HANGER	BD-H-0077	S/G B BLDWN TO ISO VALVE BD-30	BD	2		VT-3	
HANGER	BD-H-0080	DNSTRM OF VALVE BD-27	BD	2		VT-3	
HANGER	BD-H-0367	S/G C BLDWN TO ISO VALVE BD-49	BD	2		VT-3	
HANGER	BD-H-0390	S/G A BLDWN TO ISO VALVE BD-11	BD	2		VT-3	
HANGER	BD-H-0591	S/G B BLDWN TO ISO VALVE BD-30	BD	2		VT-3	
HANGER	BD-H-0592	S/G B BLDWN TO ISO VALVE BD-30	BD	2	2-1-08	VT-3	
HANGER	CS-H-0008	RHRS CONN TO CHARGING PUMP SUCTION	CS	2	2-1-09	VT-3	
HANGER	CS-H-0009	RHRS CONN TO CHARGING PUMP SUCTION	CS	2		VT-3	
HANGER	CS-H-0010	RHRS CONN TO CHARGING PUMP SUCTION	CS	2		VT-3	
HANGER	CS-H-0020	FROM HDR TO CHARGING PUMP C SUCTION	CS	2		VT-3	
HANGER	CS-H-0025	RHRS CONN TO CHARGING PUMP SUCTION	CS	2		VT-3	
HANGER	CS-H-0032	RWST CONN TO CHARGING PUMP C SUCTION	CS	2		VT-3	
HANGER	CS-H-0039	FROM HDR TO CHARGING PUMP C SUCTION	CS	2	2-2-10	VT-3	
HANGER	CS-H-0041	FROM HDR TO CHARGING PUMP C SUCTION	CS	2		VT-3	
HANGER	CS-H-0149	CHARGING PUMP C DISCH	CS	2		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.20S	CLASS 2 HANGER - SNUBBER					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER	CS-H-0355	LTDN ORIFICE LINE DNSTRM OF VALVE CS-9	CS	2		VT-3	
HANGER	CS-H-0356	LTDN ORIFICE LINE DNSTRM OF VALVE CS-9	CS	2		VT-3	
HANGER	CS-H-0359	LTDN ORIFICE LINE DNSTRM OF VALVE CS-7	CS	2		VT-3	
HANGER	CS-H-0360	LTDN ORIFICE LINE DNSTRM OF VALVE CS-7	CS	2	2-3-13	VT-3	
HANGER	CS-H-0362	LTDN ORIFICE LINE DNSTRM OF VALVE CS-8	CS	2		VT-3	
HANGER	CS-H-0363	LTDN ORIFICE LINE DNSTRM OF VALVE CS-8	CS	2		VT-3	
HANGER	CS-H-0364	NORM LTDN FROM LTDN ORIFICES TO LTDN HX	CS	2		VT-3	
HANGER	CS-H-0862	FROM HDR TO CHARGING PUMP C SUCTION	CS	2		VT-3	
HANGER	CS-H-2866	RCP C SEAL INJ AT CONT PENE M-11	CS	2		VT-3	
HANGER	CS-H-2868	RCP C SEAL INJ AT CONT PENE M-11	CS	2	2-3-13	VT-3	
HANGER	CS-H-2877	RCP B SEAL INJ AT CONT PENE M-10	CS	2		VT-3	
HANGER	CS-H-2883	RCP B SEAL INJ AT CONT PENE M-10	CS	2		VT-3	
HANGER	CT-H-0203	RWST HDR	CT	2		VT-3	
HANGER	CT-H-0220	PORTION FROM VALVE CT-26 TO CT PUMP A SUCTION	CT	2		VT-3	
HANGER	CT-H-0235	PART OF LINE FROM CONT SUMP TO VALVE CT-105	CT	2	2-1-09	VT-3	
HANGER	CT-H-0235C	PART OF LINE FROM CONT SUMP TO VALVE CT-105	CT		2-1-09	VT-3	
HANGER	CT-H-0236	PART OF LINE FROM CONT SUMP TO VALVE CT-105	CT	2		VT-3	
HANGER	CT-H-0273	SFP PUMP SUCTION FROM RWST OUTLET - AUGMENTED	CT	2		VT-3	
HANGER	CT-H-0290	FROM CONT SUMP (PENE M-50) TO VALVE CT-102	CT	2		VT-3	
HANGER	CT-H-0290C	FROM CONT SUMP (PENE M-50) TO VALVE CT-102	CT	2		VT-3	
HANGER	CT-H-0291	FROM CONT SUMP (PENE M-50) TO VALVE CT-102	CT	2		VT-3	
HANGER	CT-H-0301	LINE TO SIS RHR PUMP	CT	2	2-1-08	VT-3	
HANGER	CT-H-0323	PUMP B DISCH TO CONT SPRAY RING HDR	CT	2		VT-3	
HANGER	CT-H-0354	PUMP A DISCH TO CONT SPRAY RING HDR	CT	2		VT-3	
HANGER	CT-H-0865	FROM VALVE CT-26 TO CT PUMP A SUCTION	CT	2		VT-3	
HANGER	FW-H-0098	FROM VALVE FW-217	FW	2	2-2-11	VT-3	
HANGER	FW-H-0101	FROM PENE M-4 TO S/G A	FW	2		VT-3	
HANGER	FW-H-0103	FROM PENE M-4 TO S/G A	FW	2		VT-3	
HANGER	FW-H-0105	FROM PENE M-4 TO S/G A	FW	2		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.20S	CLASS 2 HANGER - SNUBBER					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER	FW-H-0106	FROM PENE M-4 TO S/G A	FW	2		VT-3	
HANGER	FW-H-0108	FROM PENE M-4 TO S/G A	FW	2		VT-3	
HANGER	FW-H-0110	FROM PENE M-4 TO S/G A	FW	2		VT-3	
HANGER	FW-H-0113	FROM PENE M-5 TO S/G B	FW	2	1-2-04	VT-3	
HANGER	FW-H-0118	FROM PENE M-6 TO S/G C	FW	2	2-1-09	VT-3	
HANGER	FW-H-0120	FROM PENE M-6 TO S/G C	FW	2		VT-3	
HANGER	FW-H-0122	FROM PENE M-6 TO S/G C	FW	2		VT-3	
HANGER	FW-H-0125	FROM PENE M-6 TO S/G C	FW	2		VT-3	
HANGER	FW-H-0126	FROM PENE M-6 TO S/G C	FW	2		VT-3	
HANGER	FW-H-0129	FROM PENE M-6 TO S/G C	FW	2		VT-3	
HANGER	FW-H-0156	DNSTRM OF VALVE FW-276 TO PENE M-5	FW	2		VT-3	
HANGER	FW-H-0184	LINE FROM VALVE FW-159 TO PENE M-4	FW	2	2-2-10	VT-3	
HANGER	FW-H-0189	FROM PENE M-5 TO S/G B	FW	2		VT-3	
HANGER	FW-H-0190	FROM PENE M-5 TO S/G B	FW	2		VT-3	
HANGER	FW-H-0191	FROM PENE M-5 TO S/G B	FW	2		VT-3	
HANGER	FW-H-0208	FROM PENE M-4 TO S/G A	FW	2		VT-3	
HANGER	FW-H-0211	FROM PENE M-4 TO S/G A	FW	2		VT-3	
HANGER	FW-H-0212	FROM PENE M-4 TO S/G A	FW	2		VT-3	
HANGER	FW-H-0213	FROM PENE M-4 TO S/G A	FW	2	2-3-13	VT-3	
HANGER	FW-H-0215	FROM PENE M-6 TO S/G C	FW	2		VT-3	
HANGER	FW-H-0218	FROM PENE M-6 TO S/G C	FW	2		VT-3	
HANGER	FW-H-0219	FROM PENE M-6 TO S/G C	FW	2		VT-3	
HANGER	FW-H-0220	FROM PENE M-6 TO S/G C	FW	2		VT-3	
HANGER	FW-H-0221	FROM PENE M-6 TO S/G C	FW	2		VT-3	
HANGER	FW-H-0222	FROM PENE M-5 TO S/G B	FW	2		VT-3	
HANGER	FW-H-0515	FROM VALVE FW-159 TO PENE M-4	FW	2	2-2-11	VT-3	
HANGER	FW-H-0518	FROM VALVE FW-277 TO PENE M-5	FW	2		VT-3	
HANGER	FW-H-0521	FROM VALVE FW-217 TO PENE M-6	FW	2		VT-3	
HANGER	MS-H-0003	S/G A OUTLET TO PENE M-3	MS	2		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.20S	CLASS 2 HANGER - SNUBBER					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER	MS-H-0004	S/G A OUTLET TO PENE M-3	MS	2		VT-3	
HANGER	MS-H-0006	S/G A OUTLET TO PENE M-3	MS	2		VT-3	
HANGER	MS-H-0007	S/G A OUTLET TO PENE M-3	MS	2		VT-3	
HANGER	MS-H-0008	S/G A OUTLET TO PENE M-3	MS	2		VT-3	
HANGER	MS-H-0010	S/G A OUTLET TO PENE M-3	MS	2		VT-3	
HANGER	MS-H-0012	S/G A OUTLET TO PENE M-3	MS	2		VT-3	
HANGER	MS-H-0014	S/G A OUTLET TO PENE M-3	MS	2		VT-3	
HANGER	MS-H-0015	S/G A OUTLET TO PENE M-3	MS	2		VT-3	
HANGER	MS-H-0016	S/G A OUTLET TO PENE M-3	MS	2		VT-3	
HANGER	MS-H-0020	S/G A OUTLET TO PENE M-3	MS	2		VT-3	
HANGER	MS-H-0023	S/G C OUTLET TO PENE M-1	MS	2		VT-3	
HANGER	MS-H-0024	S/G C OUTLET TO PENE M-1	MS	2		VT-3	
HANGER	MS-H-0026	S/G C OUTLET TO PENE M-1	MS	2		VT-3	
HANGER	MS-H-0027	S/G C OUTLET TO PENE M-1	MS	2		VT-3	
HANGER	MS-H-0028	S/G C OUTLET TO PENE M-1	MS	2		VT-3	
HANGER	MS-H-0030	S/G C OUTLET TO PENE M-1	MS	2		VT-3	
HANGER	MS-H-0032	S/G C OUTLET TO PENE M-1	MS	2		VT-3	
HANGER	MS-H-0076	S/G A OUTLET CONN UPSTRM OF VALVE MS-58	MS	2		VT-3	
HANGER	MS-H-0084	S/G B OUTLET CONN UPSTRM OF VALVE MS-60	MS	2		VT-3	
HANGER	MS-H-0092	S/G C OUTLET CONN UPSTRM OF VALVE MS-62	MS	2		VT-3	
HANGER	RH-H-0011	RHR HX B OUTLET FOR VALVE RH-66	RH	2	2-3-13	VT-3	
HANGER	RH-H-0033	RHR PUMP A DISCH TO RHR HX A	RH	2		VT-3	
HANGER	RH-H-0038	RCS LOOP 1 HL TO RHR PUMP SUCTION	RH	2		VT-3	
HANGER	RH-H-0042	RCS LOOP 3 HL TO RHR PUMP SUCTION	RH	2		VT-3	
HANGER	RH-H-0063	RCS PUMP B DISCH TO RHR HX B	RH	2		VT-3	
HANGER	RH-H-0067	RHR HX A OUTLET	RH	2	2-1-09	VT-3	
HANGER	RH-H-0072	RHR HX A OUTLET	RH	2		VT-3	
HANGER	RH-H-0158	RHR PUMP B DISCH TO RHR HX B	RH	2		VT-3	
HANGER	RH-H-0165	RHR HX A OUTLET	RH	2		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS						
ITEM NO. F1.20S		CLASS 2 HANGER - SNUBBER						
Component		Description	System	Class	Outage	Exam Type	Relief Request	
HANGER	RH-H-0166	RHR HX A OUTLET	RH	2	2-1-08	VT-3		
HANGER	RH-H-0167	RHR PUMP A DISCH TO RHR HX A	RH	2		VT-3		
HANGER	RH-H-0168	RHR PUMP A DISCH TO RHR HX A	RH	2		VT-3		
HANGER	RH-H-0169	RHR PUMP A DISCH TO RHR HX A	RH	2		VT-3		
HANGER	RH-H-0176	RHR HX A OUTLET	RH	2		VT-3		
HANGER	RH-H-0188	RHR PUMP A DISCH TO RHR HX A	RH	2		VT-3		
HANGER	RH-H-0189	RHR PUMP B DISCH TO RHR HX B	RH	2		VT-3		
HANGER	RH-H-0265	LOW HEAD INJ TO RCS CL FROM RHR PUMP B	RH	2	2-2-10	VT-3		
HANGER	RH-H-0275	RHR HX A OUTLET	RH	2		VT-3		
HANGER	RH-H-0290	RHR PUMP B DISCH TO RHR HX B	RH	2		VT-3		
HANGER	RH-H-0297	RHR HX B OUTLET	RH	2		VT-3		
HANGER	RH-H-0300	RHR HX B DISCH BY-PASS	RH	2		VT-3		
HANGER	RH-H-0301	RHR PUMP B DISCH TO RHR HX B	RH	2		VT-3		
HANGER	RH-H-0302	RHR PUMP B DISCH TO RHR HX B	RH	2		VT-3		
HANGER	RH-H-0303	RHR HX B OUTLET	RH	2		VT-3		
HANGER	RH-H-0314	LOW HEAD INJ TO RCS CL FROM RHR PUMP B	RH	2	2-2-10	VT-3		
HANGER	RH-H-0316	LOW HEAD INJ TO RCS CL FROM RHR PUMP B	RH	2		VT-3		
HANGER	RH-H-0353	RHR HX A OUTLET	RH	2		VT-3		
HANGER	SG-H-305B	PAUL MUNROE/ENERTECH HYDRAULIC SNUBBER - 14" BORE UNI	MS	2		VT-3		
HANGER	SG-H-306A	PAUL MUNROE/ENERTECH HYDRAULIC SNUBBER - 14" BORE UNI	MS	2		VT-3		
HANGER	SG-H-307C	PAUL MUNROE/ENERTECH HYDRAULIC SNUBBER - 14" BORE UNI	MS	2		VT-3		
HANGER	SG-H-308A	PAUL MUNROE/ENERTECH HYDRAULIC SNUBBER - 14" BORE UNI	MS	2		VT-3		
HANGER	SG-H-309B	PAUL MUNROE/ENERTECH HYDRAULIC SNUBBER - 14" BORE UNI	MS	2		VT-3		
HANGER	SG-H-310C	PAUL MUNROE/ENERTECH HYDRAULIC SNUBBER - 14" BORE UNI	MS	2		VT-3		
HANGER	SG-H-312B	PAUL MUNROE/ENERTECH HYDRAULIC SNUBBER - 14" BORE UNI	MS	2		VT-3		
HANGER	SG-H-313B	PAUL MUNROE/ENERTECH HYDRAULIC SNUBBER - 14" BORE UNI	MS	2		VT-3		
HANGER	SG-H-314C	PAUL MUNROE/ENERTECH HYDRAULIC SNUBBER - 14" BORE UNI	MS	2		VT-3		
HANGER	SG-H-323A	PAUL MUNROE/ENERTECH HYDRAULIC SNUBBER - 14" BORE UNI	MS	2		VT-3		
HANGER	SG-H-325C	PAUL MUNROE/ENERTECH HYDRAULIC SNUBBER - 14" BORE UNI	MS	2		VT-3		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.20S	CLASS 2 HANGER - SNUBBER					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER	SG-H-326A	PAUL MUNROE/ENERTECH HYDRAULIC SNUBBER - 14" BORE UNI	MS	2		VT-3	
HANGER	SI-H-0001	LOW HEAD INJ TO RCS CL FROM RHR PUMP B	SI	2		VT-3	
HANGER	SI-H-0005	LOW HEAD INJ TO RCS CL FROM RHR PUMP B	SI	2	2-2-10	VT-3	
HANGER	SI-H-0009	LOW HEAD INJ TO RCS CL FROM RHR PUMP B	SI	2		VT-3	
HANGER	SI-H-0011	LOW HEAD INJ X-CONN TO RCS HL FROM RHR PUMP B	SI	2		VT-3	
HANGER	SI-H-0020	LOW HEAD INJ TO RCS CL FROM RHR PUMP A	SI	2		VT-3	
HANGER	SI-H-0021	LOW HEAD INJ TO RCS CL FROM RHR PUMP A	SI	2		VT-3	
HANGER	SI-H-0023	LOW HEAD INJ TO RCS CL FROM RHR PUMP A	SI	2		VT-3	
HANGER	SI-H-0026	SIS LOW HEAD INJ TO RCS HL	SI	2	2-3-12	VT-3	
HANGER	SI-H-0028	SUCTION LINE TO RHR PUMP A FROM CONT SUMP A	SI	2		VT-3	
HANGER	SI-H-0030	SUCTION LINE TO RHR PUMP A FROM CONT SUMP A	SI	2		VT-3	
HANGER	SI-H-0032	SUCTION LINE TO RHR PUMP A FROM CONT SUMP A	SI	2		VT-3	
HANGER	SI-H-0058	LOW HEAD INJ TO RCS CL FROM RHR PUMP A	SI	2		VT-3	
HANGER	SI-H-0060	LOW HEAD INJ TO RCS CL FROM RHR PUMP A	SI	2		VT-3	
HANGER	SI-H-0114	ACCUM A INJ LINE TO RCS CL LOOP 1	SI	2	2-1-08	VT-3	
HANGER	SI-H-0116	ACCUM A INJ LINE TO RCS CL LOOP 1	SI	2		VT-3	
HANGER	SI-H-0131	ACCUM B INJ LINE TO RCS CL LOOP 2	SI	2		VT-3	
HANGER	SI-H-0151	LOW HEAD INJ TO RCS CL FROM RHR PUMP B	SI	2		VT-3	
HANGER	SI-H-0156	LOW HEAD INJ TO RCS CL FROM RHR PUMP B	SI	2		VT-3	
HANGER	SI-H-0162	SIS RES HX TO RCS HL LOOP 1	SI	2		VT-3	
HANGER	SI-H-0164	SIS RES HX TO RCS HL LOOP 1	SI	2		VT-3	
HANGER	SI-H-0167	SIS RES HX TO RCS HL LOOP 1	SI	2	2-3-13	VT-3	
HANGER	SI-H-0180	SIS RES HX TO RCS HL LOOP 2	SI	2		VT-3	
HANGER	SI-H-0181	SIS RES HX TO RCS HL LOOP 2	SI	2		VT-3	
HANGER	SI-H-0235	SIS LOW HEAD INJ TO RCS CL FROM RHR PUMP A	SI	2		VT-3	
HANGER	SI-H-0236	SIS LOW HEAD INJ TO RCS CL FROM RHR PUMP A	SI	2		VT-3	
HANGER	SI-H-0237	SIS LOW HEAD INJ TO RCS CL FROM RHR PUMP A	SI	2		VT-3	
HANGER	SI-H-0238	SIS LOW HEAD INJ TO RCS CL FROM RHR PUMP A	SI	2		VT-3	
HANGER	SI-H-0251	X-CONN BETWEEN LOW HEAD INJ BRANCH LINES	SI	2	2-2-10	VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS				
ITEM NO. F1.20S		CLASS 2 HANGER - SNUBBER				
Component		Description	System	Class	Outage	Exam Type
HANGER SI-H-0254		X-CONN BETWEEN LOW HEAD INJ BRANCH LINES	SI	2		VT-3
HANGER SI-H-0256		X-CONN BETWEEN LOW HEAD INJ BRANCH LINES	SI	2		VT-3
HANGER SI-H-0267		LOW HEAD INJ TO RCS CL FROM RHR PUMP B	SI	2		VT-3
HANGER SI-H-0268		LOW HEAD INJ TO RCS CL FROM RHR PUMP B	SI	2		VT-3
HANGER SI-H-0270		ACCUM TK C INJ LINE TO RCS CL LOOP 3	SI	2	2-3-13	VT-3
HANGER SI-H-0272		ACCUM TK C INJ LINE TO RCS CL LOOP 3	SI	2		VT-3
HANGER SI-H-0273		ACCUM TK C INJ LINE TO RCS CL LOOP 3	SI	2		VT-3
HANGER SI-H-0419		SIS LOW HEAD INJ TO RCS HL	SI	2		VT-3
HANGER SI-H-0981		X-CONN BETWEEN LOW HEAD INJ BRANCH LINES	SI	2		VT-3
HANGER SI-H-1032		LOW HEAD INJ TO RCS CL FROM RHR PUMP B	SI	2		VT-3
HANGER SI-H-1035		LOW HEAD INJ TO RCS CL FROM RHR PUMP B	SI	2	2-2-10	VT-3
HANGER SI-H-1104		SIS LOW HEAD INJ TO RCS HL	SI	2		VT-3
HANGER SI-H-1182		LOW HEAD INJ TO RCS CL FROM RHR PUMP A	SI	2		VT-3
HANGER SI-H-1184		LOW HEAD INJ TO RCS CL FROM RHR PUMP B	SI	2		VT-3
HANGER SI-H-1185		LOW HEAD INJ TO RCS CL FROM RHR PUMP B	SI	2		VT-3
HANGER SI-H-1191		SIS LOW HEAD INJ TO RCS CL FROM RHR PUMP A	SI	2		VT-3
HANGER SI-H-1192		X-CONN BETWEEN LOW HEAD INJ BRANCH LINES	SI	2	2-2-11	VT-3
HANGER SI-H-1199		LOW HEAD INJ TO RCS CL FROM RHR PUMP B	SI	2		VT-3
HANGER SI-H-1282		SUCTION LINE TO RHR PUMP B FROM CONT SUMP B	SI	2		VT-3
HANGER SI-H-1571		RWST OUTLET TO RHR PUMP B	SI	2		VT-3
HANGER SI-H-1574		ACCUM B INJ LINE TO RCS CL LOOP 2	SI	2		VT-3

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO. F1.20V		CLASS 2 HANGER - VARIABLE (SPRING CAN)					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER	AF-H-0301	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER	AF-H-0305	FROM FP B VALVE AF-102 TO S/G	AF	2		VT-3	
HANGER	AF-H-0315	FROM FP B VALVE AF-102 TO S/G	AF	2		VT-3	
HANGER	AF-H-0337	FROM FP B VALVE AF-64 TO S/G	AF	2		VT-3	
HANGER	AF-H-0443	FROM FP B VALVE AF-81 TO S/G	AF	2	2-1-08	VT-3	
HANGER	CT-H-0091	PUMP A DISCH TO SPRAY RING HDR	CT	2	2-1-09	VT-3	
HANGER	CT-H-0102	PUMP B DISCH TO SPRAY RING HDR	CT	2		VT-3	
HANGER	CT-H-0234	PORTION FROM VALVE CT-26 TO CT PUMP A SUCTION	CT	2		VT-3	
HANGER	CT-H-0238	PART OF LINE FROM CONT SUMP TO VALVE CT-105	CT	2		VT-3	
HANGER	CT-H-0248	CVCS CHARGING PUMPS CONN	CT	2		VT-3	
HANGER	CT-H-0272	INLET TO CT PUMP B SUCTION	CT	2		VT-3	
HANGER	CT-H-0274	INLET TO CT PUMP B SUCTION	CT	2		VT-3	
HANGER	CT-H-0279	INLET TO CT PUMP B SUCTION	CT	2		VT-3	
HANGER	CT-H-0293	FROM CONT SUMP (PENE M-50) TO VALVE CT-102	CT	2	2-2-10	VT-3	
HANGER	CT-H-0330	PUMP A DISCH TO CONT SPRAY RING HDR	CT	2		VT-3	
HANGER	CT-H-0336	PUMP A DISCH TO CONT SPRAY RING HDR	CT	2		VT-3	
HANGER	FW-H-0100	FROM PENE M-4 TO S/G A	FW	2		VT-3	
HANGER	FW-H-0117	FROM PENE M-6 TO S/G C	FW	2	2-1-09	VT-3	
HANGER	FW-H-0210	FROM PENE M-4 TO S/G A	FW	2		VT-3	
HANGER	FW-H-0217	FROM PENE M-6 TO S/G C	FW	2		VT-3	
HANGER	FW-H-0223	FROM PENE M-5 TO S/G B	FW	2		VT-3	
HANGER	FW-H-0513	FROM VALVE FW-159 TO PENE M-4	FW	2		VT-3	
HANGER	FW-H-0516	FROM VALVE FW-277 TO PENE M-5	FW	2	2-1-09	VT-3	
HANGER	FW-H-0519	FROM VALVE FW-217 TO PENE M-6	FW	2		VT-3	
HANGER	MS-H-0005	S/G A OUTLET TO PENE M-3	MS	2		VT-3	
HANGER	MS-H-0018	S/G A OUTLET TO PENE M-3	MS	2		VT-3	
HANGER	MS-H-0025	S/G C OUTLET TO PENE M-1	MS	2		VT-3	
HANGER	MS-H-0061	S/G A OUTLET TO PENE M-3	MS	2		VT-3	
HANGER	MS-H-0062	S/G C OUTLET TO PENE M-1	MS	2		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.20V	CLASS 2 HANGER - VARIABLE (SPRING CAN)					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER	MS-H-0078	S/G A OUTLET CONN UPSTRM OF VALVE MS-58	MS	2		VT-3	
HANGER	MS-H-0086	S/G B OUTLET CONN UPSTRM OF VALVE MS-60	MS	2		VT-3	
HANGER	MS-H-0094	S/G C OUTLET CONN UPSTRM OF VALVE MS-62	MS	2		VT-3	
HANGER	RH-H-0010	RHR HX B OUTLET FOR VALVE RH-66	RH	2	2-3-13	VT-3	
HANGER	RH-H-0014	RCS LOOP 1 HL TO RHR PUMP SUCTION	RH	2		VT-3	
HANGER	RH-H-0062	RCS LOOP 3 HL TO RHR PUMP SUCTION	RH	2		VT-3	
HANGER	RH-H-0103	RHR HX B OUTLET	RH	2		VT-3	
HANGER	RH-H-0126	RCS LOOP 1 HL TO RHR PUMP SUCTION	RH	2		VT-3	
HANGER	RH-H-0160	RHR HX B DISCH BY-PASS FOR VALVE RH-58	RH	2		VT-3	
HANGER	RH-H-0183	RHR HX A OUTLET	RH	2		VT-3	
HANGER	RH-H-0272	RHR PUMP A DISCH TO RHR HX A	RH	2		VT-3	
HANGER	RH-H-0349	RCS LOOP 3 HL TO RHR PUMP SUCTION	RH	2	2-3-13	VT-3	
HANGER	SI-H-0002	LOW HEAD INJ TO RCS CL FROM RHR PUMP B	SI	2		VT-3	
HANGER	SI-H-0022	LOW HEAD INJ TO RCS CL FROM RHR PUMP A	SI	2	2-3-13	VT-3	
HANGER	SI-H-0033	SUCTION LINE TO RHR PUMP A FROM CONT SUMP A	SI	2		VT-3	
HANGER	SI-H-0035	SUCTION LINE TO RHR PUMP B FROM CONT SUMP B	SI	2		VT-3	
HANGER	SI-H-0158	LOW HEAD INJ TO RCS CL FROM RHR PUMP B	SI	2		VT-3	
HANGER	SI-H-1105	SIS LOW HEAD INJ TO RCS HL	SI	2		VT-3	
HANGER	SI-H-1190	LOW HEAD INJ TO RCS CL FROM RHR PUMP A	SI	2		VT-3	
HANGER	SI-H-1196	LOW HEAD INJ TO RCS CL FROM RHR PUMP B	SI	2		VT-3	
HANGER	SI-H-1283	SUCTION LINE TO RHR PUMP B FROM CONT SUMP B	SI	2		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS						
ITEM NO. F1.30A		CLASS 3 HANGER - ANCHOR						
Component		Description	System	Class	Outage	Exam Type	Relief Request	
HANGER AF-H-0082		AFW PUMPS RECIRC HDR TO CST	AF	3		VT-3		
HANGER AF-H-0190		AFW PUMPS A&B DISCH TO VALVE AF-73	AF	3		VT-3		
HANGER AF-H-0204		AFW PUMP A OUTLET TO DISCH HDR	AF	3		VT-3		
HANGER AF-H-0228		DNSTRM OF VALVE AF-42	AF	3		VT-3		
HANGER AF-H-0246		AFW PUMP 1X-SAB DISCH TO VALVE AF-148	AF	3		VT-3		
HANGER AF-H-0266		AFW PUMP 1X-SAB DISCH TO VALVE AF-136	AF	3		VT-3		
HANGER AF-H-0270		AFW PUMP 1X-SAB DISCH TO VALVE AF-142	AF	3		VT-3		
HANGER AF-H-0406		AFW PUMP 1X-SAB DISCH TO CST	AF	3		VT-3		
HANGER CC-H-0114		BETWEEN VALVE CC-99 AND LINE 3CC20-11SN	CC	3		VT-3		
HANGER CC-H-0289		CCW HDR TO RCP	CC	3		VT-3		
HANGER CC-H-0313		FP HX 1&4A-SA OUTLET	CC	3		VT-3		
HANGER CC-H-0330		RETURN HDR FROM HXs	CC	3		VT-3		
HANGER CC-H-0367		HDR TO CCS SFP HX UNIT 4	CC	3		VT-3		
HANGER CC-H-0416		HDR TO CCS SFP HX UNIT 4	CC	3		VT-3		
HANGER CC-H-0438		TO RETURN HDR FROM RCDT HX & EX LTDN HX	CC	3		VT-3		
HANGER CC-H-0473		RETURN HDR TO CC PUMP A SUCTION	CC	3		VT-3		
HANGER CC-H-0483		PUMP A SUCTION CONN TO CC PUMP C SUCTION	CC	3	2-3-13	VT-3		
HANGER CE-H-0025		COND FROM CST TO AF PUMPS SUCTION	CE	3	2-2-10	VT-3		
HANGER CH-H-1467		ESSENTIAL SERVICE CH FOR MAIN	CH	3	2-2-10	VT-3		
HANGER CH-H-1581		ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3		
HANGER CH-H-1734		ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3		
HANGER CX-H-0361		ESSENTIAL SER CX FOR PUMP SUCTION	CX	3	2-2-10	VT-3		
HANGER CX-H-1741		ESSENTIAL SER CX FOR MAIN	CX	3		VT-3		
HANGER CX-H-1808		ESSENTIAL SER CX FOR MAIN	CX	3		VT-3		
HANGER SW-H-0042		SW BOOSTER PUMP A BY-PASS	SW	3		VT-3		
HANGER SW-H-0440		SW SUPPLY HDR A	SW	3		VT-3		
HANGER SW-H-0492		SW BOOSTER PUMP B BY-PASS	SW	3		VT-3		
HANGER SW-H-0493		SW BOOSTER PUMP B BY-PASS	SW	3		VT-3		
HANGER SW-H-0558		SW FROM RETURN HDR B TO CIRC WATER DISCH	SW	3		VT-3		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1

ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A ITEM NO. F1.30A		CLASS 1,2, AND 3 COMPONENT SUPPORTS CLASS 3 HANGER - ANCHOR					
Component	Description	System	Class	Outage	Exam Type	Relief Request	
HANGER SW-H-1227	TO AFW PUMP A SUCTION	SW	3	2-2-10	VT-3		
HANGER SW-H-1236	TO RAB HVAC CHILLER A	SW	3		VT-3		
HANGER SW-H-1242	TO RAB HVAC CHILLER A	SW	3		VT-3		
HANGER SW-H-1243	SW TO AFW PUMPS BACK-UP LINES	SW	3		VT-3		
HANGER SW-H-1258	FROM SW SUPPLY HDR TO AFW PUMP 1X BACK-UP LINE	SW	3		VT-3		
HANGER SW-H-1289	FROM SW SUPPLY HDR B TO CCW HX B	SW	3	2-2-10	VT-3		
HANGER SW-H-1451	FROM RAB HVAC CHILLER A TO RETURN HDR A	SW	3		VT-3		
HANGER SW-H-1502	FROM RAB HVAC CHILLER B TO RETURN HDR B	SW	3		VT-3		
HANGER SW-H-1872	TO RAB HVAC CHILLER B	SW	3		VT-3		
HANGER SW-H-2667	SW SUPPLY HDR B FROM SW PUMP DISCH	SW	3		VT-3		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO. F1.30B		CLASS 3 HANGER - BOX					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER	AF-H-0002	AFW PUMPS A & B DISCH TO VALVE AF-92	AF	3	2-1-08	VT-3	
HANGER	AF-H-0004	TO VALVE AF-54	AF	3		VT-3	
HANGER	AF-H-0006	TO VALVE AF-54	AF	3		VT-3	
HANGER	AF-H-0014	AFW PUMP 1X-SAB DISCH TO VALVE AF-136	AF	3		VT-3	
HANGER	AF-H-0016	TO VALVE AF-136	AF	3		VT-3	
HANGER	AF-H-0018	TO VALVE AF-136	AF	3		VT-3	
HANGER	AF-H-0023	AFW PUMP A OUTLET TO DISCH HEADER	AF	3		VT-3	
HANGER	AF-H-0025	AFW PUMP 1X-SAB DISCH TO VALVE AF-136	AF	3		VT-3	
HANGER	AF-H-0030	AFW PUMPS A & B DISCH TO VALVE AF-92	AF	3	2-2-10	VT-3	
HANGER	AF-H-0032	AFW PUMPS A & B DISCH TO VALVE AF-92	AF	3		VT-3	
HANGER	AF-H-0034	TO VALVE AF-92	AF	3		VT-3	
HANGER	AF-H-0036	TO VALVE AF-92	AF	3		VT-3	
HANGER	AF-H-0044	AFW PUMP 1X-SAB DISCH TO VALVE AF-142	AF	3		VT-3	
HANGER	AF-H-0046	TO VALVE AF-142	AF	3		VT-3	
HANGER	AF-H-0048	TO VALVE AF-142	AF	3		VT-3	
HANGER	AF-H-0049	TO VALVE AF-142	AF	3		VT-3	
HANGER	AF-H-0053	AFW PUMP 1X-SAB DISCH TO VALVE AF-142	AF	3	2-3-13	VT-3	
HANGER	AF-H-0058	AFW PUMP 1X-SAB DISCH TO VALVE AF-148	AF	3		VT-3	
HANGER	AF-H-0061	AFW PUMPS A & B DISCH TO VALVE AF-73	AF	3		VT-3	
HANGER	AF-H-0063	AFW PUMPS A & B DISCH TO VALVE AF-73	AF	3		VT-3	
HANGER	AF-H-0065	TO VALVE AF-73	AF	3		VT-3	
HANGER	AF-H-0072	AFW PUMPS A & B DISCH TO VALVE AF-148	AF	3		VT-3	
HANGER	AF-H-0074	TO VALVE AF-148	AF	3		VT-3	
HANGER	AF-H-0076	TO VALVE AF-148	AF	3		VT-3	
HANGER	AF-H-0081	AFW PUMPS A&B DISCH TO VALVE AF-73	AF	3	2-3-13	VT-3	
HANGER	AF-H-0087	AFW PUMPS RECIRC HDR TO CST	AF	3		VT-3	
HANGER	AF-H-0092	AFW PUMPS RECIRC HDR TO CST	AF	3		VT-3	
HANGER	AF-H-0097	AFW PUMPS RECIRC HDR TO CST	AF	3		VT-3	
HANGER	AF-H-0099	AFW PUMPS RECIRC HDR TO CST	AF	3		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.30B	CLASS 3 HANGER - BOX					
Component	Description	System	Class	Outage	Exam Type	Relief Request	
HANGER AF-H-0109	AFW PUMPS RECIRC HDR TO CST	AF	3		VT-3		
HANGER AF-H-0121	AFW PUMP A OUTLET TO DISCH HDR	AF	3		VT-3		
HANGER AF-H-0136	AFW PUMP B OUTLET TO DISCH HDR	AF	3		VT-3		
HANGER AF-H-0151	AFW PUMP 1X-SAB RECIRC TO CST	AF	3	2-3-13	VT-3		
HANGER AF-H-0198	AFW PUMPS A&B DISCH TO VALVE AF-73	AF	3		VT-3		
HANGER AF-H-0209	AFW PUMP A OUTLET TO DISCH HDR	AF	3		VT-3		
HANGER AF-H-0214	AFW PUMP A OUTLET TO DISCH HDR	AF	3		VT-3		
HANGER AF-H-0216	AFW PUMP A OUTLET TO DISCH HDR	AF	3		VT-3		
HANGER AF-H-0220	DNSTRM OF VALVE AF-42	AF	3		VT-3		
HANGER AF-H-0222	DNSTRM OF VALVE AF-42	AF	3		VT-3		
HANGER AF-H-0254	AFW PUMP 1X-SAB DISCH TO VALVE AF-136	AF	3		VT-3		
HANGER AF-H-0269	AFW PUMP 1X-SAB DISCH HDR	AF	3		VT-3		
HANGER AF-H-0275	AFW PUMP 1X-SAB DISCH TO VALVE AF-142	AF	3		VT-3		
HANGER AF-H-0407	TO VALVE AF-54	AF	3		VT-3		
HANGER CC-H-0095	BETWEEN VALVE CC-99 AND LINE 3CC20-11SN	CC	3	2-3-13	VT-3		
HANGER CC-H-0102	UPSTREAM OF VALVE CC-259	CC	3		VT-3		
HANGER CC-H-0105	RHR HX A INLET	CC	3		VT-3		
HANGER CC-H-0107	RHR HX A INLET	CC	3		VT-3		
HANGER CC-H-0290	CCW HDR TO RCP	CC	3		VT-3		
HANGER CC-H-0292	CCW HDR TO RCP	CC	3		VT-3		
HANGER CC-H-0295	RCP A SUCTION LINE	CC	3		VT-3		
HANGER CC-H-0297	RCP A SUCTION LINE	CC	3		VT-3		
HANGER CC-H-0299	RCP A SUCTION LINE	CC	3		VT-3		
HANGER CC-H-0301	RCP A SUCTION LINE	CC	3		VT-3		
HANGER CC-H-0304	HDR CONN TO EX LTDN HX & RCDT HX	CC	3	2-2-11	VT-3		
HANGER CC-H-0306	HDR CONN TO EX LTDN HX & RCDT HX	CC	3		VT-3		
HANGER CC-H-0308	HDR CONN TO EX LTDN HX & RCDT HX	CC	3		VT-3		
HANGER CC-H-0328	RETURN HDR FROM HXs	CC	3		VT-3		
HANGER CC-H-0340	HDR TO HXs	CC	3		VT-3		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.30B	CLASS 3 HANGER - BOX					
Component	Description	System	Class	Outage	Exam Type	Relief Request	
HANGER CC-H-0342	HDR TO HXs	CC	3		VT-3		
HANGER CC-H-0344	HDR TO HXs	CC	3		VT-3		
HANGER CC-H-0354	HDR TO HXs	CC	3		VT-3		
HANGER CC-H-0355	HDR TO HXs	CC	3	2-1-09	VT-3		
HANGER CC-H-0359	HDR TO HXs	CC	3		VT-3		
HANGER CC-H-0361	HDR TO HXs	CC	3		VT-3		
HANGER CC-H-0363	HDR TO HXs	CC	3		VT-3		
HANGER CC-H-0365	HDR TO HXs	CC	3		VT-3		
HANGER CC-H-0371	CCW HDR TO RCP	CC	3		VT-3		
HANGER CC-H-0372	CCW HDR TO RCP	CC	3		VT-3		
HANGER CC-H-0379	CCW HX B OUTLET	CC	3		VT-3		
HANGER CC-H-0381	UPSTRM OF VALVE CC-156	CC	3		VT-3		
HANGER CC-H-0388	UPSTRM OF VALVE CC-156	CC	3		VT-3		
HANGER CC-H-0394	UPSTRM OF VALVE CC-156	CC	3	2-3-13	VT-3		
HANGER CC-H-0397	RHR HX B INLET	CC	3		VT-3		
HANGER CC-H-0399	RHR HX B INLET	CC	3		VT-3		
HANGER CC-H-0402	RHR HX B INLET	CC	3		VT-3		
HANGER CC-H-0407	HDR TO CCS SFP HX UNIT 4	CC	3		VT-3		
HANGER CC-H-0409	HDR TO CCS SFP HX UNIT 4	CC	3		VT-3		
HANGER CC-H-0414	HDR TO CCS SFP HX UNIT 4	CC	3		VT-3		
HANGER CC-H-0429	DNSTRM OF VALVE CC-202 TO RETURN HDR	CC	3		VT-3		
HANGER CC-H-0431	DNSTRM OF VALVE CC-202 TO RETURN HDR	CC	3		VT-3		
HANGER CC-H-0436	TO RETURN HDR FROM RCDT HX & EX LTDN HX	CC	3		VT-3		
HANGER CC-H-0439	TO RETURN HDR FROM RCDT HX & EX LTDN HX	CC	3		VT-3		
HANGER CC-H-0441	TO RETURN HDR FROM RCDT HX & EX LTDN HX	CC	3		VT-3		
HANGER CC-H-0446	HDR TO HXs	CC	3	2-3-13	VT-3		
HANGER CC-H-0448	HDR TO HXs	CC	3		VT-3		
HANGER CC-H-0450	HDR TO HXs	CC	3		VT-3		
HANGER CC-H-0452	HDR TO HXs	CC	3		VT-3		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.30B	CLASS 3 HANGER - BOX					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER	CC-H-0454	HDR TO HXs	CC	3		VT-3	
HANGER	CC-H-0456	HDR TO HXs	CC	3		VT-3	
HANGER	CC-H-0460	HDR TO HXs	CC	3		VT-3	
HANGER	CC-H-0464	HDR TO HXs	CC	3		VT-3	
HANGER	CC-H-0467	RETURN HDR TO CC PUMP A SUCTION	CC	3		VT-3	
HANGER	CC-H-0469	RETURN HDR TO CC PUMP A SUCTION	CC	3		VT-3	
HANGER	CC-H-0471	RETURN HDR TO CC PUMP A SUCTION	CC	3	2-3-13	VT-3	
HANGER	CC-H-0477	PUMP A SUCTION CONN TO CC PUMP C SUCTION	CC	3		VT-3	
HANGER	CC-H-0479	PUMP A SUCTION CONN TO CC PUMP C SUCTION	CC	3		VT-3	
HANGER	CC-H-0481	PUMP A SUCTION CONN TO CC PUMP C SUCTION	CC	3		VT-3	
HANGER	CC-H-0497	RHR HX B INLET	CC	3		VT-3	
HANGER	CC-H-0505	RHR HX B INLET	CC	3		VT-3	
HANGER	CC-H-0536	RECYCLE EVAP COND INLET	CC	3		VT-3	
HANGER	CC-H-0539	RECYCLE EVAP COND INLET	CC	3		VT-3	
HANGER	CC-H-0541	RECYCLE EVAP COND INLET	CC	3		VT-3	
HANGER	CC-H-0546	RECYCLE EVAP COND INLET	CC	3		VT-3	
HANGER	CC-H-0682	LTDN HX INLET FROM HDR	CC	3	2-3-13	VT-3	
HANGER	CC-H-0684	LTDN HX INLET FROM HDR	CC	3		VT-3	
HANGER	CC-H-0794	RECYCLE EVAP COND (CVCS) OUTLET TO RETURN HDR	CC	3		VT-3	
HANGER	CC-H-0898	RETURN HDR TO CC PUMP A SUCTION	CC	3		VT-3	
HANGER	CC-H-0903	CC PUMP C SUCTION INLET	CC	3		VT-3	
HANGER	CC-H-0906	RHR HX A OUTLET	CC	3		VT-3	
HANGER	CC-H-0909	RHR HX A OUTLET	CC	3		VT-3	
HANGER	CC-H-0911	RHR HX A OUTLET	CC	3		VT-3	
HANGER	CC-H-0924	CC PUMP A DISCH TO CC PUMPS A&B DISCH	CC	3		VT-3	
HANGER	CC-H-1238	RHR PUMP A INLET	CC	3		VT-3	
HANGER	CC-H-1351	TO CCS SFP HX UNIT 4	CC	3	2-3-13	VT-3	
HANGER	CC-H-1556	RECYCLE EVAP COND (CVCS) OUTLET TO RETURN HDR	CC	3		VT-3	
HANGER	CC-H-1570	CC HX B OUTLET	CC	3		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO. F1.30B		CLASS 3 HANGER - BOX					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER	CC-H-1572	CC HX B OUTLET	CC	3		VT-3	
HANGER	CC-H-1577	FROM HDR TO HX'S & RECYCLE PKG	CC	3		VT-3	
HANGER	CC-H-1604	RETURN HDR TO CC PUMP A SUCTION	CC	3		VT-3	
HANGER	CC-H-1759	FP HX 1&4A OUTLET	CC	3		VT-3	
HANGER	CC-H-1809	FROM CCS SFP HX UNIT 4	CC	3		VT-3	
HANGER	CC-H-1967	RHR HX A OUTLET	CC	3		VT-3	
HANGER	CC-H-1974	RECYCLE EVAP COND (CVCS) OUTLET TO RETURN HDR	CC	3		VT-3	
HANGER	CC-H-1999	FP HX 1&4A OUTLET	CC	3	2-3-13	VT-3	
HANGER	CC-H-2207	RHR HX B OUTLET	CC	3		VT-3	
HANGER	CE-H-0015	COND FROM CST TO AF PUMPS SUCTION	CE	3		VT-3	
HANGER	CE-H-0022	COND FROM CST TO AF PUMPS SUCTION	CE	3	2-1-08	VT-3	
HANGER	CE-H-0027	COND FROM CST TO AF PUMPS SUCTION	CE	3		VT-3	
HANGER	CH-H-0273	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER	CH-H-0279	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER	CH-H-0281	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER	CH-H-0284	ESSENTIAL SERVICE CH FOR MAIN	CH	3	2-1-09	VT-3	
HANGER	CH-H-0335	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER	CH-H-0341	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER	CH-H-0343	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER	CH-H-0345	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER	CH-H-1463	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER	CH-H-1465	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER	CH-H-1772	ESSENTIAL SERVICE CH FOR MAIN	CH	3	2-3-13	VT-3	
HANGER	CH-H-1776	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER	CX-H-0349	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3	
HANGER	CX-H-0355	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3	
HANGER	CX-H-0357	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3	
HANGER	CX-H-0463	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3	
HANGER	CX-H-0469	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.30B	CLASS 3 HANGER - BOX					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER CX-H-0471		ESSENTIAL SER CX FOR MAIN	CX	3		VT-3	
HANGER CX-H-0473		ESSENTIAL SER CX FOR MAIN	CX	3		VT-3	
HANGER CX-H-1542		ESSENTIAL SER CX FOR PUMP SUCTION	CX	3		VT-3	
HANGER CX-H-1614		ESSENTIAL SER CX FOR MAIN	CX	3	2-2-11	VT-3	
HANGER CX-H-1921		ESSENTIAL SER CX FOR MAIN	CX	3		VT-3	
HANGER EA-H-0165		INTAKE AIR TO D/G A	EA	3		VT-3	
HANGER EA-H-0166		INTAKE AIR TO D/G A	EA	3		VT-3	
HANGER EA-H-0168		INTAKE AIR TO D/G A	EA	3		VT-3	
HANGER EA-H-0170		INTAKE AIR TO D/G A	EA	3	2-1-09	VT-3	
HANGER EA-H-0173		INTAKE AIR TO D/G A	EA	3		VT-3	
HANGER EA-H-0174		INTAKE AIR TO D/G A	EA	3		VT-3	
HANGER EA-H-0176		INTAKE AIR TO D/G A	EA	3		VT-3	
HANGER EA-H-0178		INTAKE AIR TO D/G A	EA	3		VT-3	
HANGER EA-H-0181		INTAKE AIR TO D/G B	EA	3		VT-3	
HANGER EA-H-0182		INTAKE AIR TO D/G B	EA	3		VT-3	
HANGER EA-H-0184		INTAKE AIR TO D/G B	EA	3		VT-3	
HANGER EA-H-0186		INTAKE AIR TO D/G B	EA	3	2-3-13	VT-3	
HANGER EA-H-0189		INTAKE AIR TO D/G B	EA	3		VT-3	
HANGER EA-H-0190		INTAKE AIR TO D/G B	EA	3		VT-3	
HANGER EA-H-0192		INTAKE AIR TO D/G B	EA	3		VT-3	
HANGER EA-H-0194		INTAKE AIR TO D/G B	EA	3		VT-3	
HANGER MS-H-0182		STM SUPPLY TO TURB DRIVEN AFW PUMP	MS	3		VT-3	
HANGER MS-H-0194		STM SUPPLY TO TURB DRIVEN AFW PUMP	MS	3		VT-3	
HANGER MS-H-0418		MS DRAIN HDR INLET TO CONDENSER	MS	3	2-1-09	VT-3	
HANGER MS-H-0420		MS DRAIN HDR INLET TO CONDENSER	MS	3		VT-3	
HANGER MS-H-1102		RUPTURE DISCH VENT FOR AFW PUMP TURB EXHAUST	MS	3		VT-3	
HANGER MS-H-1393		VENT ON AFW PUMP TURB 1X-NNS	MS	3		VT-3	
HANGER SF-H-0453		SFP 1&4B PUMP SUCTION	SF	3		VT-3	
HANGER SF-H-0456		EMER COOLING CONN ON SFP PUMP 1&4B DISCH	SF	3	2-2-11	VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.30B	CLASS 3 HANGER - BOX					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER	SF-H-0466	NFP DISCH TO PUMP 1&4A SUCTION	SF	3		VT-3	
HANGER	SF-H-0469	SFP PUMP 1&4A SUCTION	SF	3		VT-3	
HANGER	SF-H-0476	SFP PUMP 1&4A SUCTION	SF	3		VT-3	
HANGER	SF-H-0488	EMER COOLING CONN ON SFP PUMP 1&4A DISCH	SF	3		VT-3	
HANGER	SF-H-0496	COMMON TO UNITS 1&4	SF	3		VT-3	
HANGER	SF-H-0497	COMMON TO UNITS 1&4	SF	3		VT-3	
HANGER	SF-H-0498	COMMON TO UNITS 1&4	SF	3		VT-3	
HANGER	SF-H-0501	COMMON TO UNITS 1&4	SF	3		VT-3	
HANGER	SF-H-0507	COMMON TO UNITS 1&4	SF	3		VT-3	
HANGER	SF-H-0510	COMMON TO UNITS 1&4	SF	3		VT-3	
HANGER	SF-H-0884	COMMON TO UNITS 1&4	SF	3	2-2-11	VT-3	
HANGER	SF-H-0886	COMMON TO UNITS 1&4	SF	3		VT-3	
HANGER	SF-H-0888	COMMON TO UNITS 1&4	SF	3		VT-3	
HANGER	SF-H-0896	COMMON TO UNITS 1&4	SF	3		VT-3	
HANGER	SF-H-0899	COMMON TO UNITS 1&4	SF	3		VT-3	
HANGER	SF-H-0904	COMMON TO UNITS 1&4	SF	3		VT-3	
HANGER	SF-H-0906	COMMON TO UNITS 1&4	SF	3		VT-3	
HANGER	SF-H-0908	COMMON TO UNITS 1&4	SF	3		VT-3	
HANGER	SF-H-0912	COMMON TO UNITS 1&4	SF	3		VT-3	
HANGER	SF-H-0916	COMMON TO UNITS 1&4	SF	3	2-3-13	VT-3	
HANGER	SF-H-0919	COMMON TO UNITS 1&4	SF	3		VT-3	
HANGER	SF-H-0921	COMMON TO UNITS 1&4	SF	3		VT-3	
HANGER	SW-H-0056	SW RETURN FROM CONT FAN COOLERS TO SW RETURN HDR A	SW	3	2-2-10	VT-3	
HANGER	SW-H-0070	SW SUPPLY TO CONT FAN COOLER AH-2	SW	3		VT-3	
HANGER	SW-H-0073	SW SUPPLY TO CONT FAN COOLER AH-2	SW	3		VT-3	
HANGER	SW-H-0102	SW RETURN FROM CONT FAN COOLER AH-1 TO SW RETURN HDR	SW	3		VT-3	
HANGER	SW-H-0106	SW RETURN FROM CONT FAN COOLER AH-1 TO SW RETURN HDR	SW	3		VT-3	
HANGER	SW-H-0111	SW RETURN FROM CONT FAN COOLER AH-1 TO SW RETURN HDR	SW	3	2-2-10	VT-3	
HANGER	SW-H-0265	SW RETURN FROM DG A COOLING TO SW RETURN HDR A	SW	3		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO. F1.30B		CLASS 3 HANGER - BOX					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER	SW-H-0266	SW RETURN FROM DG A COOLING TO SW RETURN HDR A	SW	3		VT-3	
HANGER	SW-H-0267	SW RETURN FROM DG A COOLING TO SW RETURN HDR A	SW	3		VT-3	
HANGER	SW-H-0268	SW RETURN FROM DG A COOLING TO SW RETURN HDR A	SW	3		VT-3	
HANGER	SW-H-0269	SW RETURN FROM DG A COOLING TO SW RETURN HDR A	SW	3		VT-3	
HANGER	SW-H-0270	SW RETURN FROM DG A COOLING TO SW RETURN HDR A	SW	3		VT-3	
HANGER	SW-H-0271	SW RETURN FROM DG A COOLING TO SW RETURN HDR A	SW	3		VT-3	
HANGER	SW-H-0272	SW RETURN FROM DG A COOLING TO SW RETURN HDR A	SW	3		VT-3	
HANGER	SW-H-0273	SW RETURN FROM DG A COOLING TO SW RETURN HDR A	SW	3		VT-3	
HANGER	SW-H-0274	SW FROM SUPPLY HDR A TO DG A COOLING	SW	3		VT-3	
HANGER	SW-H-0275	SW FROM SUPPLY HDR A TO DG A COOLING	SW	3		VT-3	
HANGER	SW-H-0276	SW FROM SUPPLY HDR A TO DG A COOLING	SW	3		VT-3	
HANGER	SW-H-0277	SW FROM SUPPLY HDR A TO DG A COOLING	SW	3		VT-3	
HANGER	SW-H-0278	SW FROM SUPPLY HDR A TO DG A COOLING	SW	3		VT-3	
HANGER	SW-H-0279	SW FROM SUPPLY HDR A TO DG A COOLING	SW	3	2-2-11	VT-3	
HANGER	SW-H-0280	SW FROM SUPPLY HDR A TO DG A COOLING	SW	3		VT-3	
HANGER	SW-H-0281	SW FROM SUPPLY HDR A TO DG A COOLING	SW	3		VT-3	
HANGER	SW-H-0282	SW FROM SUPPLY HDR A TO DG A COOLING	SW	3		VT-3	
HANGER	SW-H-0283	SW RETURN FROM DG B COOLING TO RETURN HDR B	SW	3		VT-3	
HANGER	SW-H-0284	SW RETURN FROM DG B COOLING TO RETURN HDR B	SW	3		VT-3	
HANGER	SW-H-0285	SW RETURN FROM DG B COOLING TO RETURN HDR B	SW	3		VT-3	
HANGER	SW-H-0286	SW RETURN FROM DG B COOLING TO RETURN HDR B	SW	3		VT-3	
HANGER	SW-H-0287	SW RETURN FROM DG B COOLING TO RETURN HDR B	SW	3		VT-3	
HANGER	SW-H-0288	SW RETURN FROM DG B COOLING TO RETURN HDR B	SW	3		VT-3	
HANGER	SW-H-0289	SW RETURN FROM DG B COOLING TO RETURN HDR B	SW	3	2-3-13	VT-3	
HANGER	SW-H-0290	SW RETURN FROM DG B COOLING TO RETURN HDR B	SW	3		VT-3	
HANGER	SW-H-0291	SW RETURN FROM DG B COOLING TO RETURN HDR B	SW	3		VT-3	
HANGER	SW-H-0292	FROM SW SUPPLY HDR B TO DG B COOLING	SW	3		VT-3	
HANGER	SW-H-0293	FROM SW SUPPLY HDR B TO DG B COOLING	SW	3		VT-3	
HANGER	SW-H-0294	FROM SW SUPPLY HDR B TO DG B COOLING	SW	3		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS				
ITEM NO. F1.30B		CLASS 3 HANGER - BOX				
Component	Description	System	Class	Outage	Exam Type	Relief Request
HANGER SW-H-0295	FROM SW SUPPLY HDR B TO DG B COOLING	SW	3		VT-3	
HANGER SW-H-0296	FROM SW SUPPLY HDR B TO DG B COOLING	SW	3		VT-3	
HANGER SW-H-0297	FROM SW SUPPLY HDR B TO DG B COOLING	SW	3		VT-3	
HANGER SW-H-0298	FROM SW SUPPLY HDR B TO DG B COOLING	SW	3		VT-3	
HANGER SW-H-0299	FROM SW SUPPLY HDR B TO DG B COOLING	SW	3	2-3-13	VT-3	
HANGER SW-H-0300	FROM SW SUPPLY HDR B TO DG B COOLING	SW	3		VT-3	
HANGER SW-H-0378	SW SUPPLY HDR A FROM SW PUMP DISCH	SW	3		VT-3	
HANGER SW-H-0398	SW SUPPLY HDR B FROM SW PUMP DISCH	SW	3		VT-3	
HANGER SW-H-0400	SW SUPPLY HDR B FROM SW PUMP DISCH	SW	3		VT-3	
HANGER SW-H-0402	SW SUPPLY HDR B FROM SW PUMP DISCH	SW	3		VT-3	
HANGER SW-H-0404	SW SUPPLY HDR B FROM SW PUMP DISCH	SW	3		VT-3	
HANGER SW-H-0406	SW SUPPLY HDR B FROM SW PUMP DISCH	SW	3		VT-3	
HANGER SW-H-0408	SW SUPPLY HDR B FROM SW PUMP DISCH	SW	3		VT-3	
HANGER SW-H-0410	SW SUPPLY HDR B FROM SW PUMP DISCH	SW	3		VT-3	
HANGER SW-H-0412	SW SUPPLY HDR B FROM SW PUMP DISCH	SW	3		VT-3	
HANGER SW-H-0417	FROM SW SUPPLY HDR B TO DG B COOLING	SW	3		VT-3	
HANGER SW-H-0420	FROM SW SUPPLY HDR B TO DG B COOLING	SW	3	2-3-13	VT-3	
HANGER SW-H-0424	FROM SW SUPPLY HDR B TO DG B COOLING	SW	3		VT-3	
HANGER SW-H-0430	SW SUPPLY HDR B FROM SW PUMP DISCH	SW	3		VT-3	
HANGER SW-H-0432	SW SUPPLY HDR B FROM SW PUMP DISCH	SW	3		VT-3	
HANGER SW-H-0436	SW SUPPLY HDR FROM SW PUMP DISCH	SW	3		VT-3	
HANGER SW-H-0448	SW SUPPLY HDR A	SW	3		VT-3	
HANGER SW-H-0449	SW SUPPLY HDR A	SW	3	2-1-09	VT-3	
HANGER SW-H-0452	SW FROM SUPPLY HDR A TO DG A COOLING	SW	3		VT-3	
HANGER SW-H-0456	SW FROM SUPPLY HDR A TO DG A COOLING	SW	3		VT-3	
HANGER SW-H-0460	SW FROM SUPPLY HDR A TO DG A COOLING	SW	3		VT-3	
HANGER SW-H-0464	SW FROM SUPPLY HDR A TO DG A COOLING	SW	3		VT-3	
HANGER SW-H-0468	SW FROM SUPPLY HDR A TO DG A COOLING	SW	3		VT-3	
HANGER SW-H-0471	SW FROM SUPPLY HDR A TO DG A COOLING	SW	3		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.30B	CLASS 3 HANGER - BOX					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER	SW-H-0473	SW FROM SUPPLY HDR A TO DG A COOLING	SW	3		VT-3	
HANGER	SW-H-0475	SW FROM SUPPLY HDR A TO DG A COOLING	SW	3		VT-3	
HANGER	SW-H-0477	SW FROM SUPPLY HDR A TO DG A COOLING	SW	3		VT-3	
HANGER	SW-H-0479	SW FROM SUPPLY HDR A TO DG A COOLING	SW	3		VT-3	
HANGER	SW-H-0484	SW FROM RETURN HDR B TO CIRC WATER DISCH	SW	3		VT-3	
HANGER	SW-H-0487	SW FROM RETURN HDR B TO CIRC WATER DISCH	SW	3		VT-3	
HANGER	SW-H-0489	SW FROM RETURN HDR B TO CIRC WATER DISCH	SW	3		VT-3	
HANGER	SW-H-0497	SW BOOSTER PUMP B DISCH	SW	3		VT-3	
HANGER	SW-H-0498	SW BOOSTER PUMP B DISCH	SW	3		VT-3	
HANGER	SW-H-0504	SW BOOSTER PUMP B BY-PASS	SW	3		VT-3	
HANGER	SW-H-0507	SW BOOSTER PUMP A BY-PASS	SW	3	2-2-10	VT-3	
HANGER	SW-H-0516	SW BOOSTER PUMP A DISCH HDR	SW	3		VT-3	
HANGER	SW-H-0523	SW FROM RETURN HDR B TO CIRC WATER DISCH	SW	3		VT-3	
HANGER	SW-H-0525	SW FROM CCW HX B TO SW RETURN HDR B	SW	3		VT-3	
HANGER	SW-H-0545	SW RETURN HDR A	SW	3		VT-3	
HANGER	SW-H-0547	SW RETURN HDR A	SW	3	2-2-10	VT-3	
HANGER	SW-H-0549	SW RETURN HDR A	SW	3		VT-3	
HANGER	SW-H-0551	SW RETURN HDR A	SW	3		VT-3	
HANGER	SW-H-0552	SW FROM RETURN HDR B TO CIRC WATER DISCH	SW	3		VT-3	
HANGER	SW-H-0554	SW FROM RETURN HDR B TO CIRC WATER DISCH	SW	3		VT-3	
HANGER	SW-H-0556	SW FROM RETURN HDR B TO CIRC WATER DISCH	SW	3		VT-3	
HANGER	SW-H-0561	SW RETURN HDR A	SW	3		VT-3	
HANGER	SW-H-0563	SW RETURN HDR A	SW	3		VT-3	
HANGER	SW-H-0565	SW RETURN HDR A	SW	3		VT-3	
HANGER	SW-H-0572	SW SUPPLY HDR A FROM SW PUMP DISCH	SW	3		VT-3	
HANGER	SW-H-0614	SW BOOSTER PUMP B HDR TO CONT FAN COOLER AH-1	SW	3	2-2-11	VT-3	
HANGER	SW-H-0616	SW BOOSTER PUMP B HDR TO CONT FAN COOLER AH-1	SW	3		VT-3	
HANGER	SW-H-0618	SW BOOSTER PUMP B HDR TO CONT FAN COOLER AH-1	SW	3		VT-3	
HANGER	SW-H-0623	SW BOOSTER PUMP B HDR TO CONT FAN COOLER AH-1	SW	3		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS				
ITEM NO. F1.30B		CLASS 3 HANGER - BOX				
Component	Description	System	Class	Outage	Exam Type	Relief Request
HANGER SW-H-0798	SW SUPPLY HDR B FROM SW PUMP DISCH	SW	3		VT-3	
HANGER SW-H-0801	SW RETURN FROM DG A COOLING TO SW RETURN HDR A	SW	3		VT-3	
HANGER SW-H-0803	SW FROM SUPPLY HDR A TO DG A COOLING	SW	3		VT-3	
HANGER SW-H-0910	SW RETURN FROM DG B COOLING TO RETURN HDR B	SW	3		VT-3	
HANGER SW-H-0913	SW FROM RETURN HDR B TO CIRC WATER DISCH	SW	3		VT-3	
HANGER SW-H-0915	SW FROM RETURN HDR B TO CIRC WATER DISCH	SW	3	2-3-13	VT-3	
HANGER SW-H-0917	SW FROM RETURN HDR B TO CIRC WATER DISCH	SW	3		VT-3	
HANGER SW-H-0919	SW FROM RETURN HDR B TO CIRC WATER DISCH	SW	3		VT-3	
HANGER SW-H-0921	SW FROM RETURN HDR B TO CIRC WATER DISCH	SW	3		VT-3	
HANGER SW-H-0923	SW FROM RETURN HDR B TO CIRC WATER DISCH	SW	3		VT-3	
HANGER SW-H-0925	SW FROM RETURN HDR B TO CIRC WATER DISCH	SW	3		VT-3	
HANGER SW-H-0964	SW RETURN HDR A	SW	3		VT-3	
HANGER SW-H-0966	SW RETURN HDR A	SW	3		VT-3	
HANGER SW-H-0968	SW RETURN HDR A	SW	3		VT-3	
HANGER SW-H-0970	SW RETURN HDR A	SW	3		VT-3	
HANGER SW-H-0972	SW RETURN HDR A	SW	3	2-2-11	VT-3	
HANGER SW-H-0974	SW RETURN HDR A	SW	3		VT-3	
HANGER SW-H-0976	SW RETURN HDR A	SW	3		VT-3	
HANGER SW-H-1229	TO AFW PUMP A SUCTION	SW	3		VT-3	
HANGER SW-H-1233	TO AFW PUMP A SUCTION	SW	3		VT-3	
HANGER SW-H-1239	TO RAB HVAC CHILLER A	SW	3		VT-3	
HANGER SW-H-1246	SW TO AFW PUMPS BACK-UP LINES	SW	3		VT-3	
HANGER SW-H-1250	SW TO AFW PUMPS BACK-UP LINES	SW	3		VT-3	
HANGER SW-H-1260	FROM SW SUPPLY HDR TO AFW PUMP 1X BACK-UP LINE	SW	3		VT-3	
HANGER SW-H-1267	FROM SW SUPPLY HDR B TO AFW PUMP 1X BACK-UP LINE	SW	3		VT-3	
HANGER SW-H-1308	TO AFW PUMP B SUCTION	SW	3	2-2-11	VT-3	
HANGER SW-H-1325	SW RETURN FROM DG B COOLING TO RETURN HDR B	SW	3		VT-3	
HANGER SW-H-1326	SW RETURN FROM DG B COOLING TO RETURN HDR B	SW	3		VT-3	
HANGER SW-H-1327	SW RETURN FROM DG B COOLING TO RETURN HDR B	SW	3		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.30B	CLASS 3 HANGER - BOX					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER SW-H-1329		SW RETURN FROM DG B COOLING TO RETURN HDR B	SW	3		VT-3	
HANGER SW-H-1331		SW RETURN FROM DG B COOLING TO RETURN HDR B	SW	3		VT-3	
HANGER SW-H-1338		SW RETURN FROM DG B COOLING TO RETURN HDR B	SW	3		VT-3	
HANGER SW-H-1340		SW RETURN FROM DG B COOLING TO RETURN HDR B	SW	3		VT-3	
HANGER SW-H-1348		SW RETURN FROM DG B COOLING TO RETURN HDR B	SW	3		VT-3	
HANGER SW-H-1350		FROM SW SUPPLY HDR B TO DG B COOLING	SW	3		VT-3	
HANGER SW-H-1352		FROM SW SUPPLY HDR B TO DG B COOLING	SW	3	2-3-13	VT-3	
HANGER SW-H-1354		FROM SW SUPPLY HDR B TO DG B COOLING	SW	3		VT-3	
HANGER SW-H-1356		FROM SW SUPPLY HDR B TO DG B COOLING	SW	3		VT-3	
HANGER SW-H-1358		FROM SW SUPPLY HDR B TO DG B COOLING	SW	3		VT-3	
HANGER SW-H-1360		FROM SW SUPPLY HDR B TO DG B COOLING	SW	3		VT-3	
HANGER SW-H-1362		FROM SW SUPPLY HDR B TO DG B COOLING	SW	3		VT-3	
HANGER SW-H-1396		SW RETURN FROM DG A COOLING TO SW RETURN HDR A	SW	3		VT-3	
HANGER SW-H-1397		SW RETURN FROM DG A COOLING TO SW RETURN HDR A	SW	3		VT-3	
HANGER SW-H-1398		SW RETURN FROM DG A COOLING TO SW RETURN HDR A	SW	3		VT-3	
HANGER SW-H-1400		SW RETURN FROM DG A COOLING TO SW RETURN HDR A	SW	3		VT-3	
HANGER SW-H-1409		SW FROM SUPPLY HDR A TO DG A COOLING	SW	3	2-2-11	VT-3	
HANGER SW-H-1411		SW FROM SUPPLY HDR A TO DG A COOLING	SW	3		VT-3	
HANGER SW-H-1413		SW FROM SUPPLY HDR A TO DG A COOLING	SW	3		VT-3	
HANGER SW-H-1415		SW FROM SUPPLY HDR A TO DG A COOLING	SW	3		VT-3	
HANGER SW-H-1447		SW FROM SUPPLY HDR A TO DG A COOLING	SW	3		VT-3	
HANGER SW-H-1449		SW FROM SUPPLY HDR A TO DG A COOLING	SW	3		VT-3	
HANGER SW-H-1458		FROM RAB HVAC CHILLER A TO RETURN HDR A	SW	3		VT-3	
HANGER SW-H-1504		FROM RAB HVAC CHILLER B TO RETURN HDR B	SW	3		VT-3	
HANGER SW-H-1537		SW FROM CCW HX A TO SW RETURN HDR A	SW	3		VT-3	
HANGER SW-H-1570		TO RAB HVAC CHILLER B	SW	3		VT-3	
HANGER SW-H-1601		SW FROM CCW HX B TO SW RETURN HDR B	SW	3		VT-3	
HANGER SW-H-1603		SW FROM CCW HX B TO SW RETURN HDR B	SW	3		VT-3	
HANGER SW-H-1607		SW FROM CCW HX B TO SW RETURN HDR B	SW	3	2-2-10	VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.30B	CLASS 3 HANGER - BOX					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER	SW-H-1736	SW RETURN FROM CONT FAN COOLERS TO SW RETURN HDR B	SW	3		VT-3	
HANGER	SW-H-1739	SW RETURN FROM CONT FAN COOLERS TO SW RETURN HDR B	SW	3		VT-3	
HANGER	SW-H-2100	TO RAB HVAC CHILLER B	SW	3		VT-3	
HANGER	SW-H-2109	SW FOR HVAC ESW CHILLER WC-2B RECIRC LOOP - PUMP P-7B D	SW	3		VT-3	
HANGER	SW-H-2113	WATER CHILLER WC-2B P-7B DISCH	SW	3		VT-3	
HANGER	SW-H-2118	TO RAB HVAC CHILLER A	SW	3		VT-3	
HANGER	SW-H-2129	SW FOR HVAC ESW CHILLER WC-2A RECIRC LOOP - PUMP P-7A D	SW	3		VT-3	
HANGER	SW-H-2231	SW FROM RETURN HDR B TO CIRC WATER DISCH	SW	3	2-3-13	VT-3	
HANGER	SW-H-2297	SW RETURN FROM CONT FAN COOLER AH-1 TO SW RETURN HDR	SW	3		VT-3	
HANGER	SW-H-2302	SW RETURN HDR B TO NORM SW DISCH HDR	SW	3		VT-3	
HANGER	SW-H-2648	SW FROM SW SUPPLY HDR B TO CCW HX B	SW	3		VT-3	
HANGER	SW-H-2649	SW FROM SW SUPPLY HDR B TO CCW HX B	SW	3		VT-3	
HANGER	SW-H-2668	SW SUPPLY HDR B	SW	3		VT-3	
HANGER	SW-H-2911	NSW PUMP A DISCH TO HDR	SW	3		VT-3	
HANGER	SW-H-3608	ESW STRAINER BACKWASH HDR	SW	3		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS				
ITEM NO. F1.30R		CLASS 3 HANGER - RIGID				
Component	Description	System	Class	Outage	Exam Type	Relief Request
HANGER AF-H-0007	TO VALVE AF-54	AF	3	2-3-13	VT-3	
HANGER AF-H-0008	TO VALVE AF-54	AF	3		VT-3	
HANGER AF-H-0019	TO VALVE AF-136	AF	3		VT-3	
HANGER AF-H-0020	TO VALVE AF-136	AF	3		VT-3	
HANGER AF-H-0037	TO VALVE AF-92	AF	3		VT-3	
HANGER AF-H-0038	TO VALVE AF-92	AF	3		VT-3	
HANGER AF-H-0066	TO VALVE AF-73	AF	3		VT-3	
HANGER AF-H-0067	TO VALVE AF-73	AF	3		VT-3	
HANGER AF-H-0077	TO VALVE AF-148	AF	3		VT-3	
HANGER AF-H-0078	TO VALVE AF-148	AF	3	2-3-13	VT-3	
HANGER AF-H-0079	BETWEEN VALVES AF-148 & AF-149	AF	3		VT-3	
HANGER AF-H-0083	AFW PUMPS RECIRC HDR TO CST	AF	3		VT-3	
HANGER AF-H-0085	AFW PUMPS RECIRC HDR TO CST	AF	3		VT-3	
HANGER AF-H-0086	AFW PUMPS RECIRC HDR TO CST	AF	3		VT-3	
HANGER AF-H-0091	AFW PUMPS RECIRC HDR TO CST	AF	3		VT-3	
HANGER AF-H-0095	AFW PUMPS RECIRC HDR TO CST	AF	3		VT-3	
HANGER AF-H-0101	AFW PUMPS RECIRC HDR TO CST	AF	3		VT-3	
HANGER AF-H-0103	AFW PUMPS RECIRC HDR TO CST	AF	3		VT-3	
HANGER AF-H-0104	AFW PUMPS RECIRC HDR TO CST	AF	3		VT-3	
HANGER AF-H-0105	AFW PUMPS RECIRC HDR TO CST	AF	3		VT-3	
HANGER AF-H-0107	AFW PUMPS RECIRC HDR TO CST	AF	3		VT-3	
HANGER AF-H-0111	AFW PUMPS RECIRC HDR TO CST	AF	3		VT-3	
HANGER AF-H-0113	AFW PUMPS RECIRC HDR TO CST	AF	3		VT-3	
HANGER AF-H-0114	AFW PUMPS RECIRC HDR TO CST	AF	3		VT-3	
HANGER AF-H-0118	AFW PUMP A OUTLET TO DISCH HDR	AF	3		VT-3	
HANGER AF-H-0119	AFW PUMP A OUTLET TO DISCH HDR	AF	3		VT-3	
HANGER AF-H-0120	AFW PUMP A OUTLET TO DISCH HDR	AF	3		VT-3	
HANGER AF-H-0124	AFW PUMP A OUTLET TO DISCH HDR	AF	3		VT-3	
HANGER AF-H-0125	AFW PUMP A RECIRC TO CST	AF	3		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS						
ITEM NO. F1.30R		CLASS 3 HANGER - RIGID						
Component	Description	System	Class	Outage	Exam Type	Relief Request		
HANGER AF-H-0126	AFW PUMP A RECIRC TO CST	AF	3	2-3-12	VT-3			
HANGER AF-H-0127	AFW PUMP A RECIRC TO CST	AF	3		VT-3			
HANGER AF-H-0128	AFW PUMP A RECIRC TO CST	AF	3		VT-3			
HANGER AF-H-0129	AFW PUMP A RECIRC TO CST	AF	3		VT-3			
HANGER AF-H-0133	AFW PUMP B OUTLET TO DISCH HDR	AF	3		VT-3			
HANGER AF-H-0134	AFW PUMP B OUTLET TO DISCH HDR	AF	3		VT-3			
HANGER AF-H-0135	AFW PUMP B OUTLET TO DISCH HDR	AF	3		VT-3			
HANGER AF-H-0139	AFW PUMP B OUTLET TO DISCH HDR	AF	3		VT-3			
HANGER AF-H-0140	AFW PUMP B RECIRC TO CST	AF	3		VT-3			
HANGER AF-H-0141	AFW PUMP B RECIRC TO CST	AF	3		VT-3			
HANGER AF-H-0142	AFW PUMP B RECIRC TO CST	AF	3	2-3-13	VT-3			
HANGER AF-H-0143	AFW PUMP B RECIRC TO CST	AF	3		VT-3			
HANGER AF-H-0144	AFW PUMP B RECIRC TO CST	AF	3		VT-3			
HANGER AF-H-0148	AFW PUMP 1X-SAB RECIRC TO CST	AF	3		VT-3			
HANGER AF-H-0149	AFW PUMP 1X-SAB RECIRC TO CST	AF	3		VT-3			
HANGER AF-H-0150	AFW PUMP 1X-SAB RECIRC TO CST	AF	3		VT-3			
HANGER AF-H-0153	AFW PUMP 1X-SAB OUTLET TO DISCH HDR	AF	3		VT-3			
HANGER AF-H-0154	AFW PUMP 1X-SAB OUTLET TO DISCH HDR	AF	3		VT-3			
HANGER AF-H-0158	AFW PUMP 1X-SAB OUTLET TO DISCH HDR	AF	3		VT-3			
HANGER AF-H-0159	AFW PUMP 1X-SAB OUTLET TO DISCH HDR	AF	3		VT-3			
HANGER AF-H-0160	AFW PUMP 1X-SAB OUTLET TO DISCH HDR	AF	3	2-2-10	VT-3			
HANGER AF-H-0161	AFW PUMP 1X-SAB OUTLET TO DISCH HDR	AF	3		VT-3			
HANGER AF-H-0165	DNSTRM OF VALVE AF-42	AF	3		VT-3			
HANGER AF-H-0166	DNSTRM OF VALVE AF-42	AF	3		VT-3			
HANGER AF-H-0187	AFW PUMPS A & B DISCH HDR	AF	3		VT-3			
HANGER AF-H-0188	AFW PUMP A OUTLET TO DISCH HDR	AF	3		VT-3			
HANGER AF-H-0191	AFW PUMPS A&B DISCH TO VALVE AF-73	AF	3		VT-3			
HANGER AF-H-0192	AFW PUMPS A&B DISCH TO VALVE AF-73	AF	3		VT-3			
HANGER AF-H-0193	AFW PUMPS A&B DISCH TO VALVE AF-73	AF	3		VT-3			

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS				
ITEM NO. F1.30R		CLASS 3 HANGER - RIGID				
Component	Description	System	Class	Outage	Exam Type	Relief Request
HANGER AF-H-0194	AFW PUMPS A&B DISCH TO VALVE AF-73	AF	3		VT-3	
HANGER AF-H-0195	AFW PUMPS A&B DISCH TO VALVE AF-73	AF	3	2-2-11	VT-3	
HANGER AF-H-0196	AFW PUMPS A&B DISCH TO VALVE AF-73	AF	3		VT-3	
HANGER AF-H-0200	AFW PUMPS A&B DISCH TO VALVE AF-73	AF	3		VT-3	
HANGER AF-H-0201	AFW PUMPS A&B DISCH TO VALVE AF-73	AF	3		VT-3	
HANGER AF-H-0205	AFW PUMP A OUTLET TO DISCH HDR	AF	3		VT-3	
HANGER AF-H-0206	AFW PUMP A OUTLET TO DISCH HDR	AF	3		VT-3	
HANGER AF-H-0208	AFW PUMP A OUTLET TO DISCH HDR	AF	3		VT-3	
HANGER AF-H-0212	AFW PUMP A OUTLET TO DISCH HDR	AF	3		VT-3	
HANGER AF-H-0224	DNSTRM OF VALVE AF-42	AF	3		VT-3	
HANGER AF-H-0225	DNSTRM OF VALVE AF-42	AF	3		VT-3	
HANGER AF-H-0226	DNSTRM OF VALVE AF-42	AF	3	2-2-11	VT-3	
HANGER AF-H-0227	DNSTRM OF VALVE AF-42	AF	3		VT-3	
HANGER AF-H-0231	AFW PUMPS A & B DISCH HDR	AF	3		VT-3	
HANGER AF-H-0234	AFW PUMP 1X-SAB DISCH TO VALVE AF-148	AF	3		VT-3	
HANGER AF-H-0235	AFW PUMP 1X-SAB DISCH TO VALVE AF-148	AF	3		VT-3	
HANGER AF-H-0236	AFW PUMP 1X-SAB DISCH TO VALVE AF-148	AF	3		VT-3	
HANGER AF-H-0237	AFW PUMP 1X-SAB DISCH TO VALVE AF-148	AF	3		VT-3	
HANGER AF-H-0239	AFW PUMP 1X-SAB DISCH TO VALVE AF-148	AF	3		VT-3	
HANGER AF-H-0241	AFW PUMP 1X-SAB DISCH TO VALVE AF-148	AF	3		VT-3	
HANGER AF-H-0242	AFW PUMP 1X-SAB DISCH TO VALVE AF-148	AF	3		VT-3	
HANGER AF-H-0243	AFW PUMP 1X-SAB DISCH TO VALVE AF-148	AF	3	2-3-13	VT-3	
HANGER AF-H-0244	AFW PUMP 1X-SAB DISCH TO VALVE AF-148	AF	3		VT-3	
HANGER AF-H-0245	AFW PUMP 1X-SAB DISCH TO VALVE AF-148	AF	3		VT-3	
HANGER AF-H-0249	AFW PUMP 1X-SAB DISCH TO VALVE AF-142	AF	3		VT-3	
HANGER AF-H-0252	AFW PUMP 1X-SAB DISCH TO VALVE AF-136	AF	3		VT-3	
HANGER AF-H-0253	AFW PUMP 1X-SAB DISCH TO VALVE AF-136	AF	3		VT-3	
HANGER AF-H-0257	AFW PUMP 1X-SAB DISCH TO VALVE AF-136	AF	3		VT-3	
HANGER AF-H-0258	AFW PUMP 1X-SAB DISCH TO VALVE AF-136	AF	3		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.30R	CLASS 3 HANGER - RIGID					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER AF-H-0259		AFW PUMP 1X-SAB DISCH TO VALVE AF-136	AF	3		VT-3	
HANGER AF-H-0260		AFW PUMP 1X-SAB DISCH TO VALVE AF-136	AF	3		VT-3	
HANGER AF-H-0261		AFW PUMP 1X-SAB DISCH TO VALVE AF-136	AF	3	2-2-10	VT-3	
HANGER AF-H-0262		AFW PUMP 1X-SAB DISCH TO VALVE AF-136	AF	3		VT-3	
HANGER AF-H-0263		AFW PUMP 1X-SAB DISCH TO VALVE AF-136	AF	3		VT-3	
HANGER AF-H-0264		AFW PUMP 1X-SAB DISCH TO VALVE AF-136	AF	3		VT-3	
HANGER AF-H-0267		AFW PUMP 1X-SAB DISCH HDR	AF	3		VT-3	
HANGER AF-H-0272		AFW PUMP 1X-SAB DISCH TO VALVE AF-142	AF	3		VT-3	
HANGER AF-H-0273		AFW PUMP 1X-SAB DISCH TO VALVE AF-142	AF	3		VT-3	
HANGER AF-H-0276		AFW PUMP 1X-SAB DISCH TO VALVE AF-142	AF	3		VT-3	
HANGER AF-H-0277		AFW PUMP 1X-SAB DISCH TO VALVE AF-142	AF	3		VT-3	
HANGER AF-H-0278		AFW PUMP 1X-SAB DISCH TO VALVE AF-142	AF	3		VT-3	
HANGER AF-H-0280		AFW PUMP 1X-SAB DISCH TO VALVE AF-142	AF	3	2-3-13	VT-3	
HANGER AF-H-0281		AFW PUMP 1X-SAB DISCH TO VALVE AF-142	AF	3		VT-3	
HANGER AF-H-0282		AFW PUMP 1X-SAB DISCH TO VALVE AF-142	AF	3		VT-3	
HANGER AF-H-0283		AFW PUMP 1X-SAB DISCH TO VALVE AF-142	AF	3		VT-3	
HANGER AF-H-0284		AFW PUMP 1X-SAB DISCH TO VALVE AF-142	AF	3		VT-3	
HANGER AF-H-0352		AFW PUMPS A & B DISCH TO VALVE AF-73	AF	3		VT-3	
HANGER AF-H-0370		AFW PUMPS RECIRC HDR TO CST	AF	3		VT-3	
HANGER AF-H-0371		AFW PUMPS RECIRC HDR TO CST	AF	3		VT-3	
HANGER AF-H-0372		AFW PUMPS RECIRC HDR TO CST	AF	3		VT-3	
HANGER AF-H-0373		AFW PUMPS RECIRC HDR TO CST	AF	3		VT-3	
HANGER AF-H-0374		AFW PUMPS RECIRC HDR TO CST	AF	3		VT-3	
HANGER AF-H-0375		AFW PUMPS RECIRC HDR TO CST	AF	3		VT-3	
HANGER AF-H-0381		AFW PUMPS RECIRC HDR TO CST	AF	3		VT-3	
HANGER AF-H-0382		AFW PUMPS RECIRC HDR TO CST	AF	3		VT-3	
HANGER AF-H-0383		AFW PUMPS RECIRC HDR TO CST	AF	3		VT-3	
HANGER AF-H-0384		AFW PUMPS RECIRC HDR TO CST	AF	3		VT-3	
HANGER AF-H-0385		AFW PUMPS RECIRC HDR TO CST	AF	3		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.30R	CLASS 3 HANGER - RIGID					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER	AF-H-0386	AFW PUMPS RECIRC HDR TO CST	AF	3		VT-3	
HANGER	AF-H-0387	AFW PUMPS RECIRC HDR TO CST	AF	3		VT-3	
HANGER	AF-H-0394	AFW PUMP A RECIRC TO CST	AF	3		VT-3	
HANGER	AF-H-0395	AFW PUMP A RECIRC TO CST	AF	3	2-3-13	VT-3	
HANGER	AF-H-0396	AFW PUMP B RECIRC TO CST	AF	3		VT-3	
HANGER	AF-H-0397	AFW PUMP B RECIRC TO CST	AF	3		VT-3	
HANGER	AF-H-0400	AFW PUMP 1X-SAB DISCH TO VALVE AF-148	AF	3		VT-3	
HANGER	AF-H-0413	AFW PUMP 1X-SAB DISCH TO VALVE AF-136	AF	3		VT-3	
HANGER	AF-H-0414	AFW PUMP 1X-SAB DISCH TO VALVE AF-136	AF	3		VT-3	
HANGER	AF-H-0421	AFW PUMPS A & B DISCH TO VALVE AF-73	AF	3		VT-3	
HANGER	AF-H-0422	AFW PUMPS A & B DISCH TO VALVE AF-73	AF	3		VT-3	
HANGER	AF-H-0447	AFW PUMP 1X-SAB DISCH TO VALVE AF-142	AF	3		VT-3	
HANGER	AF-H-0452	AFW PUMPS RECIRC HDR TO CST	AF	3		VT-3	
HANGER	AF-H-0453	AFW PUMPS RECIRC HDR TO CST	AF	3	2-3-13	VT-3	
HANGER	AF-H-0454	AFW PUMPS RECIRC HDR TO CST	AF	3		VT-3	
HANGER	AF-H-0459	AFW PUMP A RECIRC TO CST	AF	3		VT-3	
HANGER	AF-H-0464	AFW PUMP B RECIRC TO CST	AF	3		VT-3	
HANGER	AF-H-0473	AFW PUMP 1X-SAB DISCH TO VALVE AF-136	AF	3		VT-3	
HANGER	AF-H-0475	AFW PUMP 1X-SAB DISCH TO VALVE AF-142	AF	3		VT-3	
HANGER	AF-H-0477	AFW PUMP 1X-SAB DISCH TO VALVE AF-148	AF	3	2-3-13	VT-3	
HANGER	CC-H-0089	BETWEEN VALVES CC-95 AND CC-99	CC	3		VT-3	
HANGER	CC-H-0090	BETWEEN VALVES CC-95 AND CC-99	CC	3	2-2-10	VT-3	
HANGER	CC-H-0091	BETWEEN VALVES CC-95 AND CC-99	CC	3		VT-3	
HANGER	CC-H-0094	BETWEEN VALVES CC-95 AND CC-99	CC	3		VT-3	
HANGER	CC-H-0097	UPSTREAM OF VALVE CC-259	CC	3		VT-3	
HANGER	CC-H-0099	UPSTREAM OF VALVE CC-259	CC	3		VT-3	
HANGER	CC-H-0101	UPSTREAM OF VALVE CC-259	CC	3		VT-3	
HANGER	CC-H-0113	RHR HX A INLET	CC	3		VT-3	
HANGER	CC-H-0213	RCP A BRNGS DISCH UPSTRM TO VALVE CC-491	CC	3		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS						
ITEM NO. F1.30R		CLASS 3 HANGER - RIGID						
Component	Description	System	Class	Outage	Exam Type	Relief Request		
HANGER CC-H-0214	RCP A BRNGS DISCH UPSTRM TO VALVE CC-491	CC	3		VT-3			
HANGER CC-H-0216	RCP A BRNGS DISCH UPSTRM TO VALVE CC-491	CC	3		VT-3			
HANGER CC-H-0309	HDR CONN TO EX LTDN HX & RCDT HX	CC	3	2-2-10	VT-3			
HANGER CC-H-0314	FP HX 1&4A-SA OUTLET	CC	3		VT-3			
HANGER CC-H-0316	FP HX 1&4A-SA OUTLET	CC	3		VT-3			
HANGER CC-H-0320	FP HX 1&4A-SA OUTLET	CC	3		VT-3			
HANGER CC-H-0322	SFP HX TO RETURN HDR	CC	3		VT-3			
HANGER CC-H-0323	SFP HX TO RETURN HDR	CC	3		VT-3			
HANGER CC-H-0324	RETURN HDR FROM HXs	CC	3		VT-3			
HANGER CC-H-0325	RETURN HDR FROM HXs	CC	3		VT-3			
HANGER CC-H-0326	RETURN HDR FROM HXs	CC	3		VT-3			
HANGER CC-H-0327	RETURN HDR FROM HXs	CC	3		VT-3			
HANGER CC-H-0336	FROM CCS SFP HX UNIT 4	CC	3	2-3-13	VT-3			
HANGER CC-H-0338	FROM CCS SFP HX UNIT 4	CC	3		VT-3			
HANGER CC-H-0341	HDR TO HXs	CC	3		VT-3			
HANGER CC-H-0346	HDR TO HXs	CC	3		VT-3			
HANGER CC-H-0348	HDR TO HXs	CC	3		VT-3			
HANGER CC-H-0350	HDR TO HXs	CC	3		VT-3			
HANGER CC-H-0351	HDR TO HXs	CC	3		VT-3			
HANGER CC-H-0352	HDR TO HXs	CC	3		VT-3			
HANGER CC-H-0368	CCW HDR TO RCP	CC	3		VT-3			
HANGER CC-H-0369	CCW HDR TO RCP	CC	3	2-1-08	VT-3			
HANGER CC-H-0370	CCW HDR TO RCP	CC	3		VT-3			
HANGER CC-H-0374	BETWEEN VALVES CC-109 AND CC-113	CC	3		VT-3			
HANGER CC-H-0375	BETWEEN VALVES CC-109 AND CC-113	CC	3		VT-3			
HANGER CC-H-0376	BETWEEN VALVES CC-109 AND CC-113	CC	3		VT-3			
HANGER CC-H-0377	BETWEEN VALVES CC-109 AND CC-113	CC	3		VT-3			
HANGER CC-H-0378	CCW HX B OUTLET	CC	3		VT-3			
HANGER CC-H-0380	UPSTRM OF VALVE CC-156	CC	3		VT-3			

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS				
ITEM NO. F1.30R		CLASS 3 HANGER - RIGID				
Component	Description	System	Class	Outage	Exam Type	Relief Request
HANGER CC-H-0382	UPSTRM OF VALVE CC-156	CC	3		VT-3	
HANGER CC-H-0384	UPSTRM OF VALVE CC-156	CC	3	2-3-13	VT-3	
HANGER CC-H-0385	UPSTRM OF VALVE CC-156	CC	3		VT-3	
HANGER CC-H-0386	UPSTRM OF VALVE CC-156	CC	3		VT-3	
HANGER CC-H-0387	UPSTRM OF VALVE CC-156	CC	3		VT-3	
HANGER CC-H-0392	UPSTRM OF VALVE CC-156	CC	3		VT-3	
HANGER CC-H-0393	UPSTRM OF VALVE CC-156	CC	3		VT-3	
HANGER CC-H-0404	RHR HX B INLET	CC	3		VT-3	
HANGER CC-H-0411	HDR TO CCS SFP HX UNIT 4	CC	3		VT-3	
HANGER CC-H-0412	HDR TO CCS SFP HX UNIT 4	CC	3		VT-3	
HANGER CC-H-0413	HDR TO CCS SFP HX UNIT 4	CC	3		VT-3	
HANGER CC-H-0419	RCP A DISCH TO RETURN HDR	CC	3	2-2-11	VT-3	
HANGER CC-H-0426	TO RETURN HDR FROM RCDT HX & EX LTDN HX	CC	3		VT-3	
HANGER CC-H-0428	DNSTRM OF VALVE CC-202 TO RETURN HDR	CC	3		VT-3	
HANGER CC-H-0433	TO RETURN HDR FROM RCDT HX & EX LTDN HX	CC	3		VT-3	
HANGER CC-H-0443	TO RETURN HDR FROM RCDT HX & EX LTDN HX	CC	3		VT-3	
HANGER CC-H-0444	TO RETURN HDR FROM RCDT HX & EX LTDN HX	CC	3		VT-3	
HANGER CC-H-0458	HDR TO HXs	CC	3		VT-3	
HANGER CC-H-0462	HDR TO HXs	CC	3		VT-3	
HANGER CC-H-0474	RETURN HDR TO CC PUMP B SUCTION	CC	3		VT-3	
HANGER CC-H-0475	RETURN HDR TO CC PUMP B SUCTION	CC	3		VT-3	
HANGER CC-H-0492	RHR HX B INLET	CC	3		VT-3	
HANGER CC-H-0493	RHR HX B INLET	CC	3		VT-3	
HANGER CC-H-0494	RHR HX B INLET	CC	3		VT-3	
HANGER CC-H-0495	RHR HX B INLET	CC	3		VT-3	
HANGER CC-H-0499	RHR HX B INLET	CC	3	2-1-08	VT-3	
HANGER CC-H-0502	RHR HX B INLET	CC	3		VT-3	
HANGER CC-H-0504	RHR HX B INLET	CC	3		VT-3	
HANGER CC-H-0509	RETURN HDR TO CC PUMP B SUCTION	CC	3		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS						
ITEM NO. F1.30R		CLASS 3 HANGER - RIGID						
Component		Description	System	Class	Outage	Exam Type	Relief Request	
HANGER CC-H-0510		RETURN HDR TO CC PUMP B SUCTION	CC	3		VT-3		
HANGER CC-H-0512		RETURN HDR TO CC PUMP B SUCTION	CC	3		VT-3		
HANGER CC-H-0513		LINE FROM HDR TO HX'S & RECY PKG	CC	3	2-2-11	VT-3		
HANGER CC-H-0526		RECYCLE EVAP COND INLET	CC	3		VT-3		
HANGER CC-H-0527		RECYCLE EVAP COND INLET	CC	3		VT-3		
HANGER CC-H-0544		RECYCLE EVAP COND INLET	CC	3		VT-3		
HANGER CC-H-0545		RECYCLE EVAP COND INLET	CC	3		VT-3		
HANGER CC-H-0558		LTDN HX OUTLET TO RETURN HDR	CC	3		VT-3		
HANGER CC-H-0559		LTDN HX OUTLET TO RETURN HDR	CC	3		VT-3		
HANGER CC-H-0560		LTDN HX OUTLET TO RETURN HDR	CC	3		VT-3		
HANGER CC-H-0561		LTDN HX OUTLET TO RETURN HDR	CC	3		VT-3		
HANGER CC-H-0562		LTDN HX OUTLET TO RETURN HDR	CC	3		VT-3		
HANGER CC-H-0566		LTDN HX OUTLET TO RETURN HDR	CC	3	2-3-13	VT-3		
HANGER CC-H-0567		LTDN HX OUTLET TO RETURN HDR	CC	3		VT-3		
HANGER CC-H-0568		LTDN HX OUTLET TO RETURN HDR	CC	3		VT-3		
HANGER CC-H-0569		LTDN HX OUTLET TO RETURN HDR	CC	3		VT-3		
HANGER CC-H-0571		LTDN HX OUTLET TO RETURN HDR	CC	3		VT-3		
HANGER CC-H-0572		LTDN HX OUTLET TO RETURN HDR	CC	3		VT-3		
HANGER CC-H-0679		LTDN HX INLET FROM HDR	CC	3		VT-3		
HANGER CC-H-0680		LTDN HX INLET FROM HDR	CC	3		VT-3		
HANGER CC-H-0767		COMMON RETURN HDR FOR SAMPLE HX'S AND RECYCLE EVAP P	CC	3		VT-3		
HANGER CC-H-0768		COMMON RETURN HDR FOR SAMPLE HX'S AND RECYCLE EVAP P	CC	3		VT-3		
HANGER CC-H-0769		COMMON RETURN HDR FOR SAMPLE HX'S AND RECYCLE EVAP P	CC	3	2-3-13	VT-3		
HANGER CC-H-0770		COMMON RETURN HDR FOR SAMPLE HX'S AND RECYCLE EVAP P	CC	3		VT-3		
HANGER CC-H-0784		RECYCLE EVAP COND (CVCS) OUTLET TO RETURN HDR	CC	3		VT-3		
HANGER CC-H-0785		RECYCLE EVAP COND (CVCS) OUTLET TO RETURN HDR	CC	3		VT-3		
HANGER CC-H-0787		RECYCLE EVAP COND (CVCS) OUTLET TO RETURN HDR	CC	3		VT-3		
HANGER CC-H-0788		RECYCLE EVAP COND (CVCS) OUTLET TO RETURN HDR	CC	3		VT-3		
HANGER CC-H-0796		RECYCLE EVAP COND (CVCS) OUTLET TO RETURN HDR	CC	3		VT-3		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO. F1.30R		CLASS 3 HANGER - RIGID					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER	CC-H-0797	RECYCLE EVAP COND (CVCS) OUTLET TO RETURN HDR	CC	3		VT-3	
HANGER	CC-H-0798	RECYCLE EVAP COND (CVCS) OUTLET TO RETURN HDR	CC	3		VT-3	
HANGER	CC-H-0877	RETURN HDR TO CC PUMP A SUCTION	CC	3	2-2-10	VT-3	
HANGER	CC-H-0878	RETURN HDR TO CC PUMP A SUCTION	CC	3		VT-3	
HANGER	CC-H-0880	RETURN HDR TO CC PUMP A SUCTION	CC	3		VT-3	
HANGER	CC-H-0887	UPSTRM OF VALVE CC-56	CC	3		VT-3	
HANGER	CC-H-0888	CC PUMP A SUCTION TO CC PUMP C SUCTION	CC	3		VT-3	
HANGER	CC-H-0889	CC PUMP A SUCTION TO CC PUMP C SUCTION	CC	3		VT-3	
HANGER	CC-H-0891	CC PUMP A SUCTION TO CC PUMP C SUCTION	CC	3		VT-3	
HANGER	CC-H-0892	CC PUMP A SUCTION TO CC PUMP C SUCTION	CC	3		VT-3	
HANGER	CC-H-0893	CC PUMP A SUCTION TO CC PUMP C SUCTION	CC	3		VT-3	
HANGER	CC-H-0894	RETURN HDR TO CC PUMP A SUCTION	CC	3		VT-3	
HANGER	CC-H-0896	RETURN HDR TO CC PUMP A SUCTION	CC	3		VT-3	
HANGER	CC-H-0899	RETURN HDR TO CC PUMP A SUCTION	CC	3	2-1-08	VT-3	
HANGER	CC-H-0901	CC PUMP C SUCTION INLET	CC	3		VT-3	
HANGER	CC-H-0902	CC PUMP C SUCTION INLET	CC	3		VT-3	
HANGER	CC-H-0908	RHR HX A OUTLET	CC	3		VT-3	
HANGER	CC-H-0913	RHR HX A OUTLET	CC	3		VT-3	
HANGER	CC-H-0915	RHR HX A OUTLET	CC	3		VT-3	
HANGER	CC-H-0917	RHR HX A OUTLET	CC	3		VT-3	
HANGER	CC-H-0920	CC PUMP C DISCH TO CC PUMPS A&B DISCH	CC	3		VT-3	
HANGER	CC-H-0921	CC PUMP C DISCH TO CC PUMPS A&B DISCH	CC	3		VT-3	
HANGER	CC-H-0923	CC PUMP C DISCH TO CC PUMPS A&B DISCH	CC	3		VT-3	
HANGER	CC-H-0925	CC PUMP A DISCH TO CC PUMPS A&B DISCH	CC	3	2-2-11	VT-3	
HANGER	CC-H-0926	CC PUMP A DISCH TO CC PUMPS A&B DISCH	CC	3		VT-3	
HANGER	CC-H-0927	CC PUMP B DISCH TO CC HX B	CC	3		VT-3	
HANGER	CC-H-0928	CC PUMP B DISCH TO CC HX B	CC	3		VT-3	
HANGER	CC-H-0929	CC PUMP B DISCH TO CC HX B	CC	3		VT-3	
HANGER	CC-H-0930	CC PUMP B DISCH TO CC HX B	CC	3		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO. F1.30R		CLASS 3 HANGER - RIGID					
Component	Description	System	Class	Outage	Exam Type	Relief Request	
HANGER CC-H-0931	CC PUMP B DISCH TO CC HX B	CC	3		VT-3		
HANGER CC-H-0932	CC PUMP B DISCH TO CC HX B	CC	3		VT-3		
HANGER CC-H-0933	CC PUMP B DISCH TO CC HX B	CC	3		VT-3		
HANGER CC-H-0934	CC PUMP B DISCH TO CC HX B	CC	3		VT-3		
HANGER CC-H-0935	CC PUMP B DISCH TO CC HX B	CC	3	2-1-08	VT-3		
HANGER CC-H-0936	CC PUMP B DISCH TO CC HX B	CC	3		VT-3		
HANGER CC-H-0937	CC PUMP B DISCH TO CC HX B	CC	3		VT-3		
HANGER CC-H-0938	CC PUMP B DISCH TO CC HX B	CC	3		VT-3		
HANGER CC-H-0939	CC PUMP B DISCH TO CC HX B	CC	3		VT-3		
HANGER CC-H-0940	CC PUMP C DISCH TO CC PUMPS A&B DISCH	CC	3		VT-3		
HANGER CC-H-0941	CC PUMP C DISCH TO CC PUMPS A&B DISCH	CC	3		VT-3		
HANGER CC-H-0942	CC PUMP C DISCH TO CC PUMPS A&B DISCH	CC	3		VT-3		
HANGER CC-H-0943	CC PUMP C DISCH TO CC PUMPS A&B DISCH	CC	3		VT-3		
HANGER CC-H-0945	CC PUMP A DISCH TO CC HX A	CC	3	2-1-09	VT-3		
HANGER CC-H-0947	CC PUMP A DISCH TO CC HX A	CC	3		VT-3		
HANGER CC-H-0948	CC PUMP A DISCH TO CC HX A	CC	3		VT-3		
HANGER CC-H-0949	CC PUMP C DISCH TO LINE 3CC18-19SAB	CC	3		VT-3		
HANGER CC-H-0951	CC PUMP A DISCH TO CC HX A	CC	3		VT-3		
HANGER CC-H-0952	CC PUMP A DISCH TO CC HX A	CC	3		VT-3		
HANGER CC-H-1332	FP HX 1&4A OUTLET	CC	3		VT-3		
HANGER CC-H-1333	FP HX 1&4A OUTLET	CC	3		VT-3		
HANGER CC-H-1343	HDR TO CCS SFP HX UNIT 4	CC	3		VT-3		
HANGER CC-H-1344	CCS SFP HX FROM UNIT 4	CC	3		VT-3		
HANGER CC-H-1345	TO CCS SFP HX UNIT 4	CC	3		VT-3		
HANGER CC-H-1346	TO CCS SFP HX UNIT 4	CC	3	2-3-13	VT-3		
HANGER CC-H-1347	CCS SFP HX FROM UNIT 4	CC	3		VT-3		
HANGER CC-H-1348	CCS SFP HX FROM UNIT 4	CC	3		VT-3		
HANGER CC-H-1350	CCS SFP HX FROM UNIT 4	CC	3		VT-3		
HANGER CC-H-1583	UPSTRM OF VALVE CC-127	CC	3		VT-3		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS				
ITEM NO. F1.30R		CLASS 3 HANGER - RIGID				
Component	Description	System	Class	Outage	Exam Type	Relief Request
HANGER CC-H-1588	CC PUMP C DISCH TO CC PUMPS A&B DISCH	CC	3		VT-3	
HANGER CC-H-1594	CC PUMP B DISCH TO CC HX B	CC	3		VT-3	
HANGER CC-H-1595	CC PUMP B DISCH TO CC HX B	CC	3		VT-3	
HANGER CC-H-1724	RHR HX B INLET	CC	3		VT-3	
HANGER CC-H-1769	TO RETUTN HDR FROM RCDT HX & EX LTDN HX	CC	3	2-2-11	VT-3	
HANGER CC-H-1777	CC PUMP C DISCH TO CC PUMPS A&B DISCH	CC	3		VT-3	
HANGER CC-H-1778	CC PUMP C DISCH TO CC PUMPS A&B DISCH	CC	3		VT-3	
HANGER CC-H-1779	CC PUMP C DISCH TO CC PUMPS A&B DISCH	CC	3		VT-3	
HANGER CC-H-1801	CC PUMP C DISCH TO CC PUMPS A&B DISCH	CC	3		VT-3	
HANGER CC-H-1802	CC PUMP A DISCH TO CC HX A	CC	3		VT-3	
HANGER CC-H-1808	FROM CCS SFP HX UNIT 4	CC	3		VT-3	
HANGER CC-H-1810	TO CCS SFP HX UNIT 4	CC	3		VT-3	
HANGER CC-H-1816	CONN FROM HDR TO HX'S & RECYCLE PKG	CC	3		VT-3	
HANGER CC-H-1817	CONN FROM HDR TO HX'S & RECYCLE PKG	CC	3		VT-3	
HANGER CC-H-1818	HDR TO HXs	CC	3		VT-3	
HANGER CC-H-1952	CC PUMP A SUCTION CONN TO CC PUMP C SUCTION	CC	3	2-3-13	VT-3	
HANGER CC-H-1953	CC PUMP A SUCTION CONN TO CC PUMP C SUCTION	CC	3		VT-3	
HANGER CC-H-1964	RETURN HDR TO CC PUMP A SUCTION	CC	3		VT-3	
HANGER CC-H-1966	RHR HX A OUTLET	CC	3		VT-3	
HANGER CC-H-1976	RECYCLE EVAP COND (CVCS) OUTLET TO RETURN HDR	CC	3		VT-3	
HANGER CC-H-1997	HDR TO HXs	CC	3		VT-3	
HANGER CC-H-1998	HDR TO HXs	CC	3		VT-3	
HANGER CC-H-2009	FP HX 1&4A OUTLET	CC	3		VT-3	
HANGER CC-H-2010	FP HX 1&4A OUTLET	CC	3		VT-3	
HANGER CC-H-2011	FP HX 1&4A OUTLET	CC	3		VT-3	
HANGER CC-H-2012	FP HX 1&4A OUTLET	CC	3		VT-3	
HANGER CC-H-2014	FP HX 1&4A OUTLET	CC	3		VT-3	
HANGER CC-H-2015		CC	3		VT-3	
HANGER CC-H-2075	RCP A DISCH TO RETURN HDR	CC	3	2-2-11	VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS				
ITEM NO. F1.30R		CLASS 3 HANGER - RIGID				
Component	Description	System	Class	Outage	Exam Type	Relief Request
HANGER CC-H-2189	HDR CONN TO EX LTDN HX & RCDT HX	CC	3		VT-3	
HANGER CC-H-2219	HDR TO CCS SFP HX UNIT 4	CC	3		VT-3	
HANGER CC-H-2221	CC PUMP A DISCH TO CC HX A	CC	3		VT-3	
HANGER CE-H-0002	COND FROM CST TO AF PUMPS SUCTION	CE	3		VT-3	
HANGER CE-H-0004	COND FROM CST TO AF PUMPS SUCTION	CE	3		VT-3	
HANGER CE-H-0005	COND FROM CST TO AF PUMPS SUCTION	CE	3		VT-3	
HANGER CE-H-0006	COND FROM CST TO AF PUMPS SUCTION	CE	3		VT-3	
HANGER CE-H-0007	COND FROM CST TO AF PUMPS SUCTION	CE	3	2-1-09	VT-3	
HANGER CE-H-0008	COND TO AF PUMP B SUCTION	CE	3		VT-3	
HANGER CE-H-0010	COND TO AF PUMP A SUCTION	CE	3		VT-3	
HANGER CE-H-0012	COND FROM CST TO AF PUMPS SUCTION	CE	3		VT-3	
HANGER CE-H-0013	COND FROM CST TO AF PUMPS SUCTION	CE	3		VT-3	
HANGER CE-H-0014	COND FROM CST TO AF PUMPS SUCTION	CE	3		VT-3	
HANGER CE-H-0016	COND FROM CST TO AF PUMPS SUCTION	CE	3		VT-3	
HANGER CE-H-0018	COND FROM CST TO AF PUMPS SUCTION	CE	3		VT-3	
HANGER CE-H-0019	COND FROM CST TO AF PUMPS SUCTION	CE	3		VT-3	
HANGER CE-H-0020	COND FROM CST TO AF PUMPS SUCTION	CE	3		VT-3	
HANGER CE-H-0021	COND FROM CST TO AF PUMPS SUCTION	CE	3		VT-3	
HANGER CE-H-0026	COND FROM CST TO AF PUMPS SUCTION	CE	3		VT-3	
HANGER CE-H-0471	COND TO AF PUMP A SUCTION	CE	3	2-1-08	VT-3	
HANGER CE-H-0472	COND TO AF PUMP B SUCTION	CE	3		VT-3	
HANGER CH-H-0275	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER CH-H-0339	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER CH-H-0494	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER CH-H-0503	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER CH-H-0504	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER CH-H-0901	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER CH-H-0902	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER CH-H-0903	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS						
ITEM NO.	F1.30R	CLASS 3 HANGER - RIGID						
Component		Description	System	Class	Outage	Exam Type	Relief Request	
HANGER	CH-H-0904	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3		
HANGER	CH-H-1461	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3		
HANGER	CH-H-1462	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3		
HANGER	CH-H-1521	ESSENTIAL SERVICE CH FOR MAIN	CH	3	2-1-08	VT-3		
HANGER	CH-H-1522	ESSENTIAL SERVICE CH FOR MAIN	CH	3	2-1-08	VT-3		
HANGER	CH-H-1523	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3		
HANGER	CH-H-1524	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3		
HANGER	CH-H-1525	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3		
HANGER	CH-H-1526	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3		
HANGER	CH-H-1527	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3		
HANGER	CH-H-1531	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3		
HANGER	CH-H-1532	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3		
HANGER	CH-H-1533	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3		
HANGER	CH-H-1534	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3		
HANGER	CH-H-1535	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3		
HANGER	CH-H-1536	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3		
HANGER	CH-H-1537	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3		
HANGER	CH-H-1538	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3		
HANGER	CH-H-1539	ESSENTIAL SERVICE CH FOR MAIN	CH	3	2-3-13	VT-3		
HANGER	CH-H-1540	ESSENTIAL SERVICE CH FOR MAIN	CH	3	2-3-13	VT-3		
HANGER	CH-H-1541	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3		
HANGER	CH-H-1542	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3		
HANGER	CH-H-1543	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3		
HANGER	CH-H-1544	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3		
HANGER	CH-H-1545	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3		
HANGER	CH-H-1546	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3		
HANGER	CH-H-1547	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3		
HANGER	CH-H-1548	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3		
HANGER	CH-H-1549	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO. F1.30R		CLASS 3 HANGER - RIGID					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER	CH-H-1550	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER	CH-H-1551	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER	CH-H-1569	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER	CH-H-1570	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER	CH-H-1571	ESSENTIAL SERVICE CH FOR MAIN	CH	3	2-1-08	VT-3	
HANGER	CH-H-1572	ESSENTIAL SERVICE CH FOR MAIN	CH	3	2-1-08	VT-3	
HANGER	CH-H-1573	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER	CH-H-1574	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER	CH-H-1575	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER	CH-H-1576	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER	CH-H-1578	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER	CH-H-1673	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER	CH-H-1674	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER	CH-H-1675	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER	CH-H-1676	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER	CH-H-1677	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER	CH-H-1678	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER	CH-H-1718	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER	CH-H-1719	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER	CH-H-1729	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER	CH-H-1730	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER	CH-H-1735	ESSENTIAL SERVICE CH FOR MAIN	CH	3	2-1-09	VT-3	
HANGER	CH-H-1736	ESSENTIAL SERVICE CH FOR MAIN	CH	3	2-1-09	VT-3	
HANGER	CH-H-1737	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER	CH-H-1738	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER	CH-H-1740	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER	CH-H-1767	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER	CH-H-1770	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	
HANGER	CH-H-1771	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS						
ITEM NO. F1.30R		CLASS 3 HANGER - RIGID						
Component	Description	System	Class	Outage	Exam Type	Relief Request		
HANGER CH-H-1778	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3			
HANGER CH-H-1786	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3			
HANGER CH-H-1812	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3			
HANGER CH-H-1814	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3			
HANGER CH-H-1844	ESSENTIAL SERVICE CH FOR MAIN	CH	3		VT-3			
HANGER CX-H-0353	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-0360	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-0467	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-0913	ESSENTIAL SER CX FOR MAIN	CX	3	2-1-09	VT-3			
HANGER CX-H-0914	ESSENTIAL SER CX FOR MAIN	CX	3	2-1-09	VT-3			
HANGER CX-H-0915	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-0916	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-0917	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-0918	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1497	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1498	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1499	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1500	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1501	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1502	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1503	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1504	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1506	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1507	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1508	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1509	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1510	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1511	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1512	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS						
ITEM NO. F1.30R		CLASS 3 HANGER - RIGID						
Component	Description	System	Class	Outage	Exam Type	Relief Request		
HANGER CX-H-1513	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1514	ESSENTIAL SER CX FOR MAIN	CX	3	2-3-13	VT-3			
HANGER CX-H-1515	ESSENTIAL SER CX FOR MAIN	CX	3	2-3-13	VT-3			
HANGER CX-H-1516	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1517	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1518	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1519	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1520	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1521	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1522	ESSENTIAL SER CX FOR PUMP DISCH	CX	3		VT-3			
HANGER CX-H-1523	ESSENTIAL SER CX FOR PUMP DISCH	CX	3		VT-3			
HANGER CX-H-1524	ESSENTIAL SER CX FOR PUMP DISCH	CX	3		VT-3			
HANGER CX-H-1525	ESSENTIAL SER CX FOR PUMP DISCH	CX	3		VT-3			
HANGER CX-H-1526	ESSENTIAL SER CX FOR PUMP DISCH	CX	3		VT-3			
HANGER CX-H-1527	ESSENTIAL SER CX FOR PUMP DISCH	CX	3		VT-3			
HANGER CX-H-1528	ESSENTIAL SER CX FOR PUMP DISCH	CX	3		VT-3			
HANGER CX-H-1530	ESSENTIAL SER CX FOR PUMP DISCH	CX	3		VT-3			
HANGER CX-H-1531	ESSENTIAL SER CX FOR PUMP DISCH	CX	3		VT-3			
HANGER CX-H-1541	ESSENTIAL SER CX FOR PUMP SUCTION	CX	3		VT-3			
HANGER CX-H-1545	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1546	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1547	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1548	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1549	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1615	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1617	ESSENTIAL SER CX FOR MAIN	CX	3	2-2-11	VT-3			
HANGER CX-H-1618	ESSENTIAL SER CX FOR MAIN	CX	3	2-2-11	VT-3			
HANGER CX-H-1619	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1620	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A ITEM NO. F1.30R		CLASS 1,2, AND 3 COMPONENT SUPPORTS CLASS 3 HANGER - RIGID						
Component	Description	System	Class	Outage	Exam Type	Relief Request		
HANGER CX-H-1621	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1622	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1623	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1624	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1723	ESSENTIAL SER CX FOR MAIN	CX	3	2-3-13	VT-3			
HANGER CX-H-1724	ESSENTIAL SER CX FOR MAIN	CX	3	2-3-13	VT-3			
HANGER CX-H-1725	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1726	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1727	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1728	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1729	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1730	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1731	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1732	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1749	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1750	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1802	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1803	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1804	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1805	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1806	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1807	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1857	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1858	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1865	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1866	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1888	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1889	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			
HANGER CX-H-1890	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3			

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS						
ITEM NO.	F1.30R	CLASS 3 HANGER - RIGID						
Component		Description	System	Class	Outage	Exam Type	Relief Request	
HANGER	CX-H-1891	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3		
HANGER	CX-H-1923	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3		
HANGER	CX-H-1928	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3		
HANGER	CX-H-1929	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3		
HANGER	CX-H-1933	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3		
HANGER	CX-H-1934	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3		
HANGER	CX-H-1935	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3		
HANGER	CX-H-1936	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3		
HANGER	CX-H-1947	ESSENTIAL SER CX FOR MAIN	CX	3	2-1-08	VT-3		
HANGER	CX-H-1948	ESSENTIAL SER CX FOR MAIN	CX	3	2-1-08	VT-3		
HANGER	CX-H-2330	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3		
HANGER	CX-H-2405	ESSENTIAL SER CX FOR MAIN	CX	3		VT-3		
HANGER	EA-H-0314	INTAKE AIR TO D/G B	EA	3		VT-3		
HANGER	EA-H-0317	INTAKE AIR TO D/G B	EA	3	2-1-08	VT-3		
HANGER	MS-H-0172	S/G B OUTLET TO TURB DRIVEN AFW PUMP	MS	3	2-3-13	VT-3		
HANGER	MS-H-0178	STM SUPPLY TO TURB DRIVEN AFW PUMP	MS	3		VT-3		
HANGER	MS-H-0179	STM SUPPLY TO TURB DRIVEN AFW PUMP	MS	3		VT-3		
HANGER	MS-H-0180	STM SUPPLY TO TURB DRIVEN AFW PUMP	MS	3		VT-3		
HANGER	MS-H-0181	STM SUPPLY TO TURB DRIVEN AFW PUMP	MS	3		VT-3		
HANGER	MS-H-0184	STM SUPPLY TO TURB DRIVEN AFW PUMP	MS	3		VT-3		
HANGER	MS-H-0186	STM SUPPLY TO TURB DRIVEN AFW PUMP	MS	3		VT-3		
HANGER	MS-H-0188	STM SUPPLY TO TURB DRIVEN AFW PUMP	MS	3		VT-3		
HANGER	MS-H-0189	STM SUPPLY TO TURB DRIVEN AFW PUMP	MS	3		VT-3		
HANGER	MS-H-0190	STM SUPPLY TO TURB DRIVEN AFW PUMP	MS	3	2-1-09	VT-3		
HANGER	MS-H-0191	STM SUPPLY TO TURB DRIVEN AFW PUMP	MS	3		VT-3		
HANGER	MS-H-0192	STM SUPPLY TO TURB DRIVEN AFW PUMP	MS	3		VT-3		
HANGER	MS-H-0199	STM SUPPLY TO TURB DRIVEN AFW PUMP	MS	3		VT-3		
HANGER	MS-H-0201	TURB DRIVEN AFW PUMP INLET TO MS DRAIN	MS	3		VT-3		
HANGER	MS-H-0411	MS DRAIN HDR INLET TO CONDENSER	MS	3		VT-3		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS						
ITEM NO. F1.30R		CLASS 3 HANGER - RIGID						
Component	Description	System	Class	Outage	Exam Type	Relief Request		
HANGER MS-H-0412	MS DRAIN HDR INLET TO CONDENSER	MS	3		VT-3			
HANGER MS-H-0413	MS DRAIN HDR INLET TO CONDENSER	MS	3		VT-3			
HANGER MS-H-0416	MS DRAIN HDR INLET TO CONDENSER	MS	3		VT-3			
HANGER MS-H-0417	MS DRAIN HDR INLET TO CONDENSER	MS	3	2-1-09	VT-3			
HANGER MS-H-1398	STM SUPPLY TO AFW PUMP TURB 1X-NNS	MS	3		VT-3			
HANGER MS-H-1400	STM SUPPLY TO AFW PUMP TURB 1X-NNS	MS	3		VT-3			
HANGER SF-H-0434	NFP DISCH TO 1&4B PUMP SUCTION	SF	3		VT-3			
HANGER SF-H-0435	NFP DISCH TO 1&4B PUMP SUCTION	SF	3	2-2-10	VT-3			
HANGER SF-H-0436	NFP DISCH TO 1&4B PUMP SUCTION	SF	3		VT-3			
HANGER SF-H-0437	NFP DISCH TO 1&4B PUMP SUCTION	SF	3		VT-3			
HANGER SF-H-0438	NFP DISCH TO 1&4B PUMP SUCTION	SF	3		VT-3			
HANGER SF-H-0439	SFP 1&4B PUMP SUCTION	SF	3		VT-3			
HANGER SF-H-0440	SFP 1&4B PUMP SUCTION	SF	3		VT-3			
HANGER SF-H-0441	SFP 1&4B PUMP SUCTION	SF	3		VT-3			
HANGER SF-H-0442	SFP 1&4B PUMP SUCTION	SF	3		VT-3			
HANGER SF-H-0443	SFP 1&4B PUMP SUCTION	SF	3		VT-3			
HANGER SF-H-0447	SFP 1&4B PUMP SUCTION	SF	3	2-2-11	VT-3			
HANGER SF-H-0448	SFP 1&4B PUMP SUCTION	SF	3		VT-3			
HANGER SF-H-0449	SFP 1&4B PUMP SUCTION	SF	3		VT-3			
HANGER SF-H-0450	SFP 1&4B PUMP SUCTION	SF	3		VT-3			
HANGER SF-H-0451	SFP 1&4B PUMP SUCTION	SF	3		VT-3			
HANGER SF-H-0452	SFP 1&4B PUMP SUCTION	SF	3		VT-3			
HANGER SF-H-0458	SFP PUMP 1&4B DISCH	SF	3		VT-3			
HANGER SF-H-0461	NFP DISCH TO PUMP 1&4A SUCTION	SF	3		VT-3			
HANGER SF-H-0462	NFP DISCH TO PUMP 1&4A SUCTION	SF	3		VT-3			
HANGER SF-H-0463	NFP DISCH TO PUMP 1&4A SUCTION	SF	3		VT-3			
HANGER SF-H-0464	NFP DISCH TO PUMP 1&4A SUCTION	SF	3		VT-3			
HANGER SF-H-0465	NFP DISCH TO PUMP 1&4A SUCTION	SF	3		VT-3			
HANGER SF-H-0467	NFP DISCH TO PUMP 1&4A SUCTION	SF	3	2-2-11	VT-3			

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO. F1.30R		CLASS 3 HANGER - RIGID					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER	SF-H-0468	SFP PUMP 1&4A SUCTION	SF	3		VT-3	
HANGER	SF-H-0473	SFP PUMP 1&4A SUCTION	SF	3		VT-3	
HANGER	SF-H-0474	SFP PUMP 1&4A SUCTION	SF	3		VT-3	
HANGER	SF-H-0477	SFP PUMP 1&4A SUCTION	SF	3		VT-3	
HANGER	SF-H-0479	SFP PUMP 1&4A SUCTION	SF	3		VT-3	
HANGER	SF-H-0481	SFP PUMP 1&4A SUCTION	SF	3		VT-3	
HANGER	SF-H-0484	INLET TO SFPCCS PURIF PUMP	SF	3		VT-3	
HANGER	SF-H-0485	INLET TO SFPCCS PURIF PUMP	SF	3		VT-3	
HANGER	SF-H-0486	INLET TO SFPCCS PURIF PUMP	SF	3	2-2-10	VT-3	
HANGER	SF-H-0490	SFP PUMP 1&4A DISCH	SF	3		VT-3	
HANGER	SF-H-0492	SFP PUMP 1&4A DISCH	SF	3		VT-3	
HANGER	SF-H-0494	SFP PUMP 1&4A DISCH	SF	3		VT-3	
HANGER	SF-H-0503	COMMON TO UNITS 1&4	SF	3		VT-3	
HANGER	SF-H-0504	COMMON TO UNITS 1&4	SF	3		VT-3	
HANGER	SF-H-0505	COMMON TO UNITS 1&4	SF	3		VT-3	
HANGER	SF-H-0512	COMMON TO UNITS 1&4	SF	3		VT-3	
HANGER	SF-H-0513	COMMON TO UNITS 1&4	SF	3		VT-3	
HANGER	SF-H-0882	COMMON TO UNITS 1&4	SF	3		VT-3	
HANGER	SF-H-0890	COMMON TO UNITS 1&4	SF	3		VT-3	
HANGER	SF-H-0892	COMMON TO UNITS 1&4	SF	3		VT-3	
HANGER	SF-H-0893	COMMON TO UNITS 1&4	SF	3	2-2-11	VT-3	
HANGER	SF-H-0894	COMMON TO UNITS 1&4	SF	3		VT-3	
HANGER	SF-H-0902	COMMON TO UNITS 1&4	SF	3		VT-3	
HANGER	SF-H-0910	COMMON TO UNITS 1&4	SF	3		VT-3	
HANGER	SF-H-0914	COMMON TO UNITS 1&4	SF	3		VT-3	
HANGER	SF-H-1151	COMMON TO UNITS 1&4	SF	3		VT-3	
HANGER	SF-H-1152	COMMON TO UNITS 1&4	SF	3		VT-3	
HANGER	SF-H-1175	INLET TO SFPCCS PURIF PUMP	SF	3		VT-3	
HANGER	SF-H-1176	INLET TO SFPCCS PURIF PUMP	SF	3		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A ITEM NO. F1.30R		CLASS 1,2, AND 3 COMPONENT SUPPORTS CLASS 3 HANGER - RIGID						
Component	Description	System	Class	Outage	Exam Type	Relief Request		
HANGER SF-H-1304	SFP PUMP 1&4B DISCH	SF	3		VT-3			
HANGER SF-H-1311	SFP PUMP 1&4A SUCTION	SF	3		VT-3			
HANGER SF-H-1312	SFP PUMP 1&4A SUCTION	SF	3	2-2-11	VT-3			
HANGER SF-H-1313	SFP PUMP 1&4B SUCTION	SF	3		VT-3			
HANGER SF-H-1314	SFP PUMP 1&4B DISCH	SF	3		VT-3			
HANGER SW-H-0001	AFW PUMP 1X-SAB SUCTION	SW	3		VT-3			
HANGER SW-H-0034	SW SUPPLY TO CONT FAN COOLER AH-3	SW	3	2-1-08	VT-3			
HANGER SW-H-0035	SW SUPPLY TO CONT FAN COOLER AH-3	SW	3		VT-3			
HANGER SW-H-0036	SW SUPPLY TO CONT FAN COOLER AH-3	SW	3		VT-3			
HANGER SW-H-0037	SW SUPPLY TO CONT FAN COOLER AH-3	SW	3		VT-3			
HANGER SW-H-0038	SW BOOSTER PUMP A BY-PASS	SW	3		VT-3			
HANGER SW-H-0039	SW BOOSTER PUMP A BY-PASS	SW	3		VT-3			
HANGER SW-H-0040	SW BOOSTER PUMP A BY-PASS	SW	3		VT-3			
HANGER SW-H-0041	SW BOOSTER PUMP A BY-PASS	SW	3		VT-3			
HANGER SW-H-0043	SW RETURN FROM CONT FAN COOLER AH-3	SW	3		VT-3			
HANGER SW-H-0045	SW RETURN FROM CONT FAN COOLERS TO SW RETURN HDR A	SW	3		VT-3			
HANGER SW-H-0048	SW RETURN FROM CONT FAN COOLERS TO SW RETURN HDR A	SW	3	2-2-11	VT-3			
HANGER SW-H-0052	SW RETURN FROM CONT FAN COOLERS TO SW RETURN HDR A	SW	3		VT-3			
HANGER SW-H-0054	SW RETURN FROM CONT FAN COOLERS TO SW RETURN HDR A	SW	3		VT-3			
HANGER SW-H-0060	SW RETURN FROM CONT FAN COOLERS TO SW RETURN HDR A	SW	3		VT-3			
HANGER SW-H-0061	SW SUPPLY TO CONT FAN COOLER AH-2	SW	3		VT-3			
HANGER SW-H-0062	SW SUPPLY TO CONT FAN COOLER AH-2	SW	3		VT-3			
HANGER SW-H-0063	SW SUPPLY TO CONT FAN COOLER AH-2	SW	3		VT-3			
HANGER SW-H-0064	SW SUPPLY TO CONT FAN COOLER AH-2	SW	3		VT-3			
HANGER SW-H-0065	SW SUPPLY TO CONT FAN COOLER AH-2	SW	3		VT-3			
HANGER SW-H-0066	SW SUPPLY TO CONT FAN COOLER AH-2	SW	3		VT-3			
HANGER SW-H-0068	SW SUPPLY TO CONT FAN COOLER AH-2	SW	3	2-2-10	VT-3			
HANGER SW-H-0072	SW SUPPLY TO CONT FAN COOLER AH-2	SW	3		VT-3			
HANGER SW-H-0075	SW SUPPLY TO CONT FAN COOLER AH-2	SW	3		VT-3			

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO. F1.30R		CLASS 3 HANGER - RIGID					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER	SW-H-0076	SW SUPPLY TO CONT FAN COOLER AH-2	SW	3		VT-3	
HANGER	SW-H-0098	SW RETURN FROM CONT FAN COOLER AH-1 TO SW RETURN HDR	SW	3		VT-3	
HANGER	SW-H-0099	SW RETURN FROM CONT FAN COOLER AH-1 TO SW RETURN HDR	SW	3		VT-3	
HANGER	SW-H-0101	SW RETURN FROM CONT FAN COOLER AH-1 TO SW RETURN HDR	SW	3		VT-3	
HANGER	SW-H-0104	SW RETURN FROM CONT FAN COOLER AH-1 TO SW RETURN HDR	SW	3		VT-3	
HANGER	SW-H-0109	SW RETURN FROM CONT FAN COOLER AH-1 TO SW RETURN HDR	SW	3		VT-3	
HANGER	SW-H-0110	SW RETURN FROM CONT FAN COOLER AH-1 TO SW RETURN HDR	SW	3		VT-3	
HANGER	SW-H-0113	SW RETURN FROM CONT FAN COOLER AH-4	SW	3		VT-3	
HANGER	SW-H-0114	SW RETURN FROM CONT FAN COOLER AH-4	SW	3	2-2-10	VT-3	
HANGER	SW-H-0115	SW RETURN FROM CONT FAN COOLER AH-4	SW	3		VT-3	
HANGER	SW-H-0419	FROM SW SUPPLY HDR B TO DG B COOLING	SW	3		VT-3	
HANGER	SW-H-0422	FROM SW SUPPLY HDR B TO DG B COOLING	SW	3		VT-3	
HANGER	SW-H-0423	FROM SW SUPPLY HDR B TO DG B COOLING	SW	3		VT-3	
HANGER	SW-H-0425	FROM SW SUPPLY HDR B TO DG B COOLING	SW	3		VT-3	
HANGER	SW-H-0427	SW BOOSTER PUMP B BY-PASS	SW	3		VT-3	
HANGER	SW-H-0428	SW SUPPLY HDR B FROM SW PUMP DISCH	SW	3		VT-3	
HANGER	SW-H-0429	SW SUPPLY HDR B FROM SW PUMP DISCH	SW	3		VT-3	
HANGER	SW-H-0433	SW SUPPLY HDR B FROM SW PUMP DISCH	SW	3	2-3-13	VT-3	
HANGER	SW-H-0434	SW SUPPLY HDR A FROM SW PUMP DISCH	SW	3		VT-3	
HANGER	SW-H-0435	SW SUPPLY HDR A FROM SW PUMP DISCH	SW	3		VT-3	
HANGER	SW-H-0441	SW FROM SUPPLY HDR A TO CCW HX A	SW	3		VT-3	
HANGER	SW-H-0442	SW FROM SUPPLY HDR A TO CCW HX A	SW	3		VT-3	
HANGER	SW-H-0443	SW FROM SUPPLY HDR A TO CCW HX A	SW	3		VT-3	
HANGER	SW-H-0444	SW FROM SUPPLY HDR A TO CCW HX A	SW	3		VT-3	
HANGER	SW-H-0445	SW FROM SUPPLY HDR A TO CCW HX A	SW	3		VT-3	
HANGER	SW-H-0446	SW FROM SUPPLY HDR A TO CCW HX A	SW	3		VT-3	
HANGER	SW-H-0454	SW FROM SUPPLY HDR A TO DG A COOLING	SW	3		VT-3	
HANGER	SW-H-0455	SW FROM SUPPLY HDR A TO DG A COOLING	SW	3	2-3-13	VT-3	
HANGER	SW-H-0458	SW FROM SUPPLY HDR A TO DG A COOLING	SW	3		VT-3	



Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A ITEM NO. F1.30R		CLASS 1,2, AND 3 COMPONENT SUPPORTS CLASS 3 HANGER - RIGID						
Component	Description	System	Class	Outage	Exam Type	Relief Request		
HANGER SW-H-0459	SW FROM SUPPLY HDR A TO DG A COOLING	SW	3		VT-3			
HANGER SW-H-0462	SW FROM SUPPLY HDR A TO DG A COOLING	SW	3		VT-3			
HANGER SW-H-0463	SW FROM SUPPLY HDR A TO DG A COOLING	SW	3		VT-3			
HANGER SW-H-0466	SW FROM SUPPLY HDR A TO DG A COOLING	SW	3		VT-3			
HANGER SW-H-0467	SW FROM SUPPLY HDR A TO DG A COOLING	SW	3		VT-3			
HANGER SW-H-0481	SW FROM SUPPLY HDR A TO DG A COOLING	SW	3		VT-3			
HANGER SW-H-0483	SW FROM SUPPLY HDR A TO DG A COOLING	SW	3		VT-3			
HANGER SW-H-0495	FROM SW BOOSTER PUMP B DISCH TO CONT FAN COOLERS	SW	3		VT-3			
HANGER SW-H-0496	FROM SW BOOSTER PUMP B DISCH TO CONT FAN COOLERS	SW	3		VT-3			
HANGER SW-H-0500	SW BOOSTER PUMP B DISCH	SW	3		VT-3			
HANGER SW-H-0501	SW BOOSTER PUMP B SUCTION	SW	3		VT-3			
HANGER SW-H-0502	SW BOOSTER PUMP B SUCTION	SW	3		VT-3			
HANGER SW-H-0503	SW BOOSTER PUMP B BY-PASS	SW	3		VT-3			
HANGER SW-H-0505	SW BOOSTER PUMP B BY-PASS	SW	3		VT-3			
HANGER SW-H-0506	SW BOOSTER PUMP B BY-PASS	SW	3		VT-3			
HANGER SW-H-0508	SW BOOSTER PUMP A BY-PASS	SW	3		VT-3			
HANGER SW-H-0509	SW BOOSTER PUMP A BY-PASS	SW	3	2-2-10	VT-3			
HANGER SW-H-0510	FROM SUPPLY HDR A TO SW BOOSTER PUMP A SUCTION	SW	3		VT-3			
HANGER SW-H-0511	SW BOOSTER PUMP A BY-PASS	SW	3		VT-3			
HANGER SW-H-0512	SW BOOSTER PUMP A BY-PASS	SW	3		VT-3			
HANGER SW-H-0513	SW BOOSTER PUMP A BY-PASS	SW	3		VT-3			
HANGER SW-H-0514	SW BOOSTER PUMP A DISCH HDR	SW	3		VT-3			
HANGER SW-H-0515	SW BOOSTER PUMP A DISCH HDR	SW	3		VT-3			
HANGER SW-H-0517	FROM RAB HVAC CHILLER B TO RETURN HDR B	SW	3		VT-3			
HANGER SW-H-0518	FROM RAB HVAC CHILLER B TO RETURN HDR B	SW	3		VT-3			
HANGER SW-H-0519	FROM RAB HVAC CHILLER B TO RETURN HDR B	SW	3	2-3-13	VT-3			
HANGER SW-H-0521	SW RETURN HDR B	SW	3		VT-3			
HANGER SW-H-0522	SW RETURN HDR B	SW	3		VT-3			
HANGER SW-H-0527	SW FROM HX A TO SW RETURN HDR A	SW	3		VT-3			

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO. F1.30R		CLASS 3 HANGER - RIGID					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER	SW-H-0528	SW FROM CCW HX A TO SW RETURN HDR A	SW	3		VT-3	
HANGER	SW-H-0529	SW FROM CCW HX A TO SW RETURN HDR A	SW	3		VT-3	
HANGER	SW-H-0530	SW FROM CCW HX A TO SW RETURN HDR A	SW	3		VT-3	
HANGER	SW-H-0531	SW RETURN HDR A	SW	3		VT-3	
HANGER	SW-H-0532	SW RETURN HDR A	SW	3		VT-3	
HANGER	SW-H-0533	SW RETURN HDR A	SW	3	2-2-11	VT-3	
HANGER	SW-H-0534	SW RETURN HDR A	SW	3		VT-3	
HANGER	SW-H-0535	SW RETURN HDR A	SW	3		VT-3	
HANGER	SW-H-0536	SW RETURN HDR A	SW	3		VT-3	
HANGER	SW-H-0537	SW RETURN HDR A	SW	3		VT-3	
HANGER	SW-H-0538	SW RETURN HDR A	SW	3		VT-3	
HANGER	SW-H-0539	SW RETURN HDR A	SW	3		VT-3	
HANGER	SW-H-0540	SW RETURN HDR A	SW	3		VT-3	
HANGER	SW-H-0609	SW BOOSTER PUMP B HDR TO CONT FAN COOLER AH-1	SW	3		VT-3	
HANGER	SW-H-0610	SW BOOSTER PUMP B HDR TO CONT FAN COOLER AH-1	SW	3		VT-3	
HANGER	SW-H-0612	SW BOOSTER PUMP B HDR TO CONT FAN COOLER AH-1	SW	3	2-2-10	VT-3	
HANGER	SW-H-0613	SW BOOSTER PUMP B HDR TO CONT FAN COOLER AH-1	SW	3		VT-3	
HANGER	SW-H-0620	SW BOOSTER PUMP B HDR TO CONT FAN COOLER AH-1	SW	3		VT-3	
HANGER	SW-H-0621	SW BOOSTER PUMP B HDR TO CONT FAN COOLER AH-1	SW	3		VT-3	
HANGER	SW-H-0625	SW BOOSTER PUMP B BY-PASS	SW	3		VT-3	
HANGER	SW-H-0626	SW BOOSTER PUMP B BY-PASS	SW	3		VT-3	
HANGER	SW-H-0627	SW BOOSTER PUMP B BY-PASS	SW	3		VT-3	
HANGER	SW-H-0628	SW SUPPLY TO CONT FAN COOLER AH-4	SW	3		VT-3	
HANGER	SW-H-0630	SW SUPPLY TO CONT FAN COOLER AH-4	SW	3		VT-3	
HANGER	SW-H-0631	SW SUPPLY TO CONT FAN COOLER AH-4	SW	3		VT-3	
HANGER	SW-H-0912	SW RETURN FROM DG B COOLING TO RETURN HDR B	SW	3	2-3-13	VT-3	
HANGER	SW-H-1231	TO AFW PUMP A SUCTION	SW	3		VT-3	
HANGER	SW-H-1232	TO AFW PUMP A SUCTION	SW	3		VT-3	
HANGER	SW-H-1237	TO RAB HVAC CHILLER A	SW	3		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.30R	CLASS 3 HANGER - RIGID					
Component	Description	System	Class	Outage	Exam Type	Relief Request	
HANGER SW-H-1238	TO RAB HVAC CHILLER A	SW	3		VT-3		
HANGER SW-H-1240	TO RAB HVAC CHILLER A	SW	3		VT-3		
HANGER SW-H-1241	TO RAB HVAC CHILLER A	SW	3		VT-3		
HANGER SW-H-1244	SW TO AFW PUMPS BACK-UP LINES	SW	3		VT-3		
HANGER SW-H-1245	SW TO AFW PUMPS BACK-UP LINES	SW	3		VT-3		
HANGER SW-H-1248	SW TO AFW PUMPS BACK-UP LINES	SW	3		VT-3		
HANGER SW-H-1249	SW TO AFW PUMPS BACK-UP LINES	SW	3	2-2-11	VT-3		
HANGER SW-H-1252	SW TO AFW PUMPS BACK-UP LINES	SW	3		VT-3		
HANGER SW-H-1253	SW TO AFW PUMPS BACK-UP LINES	SW	3		VT-3		
HANGER SW-H-1254	TO AFW PUMP A SUCTION	SW	3		VT-3		
HANGER SW-H-1255	TO AFW PUMP A SUCTION	SW	3		VT-3		
HANGER SW-H-1256	FROM SW SUPPLY HDR TO AFW PUMP 1X BACK-UP LINE	SW	3		VT-3		
HANGER SW-H-1257	FROM SW SUPPLY HDR TO AFW PUMP 1X BACK-UP LINE	SW	3		VT-3		
HANGER SW-H-1262	FROM SW SUPPLY HDR TO AFW PUMP 1X BACK-UP LINE	SW	3		VT-3		
HANGER SW-H-1263	FROM SW SUPPLY HDR TO AFW PUMP 1X BACK-UP LINE	SW	3		VT-3		
HANGER SW-H-1265	AFW PUMP 1X-SAB SUCTION	SW	3		VT-3		
HANGER SW-H-1266	FROM SW SUPPLY HDR B TO AFW PUMP 1X BACK-UP LINE	SW	3	2-3-13	VT-3		
HANGER SW-H-1268	FROM SW SUPPLY HDR B TO AFW PUMP 1X BACK-UP LINE	SW	3		VT-3		
HANGER SW-H-1269	FROM SW SUPPLY HDR B TO AFW PUMP 1X BACK-UP LINE	SW	3		VT-3		
HANGER SW-H-1270	FROM SW SUPPLY HDR B TO AFW PUMP 1X BACK-UP LINE	SW	3		VT-3		
HANGER SW-H-1290	FROM SW SUPPLY HDR B TO CCW HX B	SW	3		VT-3		
HANGER SW-H-1291	FROM SW SUPPLY HDR B TO CCW HX B	SW	3		VT-3		
HANGER SW-H-1292	FROM SW SUPPLY HDR B TO CCW HX B	SW	3		VT-3		
HANGER SW-H-1294	TO AFW PUMPS BACK-UP LINES	SW	3		VT-3		
HANGER SW-H-1295	TO AFW PUMPS BACK-UP LINES	SW	3		VT-3		
HANGER SW-H-1296	TO AFW PUMPS BACK-UP LINES	SW	3		VT-3		
HANGER SW-H-1297	TO AFW PUMPS BACK-UP LINES	SW	3	2-2-10	VT-3		
HANGER SW-H-1298	TO AFW PUMPS BACK-UP LINES	SW	3		VT-3		
HANGER SW-H-1299	TO AFW PUMPS BACK-UP LINES	SW	3		VT-3		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS						
ITEM NO. F1.30R		CLASS 3 HANGER - RIGID						
Component	Description	System	Class	Outage	Exam Type	Relief Request		
HANGER SW-H-1300	TO AFW PUMPS BACK-UP LINES	SW	3		VT-3			
HANGER SW-H-1301	TO AFW PUMPS BACK-UP LINES	SW	3		VT-3			
HANGER SW-H-1302	TO AFW PUMP B SUCTION	SW	3		VT-3			
HANGER SW-H-1303	TO AFW PUMP B SUCTION	SW	3		VT-3			
HANGER SW-H-1304	TO AFW PUMP B SUCTION	SW	3		VT-3			
HANGER SW-H-1305	TO AFW PUMP B SUCTION	SW	3		VT-3			
HANGER SW-H-1306	TO AFW PUMP B SUCTION	SW	3		VT-3			
HANGER SW-H-1307	TO AFW PUMP B SUCTION	SW	3		VT-3			
HANGER SW-H-1310	TO AFW PUMP B SUCTION	SW	3	2-2-10	VT-3			
HANGER SW-H-1343	SW RETURN HDR A TO NORM SW DISCH HDR	SW	3		VT-3			
HANGER SW-H-1363	FROM SW SUPPLY HDR B TO DG B COOLING	SW	3		VT-3			
HANGER SW-H-1421	SW RETURN FROM CONT FAN COOLERS TO SW RETURN HDR A	SW	3		VT-3			
HANGER SW-H-1422	SW RETURN FROM CONT FAN COOLERS TO SW RETURN HDR A	SW	3		VT-3			
HANGER SW-H-1454	FROM RAB HVAC CHILLER A TO RETURN HDR A	SW	3		VT-3			
HANGER SW-H-1457	FROM RAB HVAC CHILLER A TO RETURN HDR A	SW	3		VT-3			
HANGER SW-H-1460	FROM RAB HVAC CHILLER A TO RETURN HDR A	SW	3		VT-3			
HANGER SW-H-1503	FROM RAB HVAC CHILLER B TO RETURN HDR B	SW	3		VT-3			
HANGER SW-H-1507	FROM RAB HVAC CHILLER B TO RETURN HDR B	SW	3	2-3-13	VT-3			
HANGER SW-H-1508	FROM RAB HVAC CHILLER B TO RETURN HDR B	SW	3		VT-3			
HANGER SW-H-1534	SW FROM CCW HX A TO SW RETURN HDR A	SW	3		VT-3			
HANGER SW-H-1535	SW FROM CCW HX A TO SW RETURN HDR A	SW	3		VT-3			
HANGER SW-H-1536	SW FROM CCW HX A TO SW RETURN HDR A	SW	3		VT-3			
HANGER SW-H-1539	SW FROM CCW HX A TO SW RETURN HDR A	SW	3		VT-3			
HANGER SW-H-1540	SW FROM CCW HX A TO SW RETURN HDR A	SW	3		VT-3			
HANGER SW-H-1567	TO RAB HVAC CHILLER B	SW	3		VT-3			
HANGER SW-H-1568	TO RAB HVAC CHILLER B	SW	3		VT-3			
HANGER SW-H-1572	TO RAB HVAC CHILLER B	SW	3		VT-3			
HANGER SW-H-1573	TO RAB HVAC CHILLER B	SW	3	2-3-13	VT-3			
HANGER SW-H-1574	TO RAB HVAC CHILLER B	SW	3		VT-3			



Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A ITEM NO. F1.30R		CLASS 1,2, AND 3 COMPONENT SUPPORTS CLASS 3 HANGER - RIGID						
Component	Description	System	Class	Outage	Exam Type	Relief Request		
HANGER SW-H-1575	TO RAB HVAC CHILLER B	SW	3		VT-3			
HANGER SW-H-1576	TO RAB HVAC CHILLER B	SW	3		VT-3			
HANGER SW-H-1577	TO RAB HVAC CHILLER B	SW	3		VT-3			
HANGER SW-H-1578	TO RAB HVAC CHILLER B	SW	3		VT-3			
HANGER SW-H-1579	TO RAB HVAC CHILLER B	SW	3		VT-3			
HANGER SW-H-1580	TO AFW PUMP B SUCTION	SW	3		VT-3			
HANGER SW-H-1581	TO AFW PUMP B SUCTION	SW	3		VT-3			
HANGER SW-H-1600	SW FROM CCW HX B TO SW RETURN HDR B	SW	3		VT-3			
HANGER SW-H-1606	SW FROM CCW HX B TO SW RETURN HDR B	SW	3	2-2-11	VT-3			
HANGER SW-H-1651	SW RETURN HDR A TO NORM SW DISCH HDR	SW	3		VT-3			
HANGER SW-H-1676	SW RETURN FROM CONT FAN COOLERS TO SW RETURN HDR A	SW	3		VT-3			
HANGER SW-H-1677	SW RETURN FROM CONT FAN COOLERS TO SW RETURN HDR A	SW	3		VT-3			
HANGER SW-H-1713	SW RETURN FROM CONT FAN COOLERS TO SW RETURN HDR B	SW	3		VT-3			
HANGER SW-H-1719	SW RETURN FROM CONT FAN COOLERS TO SW RETURN HDR A	SW	3		VT-3			
HANGER SW-H-1737	SW RETURN FROM CONT FAN COOLERS TO SW RETURN HDR B	SW	3		VT-3			
HANGER SW-H-1738	SW RETURN FROM CONT FAN COOLERS TO SW RETURN HDR B	SW	3		VT-3			
HANGER SW-H-1740	SW RETURN FROM CONT FAN COOLER AH-4	SW	3		VT-3			
HANGER SW-H-1742	SW RETURN FROM CONT FAN COOLER AH-4	SW	3		VT-3			
HANGER SW-H-1825	SW SUPPLY TO CONT FAN COOLER AH-3	SW	3		VT-3			
HANGER SW-H-1826	SW BOOSTER PUMP B HDR TO CONT FAN COOLER AH-1	SW	3		VT-3			
HANGER SW-H-1828	SW SUPPLY TO CONT FAN COOLER AH-4	SW	3		VT-3			
HANGER SW-H-1830	SW SUPPLY TO CONT FAN COOLER AH-2	SW	3		VT-3			
HANGER SW-H-1870	SW FROM RETURN HDR B TO CIRC WATER DISCH	SW	3		VT-3			
HANGER SW-H-1871	SW FROM RETURN HDR B TO CIRC WATER DISCH	SW	3	2-3-13	VT-3			
HANGER SW-H-2076	SW RETURN FROM CONT FAN COOLERS TO SW RETURN HDR A	SW	3		VT-3			
HANGER SW-H-2080	SW RETURN FROM DG A COOLING TO SW RETURN HDR A	SW	3		VT-3			
HANGER SW-H-2081	SW BOOSTER PUMP B BY-PASS	SW	3		VT-3			
HANGER SW-H-2097	TO RAB HVAC CHILLER B	SW	3	2-3-13	VT-3			
HANGER SW-H-2101	TO RAB HVAC CHILLER B	SW	3		VT-3			

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS				
ITEM NO.	F1.30R	CLASS 3 HANGER - RIGID				
Component	Description	System	Class	Outage	Exam Type	Relief Request
HANGER	SW-H-2102	TO RAB HVAC CHILLER B	SW	3		VT-3
HANGER	SW-H-2103	TO RAB HVAC CHILLER B	SW	3		VT-3
HANGER	SW-H-2104	TO RAB HVAC CHILLER B	SW	3		VT-3
HANGER	SW-H-2105	TO RAB HVAC CHILLER B	SW	3		VT-3
HANGER	SW-H-2106	TO RAB HVAC CHILLER B	SW	3		VT-3
HANGER	SW-H-2107	SW FOR HVAC ESW CHILLER WC-2B RECIRC LOOP - PUMP P-7B D	SW	3		VT-3
HANGER	SW-H-2108	SW FOR HVAC ESW CHILLER WC-2B RECIRC LOOP - PUMP P-7B D	SW	3		VT-3
HANGER	SW-H-2115	WATER CHILLER WC-2B P-7B DISCH	SW	3		VT-3
HANGER	SW-H-2117	TO RAB HVAC CHILLER A	SW	3	2-3-13	VT-3
HANGER	SW-H-2119	TO RAB HVAC CHILLER A	SW	3		VT-3
HANGER	SW-H-2120	TO RAB HVAC CHILLER A	SW	3		VT-3
HANGER	SW-H-2121	TO RAB HVAC CHILLER A	SW	3		VT-3
HANGER	SW-H-2122	TO RAB HVAC CHILLER A	SW	3		VT-3
HANGER	SW-H-2123	TO RAB HVAC CHILLER A	SW	3		VT-3
HANGER	SW-H-2124	TO RAB HVAC CHILLER A	SW	3		VT-3
HANGER	SW-H-2131	SW FOR HVAC ESW CHILLER WC-2A RECIRC LOOP - PUMP P-7A D	SW	3		VT-3
HANGER	SW-H-2132	SW FOR HVAC ESW CHILLER WC-2A RECIRC LOOP - PUMP P-7A D	SW	3		VT-3
HANGER	SW-H-2135	WATER CHILLER WC-2A P-7A DISCH	SW	3		VT-3
HANGER	SW-H-2136	WATER CHILLER WC-2A P-7A DISCH	SW	3	2-3-13	VT-3
HANGER	SW-H-2137	SW FOR HVAC ESW CHILLER WC-2A RECIRC LOOP - PUMP P-7A D	SW	3		VT-3
HANGER	SW-H-2138	FROM RAB HVAC CHILLER A TO RETURN HDR A	SW	3		VT-3
HANGER	SW-H-2142	SW FOR HVAC ESW CHILLER WC-2A RECIRC LOOP - PUMP P-7A S	SW	3		VT-3
HANGER	SW-H-2143	SW FOR HVAC ESW CHILLER WC-2A RECIRC LOOP - PUMP P-7A S	SW	3		VT-3
HANGER	SW-H-2144	SW FOR HVAC ESW CHILLER WC-2A RECIRC LOOP - PUMP P-7A S	SW	3	2-3-13	VT-3
HANGER	SW-H-2177	FROM SW SUPPLY HDR B TO DG B COOLING	SW	3		VT-3
HANGER	SW-H-2230	SW RETURN HDR A	SW	3		VT-3
HANGER	SW-H-2295	SW RETURN FROM CONT FAN COOLER AH-1 TO SW RETURN HDR	SW	3		VT-3
HANGER	SW-H-2296	SW RETURN FROM CONT FAN COOLER AH-1 TO SW RETURN HDR	SW	3		VT-3
HANGER	SW-H-2299	SW RETURN FROM CONT FAN COOLER AH-1 TO SW RETURN HDR	SW	3		VT-3

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.30R	CLASS 3 HANGER - RIGID					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER	SW-H-2306	SW BOOSTER PUMP B BY-PASS	SW	3		VT-3	
HANGER	SW-H-2334	FROM RAB HVAC CHILLER A TO RETURN HDR A	SW	3		VT-3	
HANGER	SW-H-2335	TO AFW PUMP A SUCTION	SW	3		VT-3	
HANGER	SW-H-2339	FROM SUPPLY HDR A TO SW BOOSTER PUMP A SUCTION	SW	3		VT-3	
HANGER	SW-H-2353	FROM HVAC CHILLER B TO RETURN HDR B	SW	3		VT-3	
HANGER	SW-H-2354	FROM RAB HVAC CHILLER B TO RETURN HDR B	SW	3		VT-3	
HANGER	SW-H-2356	FROM RAB HVAC CHILLER B TO RETURN HDR B	SW	3		VT-3	
HANGER	SW-H-2357	FROM RAB HVAC CHILLER B TO RETURN HDR B	SW	3		VT-3	
HANGER	SW-H-2358	SW FOR HVAC ESW CHILLER B RECIRC LOOP - PUMP P-7B SUCTI	SW	3		VT-3	
HANGER	SW-H-2359	SW FOR HVAC ESW CHILLER B RECIRC LOOP - PUMP P-7B SUCTI	SW	3	2-3-13	VT-3	
HANGER	SW-H-2360	SW FOR HVAC ESW CHILLER B RECIRC LOOP - PUMP P-7B SUCTI	SW	3		VT-3	
HANGER	SW-H-2361	SW FOR HVAC ESW CHILLER B RECIRC LOOP - PUMP P-7B SUCTI	SW	3		VT-3	
HANGER	SW-H-2539	SW BOOSTER PUMP B DISCH	SW	3		VT-3	
HANGER	SW-H-2540	FROM SW BOOSTER PUMP B DISCH TO CONT FAN COOLERS	SW	3		VT-3	
HANGER	SW-H-2580	SW RETURN HDR A	SW	3		VT-3	
HANGER	SW-H-2593	SW RETURN HDR A	SW	3		VT-3	
HANGER	SW-H-2594	SW RETURN HDR A	SW	3		VT-3	
HANGER	SW-H-2595	SW FROM RETURN HDR B TO CIRC WATER DISCH	SW	3		VT-3	
HANGER	SW-H-2596	SW FROM RETURN HDR B TO CIRC WATER DISCH	SW	3		VT-3	
HANGER	SW-H-2598	SW RETURN HDR A	SW	3	2-2-10	VT-3	
HANGER	SW-H-2672	SW FROM RETURN HDR B TO CIRC WATER DISCH	SW	3		VT-3	
HANGER	SW-H-2673	SW FROM RETURN HDR B TO CIRC WATER DISCH	SW	3		VT-3	
HANGER	SW-H-2679	SW RETURN HDR A	SW	3		VT-3	
HANGER	SW-H-2680	SW RETURN HDR A	SW	3		VT-3	
HANGER	SW-H-2681	SW RETURN HDR A	SW	3		VT-3	
HANGER	SW-H-2682	SW RETURN HDR A	SW	3		VT-3	
HANGER	SW-H-2683	SW RETURN HDR A	SW	3		VT-3	
HANGER	SW-H-2684	SW RETURN HDR A	SW	3		VT-3	
HANGER	SW-H-2685	SW RETURN HDR A	SW	3		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.30R	CLASS 3 HANGER - RIGID					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER SW-H-2686		SW RETURN HDR A	SW	3	2-2-10	VT-3	
HANGER SW-H-2749		SW RETURN FROM DG A COOLING TO SW RETURN HDR A	SW	3		VT-3	
HANGER SW-H-2750		SW RETURN FROM DG A COOLING TO SW RETURN HDR A	SW	3		VT-3	
HANGER SW-H-2801		TO AFW PUMP B SUCTION	SW	3		VT-3	
HANGER SW-H-2806		FROM RAB HVAC CHILLER A TO RETURN HDR A	SW	3		VT-3	
HANGER SW-H-2807		FROM RAB HVAC CHILLER A TO RETURN HDR A	SW	3		VT-3	
HANGER SW-H-2896		ESW STRAINER BACKWASH HDR	SW	3		VT-3	
HANGER SW-H-2897		ESW STRAINER BACKWASH HDR	SW	3		VT-3	
HANGER SW-H-2898		ESW STRAINER BACKWASH HDR	SW	3		VT-3	
HANGER SW-H-2920		SW SUPPLY HDR B FROM SW PUMP DISCH	SW	3		VT-3	
HANGER SW-H-3227		CHILLER WC-2A P-7A DISCH	SW	3	2-3-13	VT-3	
HANGER SW-H-3230		FROM SW SUPPLY HDR B TO DG B COOLING	SW	3		VT-3	
HANGER SW-H-3241		SW FROM RETURN HDR B TO CIRC WATER DISCH	SW	3		VT-3	
HANGER SW-H-3242		SW FROM RETURN HDR B TO CIRC WATER DISCH	SW	3		VT-3	
HANGER SW-H-3243		SW FROM RETURN HDR B TO CIRC WATER DISCH	SW	3		VT-3	
HANGER SW-H-3244		SW FROM RETURN HDR B TO CIRC WATER DISCH	SW	3		VT-3	
HANGER SW-H-3245		SW FROM RETURN HDR B TO CIRC WATER DISCH	SW	3		VT-3	
HANGER SW-H-3246		SW FROM RETURN HDR B TO CIRC WATER DISCH	SW	3		VT-3	
HANGER SW-H-3247		SW FROM RETURN HDR B TO CIRC WATER DISCH	SW	3		VT-3	
HANGER SW-H-3248		SW FROM RETURN HDR B TO CIRC WATER DISCH	SW	3		VT-3	
HANGER SW-H-3975		SW RETURN FROM DG A COOLING TO SW RETURN HDR A	SW	3		VT-3	
HANGER SW-H-4147		SW RETURN FROM DG B COOLING TO RETURN HDR B	SW	3		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.30S	CLASS 3 HANGER - SNUBBER					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER	AF-H-0001	AFW PUMPS A & B DISCH TO VALVE AF-92	AF	3		VT-3	
HANGER	AF-H-0013	AFW PUMP 1X-SAB DISCH TO VALVE AF-136	AF	3		VT-3	
HANGER	AF-H-0043	AFW PUMP 1X-SAB DISCH TO VALVE AF-142	AF	3		VT-3	
HANGER	AF-H-0060	AFW PUMPS A & B DISCH TO VALVE AF-73	AF	3		VT-3	
HANGER	AF-H-0167	DNSTRM OF VALVE AF-42	AF	3		VT-3	
HANGER	AF-H-0170	AFW PUMP 1X-SAB DISCH TO VALVE AF-148	AF	3		VT-3	
HANGER	AF-H-0189	AFW PUMPS A&B DISCH TO VALVE AF-73	AF	3		VT-3	
HANGER	AF-H-0197	AFW PUMPS A&B DISCH TO VALVE AF-73	AF	3	2-1-08	VT-3	
HANGER	AF-H-0213	AFW PUMP A OUTLET TO DISCH HDR	AF	3		VT-3	
HANGER	AF-H-0232	AFW PUMP A OUTLET TO DISCH HDR	AF	3		VT-3	
HANGER	AF-H-0256	AFW PUMP 1X-SAB DISCH TO VALVE AF-136	AF	3		VT-3	
HANGER	AF-H-0274	AFW PUMP 1X-SAB DISCH TO VALVE AF-136	AF	3		VT-3	
HANGER	AF-H-0279	AFW PUMP 1X-SAB DISCH TO VALVE AF-142	AF	3	2-1-09	VT-3	
HANGER	AF-H-0398	AFW PUMP 1X-SAB DISCH TO VALVE AF-142	AF	3		VT-3	
HANGER	AF-H-0415	AFW PUMPS A & B DISCH TO VALVE AF-92	AF	3		VT-3	
HANGER	CC-H-0093	BETWEEN VALVES CC-95 AND CC-99	CC	3		VT-3	
HANGER	CC-H-0353	HDR TO HXs	CC	3	2-1-08	VT-3	
HANGER	CC-H-0356	HDR TO HXs	CC	3		VT-3	
HANGER	CC-H-0357	HDR TO HXs	CC	3		VT-3	
HANGER	CC-H-0391	UPSTRM OF VALVE CC-156	CC	3		VT-3	
HANGER	CC-H-0401	RHR HX B INLET	CC	3		VT-3	
HANGER	CC-H-0417	RCP A DISCH TO RETURN HDR	CC	3		VT-3	
HANGER	CC-H-0420	RCP A DISCH TO RETURN HDR	CC	3		VT-3	
HANGER	CC-H-0427	TO RETURN HDR FROM RCDT HX & EX LTDN HX	CC	3		VT-3	
HANGER	CC-H-0457	HDR TO HXs	CC	3		VT-3	
HANGER	CC-H-0459	HDR TO HXs	CC	3	2-3-13	VT-3	
HANGER	CC-H-0461	HDR TO HXs	CC	3		VT-3	
HANGER	CC-H-0463	HDR TO HXs	CC	3		VT-3	
HANGER	CC-H-0465	HDR TO HXs	CC	3		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO. F1.30S		CLASS 3 HANGER - SNUBBER					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER	CC-H-0466	HDR TO HXs	CC	3		VT-3	
HANGER	CC-H-0476	RETURN HDR TO CC PUMP B SUCTION	CC	3		VT-3	
HANGER	CC-H-0496	RHR HX B INLET	CC	3		VT-3	
HANGER	CC-H-0501	RHR HX B INLET	CC	3		VT-3	
HANGER	CC-H-0503	RHR HX B INLET	CC	3		VT-3	
HANGER	CC-H-0570	LTDN HX OUTLET TO RETURN HDR	CC	3		VT-3	
HANGER	CC-H-0681	LTDN HX INLET FROM HDR	CC	3	2-3-13	VT-3	
HANGER	CC-H-0882	BETWEEN VALVES CC-27 AND CC-128	CC	3		VT-3	
HANGER	CC-H-0910	RHR HX A OUTLET	CC	3		VT-3	
HANGER	CC-H-0916	RHR HX A OUTLET	CC	3		VT-3	
HANGER	CC-H-0918	RHR HX A OUTLET	CC	3		VT-3	
HANGER	CC-H-0919	RHR HX A OUTLET	CC	3		VT-3	
HANGER	CC-H-0950	CC PUMP A DISCH TO CC HX A	CC	3		VT-3	
HANGER	CC-H-1443	RCP A SUCTION	CC	3		VT-3	
HANGER	CC-H-1444	RCP A SUCTION	CC	3		VT-3	
HANGER	CC-H-1584	BETWEEN VALVES CC-27 & CC-128	CC	3		VT-3	
HANGER	CC-H-1668	RCP A BRNG DISCH	CC	3	2-3-13	VT-3	
HANGER	CC-H-1733	RCP A SUCTION UPSTRM OF VALVE CC-488	CC	3		VT-3	
HANGER	CC-H-1838	HDR TO HXs	CC	3		VT-3	
HANGER	CC-H-2055	RETURN HDR TO CC PUMP A SUCTION	CC	3		VT-3	
HANGER	CH-H-1739	ESSENTIAL SERVICE CH FOR MAIN	CH	3	2-1-08	VT-3	
HANGER	MS-H-0167	S/G B OUTLET TO TURB DRIVEN AFW PUMP	MS	3		VT-3	
HANGER	MS-H-0170	S/G B OUTLET TO TURB DRIVEN AFW PUMP	MS	3		VT-3	
HANGER	MS-H-0171	S/G B OUTLET TO TURB DRIVEN AFW PUMP	MS	3		VT-3	
HANGER	MS-H-0173	S/G C OUTLET TO TURB DRIVEN AFW PUMP	MS	3		VT-3	
HANGER	MS-H-0176	S/G C OUTLET TO TURB DRIVEN AFW PUMP	MS	3		VT-3	
HANGER	MS-H-0185	STM SUPPLY TO TURB DRIVEN AFW PUMP	MS	3		VT-3	
HANGER	MS-H-0187	STM SUPPLY TO TURB DRIVEN AFW PUMP	MS	3		VT-3	
HANGER	MS-H-0193	STM SUPPLY TO TURB DRIVEN AFW PUMP	MS	3		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.30S	CLASS 3 HANGER - SNUBBER					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER MS-H-0197		STM SUPPLY TO TURB DRIVEN AFW PUMP	MS	3		VT-3	
HANGER MS-H-0198		STM SUPPLY TO TURB DRIVEN AFW PUMP	MS	3		VT-3	
HANGER MS-H-0200		TURB DRIVEN AFW PUMP INLET TO MS DRAIN	MS	3	2-2-10	VT-3	
HANGER MS-H-0202		STM SUPPLY TO TURB DRIVEN AFW PUMP	MS	3		VT-3	
HANGER MS-H-0410		MS DRAIN HDR INLET TO CONDENSER	MS	3		VT-3	
HANGER MS-H-0415		MS DRAIN HDR INLET TO CONDENSER	MS	3		VT-3	
HANGER MS-H-1389		VENT ON AFW PUMP TURB 1X-NNS	MS	3		VT-3	
HANGER MS-H-1390		VENT ON AFW PUMP TURB 1X-NNS	MS	3		VT-3	
HANGER MS-H-1391		VENT ON AFW PUMP TURB 1X-NNS	MS	3		VT-3	
HANGER MS-H-1392		VENT ON AFW PUMP TURB 1X-NNS	MS	3		VT-3	
HANGER MS-H-1403		STM SUPPLY TO AFW PUMP TURB 1X-NNS	MS	3		VT-3	
HANGER MS-H-1406		STM SUPPLY TO AFW PUMP TURB 1X-NNS	MS	3		VT-3	
HANGER SF-H-0470		SFP PUMP 1&4A SUCTION	SF	3	2-1-08	VT-3	
HANGER SF-H-0891		COMMON TO UNITS 1&4	SF	3		VT-3	
HANGER SF-H-0911		COMMON TO UNITS 1&4	SF	3		VT-3	
HANGER SF-H-0918		COMMON TO UNITS 1&4	SF	3		VT-3	
HANGER SF-H-1305		SFP PUMP 1&4A DISCH	SF	3		VT-3	
HANGER SW-H-0611		SW BOOSTER PUMP B HDR TO CONT FAN COOLER AH-1	SW	3	2-2-10	VT-3	
HANGER SW-H-0629		SW SUPPLY TO CONT FAN COOLER AH-4	SW	3		VT-3	
HANGER SW-H-1264		AFW PUMP 1X-SAB SUCTION	SW	3		VT-3	
HANGER SW-H-1293		FROM SW SUPPLY HDR B TO CCW HX B	SW	3		VT-3	
HANGER SW-H-1824		SW SUPPLY TO CONT FAN COOLER AH-3	SW	3		VT-3	
HANGER SW-H-1831		SW SUPPLY TO CONT FAN COOLER AH-2	SW	3		VT-3	
HANGER SW-H-2352		FROM RAB HVAC CHILLER B TO RETURN HDR B	SW	3		VT-3	
HANGER SW-H-2355		FROM RAB HVAC CHILLER B TO RETURN HDR B	SW	3		VT-3	
HANGER SW-H-2597		SW FROM RETURN HDR B TO CIRC WATER DISCH	SW	3	2-2-10	VT-3	
HANGER SW-H-2643		TO AFW PUMP B SUCTION	SW	3		VT-3	
HANGER SW-H-2800		AFW PUMP 1X-SAB SUCTION	SW	3		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS						
ITEM NO. F1.30V		CLASS 3 HANGER - VARIABLE (SPRING CAN)						
Component	Description	System	Class	Outage	Exam Type	Relief Request		
HANGER CC-H-0406	RHR HX B INLET	CC	3		VT-3			
HANGER CC-H-0904	CC PUMP C SUCTION INLET	CC	3	2-2-10	VT-3			
HANGER CC-H-0905	RHR HX A OUTLET	CC	3		VT-3			
HANGER CC-H-1087	RCP A BRNGS DISCH UPSTRM TO VALVE CC-202	CC	3		VT-3			
HANGER CE-H-0003	COND FROM CST TO AF PUMPS SUCTION	CE	3		VT-3			
HANGER CE-H-0009	COND TO AF PUMP B SUCTION	CE	3	2-2-10	VT-3			
HANGER CE-H-0011	COND TO AF PUMP A SUCTION	CE	3		VT-3			
HANGER CE-H-0226	COND FROM CST TO AF PUMPS SUCTION	CE	3		VT-3			
HANGER MS-H-0169	S/G B OUTLET TO TURB DRIVEN AFW PUMP	MS	3		VT-3			
HANGER MS-H-0175	S/G C OUTLET TO TURB DRIVEN AFW PUMP	MS	3	2-2-11	VT-3			
HANGER MS-H-0444	MS DRAIN HDR INLET TO CONDENSER	MS	3		VT-3			
HANGER MS-H-0445	MS DRAIN HDR INLET TO CONDENSER	MS	3		VT-3			
HANGER MS-H-0522	MS DRAIN HDR INLET TO CONDENSER	MS	3		VT-3			
HANGER MS-H-1387	FROM AFW PUMP TURB EXHAUST	MS	3		VT-3			
HANGER MS-H-1388	VENT ON AFW PUMP TURB 1X-NNS	MS	3		VT-3			
HANGER MS-H-1394	VENT ON AFW PUMP TURB 1X-NNS	MS	3		VT-3			
HANGER MS-H-1402	STM SUPPLY TO AFW PUMP TURB 1X-NNS	MS	3		VT-3			
HANGER MS-H-1405	STM SUPPLY TO AFW PUMP TURB 1X-NNS	MS	3		VT-3			
HANGER MS-H-1407	STM SUPPLY TO AFW PUMP TURB 1X-NNS	MS	3		VT-3			
HANGER SF-H-1303	SFP PUMP 1&4B DISCH	SF	3		VT-3			
HANGER SF-H-1307	SFP PUMP 1&4A DISCH	SF	3		VT-3			
HANGER SF-H-1308	EMER COOLING CONN ON SFP PUMP 1&4A DISCH	SF	3	2-2-10	VT-3			
HANGER SF-H-1309	SFP PUMP 1&4A DISCH	SF	3		VT-3			
HANGER SF-H-1310	SFP PUMPS CONN TO TRANSFER CANAL	SF	3		VT-3			
HANGER SW-H-2126	TO RAB HVAC CHILLER A	SW	3		VT-3			
HANGER SW-H-2145	SW FOR HVAC ESW CHILLER WC-2A RECIRC LOOP - PUMP P-7A S	SW	3		VT-3			
HANGER SW-H-2336	SW FROM CCW HX A TO SW RETURN HDR A	SW	3		VT-3			
HANGER SW-H-2350	FROM RAB HVAC CHILLER B TO RETURN HDR B	SW	3		VT-3			
HANGER SW-H-2671	SW FROM CCW HX B TO SW RETURN HDR B	SW	3		VT-3			

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A		CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO. F1.30V		CLASS 3 HANGER - VARIABLE (SPRING CAN)					
Component		Description	System	Class	Outage	Exam Type	Relief Request
HANGER SW-H-2799		AFW PUMP 1X-SAB SUCTION	SW	3		VT-3	
HANGER SW-H-2805		SW FROM SW SUPPLY HDR B TO CCW HX B	SW	3		VT-3	
HANGER SW-H-2808		SW FOR HVAC ESW CHILLER WC-2A RECIRC LOOP - PUMP P-7A S	SW	3		VT-3	
HANGER SW-H-2810		SW FOR HVAC ESW CHILLER WC-2A RECIRC LOOP - PUMP P-7A S	SW	3		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.40	SUPPORTS OTHER THAN PIPING SUPPORTS					
Component	Description	System	Class	Outage	Exam Type	Relief Request	
II-AH-001A-H-001	CONT FAN COOLER AH-1		2		VT-3		
II-AH-001A-H-002	"		2		VT-3		
II-AH-001A-H-003	"		2		VT-3		
II-AH-001A-H-004	"		2		VT-3		
II-AH-001A-H-005	"		2		VT-3		
II-AH-001A-H-006	"		2		VT-3		
II-AH-001A-H-007	"		2		VT-3		
II-AH-001A-H-008	"		2		VT-3		
II-AH-001A-H-009	"		2		VT-3		
II-AH-001A-H-010	"		2		VT-3		
II-AH-001A-H-011	"		2		VT-3		
II-AH-001A-H-012	"		2		VT-3		
II-AH-001A-H-013	"		2		VT-3		
II-AH-001A-H-014	"		2		VT-3		
II-AH-001A-H-015	"		2		VT-3		
II-AH-001A-H-016	"		2		VT-3		
II-AH-001A-H-017	"		2		VT-3		
II-AH-001A-H-018	"		2		VT-3		
II-AH-001A-H-019	"		2		VT-3		
II-AH-001A-H-020	"		2		VT-3		
II-AH-001A-H-021	"		2		VT-3		
II-AH-001A-H-022	"		2		VT-3		
II-AH-001A-H-023	"		2		VT-3		
II-AH-001A-H-024	"		2		VT-3		
II-AH-001A-H-025	"		2		VT-3		
II-AH-001A-H-026	"		2		VT-3		
II-AH-001A-H-027	"		2		VT-3		
II-AH-001A-H-028	"		2		VT-3		
II-AH-001A-H-029	"		2		VT-3		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.40	SUPPORTS OTHER THAN PIPING SUPPORTS					
Component	Description	System	Class	Outage	Exam Type	Relief Request	
II-AH-001A-H-030	"		2		VT-3		
II-AH-001A-H-031	"		2		VT-3		
II-AH-001B-H-001	"		2		VT-3		
II-AH-001B-H-002	"		2		VT-3		
II-AH-001B-H-003	"		2		VT-3		
II-AH-001B-H-004	"		2		VT-3		
II-AH-001B-H-005	"		2		VT-3		
II-AH-001B-H-006	"		2		VT-3		
II-AH-001B-H-007	"		2		VT-3		
II-AH-001B-H-008	"		2		VT-3		
II-AH-001B-H-009	"		2		VT-3		
II-AH-001B-H-010	"		2		VT-3		
II-AH-001B-H-011	"		2		VT-3		
II-AH-001B-H-012	"		2		VT-3		
II-AH-001B-H-013	"		2		VT-3		
II-AH-001B-H-014	"		2		VT-3		
II-AH-001B-H-015	"		2		VT-3		
II-AH-001B-H-016	"		2		VT-3		
II-AH-001B-H-017	"		2		VT-3		
II-AH-001B-H-018	"		2		VT-3		
II-AH-001B-H-019	"		2		VT-3		
II-AH-001B-H-020	"		2		VT-3		
II-AH-001B-H-021	"		2		VT-3		
II-AH-001B-H-022	"		2		VT-3		
II-AH-001B-H-023	"		2		VT-3		
II-AH-001B-H-024	"		2		VT-3		
II-AH-001B-H-025	"		2		VT-3		
II-AH-001B-H-026	"		2		VT-3		
II-AH-001B-H-027	"		2		VT-3		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.40	SUPPORTS OTHER THAN PIPING SUPPORTS					
Component	Description	System	Class	Outage	Exam Type	Relief Request	
II-AH-001B-H-028	"		2		VT-3		
II-AH-001B-H-029	"		2		VT-3		
II-AH-001B-H-030	"		2		VT-3		
II-AH-001B-H-031	"		2		VT-3		
II-AH-002A-H-001	CONT FAN COOLER AH-2		2	2-2-10	VT-3		
II-AH-002A-H-002	"		2	2-2-10	VT-3		
II-AH-002A-H-003	"		2	2-2-10	VT-3		
II-AH-002A-H-004	"		2	2-2-10	VT-3		
II-AH-002A-H-005	"		2	2-2-10	VT-3		
II-AH-002A-H-006	"		2	2-2-10	VT-3		
II-AH-002A-H-007	"		2	2-2-10	VT-3		
II-AH-002A-H-008	"		2	2-2-10	VT-3		
II-AH-002A-H-009	"		2	2-2-10	VT-3		
II-AH-002A-H-010	"		2	2-2-10	VT-3		
II-AH-002A-H-011	"		2	2-2-10	VT-3		
II-AH-002A-H-012	"		2	2-2-10	VT-3		
II-AH-002A-H-013	"		2	2-2-10	VT-3		
II-AH-002A-H-014	"		2	2-2-10	VT-3		
II-AH-002A-H-015	"		2	2-2-10	VT-3		
II-AH-002A-H-016	"		2	2-2-10	VT-3		
II-AH-002A-H-017	"		2	2-2-10	VT-3		
II-AH-002A-H-018	"		2	2-2-10	VT-3		
II-AH-002A-H-019	"		2	2-2-10	VT-3		
II-AH-002A-H-020	"		2	2-2-10	VT-3		
II-AH-002A-H-021	"		2	2-2-10	VT-3		
II-AH-002A-H-022	"		2	2-2-10	VT-3		
II-AH-002A-H-023	"		2	2-2-10	VT-3		
II-AH-002A-H-024	"		2	2-2-10	VT-3		
II-AH-002A-H-025	"		2	2-2-10	VT-3		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.40	SUPPORTS OTHER THAN PIPING SUPPORTS					
Component	Description	System	Class	Outage	Exam Type	Relief Request	
II-AH-002A-H-026	"		2	2-2-10	VT-3		
II-AH-002A-H-027	"		2	2-2-10	VT-3		
II-AH-002A-H-028	"		2	2-2-10	VT-3		
II-AH-002A-H-029	"		2	2-2-10	VT-3		
II-AH-002A-H-030	"		2	2-2-10	VT-3		
II-AH-002A-H-031	"		2	2-2-10	VT-3		
II-AH-002B-H-001	"		2		VT-3		
II-AH-002B-H-002	"		2		VT-3		
II-AH-002B-H-003	"		2		VT-3		
II-AH-002B-H-004	"		2		VT-3		
II-AH-002B-H-005	"		2		VT-3		
II-AH-002B-H-006	"		2		VT-3		
II-AH-002B-H-007	"		2		VT-3		
II-AH-002B-H-008	"		2		VT-3		
II-AH-002B-H-009	"		2		VT-3		
II-AH-002B-H-010	"		2		VT-3		
II-AH-002B-H-011	"		2		VT-3		
II-AH-002B-H-012	"		2		VT-3		
II-AH-002B-H-013	"		2		VT-3		
II-AH-002B-H-014	"		2		VT-3		
II-AH-002B-H-015	"		2		VT-3		
II-AH-002B-H-016	"		2		VT-3		
II-AH-002B-H-017	"		2		VT-3		
II-AH-002B-H-018	"		2		VT-3		
II-AH-002B-H-019	"		2		VT-3		
II-AH-002B-H-020	"		2		VT-3		
II-AH-002B-H-021	"		2		VT-3		
II-AH-002B-H-022	"		2		VT-3		
II-AH-002B-H-023	"		2		VT-3		



Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A
ITEM NO. F1.40

CLASS 1,2, AND 3 COMPONENT SUPPORTS
SUPPORTS OTHER THAN PIPING SUPPORTS

Component	Description	System	Class	Outage	Exam Type	Relief Request
II-AH-002B-H-024	"		2		VT-3	
II-AH-002B-H-025	"		2		VT-3	
II-AH-002B-H-026	"		2		VT-3	
II-AH-002B-H-027	"		2		VT-3	
II-AH-002B-H-028	"		2		VT-3	
II-AH-002B-H-029	"		2		VT-3	
II-AH-002B-H-030	"		2		VT-3	
II-AH-002B-H-031	"		2		VT-3	
II-AH-003A-H-001	CONT FAN COOLER AH-3		2		VT-3	
II-AH-003A-H-002	"		2		VT-3	
II-AH-003A-H-003	"		2		VT-3	
II-AH-003A-H-004	"		2		VT-3	
II-AH-003A-H-005	"		2		VT-3	
II-AH-003A-H-006	"		2		VT-3	
II-AH-003A-H-007	"		2		VT-3	
II-AH-003A-H-008	"		2		VT-3	
II-AH-003A-H-009	"		2		VT-3	
II-AH-003A-H-010	"		2		VT-3	
II-AH-003A-H-011	"		2		VT-3	
II-AH-003A-H-012	"		2		VT-3	
II-AH-003A-H-013	"		2		VT-3	
II-AH-003A-H-014	"		2		VT-3	
II-AH-003A-H-015	"		2		VT-3	
II-AH-003A-H-016	"		2		VT-3	
II-AH-003A-H-017	"		2		VT-3	
II-AH-003A-H-018	"		2		VT-3	
II-AH-003A-H-019	"		2		VT-3	
II-AH-003A-H-020	"		2		VT-3	
II-AH-003A-H-021	"		2		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.40	SUPPORTS OTHER THAN PIPING SUPPORTS					
Component	Description	System	Class	Outage	Exam Type	Relief Request	
II-AH-003A-H-022	"		2		VT-3		
II-AH-003A-H-023	"		2		VT-3		
II-AH-003A-H-024	"		2		VT-3		
II-AH-003A-H-025	"		2		VT-3		
II-AH-003A-H-026	"		2		VT-3		
II-AH-003A-H-027	"		2		VT-3		
II-AH-003A-H-028	"		2		VT-3		
II-AH-003A-H-029	"		2		VT-3		
II-AH-003A-H-030	"		2		VT-3		
II-AH-003A-H-031	"		2		VT-3		
II-AH-003B-H-001	"		2		VT-3		
II-AH-003B-H-002	"		2		VT-3		
II-AH-003B-H-003	"		2		VT-3		
II-AH-003B-H-004	"		2		VT-3		
II-AH-003B-H-005	"		2		VT-3		
II-AH-003B-H-006	"		2		VT-3		
II-AH-003B-H-007	"		2		VT-3		
II-AH-003B-H-008	"		2		VT-3		
II-AH-003B-H-009	"		2		VT-3		
II-AH-003B-H-010	"		2		VT-3		
II-AH-003B-H-011	"		2		VT-3		
II-AH-003B-H-012	"		2		VT-3		
II-AH-003B-H-013	"		2		VT-3		
II-AH-003B-H-014	"		2		VT-3		
II-AH-003B-H-015	"		2		VT-3		
II-AH-003B-H-016	"		2		VT-3		
II-AH-003B-H-017	"		2		VT-3		
II-AH-003B-H-018	"		2		VT-3		
II-AH-003B-H-019	"		2		VT-3		

**Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval**

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS				
ITEM NO.	F1.40	SUPPORTS OTHER THAN PIPING SUPPORTS				
Component	Description	System	Class	Outage	Exam Type	Relief Request
II-AH-003B-H-020	"		2		VT-3	
II-AH-003B-H-021	"		2		VT-3	
II-AH-003B-H-022	"		2		VT-3	
II-AH-003B-H-023	"		2		VT-3	
II-AH-003B-H-024	"		2		VT-3	
II-AH-003B-H-025	"		2		VT-3	
II-AH-003B-H-026	"		2		VT-3	
II-AH-003B-H-027	"		2		VT-3	
II-AH-003B-H-028	"		2		VT-3	
II-AH-003B-H-029	"		2		VT-3	
II-AH-003B-H-030	"		2		VT-3	
II-AH-003B-H-031	"		2		VT-3	
II-AH-004A-H-001	CONT FAN COOLER AH-4		2		VT-3	
II-AH-004A-H-002	"		2		VT-3	
II-AH-004A-H-003	"		2		VT-3	
II-AH-004A-H-004	"		2		VT-3	
II-AH-004A-H-005	"		2		VT-3	
II-AH-004A-H-006	"		2		VT-3	
II-AH-004A-H-007	"		2		VT-3	
II-AH-004A-H-008	"		2		VT-3	
II-AH-004A-H-009	"		2		VT-3	
II-AH-004A-H-010	"		2		VT-3	
II-AH-004A-H-011	"		2		VT-3	
II-AH-004A-H-012	"		2		VT-3	
II-AH-004A-H-013	"		2		VT-3	
II-AH-004A-H-014	"		2		VT-3	
II-AH-004A-H-015	"		2		VT-3	
II-AH-004A-H-016	"		2		VT-3	
II-AH-004A-H-017	"		2		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A
ITEM NO. F1.40

CLASS 1,2, AND 3 COMPONENT SUPPORTS
SUPPORTS OTHER THAN PIPING SUPPORTS

Component	Description	System	Class	Outage	Exam Type	Relief Request
II-AH-004A-H-018	"		2		VT-3	
II-AH-004A-H-019	"		2		VT-3	
II-AH-004A-H-020	"		2		VT-3	
II-AH-004A-H-021	"		2		VT-3	
II-AH-004A-H-022	"		2		VT-3	
II-AH-004A-H-023	"		2		VT-3	
II-AH-004A-H-024	"		2		VT-3	
II-AH-004A-H-025	"		2		VT-3	
II-AH-004A-H-026	"		2		VT-3	
II-AH-004A-H-027	"		2		VT-3	
II-AH-004A-H-028	"		2		VT-3	
II-AH-004A-H-029	"		2		VT-3	
II-AH-004A-H-030	"		2		VT-3	
II-AH-004A-H-031	"		2		VT-3	
II-AH-004B-H-001	"		2		VT-3	
II-AH-004B-H-002	"		2		VT-3	
II-AH-004B-H-003	"		2		VT-3	
II-AH-004B-H-004	"		2		VT-3	
II-AH-004B-H-005	"		2		VT-3	
II-AH-004B-H-006	"		2		VT-3	
II-AH-004B-H-007	"		2		VT-3	
II-AH-004B-H-008	"		2		VT-3	
II-AH-004B-H-009	"		2		VT-3	
II-AH-004B-H-010	"		2		VT-3	
II-AH-004B-H-011	"		2		VT-3	
II-AH-004B-H-012	"		2		VT-3	
II-AH-004B-H-013	"		2		VT-3	
II-AH-004B-H-014	"		2		VT-3	
II-AH-004B-H-015	"		2		VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.40	SUPPORTS OTHER THAN PIPING SUPPORTS					
Component	Description	System	Class	Outage	Exam Type	Relief Request	
II-AH-004B-H-016	"		2		VT-3		
II-AH-004B-H-017	"		2		VT-3		
II-AH-004B-H-018	"		2		VT-3		
II-AH-004B-H-019	"		2		VT-3		
II-AH-004B-H-020	"		2		VT-3		
II-AH-004B-H-021	"		2		VT-3		
II-AH-004B-H-022	"		2		VT-3		
II-AH-004B-H-023	"		2		VT-3		
II-AH-004B-H-024	"		2		VT-3		
II-AH-004B-H-025	"		2		VT-3		
II-AH-004B-H-026	"		2		VT-3		
II-AH-004B-H-027	"		2		VT-3		
II-AH-004B-H-028	"		2		VT-3		
II-AH-004B-H-029	"		2		VT-3		
II-AH-004B-H-030	"		2		VT-3		
II-AH-004B-H-031	"		2		VT-3		
II-BAT-01H-001	BORIC ACID TANK 1X-SN	CS	3	2-1-08	VT-3		
II-BAT-01H-002	"	CS	3	2-1-08	VT-3		
II-BAT-01H-003	"	CS	3	2-1-08	VT-3		
II-BAT-01H-004	"	CS	3	2-1-08	VT-3		
II-BAT-01H-005	"	CS	3	2-1-08	VT-3		
II-BAT-01H-006	"	CS	3	2-1-08	VT-3		
II-BAT-01H-007	"	CS	3	2-1-08	VT-3		
II-BAT-01H-008	"	CS	3	2-1-08	VT-3		
II-BAT-01H-009	"	CS	3	2-1-08	VT-3		
II-BAT-01H-010	"	CS	3	2-1-08	VT-3		
II-BAT-01H-011	"	CS	3	2-1-08	VT-3		
II-BAT-01H-012	"	CS	3	2-1-08	VT-3		
II-BAT-01H-013	"	CS	3	2-1-08	VT-3		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.40	SUPPORTS OTHER THAN PIPING SUPPORTS					
Component	Description	System	Class	Outage	Exam Type	Relief Request	
II-BAT-01H-014	"	CS	3	2-1-08	VT-3		
II-BAT-01H-015	"	CS	3	2-1-08	VT-3		
II-BAT-01H-016	"	CS	3	2-1-08	VT-3		
II-BAT-01H-017	"	CS	3	2-1-08	VT-3		
II-BAT-01H-018	"	CS	3	2-1-08	VT-3		
II-BAT-01H-019	"	CS	3	2-1-08	VT-3		
II-BAT-01H-020	"	CS	3	2-1-08	VT-3		
II-BAT-01H-021	"	CS	3	2-1-08	VT-3		
II-BAT-01H-022	"	CS	3	2-1-08	VT-3		
II-BAT-01H-023	"	CS	3	2-1-08	VT-3		
II-BAT-01H-024	"	CS	3	2-1-08	VT-3		
II-BIT-01H-001	BORON INJECTION TANK 1X-SAB	SI	2	2-2-10	VT-3		
II-BIT-01H-002	"	SI	2	2-2-10	VT-3		
II-BIT-01H-003	"	SI	2	2-2-10	VT-3		
II-BIT-01H-004	"	SI	2	2-2-10	VT-3		
II-CCHX-1A-H-001	CCW HEAT EXCHANGER 1A-SA	CC	3	2-1-08	VT-3		
II-CCHX-1A-H-002	"	CC	3	2-1-08	VT-3		
II-CCHX-1B-H-001	CCW HEAT EXCHANGER 1B-SB	CC	3		VT-3		
II-CCHX-1B-H-002	"	CC	3		VT-3		
II-CCP-01A-H-001	CCW PUMP 1A-SA	CC	3		VT-3		
II-CCP-01A-H-002	"	CC	3		VT-3		
II-CCP-01A-H-003	"	CC	3		VT-3		
II-CCP-01A-H-004	"	CC	3		VT-3		
II-CCP-01A-H-005	"	CC	3		VT-3		
II-CCP-01B-H-001	CCW PUMP 1B-SB	CC	3		VT-3		
II-CCP-01B-H-002	"	CC	3		VT-3		
II-CCP-01B-H-003	"	CC	3		VT-3		
II-CCP-01B-H-004	"	CC	3		VT-3		
II-CCP-01B-H-005	"	CC	3		VT-3		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO. F1.40	SUPPORTS OTHER THAN PIPING SUPPORTS					
Component	Description	System	Class	Outage	Exam Type	Relief Request
II-CCP-01C-H-001	CCW PUMP 1C-SAB	CC	3	2-3-13	VT-3	
II-CCP-01C-H-002	"	CC	3	2-3-13	VT-3	
II-CCP-01C-H-003	"	CC	3	2-3-13	VT-3	
II-CCP-01C-H-004	"	CC	3	2-3-13	VT-3	
II-CCP-01C-H-005	"	CC	3	2-3-13	VT-3	
II-CCST-1H-001	CCW SURGE TANK 1X-SAB	CC	3	2-2-10	VT-3	
II-CCST-1H-002	"	CC	3	2-2-10	VT-3	
II-CEP7-1A-H-001	COND WATER PUMP P-7 1A-SA	SW	3	2-1-08	VT-3	
II-CEP7-1A-H-002	"	SW	3	2-1-08	VT-3	
II-CEP7-1A-H-003	"	SW	3	2-1-08	VT-3	
II-CEP7-1B-H-001	COND WATER PUMP P-7 1B-SB	SW	3		VT-3	
II-CEP7-1B-H-002	"	SW	3		VT-3	
II-CEP7-1B-H-003	"	SW	3		VT-3	
II-CEST-1H-001	CONDENSATE STORAGE TANK 1X-SAB	CE	3	2-2-11	VT-3	
II-CEST-1H-002	"	CE	3	2-2-11	VT-3	
II-CEST-1H-003	"	CE	3	2-2-11	VT-3	
II-CEST-1H-004	"	CE	3	2-2-11	VT-3	
II-CEST-1H-005	"	CE	3	2-2-11	VT-3	
II-CEST-1H-006	"	CE	3	2-2-11	VT-3	
II-CEST-1H-007	"	CE	3	2-2-11	VT-3	
II-CEST-1H-008	"	CE	3	2-2-11	VT-3	
II-CEST-1H-009	"	CE	3	2-2-11	VT-3	
II-CEST-1H-010	"	CE	3	2-2-11	VT-3	
II-CEST-1H-011	"	CE	3	2-2-11	VT-3	
II-CEST-1H-012	"	CE	3	2-2-11	VT-3	
II-CEST-1H-013	"	CE	3	2-2-11	VT-3	
II-CEST-1H-014	"	CE	3	2-2-11	VT-3	
II-CEST-1H-015	"	CE	3	2-2-11	VT-3	
II-CEST-1H-016	"	CE	3	2-2-11	VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY ITEM NO.	F-A F1.40	CLASS 1,2, AND 3 COMPONENT SUPPORTS SUPPORTS OTHER THAN PIPING SUPPORTS					
Component		Description	System	Class	Outage	Exam Type	Relief Request
II-CEST-1H-017		"	CE	3	2-2-11	VT-3	
II-CEST-1H-018		"	CE	3	2-2-11	VT-3	
II-CEST-1H-019		"	CE	3	2-2-11	VT-3	
II-CEST-1H-020		"	CE	3	2-2-11	VT-3	
II-CEST-1H-021		"	CE	3	2-2-11	VT-3	
II-CEST-1H-022		"	CE	3	2-2-11	VT-3	
II-CEST-1H-023		"	CE	3	2-2-11	VT-3	
II-CEST-1H-024		"	CE	3	2-2-11	VT-3	
II-CEST-1H-025		"	CE	3	2-2-11	VT-3	
II-CEST-1H-026		"	CE	3	2-2-11	VT-3	
II-CEST-1H-027		"	CE	3	2-2-11	VT-3	
II-CEST-1H-028		"	CE	3	2-2-11	VT-3	
II-CEST-1H-029		"	CE	3	2-2-11	VT-3	
II-CEST-1H-030		"	CE	3	2-2-11	VT-3	
II-CEST-1H-031		"	CE	3	2-2-11	VT-3	
II-CEST-1H-032		"	CE	3	2-2-11	VT-3	
II-CEST-1H-033		"	CE	3	2-2-11	VT-3	
II-CEST-1H-034		"	CE	3	2-2-11	VT-3	
II-CEST-1H-035		"	CE	3	2-2-11	VT-3	
II-CEST-1H-036		"	CE	3	2-2-11	VT-3	
II-CEST-1H-037		"	CE	3	2-2-11	VT-3	
II-CEST-1H-038		"	CE	3	2-2-11	VT-3	
II-CEST-1H-039		"	CE	3	2-2-11	VT-3	
II-CEST-1H-040		"	CE	3	2-2-11	VT-3	
II-CEST-1H-041		"	CE	3	2-2-11	VT-3	
II-CEST-1H-042		"	CE	3	2-2-11	VT-3	
II-CEST-1H-043		"	CE	3	2-2-11	VT-3	
II-CEST-1H-044		"	CE	3	2-2-11	VT-3	
II-CEST-1H-045		"	CE	3	2-2-11	VT-3	



Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.40	SUPPORTS OTHER THAN PIPING SUPPORTS					
Component	Description	System	Class	Outage	Exam Type	Relief Request	
II-CEST-1H-046	"	CE	3	2-2-11	VT-3		
II-CEST-1H-047	"	CE	3	2-2-11	VT-3		
II-CEST-1H-048	"	CE	3	2-2-11	VT-3		
II-CEST-1H-049	"	CE	3	2-2-11	VT-3		
II-CEST-1H-050	"	CE	3	2-2-11	VT-3		
II-CEST-1H-051	"	CE	3	2-2-11	VT-3		
II-CEST-1H-052	"	CE	3	2-2-11	VT-3		
II-CEST-1H-053	"	CE	3	2-2-11	VT-3		
II-CEST-1H-054	"	CE	3	2-2-11	VT-3		
II-CEST-1H-055	"	CE	3	2-2-11	VT-3		
II-CEST-1H-056	"	CE	3	2-2-11	VT-3		
II-CEST-1H-057	"	CE	3	2-2-11	VT-3		
II-CEST-1H-058	"	CE	3	2-2-11	VT-3		
II-CEST-1H-059	"	CE	3	2-2-11	VT-3		
II-CEST-1H-060	"	CE	3	2-2-11	VT-3		
II-CEST-1H-061	"	CE	3	2-2-11	VT-3		
II-CEST-1H-062	"	CE	3	2-2-11	VT-3		
II-CEST-1H-063	"	CE	3	2-2-11	VT-3		
II-CEST-1H-064	"	CE	3	2-2-11	VT-3		
II-CEST-1H-065	"	CE	3	2-2-11	VT-3		
II-CEST-1H-066	"	CE	3	2-2-11	VT-3		
II-CEST-1H-067	"	CE	3	2-2-11	VT-3		
II-CEST-1H-068	"	CE	3	2-2-11	VT-3		
II-CEST-1H-069	"	CE	3	2-2-11	VT-3		
II-CEST-1H-070	"	CE	3	2-2-11	VT-3		
II-CEST-1H-071	"	CE	3	2-2-11	VT-3		
II-CEST-1H-072	"	CE	3	2-2-11	VT-3		
II-CEST-1H-073	"	CE	3	2-2-11	VT-3		
II-CEST-1H-074	"	CE	3	2-2-11	VT-3		



Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.40	SUPPORTS OTHER THAN PIPING SUPPORTS					
Component	Description	System	Class	Outage	Exam Type	Relief Request	
II-CEST-1H-075	"	CE	3	2-2-11	VT-3		
II-CEST-1H-076	"	CE	3	2-2-11	VT-3		
II-CEST-1H-077	"	CE	3	2-2-11	VT-3		
II-CEST-1H-078	"	CE	3	2-2-11	VT-3		
II-CEST-1H-079	"	CE	3	2-2-11	VT-3		
II-CEST-1H-080	"	CE	3	2-2-11	VT-3		
II-CPAL-1A-H-001	CSIP A AUX LUBE OIL PUMP 1A-SA	CS	2	2-1-08	VT-3		
II-CPAL-1A-H-002	"	CS	2	2-1-08	VT-3		
II-CPAL-1B-H-001	CSIP B AUX LUBE OIL PUMP 1B-SB	CS	2		VT-3		
II-CPAL-1B-H-002	"	CS	2		VT-3		
II-CPAL-1C-H-001	CSIP C AUX LUBE OIL PUMP 1C-SAB	CS	2		VT-3		
II-CPAL-1C-H-002	"	CS	2		VT-3		
II-CPOC-1A-H-001	CSIP A OIL COOLER	CS	3		VT-3		
II-CPOC-1A-H-002	"	CS	3		VT-3		
II-CPOC-1B-H-001	CSIP B OIL COOLER	CS	3	2-2-10	VT-3		
II-CPOC-1B-H-002	"	CS	3	2-2-10	VT-3		
II-CPOC-1C-H-001	CSIP C OIL COOLER	CS	3		VT-3		
II-CPOC-1C-H-002	"	CS	3		VT-3		
II-CSIP-1CSIPA-H-001	CHARGING/SAFETY INJECTION PUMP 1A-SA	CS	2		VT-3		
II-CSIP-1CSIPA-H-002	"	CS	2		VT-3		
II-CSIP-1CSIPA-H-003	"	CS	2		VT-3		
II-CSIP-1CSIPA-H-004	"	CS	2		VT-3		
II-CSIP-1CSIPA-H-005	"	CS	2		VT-3		
II-CSIP-1CSIPB-H-001	CHARGING/SAFETY INJECTION PUMP 1S-SB	CS	2	2-2-11	VT-3		
II-CSIP-1CSIPB-H-002	"	CS	2	2-2-11	VT-3		
II-CSIP-1CSIPB-H-003	"	CS	2	2-2-11	VT-3		
II-CSIP-1CSIPB-H-004	"	CS	2	2-2-11	VT-3		
II-CSIP-1CSIPB-H-005	"	CS	2	2-2-11	VT-3		
II-CSIP-1CSIPC-H-001	CHARGING/SAFETY INJECTION PUMP 1C-SAB	CS	2		VT-3		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO. F1.40	SUPPORTS OTHER THAN PIPING SUPPORTS					
Component	Description	System	Class	Outage	Exam Type	Relief Request
II-CSIP-1CSIPC-H-002	"	CS	2		VT-3	
II-CSIP-1CSIPC-H-003	"	CS	2		VT-3	
II-CSIP-1CSIPC-H-004	"	CS	2		VT-3	
II-CSIP-1CSIPC-H-005	"	CS	2		VT-3	
II-CTAT-1H-001	CONT SPRAY ADDITIVE TANK 1X-SAB	CT	3	2-2-11	VT-3	
II-CTAT-1H-002	"	CT	3	2-2-11	VT-3	
II-CTP-01CTPA-H-001	CONT SPRAY PUMP 1A-SA	CT	2		VT-3	
II-CTP-01CTPA-H-002	"	CT	2		VT-3	
II-CTP-01CTPA-H-003	"	CT	2		VT-3	
II-CTP-01CTPB-H-001	CONT SPRAY PUMP 1B-SB	CT	2	2-3-13	VT-3	
II-CTP-01CTPB-H-002	"	CT	2	2-3-13	VT-3	
II-CTP-01CTPB-H-003	"	CT	2	2-3-13	VT-3	
II-CWP4-1A-H-001	CHILLED WATER PUMP P-4 1A-SA	CH	3	2-1-08	VT-3	
II-CWP4-1A-H-002	"	CH	3	2-1-08	VT-3	
II-CWP4-1A-H-003	"	CH	3	2-1-08	VT-3	
II-CWP4-1B-H-001	CHILLED WATER PUMP P-4 1B-SB	CH	3		VT-3	
II-CWP4-1B-H-002	"	CH	3		VT-3	
II-CWP4-1B-H-003	"	CH	3		VT-3	
II-ESWA-1A-H-001	ESW SCREEN WASH PUMP 1A-SA	SW	3		VT-3	
II-ESWA-1A-H-002	"	SW	3		VT-3	
II-ESWA-1A-H-003	"	SW	3		VT-3	
II-ESWA-1B-H-001	ESW SCREEN WASH PUMP 1B-SB	SW	3	2-3-13	VT-3	
II-ESWA-1B-H-002	"	SW	3	2-3-13	VT-3	
II-ESWA-1B-H-003	"	SW	3	2-3-13	VT-3	
II-ESWP-1A-H-001	ESW PUMP 1A-SA	SW	3	2-1-08	VT-3	
II-ESWP-1A-H-002	"	SW	3	2-1-08	VT-3	
II-ESWP-1A-H-003	"	SW	3	2-1-08	VT-3	
II-ESWP-1A-H-004	"	SW	3	2-1-08	VT-3	
II-ESWP-1A-H-005	"	SW	3	2-1-08	VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO. F1.40	SUPPORTS OTHER THAN PIPING SUPPORTS					
Component	Description	System	Class	Outage	Exam Type	Relief Request
II-ESWP-1B-H-001	ESW PUMP 1B-SB	SW	3		VT-3	
II-ESWP-1B-H-002	"	SW	3		VT-3	
II-ESWP-1B-H-003	"	SW	3		VT-3	
II-ESWP-1B-H-004	"	SW	3		VT-3	
II-ESWP-1B-H-005	"	SW	3		VT-3	
II-ESWS-1A-H-001	ESW PUMP A STRAINER	SW	3		VT-3	
II-ESWS-1A-H-002	"	SW	3		VT-3	
II-ESWS-1B-H-001	ESW PUMP B STRAINER	SW	3	2-3-13	VT-3	
II-ESWS-1B-H-002	"	SW	3	2-3-13	VT-3	
II-FOTP-1A-H-001	DIESEL FUEL OIL TRANSFER PUMP 1A-SA	FO	3	2-1-08	VT-3	
II-FOTP-1A-H-002	"	FO	3	2-1-08	VT-3	
II-FOTP-1A-H-003	"	FO	3	2-1-08	VT-3	
II-FOTP-1B-H-001	DIESEL FUEL OIL TRANSFER PUMP 1B-SB	FO	3		VT-3	
II-FOTP-1B-H-002	"	FO	3		VT-3	
II-FOTP-1B-H-003	"	FO	3		VT-3	
II-FPCP-1A-H-001	FUEL POOL COOLING PUMP 1&4A-SA	SF	3	2-1-08	VT-3	
II-FPCP-1A-H-002	"	SF	3	2-1-08	VT-3	
II-FPCP-1A-H-003	"	SF	3	2-1-08	VT-3	
II-FPCP-1B-H-001	FUEL POOL COOLING PUMP 1&4B-SB	SF	3		VT-3	
II-FPCP-1B-H-002	"	SF	3		VT-3	
II-FPCP-1B-H-003	"	SF	3		VT-3	
II-FPHX-1A-H-001	FUEL POOL HX 1&4A-SA	SF	3		VT-3	
II-FPHX-1A-H-002	"	SF	3		VT-3	
II-FPHX-1B-H-001	FUEL POOL HX 1&4B-SB	SF	3	2-3-13	VT-3	
II-FPHX-1B-H-002	"	SF	3	2-3-13	VT-3	
II-FPS-01A-H-001	FUEL POOL STRAINER 1&4A-SA	SF	3	2-1-08	VT-3	
II-FPS-01B-H-001	FUEL POOL STRAINER 1&4B-SB	SF	3	2-3-13	VT-3	
II-N2A-01A-H-003	NITROGEN ACCUM TANK 1A-SA	SI	3	2-1-08	VT-3	
II-N2A-01A-H-006	"	SI	3	2-1-08	VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS				
ITEM NO.	F1.40	SUPPORTS OTHER THAN PIPING SUPPORTS				
Component	Description	System	Class	Outage	Exam Type	Relief Request
II-N2A-01B-H-002	NITROGEN ACCUM TANK 1B-NNS	SI	N		VT-3	
II-N2A-01B-H-005	"	SI	N		VT-3	
II-N2A-01C-H-001	NITROGEN ACCUM TANK 1C-SB	SI	3		VT-3	
II-N2A-01C-H-004	"	SI	3		VT-3	
II-PZR-01H-001	PRESSURIZER 1X-SN	RC	1	2-2-10	VT-3	
II-PZR-01H-002	"	RC	1	2-2-10	VT-3	
II-PZR-01H-003	"	RC	1	2-2-10	VT-3	
II-PZR-01H-004	"	RC	1	2-2-10	VT-3	
II-PZR-01H-005	"	RC	1	2-2-10	VT-3	
II-PZR-01H-006	"	RC	1	2-2-10	VT-3	
II-PZR-01H-007	"	RC	1	2-2-10	VT-3	
II-PZR-01H-008	"	RC	1	2-2-10	VT-3	
II-PZR-01H-009	"	RC	1	2-2-10	VT-3	
II-PZR-01H-010	"	RC	1	2-2-10	VT-3	
II-PZR-01H-011	"	RC	1	2-2-10	VT-3	
II-PZR-01H-012	"	RC	1	2-2-10	VT-3	
II-PZR-01H-013	"	RC	1	2-2-10	VT-3	
II-PZR-01H-014	"	RC	1	2-2-10	VT-3	
II-PZR-01H-015	"	RC	1	2-2-10	VT-3	
II-PZR-01H-016	"	RC	1	2-2-10	VT-3	
II-PZR-01H-017	"	RC	1	2-2-10	VT-3	
II-PZR-01H-018	"	RC	1	2-2-10	VT-3	
II-PZR-01H-019	"	RC	1	2-2-10	VT-3	
II-PZR-01H-020	"	RC	1	2-2-10	VT-3	
II-PZR-01H-021	"	RC	1	2-2-10	VT-3	
II-PZR-01H-022	"	RC	1	2-2-10	VT-3	
II-PZR-01H-023	"	RC	1	2-2-10	VT-3	
II-PZR-01H-024	"	RC	1	2-2-10	VT-3	
II-PZR-01H-025	"	RC	1	2-2-10	VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.40	SUPPORTS OTHER THAN PIPING SUPPORTS					
Component	Description	System	Class	Outage	Exam Type	Relief Request	
II-PZR-01H-026	"	RC	1	2-2-10	VT-3		
II-PZR-01H-027	"	RC	1	2-2-10	VT-3		
II-PZR-01H-028	"	RC	1	2-2-10	VT-3		
II-PZR-01H-029	"	RC	1	2-2-10	VT-3		
II-PZR-01H-030	"	RC	1	2-2-10	VT-3		
II-PZR-01H-031	"	RC	1	2-2-10	VT-3		
II-PZR-01H-032	"	RC	1	2-2-10	VT-3		
II-RCDX-1H-001	REACTOR COOLANT DRAIN TANK HX 1X-SN	RC	2	2-2-11	VT-3		
II-RCDX-1H-002	"	RC	2	2-2-11	VT-3		
II-RCF-01H-001	REACTOR COOLANT FILTER 1X-SN	CS	2	2-2-11	VT-3		
II-RCF-01H-002	"	CS	2	2-2-11	VT-3		
II-RCF-01H-003	"	CS	2	2-2-11	VT-3		
II-RCP-01RCPA-H-001	REACTOR COOLANT PUMP 1A-SN	RC	1	2-1-08	VT-3		
II-RCP-01RCPA-H-002	"	RC	1	2-1-08	VT-3		
II-RCP-01RCPA-H-003	"	RC	1	2-1-08	VT-3		
II-RCP-01RCPB-H-001	REACTOR COOLANT PUMP 1B-SN	RC	1		VT-3		
II-RCP-01RCPB-H-002	"	RC	1		VT-3		
II-RCP-01RCPB-H-003	"	RC	1		VT-3		
II-RCP-01RCPC-H-001	REACTOR COOLANT PUMP 1C-SN	RC	1		VT-3		
II-RCP-01RCPC-H-002	"	RC	1		VT-3		
II-RCP-01RCPC-H-003	"	RC	1		VT-3		
II-RHPC-1A-H-001	RHR PUMP 1A-SA COOLER	RH	2	2-1-08	VT-3		
II-RHPC-1B-H-001	RHR PUMP 1B-SB COOLER	RH	2	2-3-13	VT-3		
II-RHR-01RHRA-H-001	RHR HX 1A-SA	RH	2		VT-3		
II-RHR-01RHRA-H-002	"	RH	2		VT-3		
II-RHR-01RHRA-H-003	"	RH	2		VT-3		
II-RHR-01RHRA-H-004	"	RH	2		VT-3		
II-RHR-01RHRA-H-005	"	RH	2		VT-3		
II-RHR-01RHRA-H-006	"	RH	2		VT-3		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO. F1.40	SUPPORTS OTHER THAN PIPING SUPPORTS					
Component	Description	System	Class	Outage	Exam Type	Relief Request
II-RHR-01RHRA-H-007	"	RH	2		VT-3	
II-RHR-01RHRA-H-008	"	RH	2		VT-3	
II-RHR-01RHRB-H-001	RHR HX 1B-SB	RH	2	2-3-13	VT-3	
II-RHR-01RHRB-H-002	"	RH	2	2-3-13	VT-3	
II-RHR-01RHRB-H-003	"	RH	2	2-3-13	VT-3	
II-RHR-01RHRB-H-004	"	RH	2	2-3-13	VT-3	
II-RHR-01RHRB-H-005	"	RH	2	2-3-13	VT-3	
II-RHR-01RHRB-H-006	"	RH	2	2-3-13	VT-3	
II-RHR-01RHRB-H-007	"	RH	2	2-3-13	VT-3	
II-RHR-01RHRB-H-008	"	RH	2	2-3-13	VT-3	
II-RHRP-1RHRPA-H-001	RHR PUMP 1A-SA	RH	2	2-1-08	VT-3	
II-RHRP-1RHRPA-H-002	"	RH	2	2-1-08	VT-3	
II-RHRP-1RHRPA-H-003	"	RH	2	2-1-08	VT-3	
II-RHRP-1RHRPB-H-001	RHR PUMP 1B-SB	RH	2		VT-3	
II-RHRP-1RHRPB-H-002	"	RH	2		VT-3	
II-RHRP-1RHRPB-H-003	"	RH	2		VT-3	
II-RHX-01H-001	REGENERATIVE HX 1X-SN	CS	2	2-3-12	VT-3	
II-RHX-01H-002	"	CS	2	2-3-12	VT-3	
II-RHX-01H-003	"	CS	2	2-3-12	VT-3	
II-RHX-01H-004	"	CS	2	2-3-12	VT-3	
II-RHX-01H-005	"	CS	2	2-3-12	VT-3	
II-RHX-01H-006	"	CS	2	2-3-12	VT-3	
II-RPV-01H-001	REACTOR VESSEL 1X-SN	RC	1	2-3-13	VT-3	
II-RPV-01H-002	"	RC	1	2-3-13	VT-3	
II-RPV-01H-003	"	RC	1	2-3-13	VT-3	
II-RPV-01H-004	"	RC	1	2-3-13	VT-3	
II-RPV-01H-005	"	RC	1	2-3-13	VT-3	
II-RPV-01H-006	"	RC	1	2-3-13	VT-3	
II-SERF-1H-001	SEAL WATER RETURN FILTER 1X-SN	CS	2	2-2-11	VT-3	

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.40	SUPPORTS OTHER THAN PIPING SUPPORTS					
Component	Description	System	Class	Outage	Exam Type	Relief Request	
II-SERF-1H-002	"	CS	2	2-2-11	VT-3		
II-SERF-1H-003	"	CS	2	2-2-11	VT-3		
II-SG-001SGA-H-001	STEAM GENERATOR 1A-SN	SG	1		VT-3		
II-SG-001SGA-H-002	"	SG	1		VT-3		
II-SG-001SGA-H-003	"	SG	1		VT-3		
II-SG-001SGA-H-004	"	SG	1		VT-3		
II-SG-001SGA-H-005A	S/G A UPPER LATERAL SUPPORT	SG	1		VT-3		
II-SG-001SGA-H-005B	"	SG	1		VT-3		
II-SG-001SGA-H-006A	"	SG	1		VT-3		
II-SG-001SGA-H-006B	"	SG	1		VT-3		
II-SG-001SGA-H-007	STEAM GENERATOR 1A-SN	SG	1		VT-3		
II-SG-001SGA-H-008	"	SG	1		VT-3		
II-SG-001SGB-H-001	STEAM GENERATOR 1B-SN	SG	1	2-2-11	VT-3		
II-SG-001SGB-H-002	"	SG	1	2-2-11	VT-3		
II-SG-001SGB-H-003	"	SG	1	2-2-11	VT-3		
II-SG-001SGB-H-004	"	SG	1	2-2-11	VT-3		
II-SG-001SGB-H-005A	S/G B UPPER LATERAL SUPPORT	SG	1	2-2-11	VT-3		
II-SG-001SGB-H-005B	"	SG	1	2-2-11	VT-3		
II-SG-001SGB-H-006A	"	SG	1	2-2-11	VT-3		
II-SG-001SGB-H-006B	"	SG	1	2-2-11	VT-3		
II-SG-001SGB-H-007	STEAM GENERATOR 1B-SN	SG	1	2-2-11	VT-3		
II-SG-001SGB-H-008	"	SG	1	2-2-11	VT-3		
II-SG-001SGC-H-001	STEAM GENERATOR 1C-SN	SG	1		VT-3		
II-SG-001SGC-H-002	"	SG	1		VT-3		
II-SG-001SGC-H-003	"	SG	1		VT-3		
II-SG-001SGC-H-004	"	SG	1		VT-3		
II-SG-001SGC-H-005A	S/G C UPPER LATERAL SUPPORT	SG	1		VT-3		
II-SG-001SGC-H-005B	"	SG	1		VT-3		
II-SG-001SGC-H-006A	"	SG	1		VT-3		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval

CATEGORY ITEM NO.	F-A F1.40	CLASS 1,2, AND 3 COMPONENT SUPPORTS SUPPORTS OTHER THAN PIPING SUPPORTS					
Component		Description	System	Class	Outage	Exam Type	Relief Request
II-SG-001SGC-H-006B		"	SG	1		VT-3	
II-SG-001SGC-H-007		STEAM GENERATOR 1C-SN	SG	1		VT-3	
II-SG-001SGC-H-008		"	SG	1		VT-3	
II-SGAP-1A-H-001		S/G AUX FEED PUMP 1A-SA	AF	3		VT-3	
II-SGAP-1A-H-002		"	AF	3		VT-3	
II-SGAP-1A-H-003		"	AF	3		VT-3	
II-SGAP-1B-H-001		S/G AUX FEED PUMP 1B-SB	AF	3	2-2-11	VT-3	
II-SGAP-1B-H-002		"	AF	3	2-2-11	VT-3	
II-SGAP-1B-H-003		"	AF	3	2-2-11	VT-3	
II-SGAP-1T-H-001		TURB DRIVEN S/G AUX FEED PUMP 1X-SAB	AF	3	2-3-13	VT-3	
II-SGAP-1T-H-002		"	AF	3	2-3-13	VT-3	
II-SGAP-1T-H-003		"	AF	3	2-3-13	VT-3	
II-SWBP-1A-H-001		S/W BOOSTER PUMP 1A-SA	SW	3		VT-3	
II-SWBP-1A-H-002		"	SW	3		VT-3	
II-SWBP-1A-H-003		"	SW	3		VT-3	
II-SWBP-1B-H-001		S/W BOOSTER PUMP 1B-SB	SW	3	2-3-13	VT-3	
II-SWBP-1B-H-002		"	SW	3	2-3-13	VT-3	
II-SWBP-1B-H-003		"	SW	3	2-3-13	VT-3	
II-SWIF-1A-H-001		SEAL WATER INJECTION FILTER 1A-SN	CS	2	2-1-08	VT-3	
II-SWIF-1A-H-002		"	CS	2	2-1-08	VT-3	
II-SWIF-1A-H-003		"	CS	2	2-1-08	VT-3	
II-SWIF-1B-H-001		SEAL WATER INJECTION FILTER 1B-SN	CS	2		VT-3	
II-SWIF-1B-H-002		"	CS	2		VT-3	
II-SWIF-1B-H-003		"	CS	2		VT-3	
II-VCT-01H-001		VOLUME CONTROL TANK 1X-SN	CS	2	2-2-10	VT-3	
II-VCT-01H-002		"	CS	2	2-2-10	VT-3	
II-VCT-01H-003		"	CS	2	2-2-10	VT-3	
II-VCT-01H-004		"	CS	2	2-2-10	VT-3	
II-VCT-01H-005		"	CS	2	2-2-10	VT-3	

**Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component Support/Snubber Examination Listing for 2nd 10-Year Interval**

CATEGORY	F-A	CLASS 1,2, AND 3 COMPONENT SUPPORTS					
ITEM NO.	F1.40	SUPPORTS OTHER THAN PIPING SUPPORTS					
Component	Description	System	Class	Outage	Exam Type	Relief Request	
II-VCT-01H-006	"	CS	2	2-2-10	VT-3		
II-VCT-01H-007	"	CS	2	2-2-10	VT-3		
II-VCT-01H-008	"	CS	2	2-2-10	VT-3		
II-VCT-01H-009	"	CS	2	2-2-10	VT-3		
II-VCT-01H-010	"	CS	2	2-2-10	VT-3		
II-WC2-01A-H-001	HVAC CHILLER WC-2 1A-SA	CH	3		VT-3		
II-WC2-01A-H-002		CH	3		VT-3		
II-WC2-01A-H-003		CH	3		VT-3		
II-WC2-01A-H-004		CH	3		VT-3		
II-WC2-01A-H-005		CH	3		VT-3		
II-WC2-01A-H-006		CH	3		VT-3		
II-WC2-01A-H-007		CH	3		VT-3		
II-WC2-01A-H-008		CH	3		VT-3		
II-WC2-01A-H-009		CH	3		VT-3		
II-WC2-01B-H-001	HVAC CHILLER WC-2 1B-SB	CH	3	2-3-13	VT-3		
II-WC2-01B-H-002	"	CH	3	2-3-13	VT-3		
II-WC2-01B-H-003	"	CH	3	2-3-13	VT-3		
II-WC2-01B-H-004	"	CH	3	2-3-13	VT-3		
II-WC2-01B-H-005	"	CH	3	2-3-13	VT-3		
II-WC2-01B-H-006	"	CH	3	2-3-13	VT-3		
II-WC2-01B-H-007	"	CH	3	2-3-13	VT-3		
II-WC2-01B-H-008	"	CH	3	2-3-13	VT-3		
II-WC2-01B-H-009	"	CH	3	2-3-13	VT-3		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY F-A CLASS 1,2, AND 3 COMPONENT SUPPORTS
ITEM NO. F1.50 SPRING SUPPORTS AND CONSTANT LOAD SUPPORTS

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
NONE	/						

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY F-A CLASS 1,2, AND 3 COMPONENT SUPPORTS
ITEM NO. F1.60 SLIDING SURFACES

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
NONE	/						

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY F-A CLASS 1,2, AND 3 COMPONENT SUPPORTS
ITEM NO. F1.70 HOT OR COLD POSITION OF SPRING SUPPORTS AND CONSTANT LOAD SUPPORTS

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
NONE	/						

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	FSAR	FINAL SAFETY ANALYSIS REPORT - SECTION 6.6.8					
ITEM NO.	6.6.8B	AUGMENTED PIPING WELD VOLUMETRIC EXAMINATION PER FSAR					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-AF-005AF-01-FW-6	PC,PIP / PBCC,T	AF	2	2-2-11	UT-45S		Was II-AF-005AF-FW-253.
II-AF-005AF-FW-249	PC,VLV / PC,PIP	AF	2	2-2-11	UT-45S		
II-AF-005AF-FW-250	PC,PIP / PBCC,T	AF	2	2-2-11	UT-45S		
II-AF-005AF-FW-251	PC,VLV / PC,PIP	AF	2	2-2-11	UT-45S		
II-AF-005AF-FW-252	PC,PIP / PE,LR	AF	2	2-2-11	UT-45S		
II-AF-005AF-SW-A3	PE,LR / PC,PIP	AF	2	2-2-11	UT-45S		
II-AF-005AF-SW-B3	PC,VEN / PC,PIP	AF	2	2-2-11	UT-45S		
II-AF-005AF-SW-B4	PC,PIP / PC,VEN	AF	2	2-2-11	UT-45S		
II-AF-005AF-SW-B5	PBCC,T / PC,PIP	AF	2	2-2-11	UT-45S		
II-AF-005AF-SW-B6	PC,PIP / PBCC,T	AF	2	2-2-11	UT-45S		
II-AF-005AF-SW-C3	PC,PIP / PE,LR	AF	2	2-2-11	UT-45S		
II-AF-005AF-SW-C4	PE,LR / PC,PIP	AF	2	2-2-11	UT-45S		
II-AF-006AF-01-FW-3	PC,PIP / PBCC,T	AF	2	2-3-12	UT-45S		Was II-AF-006AF-FW-248.

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	FSAR	FINAL SAFETY ANALYSIS REPORT - SECTION 6.6.8					
ITEM NO.	6.6.8B	AUGMENTED PIPING WELD VOLUMETRIC EXAMINATION PER FSAR					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-AF-006AF-FW-244	PC,VLV / PC,PIP	AF	2	2-3-12	UT-45S		
II-AF-006AF-FW-245	PC,PIP / PBCC,T	AF	2	2-3-12	UT-45S		
II-AF-006AF-FW-246	PC,VLV / PC,PIP	AF	2	2-3-12	UT-45S		
II-AF-006AF-FW-247	PC,PIP / PE,LR	AF	2	2-3-12	UT-45S		
II-AF-006AF-SW-A3	PE,LR / PC,PIP	AF	2	2-3-12	UT-45S		
II-AF-006AF-SW-B3	PC,VEN / PC,PIP	AF	2	2-3-12	UT-45S		
II-AF-006AF-SW-B4	PC,PIP / PC,VEN	AF	2	2-3-12	UT-45S		
II-AF-006AF-SW-B5	PBCC,T / PC,PIP	AF	2	2-3-12	UT-45S		
II-AF-006AF-SW-C3	PC,PIP / PE,LR	AF	2	2-3-12	UT-45S		
II-AF-006AF-SW-C4	PE,LR / PC,PIP	AF	2	2-3-12	UT-45S		
II-AF-007AF-01-FW-3	PC,PIP / PBCC,T	AF	2	2-3-12	UT-45S		Was II-AF-007AF-FW-243.
II-AF-007AF-FW-239	PC,VLV / PC,PIP	AF	2	2-3-12	UT-45S		
II-AF-007AF-FW-240	PC,PIP / PBCC,T	AF	2	2-3-12	UT-45S		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY FSAR
ITEM NO. 6.6.8B

FINAL SAFETY ANALYSIS REPORT - SECTION 6.6.8
AUGMENTED PIPING WELD VOLUMETRIC EXAMINATION PER FSAR

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-AF-007AF-FW-241	PC,VLV / PC,PIP	AF	2	2-3-12	UT-45S		
II-AF-007AF-FW-242	PC,PIP / PE,LR	AF	2	2-3-12	UT-45S		
II-AF-007AF-SW-A3	PE,LR / PC,PIP	AF	2	2-3-12	UT-45S		
II-AF-007AF-SW-B3	PC,VEN / PC,PIP	AF	2	2-3-12	UT-45S		
II-AF-007AF-SW-B4	PC,PIP / PC,VEN	AF	2	2-3-12	UT-45S		
II-AF-007AF-SW-B5	PBCC,T / PC,PIP	AF	2	2-3-12	UT-45S		
II-AF-007AF-SW-B6	PC,PIP / PBCC,T	AF	2	2-3-12	UT-45S		
II-AF-007AF-SW-C3	PC,PIP / PE,LR	AF	2	2-3-12	UT-45S		
II-AF-007AF-SW-C4	PE,LR / PC,PIP	AF	2	2-3-12	UT-45S		
II-CS-022CS-FW-561	PC,VLV / PC,PIP	CS	2	2-2-10	UT-45S		Not HPSI.
II-CS-022CS-FW-562	PC,PIP / PI,FHB	CS	2	2-2-10	UT-45S		Not HPSI.
II-CS-092CS-FW-3028	PI,FHB / PC,PIP	CS	2	2-2-10	UT-45S		Not HPSI.
II-CS-092CS-FW-3029	PC,PIP / PC,VLV	CS	2	2-2-10	UT-45S		Not HPSI.

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	FSAR	FINAL SAFETY ANALYSIS REPORT - SECTION 6.6.8					
ITEM NO.	6.6.8B	AUGMENTED PIPING WELD VOLUMETRIC EXAMINATION PER FSAR					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-FW-002AF-01-FW-1	PBCC,T / PC,PIP	AF	2	2-1-08	UT-45S		
II-FW-002AF-01-FW-2	PC,PIP / PBCC,T	AF	2	2-1-08	UT-45S		Was II-FW-002AF-SW-A4.
II-FW-002AF-01-FW-5	PC,VLV / PC,PIP	AF	2	2-1-09	UT-45S		Was II-FW-002AF-FW-259.
II-FW-002AF-16-1-SW-2	PC,PIP / PC,PIP	AF	2	2-1-09	UT-45S		
II-FW-002AF-16-2-SW-2	PC,PIP / PC,PIP	AF	2	2-1-08	UT-45S		
II-FW-002AF-FW-257	PC,VLV / PC,PIP	AF	2	2-1-09	UT-45S		
II-FW-002AF-FW-258	PC,PIP / PC,VLV	AF	2	2-1-09	UT-45S		
II-FW-002AF-FW-260	PC,PIP / PP,FHS	AF	2	2-1-08	UT-45S		
II-FW-003AF-01-FW-1	PBCC,T / PC,PIP	AF	2	2-2-11	UT-45S		Was II-FW-003AF-17-2-SW-1.
II-FW-003AF-01-FW-2	PC,PIP / PBCC,T	AF	2	2-3-13	UT-45S		Was II-FW-003AF-SW-A4.
II-FW-003AF-01-FW-4	PC,VLV / PC,PIP	AF	2	2-3-13	UT-45S		Was II-FW-003AF-FW-266.
II-FW-003AF-17-2-SW-2	PC,PIP / PC,PIP	AF	2	2-2-11	UT-45S		
II-FW-003AF-FW-267	PC,PIP / PP,FHS	AF	2	2-2-11	UT-45S		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	FSAR	FINAL SAFETY ANALYSIS REPORT - SECTION 6.6.8					
ITEM NO.	6.6.8B	AUGMENTED PIPING WELD VOLUMETRIC EXAMINATION PER FSAR					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-FW-003AF-FW-268	PC,VLV / PC,PIP	AF	2	2-2-11	UT-45S		
II-FW-003AF-FW-269	PC,PIP / PC,VLV	AF	2	2-2-11	UT-45S		
II-FW-004AF-01-FW-1	PC,VLV / PC,PIP	AF	2	2-3-13	UT-45S		Was II-FW-004AF-FW-276.
II-FW-004AF-01-FW-2	PC,PIP / PC,VLV	AF	2	2-3-13	UT-45S		Was II-FW-004AF-FW-277.
II-FW-004AF-01-FW-3	PC,VLV / PC,PIP	AF	2	2-3-13	UT-45S		Was II-FW-004AF-FW-273.
II-FW-004AF-01-FW-4	PC,PIP / PBCC,T	AF	2	2-3-13	UT-45S		Was II-FW-004AF-SW-A4.
II-FW-004AF-01-FW-5	PBCC,T / PC,PIP	AF	2	2-3-13	UT-45S		Was II-FW-004AF-18-2-SW-1.
II-FW-004AF-01-FW-7	PC,PIP / PP,FHS	AF	2	2-3-13	UT-45S		Was II-FW-004AF-FW-274.
II-FW-004AF-18-2-SW-2	PC,PIP / PC,PIP	AF	2	2-3-13	UT-45S		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	FSAR	FINAL SAFETY ANALYSIS REPORT - SECTION 6.6.8					
ITEM NO.	6.6.8C	AUGMENTED PIPING WELD VOLUMETRIC EXAMINATION PER FSAR					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-FW-001FW-32-3-SW-1	PBC,S / PC,PIP	FW	N	2-2-11	UT-45S		
II-FW-001FW-32-4-SW-1	PF,A / PC,PIP	FW	N	2-2-11	UT-45S		
II-FW-001FW-32-5-SW-5	PC,PIP / PF,A	FW	N	2-2-11	UT-45S		
II-FW-001FW-36-1-SW-2	PF,A / PC,PIP	FW	N	2-2-11	UT-45S		
II-FW-001FW-36-2-SW-1	PC,PIP / PF,A	FW	N	2-2-11	UT-45S		
II-FW-001FW-36-2-SW-6	PC,PIP / PC,PIP	FW	N	2-2-11	UT-45S		
II-FW-001FW-36-2-SW-7	PBC,S / PC,PIP	FW	N	2-2-11	UT-45S		
II-FW-001FW-39-3-SW-1	PF,A / PC,PIP	FW	N	2-2-11	UT-45S		
II-FW-001FW-39-4-SW-1	PC,PIP / PF,A	FW	N	2-2-11	UT-45S		
II-FW-001FW-39-4-SW-6	PBC,S / PC,PIP	FW	N	2-2-11	UT-45S		
II-FW-001FW-FW-469	PC,PIP / PC,VLV	FW	N	2-2-11	UT-45S		
II-FW-001FW-FW-470	PC,PIP / PC,PIP	FW	N	2-2-11	UT-45S		
II-FW-001FW-FW-473	PC,PIP / PC,VLV	FW	N	2-2-11	UT-45S		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY FSAR
ITEM NO. 6.6.8C

FINAL SAFETY ANALYSIS REPORT - SECTION 6.6.8
AUGMENTED PIPING WELD VOLUMETRIC EXAMINATION PER FSAR

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-FW-001FW-FW-476	PC,PIP / PC,VLV	FW	N	2-2-11	UT-45S		
II-FW-001FW-FW-499	PC,VLV / PC,PIP	FW	N	2-2-11	UT-45S		
II-FW-001FW-FW-500	PC,PIP / PC,VLV	FW	N	2-2-11	UT-45S		
II-FW-001FW-FW-501	PC,VLV / PC,PIP	FW	2	2-2-11	UT-45S		
II-FW-001FW-FW-502	PC,PIP / PI,FHB	FW	2	2-2-11	UT-45S		
II-FW-001FW-FW-503	PC,VLV / PC,PIP	FW	N	2-2-11	UT-45S		
II-FW-001FW-FW-504	PC,PIP / PC,VLV	FW	N	2-2-11	UT-45S		
II-FW-001FW-FW-505	PC,VLV / PC,PIP	FW	2	2-2-11	UT-45S		
II-FW-001FW-FW-506	PC,PIP / PI,FHB	FW	2	2-2-11	UT-45S		
II-FW-001FW-FW-507	PC,VLV / PC,PIP	FW	N	2-2-11	UT-45S		
II-FW-001FW-FW-508	PC,PIP / PC,VLV	FW	N	2-2-11	UT-45S		
II-FW-001FW-FW-509	PC,VLV / PC,PIP	FW	2	2-2-11	UT-45S		
II-FW-001FW-FW-510	PC,PIP / PP,FHS	FW	2	2-2-11	UT-45S		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY FSAR
ITEM NO. 6.6.8C

FINAL SAFETY ANALYSIS REPORT - SECTION 6.6.8
AUGMENTED PIPING WELD VOLUMETRIC EXAMINATION PER FSAR

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-FW-001FW-SW-A4	PC,PIP / PBC,S	FW	2	2-2-11	UT-45S		
II-FW-001FW-SW-B4	PC,PIP / PBC,S	FW	2	2-2-11	UT-45S		
II-FW-001FW-SW-C4	PC,PIP / PBC,S	FW	2	2-2-11	UT-45S		
II-FW-001FW-SW-D3	PBCC,T / PC,PIP	FW	N	2-2-11	UT-45S		
II-FW-001FW-SW-D4	PC,PIP / PBCC,T	FW	N	2-2-11	UT-45S		
II-FW-001FW-SW-E3	PBCC,T / PC,PIP	FW	N	2-2-11	UT-45S		
II-FW-001FW-SW-E4	PC,PIP / PBCC,T	FW	N	2-2-11	UT-45S		
II-FW-001FW-SW-F3	PBCC,T / PC,PIP	FW	N	2-2-11	UT-45S		
II-FW-001FW-SW-F4	PC,PIP / PBCC,T	FW	N	2-2-11	UT-45S		
II-FW-001FW-SW-K3	PC,PIP / PC,PIP	FW	N	2-2-11	UT-45S		
II-FW-001FW-SW-K8	PC,PB / PC,PIP	FW	N	2-2-11	UT-45S		
II-FW-002FW-39-5-SW-1	PC,PIP / PE,LR	FW	N	2-1-08	UT-45S		
II-FW-002FW-39-5-SW-2	PE,LR-P / PIPE	FW	N	2-1-08	UT-45S		



Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	FSAR	FINAL SAFETY ANALYSIS REPORT - SECTION 6.6.8					
ITEM NO.	6.6.8C	AUGMENTED PIPING WELD VOLUMETRIC EXAMINATION PER FSAR					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-FW-002FW-39-5-SW-3	PC,PIP / PE,LR	FW	N	2-1-08	UT-45S		
II-FW-002FW-39-5-SW-4	PE,LR-P / ,PIPE	FW	N	2-1-08	UT-45S		
II-FW-002FW-39-5-SW-5	PC,PIP / PE,LR	FW	N	2-1-08	UT-45S		
II-FW-002FW-39-5-SW-6	PE,LR-P / ,PIPE	FW	N	2-1-08	UT-45S		
II-FW-002FW-39-5-SW-7	PC,PIP / PC,PIP	FW	N	2-1-08	UT-45S		
II-FW-002FW-39-FW-481	PBC,S / PC,PIP	FW	N	2-1-08	UT-45S		
II-FW-002FW-39-FW-482	PC,PIP / PC,VLV	FW	N	2-1-08	UT-45S		
II-FW-002FW-FW-576	PBCC,T / PC,RED	FW	N	2-1-08	UT-45S		
II-FW-003FW-36-3-SW-1	PC,PIP / PE,LR	FW	N	2-1-08	UT-45S		
II-FW-003FW-36-3-SW-10	PE,LR-P / ,PIPE	FW	N	2-2-11	UT-45S		
II-FW-003FW-36-3-SW-11	PC,PIP / PE,LR	FW	N	2-2-11	UT-45S		
II-FW-003FW-36-3-SW-12	PE,LR-P / ,PIPE	FW	N	2-2-11	UT-45S		
II-FW-003FW-36-3-SW-13	PC,PIP / PE,LR	FW	N	2-2-11	UT-45S		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	FSAR	FINAL SAFETY ANALYSIS REPORT - SECTION 6.6.8					
ITEM NO.	6.6.8C	AUGMENTED PIPING WELD VOLUMETRIC EXAMINATION PER FSAR					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-FW-003FW-36-3-SW-14	PE,LR-P / ,PIPE	FW	N	2-3-13	UT-45S		
II-FW-003FW-36-3-SW-2	PE,LR-P / ,PIPE	FW	N	2-2-11	UT-45S		
II-FW-003FW-36-3-SW-3	PC,PIP / PE,LR	FW	N	2-2-11	UT-45S		
II-FW-003FW-36-3-SW-4	PE,LR-P / ,PIPE	FW	N	2-2-11	UT-45S		
II-FW-003FW-36-3-SW-5	PC,PIP / PE,LR	FW	N	2-2-11	UT-45S		
II-FW-003FW-36-3-SW-6	PE,LR-P / ,PIPE	FW	N	2-2-11	UT-45S		
II-FW-003FW-36-3-SW-7	PC,PIP / PE,LR	FW	N	2-2-11	UT-45S		
II-FW-003FW-36-3-SW-8	PE,LR-P / ,PIPE	FW	N	2-2-11	UT-45S		
II-FW-003FW-36-3-SW-9	PC,PIP / PE,LR	FW	N	2-2-11	UT-45S		
II-FW-003FW-36-FW-478	PBC,S / PC,PIP	FW	N	2-1-08	UT-45S		
II-FW-003FW-36-FW-479	PC,VLV / C,PIPE	FW	N	2-3-13	UT-45S		
II-FW-003FW-FW-578	PBCC,T / PC,RED	FW	N	2-1-08	UT-45S		
II-FW-004FW-32-6-SW-1	PC,PIP / PE,LR	FW	N	2-3-13	UT-45S		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	FSAR	FINAL SAFETY ANALYSIS REPORT - SECTION 6.6.8					
ITEM NO.	6.6.8C	AUGMENTED PIPING WELD VOLUMETRIC EXAMINATION PER FSAR					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-FW-004FW-32-6-SW-2	PE,LR-P / ,PIPE	FW	N	2-3-13	UT-45S		
II-FW-004FW-32-6-SW-3	PC,PIP / PE,LR	FW	N	2-3-13	UT-45S		
II-FW-004FW-32-6-SW-4	PE,LR-P / ,PIPE	FW	N	2-3-13	UT-45S		
II-FW-004FW-32-6-SW-5	PC,PIP / PE,LR	FW	N	2-3-13	UT-45S		
II-FW-004FW-32-6-SW-6	PE,LR-P / ,PIPE	FW	N	2-3-13	UT-45S		
II-FW-004FW-32-6-SW-7	PC,PIP / PC,PIP	FW	N	2-3-13	UT-45S		
II-FW-004FW-32-FW-478	PC,PIP / PC,VLV	FW	N	2-3-13	UT-45S		
II-FW-004FW-FW-477	PBC,S / PC,PIP	FW	N	2-3-13	UT-45S		
II-FW-004FW-FW-574	PBCC,T / PC,RED	FW	N	2-1-08	UT-45S		
II-MS-001MS-64-1-MW-1	PC,PIP / PC,PIP	MS	N	2-3-13	UT-45S		
II-MS-001MS-64-1-MW-1A	PLSW,P /	MS	N	2-3-13	UT-45S		
II-MS-001MS-64-1-MW-1B	PLSW,P /	MS	N	2-3-13	UT-45S		
II-MS-001MS-64-1-MW-2	PC,PIP / PC,PIP	MS	N	2-3-13	UT-45S		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	FSAR	FINAL SAFETY ANALYSIS REPORT - SECTION 6.6.8					
ITEM NO.	6.6.8C	AUGMENTED PIPING WELD VOLUMETRIC EXAMINATION PER FSAR					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-MS-001MS-64-1-MW-2A	PLSW,P /	MS	N	2-3-13	UT-45S		
II-MS-001MS-64-1-MW-2B	PLSW,P /	MS	N	2-3-13	UT-45S		
II-MS-001MS-FW-256	PE,LR / PC,PIP	MS	N	2-3-13	UT-45S		
II-MS-001MS-FW-256A	PLSW,P /	MS	N	2-3-13	UT-45S		
II-MS-001MS-FW-256B	PLSW,P /	MS	N	2-3-13	UT-45S		
II-MS-001MS-FW-257	PC,PIP / PC,PIP	MS	N	2-3-13	UT-45S		
II-MS-001MS-FW-258	PC,PIP / PC,PIP	MS	N	2-3-13	UT-45S		
II-MS-001MS-FW-258A	PLSW,P /	MS	N	2-3-13	UT-45S		
II-MS-001MS-FW-259	PC,PIP / PC,PIP	MS	N	2-3-13	UT-45S		
II-MS-001MS-FW-259A	PLSW,P /	MS	N	2-3-13	UT-45S		
II-MS-001MS-FW-260	PE,LR / PC,PIP	MS	N	2-3-13	UT-45S		
II-MS-001MS-FW-260A	PLSW,P /	MS	N	2-3-13	UT-45S		
II-MS-001MS-FW-260B	PLSW,P /	MS	N	2-3-13	UT-45S		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	FSAR	FINAL SAFETY ANALYSIS REPORT - SECTION 6.6.8					
ITEM NO.	6.6.8C	AUGMENTED PIPING WELD VOLUMETRIC EXAMINATION PER FSAR					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-MS-001MS-FW-261	PC,PIP / PC,PIP	MS	N	2-3-13	UT-45S		
II-MS-001MS-FW-262	PC,PIP / PC,PIP	MS	N	2-3-13	UT-45S		
II-MS-001MS-FW-263	PE,LR / PC,PIP	MS	N	2-3-13	UT-45S		
II-MS-001MS-FW-263A	PLSW,P /	MS	N	2-3-13	UT-45S		
II-MS-001MS-FW-263B	PLSW,P /	MS	N	2-3-13	UT-45S		
II-MS-001MS-FW-282	PC,VLV / PC,PIP	MS	N	2-3-13	UT-45S		
II-MS-001MS-FW-283	PC,PIP / PC,VLV	MS	2	2-1-08	UT-45S		
II-MS-001MS-FW-283A	PLSW,P /	MS	2	2-1-08	UT-45S		
II-MS-001MS-FW-284	PC,PIP / PC,PIP	MS	2	2-1-08	UT-45S		
II-MS-001MS-FW-285	PC,PIP / PC,PIP	MS	2	2-2-11	UT-45S		
II-MS-001MS-FW-286	PC,PIP / PC,VLV	MS	2	2-2-11	UT-45S		
II-MS-001MS-FW-286A	PLSW,P /	MS	2	2-2-11	UT-45S		
II-MS-001MS-FW-287	PC,VLV / PC,PIP	MS	N	2-3-13	UT-45S		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	FSAR	FINAL SAFETY ANALYSIS REPORT - SECTION 6.6.8					
ITEM NO.	6.6.8C	AUGMENTED PIPING WELD VOLUMETRIC EXAMINATION PER FSAR					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-MS-001MS-FW-301	PC,PIP / PC,PIP	MS	2	2-3-13	UT-45S		
II-MS-001MS-FW-302	PC,PIP / PC,VLV	MS	2	2-3-13	UT-45S		
II-MS-001MS-FW-302A	PLSW,P /	MS	2	2-3-13	UT-45S		
II-MS-001MS-FW-303	PC,VLV / PC,PIP	MS	N	2-3-13	UT-45S		
II-MS-001MS-SW-A11	PC,PIP / PC,NOZ	MS	2	2-1-08	UT-45S		
II-MS-001MS-SW-A12	PC,PIP / PC,NOZ	MS	2	2-1-08	UT-45S		
II-MS-001MS-SW-A13	PC,PIP / PC,NOZ	MS	2	2-1-08	UT-45S		
II-MS-001MS-SW-A14	PC,PIP / PC,NOZ	MS	2	2-1-08	UT-45S		
II-MS-001MS-SW-A15	PC,PIP / PC,NOZ	MS	2	2-1-08	UT-45S		
II-MS-001MS-SW-A3	PC,PIP / PC,PIP	MS	2	2-1-08	UT-45S		
II-MS-001MS-SW-A30	PBCC,E / PC,PIP	MS	2	2-1-08	UT-45S		
II-MS-001MS-SW-A34	PC,PIP / PC,PIP	MS	2	2-1-08	UT-45S		
II-MS-001MS-SW-A3A	PLSW,P /	MS	2	2-1-08	UT-45S		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY FSAR
ITEM NO. 6.6.8C

FINAL SAFETY ANALYSIS REPORT - SECTION 6.6.8
AUGMENTED PIPING WELD VOLUMETRIC EXAMINATION PER FSAR

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-MS-001MS-SW-A4	PBCC,E / PC,PIP	MS	2	2-1-09	UT-45S		
II-MS-001MS-SW-A5	PC,PIP / PC,CAP	MS	2	2-1-09	UT-45S		
II-MS-001MS-SW-B11	PC,PIP / PC,NOZ	MS	2	2-2-11	UT-45S		
II-MS-001MS-SW-B12	PC,PIP / PC,NOZ	MS	2	2-2-11	UT-45S		
II-MS-001MS-SW-B13	PC,PIP / PC,NOZ	MS	2	2-2-11	UT-45S		
II-MS-001MS-SW-B14	PC,PIP / PC,NOZ	MS	2	2-2-11	UT-45S		
II-MS-001MS-SW-B15	PC,PIP / PC,NOZ	MS	2	2-2-11	UT-45S		
II-MS-001MS-SW-B3	PC,PIP / PC,PIP	MS	2	2-2-11	UT-45S		
II-MS-001MS-SW-B30	PBCC,E / PC,PIP	MS	2	2-2-11	UT-45S		
II-MS-001MS-SW-B34	PBCC,E / PC,PIP	MS	2	2-2-11	UT-45S		
II-MS-001MS-SW-B35	PC,PIP / PC,PIP	MS	2	2-2-11	UT-45S		
II-MS-001MS-SW-B3A	PLSW,P /	MS	2	2-2-11	UT-45S		
II-MS-001MS-SW-B4	PBCC,E / PC,PIP	MS	2	2-2-11	UT-45S		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY FSAR
ITEM NO. 6.6.8C

FINAL SAFETY ANALYSIS REPORT - SECTION 6.6.8
AUGMENTED PIPING WELD VOLUMETRIC EXAMINATION PER FSAR

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-MS-001MS-SW-B5	PC,PIP / PC,CAP	MS	2	2-2-11	UT-45S		
II-MS-001MS-SW-C11	PC,PIP / PC,NOZ	MS	2	2-3-13	UT-45S		
II-MS-001MS-SW-C12	PC,PIP / PC,NOZ	MS	2	2-3-13	UT-45S		
II-MS-001MS-SW-C13	PC,PIP / PC,NOZ	MS	2	2-3-13	UT-45S		
II-MS-001MS-SW-C14	PC,PIP / PC,NOZ	MS	2	2-3-13	UT-45S		
II-MS-001MS-SW-C15	PC,PIP / PC,NOZ	MS	2	2-3-13	UT-45S		
II-MS-001MS-SW-C3	PC,PIP / PC,PIP	MS	2	2-3-13	UT-45S		
II-MS-001MS-SW-C30	PBCC,E / PC,PIP	MS	2	2-3-13	UT-45S		
II-MS-001MS-SW-C34	PBCC,E / PC,PIP	MS	2	2-3-13	UT-45S		
II-MS-001MS-SW-C36	PC,PIP / PC,PIP	MS	2	2-3-13	UT-45S		
II-MS-001MS-SW-C3A	PLSW,P /	MS	2	2-3-13	UT-45S		
II-MS-001MS-SW-C4	PBCC,E / PC,PIP	MS	2	2-3-13	UT-45S		
II-MS-001MS-SW-C5	PC,PIP / PC,CAP	MS	2	2-3-13	UT-45S		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY FSAR
ITEM NO. 6.6.8C

FINAL SAFETY ANALYSIS REPORT - SECTION 6.6.8
AUGMENTED PIPING WELD VOLUMETRIC EXAMINATION PER FSAR

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-MS-001MS-SW-D1	PC,PIP / PE,LR	MS	N	2-3-13	UT-45S		
II-MS-001MS-SW-D1A	PLSW,P /	MS	N	2-3-13	UT-45S		
II-MS-001MS-SW-D1B	PLSW,P /	MS	N	2-3-13	UT-45S		
II-MS-001MS-SW-E1	PC,PIP / PC,PIP	MS	N	2-3-13	UT-45S		
II-MS-001MS-SW-F1	PC,PIP / PE,LR	MS	N	2-3-13	UT-45S		
II-MS-001MS-SW-F1A	PLSW,P /	MS	N	2-3-13	UT-45S		
II-MS-001MS-SW-F1B	PLSW,P /	MS	N	2-3-13	UT-45S		
II-MS-001MS-SW-G1	PC,PIP / PC,PIP	MS	N	2-3-13	UT-45S		
II-MS-001MS-SW-G2	C,PIPE- / C,PIPE	MS	N	2-3-13	UT-45S		
II-MS-001MS-SW-H1	PC,PIP / PE,LR	MS	N	2-3-13	UT-45S		
II-MS-001MS-SW-H1A	PLSW,P /	MS	N	2-3-13	UT-45S		
II-MS-001MS-SW-H1B	PLSW,P /	MS	N	2-3-13	UT-45S		
II-MS-001MS-SW-I1	PC,PIP / PC,PIP	MS	N	2-3-13	UT-45S		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY FSAR FINAL SAFETY ANALYSIS REPORT - SECTION 6.6.8
ITEM NO. 6.6.8C AUGMENTED PIPING WELD VOLUMETRIC EXAMINATION PER FSAR

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-MS-001MS-SW-J1	PC,PIP / PC,CAP	MS	N	2-3-13	UT-45S		
II-MS-001MS-SW-J12	PC,PIP / PC,PIP	MS	N	2-3-13	UT-45S		
II-MS-001MS-SW-J12A	PLSW,P /	MS	N	2-3-13	UT-45S		
II-MS-001MS-SW-J12B	PLSW,P /	MS	N	2-3-13	UT-45S		
II-MS-001MS-SW-J1A	PLSW,P /	MS	N	2-3-13	UT-45S		
II-MS-001MS-SW-J2	PC,PIP / PC,CAP	MS	N	2-3-13	UT-45S		
II-MS-001MS-SW-J2A	PLSW,P /	MS	N	2-3-13	UT-45S		
II-MS-001MS-SW-K1	PC,PIP / PC,PIP	MS	N	2-3-13	UT-45S		
II-MS-001MS-SW-K1A	PLSW,P /	MS	N	2-3-13	UT-45S		
II-MS-001MS-SW-K1B	PLSW,P /	MS	N	2-3-13	UT-45S		
II-MS-001MS-SW-M1	PC,PIP / PC,PIP	MS	N	2-3-13	UT-45S		
II-MS-001MS-SW-M1A	PLSW,P /	MS	N	2-3-13	UT-45S		
II-MS-001MS-SW-M1B	PLSW,P /	MS	N	2-3-13	UT-45S		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY FSAR
ITEM NO. 6.6.8C

FINAL SAFETY ANALYSIS REPORT - SECTION 6.6.8
AUGMENTED PIPING WELD VOLUMETRIC EXAMINATION PER FSAR

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-MS-002MS-FW-565	PC,PIP / PE,LR	MS	2	2-2-10	UT-45S		
II-MS-002MS-FW-566	PC,PIP / PC,VLV	MS	2	2-2-10	UT-45S		
II-MS-002MS-FW-567	PC,VLV / PC,PIP	MS	2	2-2-10	UT-45S		
II-MS-002MS-FW-568	PC,PIP / PC,VLV	MS	2	2-2-10	UT-45S		
II-MS-002MS-FW-680	PC,PIP / PE,LR	MS	2	2-3-13	UT-45S		
II-MS-002MS-FW-681	PC,PIP / PC,VLV	MS	2	2-3-13	UT-45S		
II-MS-002MS-FW-682	PC,VLV / PC,PIP	MS	2	2-3-13	UT-45S		
II-MS-002MS-FW-683	PC,PIP / PC,VLV	MS	2	2-3-13	UT-45S		
II-MS-002MS-FW-690	PC,PIP / PC,VLV	MS	2	2-1-09	UT-45S		
II-MS-002MS-FW-691	PC,VLV / PC,PIP	MS	2	2-1-09	UT-45S		
II-MS-002MS-FW-692	PC,PIP / PC,VLV	MS	2	2-1-09	UT-45S		
II-MS-002MS-FW-693	PC,PIP / PE,LR	MS	2	2-1-09	UT-45S		
II-MS-002MS-SW-A3	PE,LR / PC,PIP	MS	2	2-1-09	UT-45S		



Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY FSAR
ITEM NO. 6.6.8C

FINAL SAFETY ANALYSIS REPORT - SECTION 6.6.8
AUGMENTED PIPING WELD VOLUMETRIC EXAMINATION PER FSAR

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-MS-002MS-SW-C3	PE,LR / PC,PIP	MS	2	2-2-10	UT-45S		
II-MS-002MS-SW-E3	PE,LR / PC,PIP	MS	2	2-3-13	UT-45S		
II-MS-007MS-96-FW-101	PC,PIP / PC,VLV	MS	2	2-1-09	UT-45S		
II-MS-007MS-FW-563	PC,PIP / PC,VLV	MS	2	2-1-09	UT-45S		
II-MS-007MS-FW-564	PC,PIP / PE,LR	MS	2	2-1-09	UT-45S		
II-MS-007MS-FW-679	PC,PIP / PE,LR	MS	2	2-1-09	UT-45S		
II-MS-007MS-SW-A3	PE,LR / PC,PIP	MS	2	2-1-09	UT-45S		
II-MS-007MS-SW-B3	PE,LR / PC,PIP	MS	2	2-1-09	UT-45S		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY FSAR
ITEM NO. 6.6.8D

FINAL SAFETY ANALYSIS REPORT - SECTION 6.6.8
AUGMENTED PIPING WELD SURFACE EXAMINATION PER FSAR

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-FW-001FW-SW-A3	PBC,S / PC,PIP	FW	2	2-2-11	MT		
II-FW-001FW-SW-B3	PBC,S / PC,PIP	FW	2	2-2-11	MT		
II-FW-001FW-SW-C3	PBC,S / PC,PIP	FW	2	2-2-11	MT		
II-FW-002AF-01-FW-1	PBCC,T / PC,PIP	AF	2	2-1-08	MT		WaS II-FW-002AF-16-2-SW-1.
II-FW-002FW-16-4-SW-1	PC,PIP / PE,LR	FW	2	2-1-08	MT		
II-FW-002FW-16-4-SW-2	PE,LR / PC,PIP	FW	2	2-1-08	MT		
II-FW-002FW-25-2A-SW-1	PC,RED / PC,PIP	FW	N	2-1-08	MT		
II-FW-002FW-25-2A-SW-10	PSW,E / PSW,P	FW	N	2-1-08	MT		
II-FW-002FW-25-2A-SW-2	PC,PIP / PE,LR	FW	N	2-1-08	MT		
II-FW-002FW-25-2A-SW-3	PE,LR / PC,PIP	FW	N	2-1-08	MT		
II-FW-002FW-25-2A-SW-4	PC,PIP / PE,LR	FW	N	2-1-08	MT		
II-FW-002FW-25-2A-SW-5	PE,LR / PC,PIP	FW	N	2-1-08	MT		
II-FW-002FW-25-2A-SW-6	PC,PIP / PBCC,T	FW	N	2-1-08	MT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	FSAR	FINAL SAFETY ANALYSIS REPORT - SECTION 6.6.8					
ITEM NO.	6.6.8D	AUGMENTED PIPING WELD SURFACE EXAMINATION PER FSAR					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-FW-002FW-25-2A-SW-7	PBCC,T / C,PIPE	FW	N	2-1-08	MT		
II-FW-002FW-25-2A-SW-8	PBCC,T / C,RED	FW	N	2-1-08	MT		
II-FW-002FW-25-2A-SW-9	PSW,R / PSW,E	FW	N	2-1-08	MT		
II-FW-002FW-FW-559	PC,VLV / PC,PIP	FW	2	2-1-08	MT		
II-FW-002FW-FW-560	PC,PIP / PC,VLV	FW	2	2-1-08	MT		
II-FW-002FW-FW-561	PC,VLV / PC,PIP	FW	2	2-1-08	MT		
II-FW-002FW-FW-562	PE,LR / PC,PIP	FW	2	2-1-08	MT		
II-FW-002FW-FW-577	PC,PIP / PC,VLV	FW	N	2-1-08	MT		
II-FW-002FW-FW-581	PSW,P / PSW,VL	FW	N	2-1-08	MT		
II-FW-002FW-SW-C3	PC,PIP / PE,LR	FW	2	2-1-08	MT		
II-FW-002FW-SW-C5	PC,PIP / PE,LR	FW	2	2-1-08	MT		
II-FW-002FW-SW-C6	PE,LR / PC,PIP	FW	2	2-1-08	MT		
II-FW-002FW-SW-C7	PC,PIP / PE,LR	FW	2	2-1-08	MT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	FSAR	FINAL SAFETY ANALYSIS REPORT - SECTION 6.6.8					
ITEM NO.	6.6.8D	AUGMENTED PIPING WELD SURFACE EXAMINATION PER FSAR					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-FW-002FW-SW-C8	PE,LR / PC,PIP	FW	2	2-1-08	MT		
II-FW-002FW-SW-D3	PF,WN / PC,PIP	FW	2	2-1-08	MT		
II-FW-002FW-SW-E3	PC,PIP / PF,WN	FW	2	2-1-08	MT		
II-FW-003FW-17-2-SW-2	PC,PIP / PC,PIP	FW	2	2-1-08	MT		
II-FW-003FW-25-3A-SW-1	PC,RED / PC,PIP	FW	N	2-1-08	MT		
II-FW-003FW-25-3A-SW-10	PSW,E / PSW,P	FW	N	2-1-08	MT		
II-FW-003FW-25-3A-SW-2	PC,PIP / PE,LR	FW	N	2-1-08	MT		
II-FW-003FW-25-3A-SW-3	PE,LR / PC,PIP	FW	N	2-1-08	MT		
II-FW-003FW-25-3A-SW-4	PC,PIP / PE,LR	FW	N	2-1-08	MT		
II-FW-003FW-25-3A-SW-5	PE,LR / PC,PIP	FW	N	2-1-08	MT		
II-FW-003FW-25-3A-SW-6	PC,PIP / PBCC,T	FW	N	2-1-08	MT		4 LINEAR IND. OUTSIDE EXAM AREA NOTED REF DATA SHT 0284-271
II-FW-003FW-25-3A-SW-7	PBCC,T / PC,PIP	FW	N	2-1-08	MT		LINEAR INDI OUTSIDE EXAM AREA 7/16" LG REF EXAM 0284-272
II-FW-003FW-25-3A-SW-8	PBCC,T / PC,RED	FW	N	2-1-08	MT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	FSAR	FINAL SAFETY ANALYSIS REPORT - SECTION 6.6.8					
ITEM NO.	6.6.8D	AUGMENTED PIPING WELD SURFACE EXAMINATION PER FSAR					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-FW-003FW-25-3A-SW-9	PSW,R / PSW,E	FW	N	2-1-08	MT		
II-FW-003FW-FW-565	PC,VLV / PC,PIP	FW	2	2-1-08	MT		
II-FW-003FW-FW-566	PC,PIP / PC,VLV	FW	2	2-1-08	MT		
II-FW-003FW-FW-567	PC,VLV / PC,PIP	FW	2	2-1-08	MT		
II-FW-003FW-FW-568	PE,LR / PC,PIP	FW	2	2-1-08	MT		
II-FW-003FW-FW-579	PC,PIP / PC,VLV	FW	N	2-1-08	MT		
II-FW-003FW-FW-582	PSW,P / PSW,VL	FW	N	2-1-08	MT		
II-FW-003FW-SW-C3	PC,PIP / PE,LR	FW	2	2-1-08	MT		
II-FW-003FW-SW-C4	PE,LR / PC,PIP	FW	2	2-1-08	MT		
II-FW-003FW-SW-C5	PC,PIP / PE,LR	FW	2	2-1-08	MT		INDICATION FOUND IN BASE METAL IN FIRST INTERVAL - REPAIRED BY WELDING(RPT-284-149)
II-FW-003FW-SW-C6	PE,LR / PC,PIP	FW	2	2-1-08	MT		
II-FW-003FW-SW-C7	PC,PIP / PE,LR	FW	2	2-1-08	MT		
II-FW-003FW-SW-C8	PE,LR / PC,PIP	FW	2	2-1-08	MT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	FSAR	FINAL SAFETY ANALYSIS REPORT - SECTION 6.6.8					
ITEM NO.	6.6.8D	AUGMENTED PIPING WELD SURFACE EXAMINATION PER FSAR					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-FW-003FW-SW-C9	PC,PIP / PE,LR	FW	2	2-1-08	MT		
II-FW-003FW-SW-D3	PF,WN / PC,PIP	FW	2	2-1-08	MT		
II-FW-003FW-SW-E3	PC,PIP / PF,WN	FW	2	2-1-08	MT		
II-FW-004FW-18-2-SW-2	PC,PIP / PC,PIP	FW	2	2-1-09	MT		
II-FW-004FW-18-4-SW-1	PE,LR / PC,PIP	FW	2	2-1-09	MT		
II-FW-004FW-25-1A-SW-1	PC,RED / PC,PIP	FW	N	2-1-09	MT		
II-FW-004FW-25-1A-SW-10	PSW,E / PSW,P	FW	N	2-1-09	PT		EXAM CHANGED TO PT PER CNF 89-001
II-FW-004FW-25-1A-SW-2	PC,PIP / PE,LR	FW	N	2-1-09	MT		
II-FW-004FW-25-1A-SW-3	PE,LR / PC,PIP	FW	N	2-1-09	MT		
II-FW-004FW-25-1A-SW-4	PC,PIP / PE,LR	FW	N	2-1-09	MT		
II-FW-004FW-25-1A-SW-5	PE,LR / PC,PIP	FW	N	2-1-09	MT		
II-FW-004FW-25-1A-SW-6	PC,PIP / PBCC,T	FW	N	2-1-09	MT		
II-FW-004FW-25-1A-SW-7	PBCC,T / PC,PIP	FW	N	2-1-09	MT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	FSAR	FINAL SAFETY ANALYSIS REPORT - SECTION 6.6.8						
ITEM NO.	6.6.8D	AUGMENTED PIPING WELD SURFACE EXAMINATION PER FSAR						
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments	
II-FW-004FW-25-1A-SW-8	PBCC,T / PC,RED	FW	N	2-1-09	MT			
II-FW-004FW-25-1A-SW-9	PSW,R / PSW,E	FW	N	2-1-09	PT		EXAM CHANGED TO PT PER CNF 89-001	
II-FW-004FW-FW-570	PC,VLV / PC,PIP	FW	2	2-1-09	MT			
II-FW-004FW-FW-571	PC,PIP / PC,VLV	FW	2	2-1-09	MT			
II-FW-004FW-FW-572	PC,VLV / PC,PIP	FW	2	2-1-09	MT			
II-FW-004FW-FW-573	PE,LR / PC,PIP	FW	2	2-1-09	MT			
II-FW-004FW-FW-575	PC,PIP / PC,VLV	FW	N	2-1-09	MT			
II-FW-004FW-FW-580	PSW,P / PSW,VL	FW	N	2-1-09	PT		EXAM CHANGED TO PT PER CNF 89-001	
II-FW-004FW-SW-C3	PC,PIP / PE,LR	FW	2	2-1-09	MT			
II-FW-004FW-SW-C4	PE,LR / PC,PIP	FW	2	2-1-09	MT			
II-FW-004FW-SW-C5	PC,PIP / PE,LR	FW	2	2-1-09	MT			
II-FW-004FW-SW-C6	PE,LR / PC,PIP	FW	2	2-1-09	MT			
II-FW-004FW-SW-C7	PC,PIP / PE,LR	FW	2	2-1-09	MT			

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	FSAR	FINAL SAFETY ANALYSIS REPORT - SECTION 6.6.8					
ITEM NO.	6.6.8D	AUGMENTED PIPING WELD SURFACE EXAMINATION PER FSAR					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-FW-004FW-SW-C9	PC,PIP / PE,LR	FW	2	2-1-09	MT		
II-FW-004FW-SW-D3	PF,RFW / PC,PIP	FW	2	2-1-09	MT		
II-FW-004FW-SW-E3	PC,PIP / PF,RFW	FW	2	2-1-09	MT		
II-MS-001MS-SW-A20	PC,PIP / PBC,S	MS	2	2-1-09	MT		
II-MS-001MS-SW-A6	PBC,S / PC,PIP	MS	2	2-1-09	MT		
II-MS-001MS-SW-B20	PC,PIP / PBC,S	MS	2	2-2-11	MT		
II-MS-001MS-SW-B6	PBC,S / PC,PIP	MS	2	2-2-11	MT		
II-MS-001MS-SW-C19	PC,PIP / PBC,S	MS	2	2-3-13	MT		
II-MS-001MS-SW-C6	PBC,S / PC,PIP	MS	2	2-3-13	MT		
II-MS-009MS-44-1-SW-1	PE,LR / PC,PIP	MS	2	2-1-09	MT		
II-MS-009MS-44-1-SW-2	PC,PIP / PE,LR	MS	2	2-1-09	MT		
II-MS-009MS-44-1-SW-3	PE,LR / PC,PIP	MS	2	2-1-09	MT		
II-MS-009MS-44-2-SW-1	PE,LR / PC,PIP	MS	2	2-2-10	MT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	FSAR	FINAL SAFETY ANALYSIS REPORT - SECTION 6.6.8					
ITEM NO.	6.6.8D	AUGMENTED PIPING WELD SURFACE EXAMINATION PER FSAR					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-MS-009MS-44-2-SW-2	PC,PIP / PE,LR	MS	2	2-2-10	MT		
II-MS-009MS-44-2-SW-3	PE,LR / PC,PIP	MS	2	2-2-10	MT		
II-MS-009MS-45-1-SW-1	PE,LR / PC,PIP	MS	2	2-3-13	MT		
II-MS-009MS-45-1-SW-2	PC,PIP / PE,LR	MS	2	2-3-13	MT		
II-MS-009MS-45-1-SW-3	PE,LR / PC,PIP	MS	2	2-3-13	MT		
II-MS-009MS-FW-582	PC,PIP / PE,LR	MS	2	2-1-09	MT		
II-MS-009MS-FW-583	PC,PIP / PC,VLV	MS	2	2-1-09	MT		
II-MS-009MS-FW-585	PC,PIP / PE,LR	MS	2	2-2-10	MT		
II-MS-009MS-FW-586	PC,PIP / PC,VLV	MS	2	2-2-10	MT		
II-MS-009MS-FW-588	PC,PIP / PE,LR	MS	2	2-3-13	MT		
II-MS-009MS-FW-589	PC,PIP / PC,VLV	MS	2	2-3-13	MT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	FSAR	FINAL SAFETY ANALYSIS REPORT - SECTION 6.6.8					
ITEM NO.	6.6.8E	AUGMENTED PIPING WELD SURFACE EXAMINATION PER FSAR					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-BD-001BD-FW-1	PP,FHS / PC,PB	BD	2	2-2-11	MT		
II-BD-001BD-FW-2	PC,PB / PC,VLV	BD	2	2-2-11	MT		
II-BD-001BD-SW-A8	PC,PB / PC,PB	BD	2	2-2-11	MT		
II-BD-002BD-FW-4	PP,FHS / PC,PB	BD	2	2-3-13	MT		
II-BD-002BD-FW-5	PC,PB / PC,VLV	BD	2	2-3-13	MT		
II-BD-002BD-SW-A3	PC,PB / PC,PB	BD	2	2-3-13	MT		
II-BD-003BD-46-1-SW-1	PC,PIP / PC,PIP	BD	2	2-3-13	MT		
II-BD-003BD-FW-7	PP,FHS / PC,PB	BD	2	2-3-13	MT		
II-BD-003BD-FW-8	PC,PB / PC,VLV	BD	2	2-3-13	MT		
II-BD-003BD-SW-A8	PC,PB / PC,PB	BD	2	2-3-13	MT		
II-BD-007BD-61-1-SW-1	PE,LR / PC,PIP	BD	2	2-2-11	MT		
II-BD-007BD-FW-312	PE,LR / PC,PIP	BD	2	2-2-11	MT		
II-BD-007BD-FW-313	PC,PB / PP,FHS	BD	2	2-2-11	MT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	FSAR	FINAL SAFETY ANALYSIS REPORT - SECTION 6.6.8					
ITEM NO.	6.6.8E	AUGMENTED PIPING WELD SURFACE EXAMINATION PER FSAR					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-BD-007BD-M53-PW-1	PP,FHS / NTERN	BD	2		MT		Inaccessible. Inside Containment Penetration.
II-BD-007BD-SW-A3	PC,PIP / PE,LR	BD	2	2-2-11	MT		
II-BD-007BD-SW-A6	PC,PIP / PE,LR	BD	2	2-2-11	MT		
II-BD-007BD-SW-B3	PC,PIP / PC,PIP	BD	2	2-2-11	MT		
II-BD-007BD-SW-B4	PC,PIP / PC,PIP	BD	2	2-2-11	MT		
II-BD-008BD-FW-319	PC,PIP / PE,LR	BD	2	2-2-11	MT		
II-BD-008BD-FW-320	PC,PB / PP,FHS	BD	2	2-2-11	MT		
II-BD-008BD-M52-PW-1	PP,FHS / NTERN	BD	2		MT		Inaccessible. Inside Containment Penetration.
II-BD-008BD-SW-A3	PC,PIP / PE,LR	BD	2	2-2-11	MT		
II-BD-008BD-SW-A4	PE,LR / PC,PB	BD	2	2-2-11	MT		
II-BD-008BD-SW-A5	PC,PIP / PE,LR	BD	2	2-2-11	MT		
II-BD-008BD-SW-A6	PE,LR / PC,PIP	BD	2	2-2-11	MT		
II-BD-008BD-SW-A9	PC,PB / PC,PIP	BD	2	2-2-11	MT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY FSAR
ITEM NO. 6.6.8E

FINAL SAFETY ANALYSIS REPORT - SECTION 6.6.8
AUGMENTED PIPING WELD SURFACE EXAMINATION PER FSAR

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-BD-008BD-SW-B3	PE,LR / PC,PB	BD	2	2-2-11	MT		
II-BD-008BD-SW-B4	PC,PB / PE,LR	BD	2	2-2-11	MT		
II-BD-008BD-SW-B5	PE,LR / PC,PB	BD	2	2-2-11	MT		
II-BD-009BD-56-1-SW-1	PE,LR / PC,PB	BD	2	2-2-11	MT		
II-BD-009BD-FW-305	PC,PB / PE,LR	BD	2	2-2-11	MT		
II-BD-009BD-FW-306	PC,PB / PP,FHS	BD	2	2-2-11	MT		
II-BD-009BD-M51-PW-1	PP,FHS / NTERN	BD	2		MT		Inaccessible. Inside Containment Penetration.
II-BD-009BD-SW-A3	PC,PIP / PE,LR	BD	2	2-2-11	MT		
II-BD-009BD-SW-A5	PC,PB / PC,PB	BD	2	2-2-11	MT		
II-BD-009BD-SW-B3	PE,LR / PC,PIP	BD	2	2-2-11	MT		
II-BD-009BD-SW-B4	PC,PIP / PE,LR	BD	2	2-2-11	MT		
II-BD-009BD-SW-B5	PE,LR / PC,PB	BD	2	2-2-11	MT		
II-BD-010BD-F5SN-MW-1	PC,VLV / PC,RED	BD	2	2-1-08	MT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY FSAR
ITEM NO. 6.6.8E

FINAL SAFETY ANALYSIS REPORT - SECTION 6.6.8
AUGMENTED PIPING WELD SURFACE EXAMINATION PER FSAR

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-BD-010BD-FW-206	PC,VLV / PC,PIP	BD	2	2-1-09	PT		EXAM CHANGED FROM MT TO PT PER CNF 89-002
II-BD-010BD-FW-310	PC,RED / PE,LR	BD	2	2-1-08	MT		
II-BD-010BD-FW-311	PBCC,T / PC,PIP	BD	2	2-1-08	MT		
II-BD-010BD-SW-A3	PE,LR / PC,PB	BD	2	2-1-08	MT		
II-BD-010BD-SW-A4	PC,PB / PBCC,T	BD	2	2-1-08	MT		
II-BD-010BD-SW-A5	PE,RED / PBCC,T	BD	2	2-1-08	MT		
II-BD-010BD-SW-A6	PC,PIP / PE,RED	BD	2	2-1-08	MT		
II-BD-011BD-F6SN-MW-1	PC,VLV / PC,RED	BD	2	2-1-08	MT		
II-BD-011BD-FW-231	PC,VLV / PC,PIP	BD	2	2-1-08	MT		
II-BD-011BD-FW-304	PC,RED / PE,LR	BD	2	2-1-08	MT		
II-BD-011BD-FW-305	PBCC,T / PC,PIP	BD	2	2-1-08	PT		
II-BD-011BD-SW-A3	PC,PIP / PE,RED	BD	2	2-1-08	MT		
II-BD-011BD-SW-A4	PE,RED / PBCC,T	BD	2	2-1-08	MT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	FSAR	FINAL SAFETY ANALYSIS REPORT - SECTION 6.6.8					
ITEM NO.	6.6.8E	AUGMENTED PIPING WELD SURFACE EXAMINATION PER FSAR					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-BD-011BD-SW-A5	PC,PB / PBCC,T	BD	2	2-1-08	PT		
II-BD-011BD-SW-A6	PE,LR / PC,PB	BD	2	2-1-08	MT		
II-BD-012BD-F4SN-MW-1	PC,VLV / PC,RED	BD	2	2-1-09	MT		
II-BD-012BD-FW-190	PC,VLV / PC,PIP	BD	2	2-1-09	PT		EXAM CHANGED FROM MT TO PT PER CNF 89-002
II-BD-012BD-FW-317	PC,RED / PE,LR	BD	2	2-1-09	MT		
II-BD-012BD-FW-318	PBCC,T / PC,PIP	BD	2	2-1-09	MT		
II-BD-012BD-SW-A3	PC,PIP / PE,RED	BD	2	2-1-09	PT		EXAM CHANGED FROM MT TO PT PER CNF 89-002
II-BD-012BD-SW-A4	PE,RED / PBCC,T	BD	2	2-1-09	MT		
II-BD-012BD-SW-A5	PC,PB / PBCC,T	BD	2	2-1-09	MT		
II-BD-012BD-SW-A6	PE,LR / PC,PB	BD	2	2-1-09	MT		
II-CS-004CS-FW-97	PP,FHS / PC,PIP	CS	2	2-3-13	PT		Not HPSI.
II-CS-004CS-FW-98	PC,PIP / PC,VLV	CS	2	2-3-13	PT		Not HPSI.
II-CS-026CS-FW-112	PC,PIP / PI,FHB	CS	2	2-3-13	PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	FSAR	FINAL SAFETY ANALYSIS REPORT - SECTION 6.6.8					
ITEM NO.	6.6.8E	AUGMENTED PIPING WELD SURFACE EXAMINATION PER FSAR					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CS-026CS-FW-113	PC,VLV / PC,PIP	CS	2	2-3-13	PT		
II-CS-027CS-FW-1420	PC,VLV / PC,PIP	CS	2	2-3-13	PT		
II-CS-027CS-FW-1421	PC,PIP / PI,FHB	CS	2	2-3-13	PT		
II-CS-033CS-FW-1437	PC,VLV / PC,PIP	CS	2	2-3-13	PT		
II-CS-033CS-FW-1438	PC,PIP / PI,FHB	CS	2	2-3-13	PT		
II-CS-088CS-FW-1467	PI,FHB / PC,PIP	CS	2	2-1-09	PT		
II-CS-088CS-FW-1468	PC,PIP / PC,VLV	CS	2	2-1-09	PT		
II-CS-088CS-M9-PW-1	PP,FHS / NTERN	CS	2		SUR		Inaccessible. Inside Containment Penetration.
II-CS-089CS-FW-1771	PC,PIP / PE,LR	CS	2	2-3-13	PT		Not HPSI.
II-CS-089CS-FW-1986	PSW,VL / PC,PIP	CS	2	2-3-13	PT		Not HPSI.
II-CS-089CS-FW-1987	PC,PIP / PE,RED	CS	2	2-3-13	PT		Not HPSI.
II-CS-089CS-FW-1992	PSW,VL / PC,PIP	CS	2	2-3-13	PT		Not HPSI.
II-CS-089CS-FW-1993	PC,PIP / PBC,S	CS	2	2-3-13	PT		Not HPSI.

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	FSAR	FINAL SAFETY ANALYSIS REPORT - SECTION 6.6.8					
ITEM NO.	6.6.8E	AUGMENTED PIPING WELD SURFACE EXAMINATION PER FSAR					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CS-089CS-FW-1998	PSW,VL / PC,PIP	CS	2	2-2-11	PT		Not HPSI.
II-CS-089CS-FW-1999	PC,PIP / PE,RED	CS	2	2-2-11	PT		Not HPSI.
II-CS-089CS-FW-3027	PC,PIP / PP,FHS	CS	2	2-3-13	PT		Not HPSI.
II-CS-089CS-M7-PW-1	PP,FHS / NTERN	CS	2		PT		Not HPSI. Inaccessible.
II-CS-089CS-SW-A3	PE,LR / PC,PIP	CS	2	2-3-13	PT		Not HPSI.
II-CS-089CS-SW-B3	PE,RED / PC,PIP	CS	2	2-3-13	PT		Not HPSI.
II-CS-089CS-SW-B4	PC,PIP / PBCC,T	CS	2	2-3-13	PT		Not HPSI.
II-CS-089CS-SW-B5	PC,PIP / PBCC,T	CS	2	2-3-13	PT		Not HPSI.
II-CS-089CS-SW-B6	PE,RED / PC,PIP	CS	2	2-3-13	PT		Not HPSI.
II-CS-089CS-SW-B7	PBCC,T / PC,PIP	CS	2	2-3-13	PT		Not HPSI.
II-CS-089CS-SW-B8	PC,PIP / PBC,S	CS	2	2-3-13	PT		Not HPSI.
II-CS-089CS-SW-B9	PC,PIP / PBC,S	CS	2	2-2-11	PT		Not HPSI.
II-CS-103CS-496-1-SW-1	PBCC,T / PC,PIP	CS	2	2-2-11	PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	FSAR	FINAL SAFETY ANALYSIS REPORT - SECTION 6.6.8					
ITEM NO.	6.6.8E	AUGMENTED PIPING WELD SURFACE EXAMINATION PER FSAR					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CS-103CS-496-1-SW-2	PC,PIP / PBCC,T	CS	2	2-2-11	PT		
II-CS-103CS-FW-2097	PI,FHB / PC,PIP	CS	2	2-2-11	PT		
II-CS-103CS-FW-2098	PC,PIP / PSW,VL	CS	2	2-2-11	PT		
II-CS-103CS-M10-PW-1	PP,FHS / NTERN	CS	2		PT		Inaccessible. Inside Containment Penetration.
II-CS-107CS-539-1-SW-1	PBCC,T / PC,PIP	CS	2	2-1-09	PT		
II-CS-107CS-FW-2071	PI,FHB / PC,PIP	CS	2	2-1-09	PT		
II-CS-107CS-FW-2072	PC,PIP / PC,VLV	CS	2	2-1-09	PT		
II-CS-107CS-M11-PW-1	PP,FHS / NTERN	CS	2		SUR		Inaccessible. Inside Containment Penetration.
II-CS-107CS-SW-C4	PC,PIP / PBCC,T	CS	2	2-1-09	PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY FSAR
ITEM NO. 6.6.8F

FINAL SAFETY ANALYSIS REPORT - SECTION 6.6.8
AUGMENTED WELDED ATTACHMENT SURFACE EXAMINATION PER FSAR

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-BD-007BD-H-0015I(8)	PC,PIP / PI,LUG	BD	2	2-2-11	MT		
II-BD-009BD-H-0031I(2)	PC,PIP / PI,TRU	BD	2	2-2-11	MT		
II-BD-011BD-H-0513I(4)	PC,PIP / PI,LUG	BD	2	2-1-08	MT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CS-001CS-128-1-SW-1	PC,PIP / PC,PIP	CS	2		PT		
II-CS-001CS-128-1-SW-2	PC,PIP / PE,LR	CS	2	2-2-10	PT		
II-CS-001CS-128-2-SW-1	PBCC,T / PC,PIP	CS	2	2-2-11	PT		
II-CS-001CS-128-2-SW-2	PC,PIP / PC,PIP	CS	2	2-2-11	PT		
II-CS-001CS-128-3-SW-1	PE,SR / PC,PIP	CS	2	2-2-11	PT		
II-CS-001CS-128-3-SW-1A	PLSW,P /	CS	2	2-2-11	PT		
II-CS-001CS-128-3-SW-2	PC,PIP / PBCC,T	CS	2		PT		
II-CS-001CS-128-FW-158	PC,PIP / PC,VLV	CS	2	2-2-11	PT		
II-CS-001CS-128-FW-159	PC,VLV / PC,PIP	CS	2	2-2-11	PT		
II-CS-001CS-131-2-SW-1	PC,PIP / PE,LR	CS	2		PT		
II-CS-001CS-131-2-SW-2	PE,LR / PC,PIP	CS	2		PT		
II-CS-001CS-131-3-SW-1	PC,PIP / PC,PIP	CS	2		PT		
II-CS-001CS-134-2-SW-2	PC,PIP / PE,LR	CS	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CS-001CS-134-2-SW-3	PBCC,T / PC,PIP	CS	2		PT		
II-CS-001CS-134-2-SW-4	PE,SR / PC,PIP	CS	2		PT		
II-CS-001CS-FW-150	PC,PIP / PC,VLV	CS	2	2-1-08	PT		
II-CS-001CS-FW-151	PC,VLV / PC,PIP	CS	2		PT		
II-CS-001CS-FW-152	PC,VLV / PC,PIP	CS	2	2-3-13	PT		
II-CS-001CS-FW-153	PC,PIP / PC,VLV	CS	2		PT		
II-CS-001CS-FW-154	PE,SR / PC,PIP	CS	2		PT		
II-CS-001CS-FW-157	PC,VLV / PC,PIP	CS	2		PT		
II-CS-001CS-FW-191	PBCC,T / PC,PIP	CS	2	2-1-08	PT		
II-CS-001CS-FW-194	PC,PIP / PE,LR	CS	2		PT		
II-CS-001CS-FW-195	PC,PIP / PC,VLV	CS	2	2-2-11	PT		
II-CS-001CS-FW-196	PC,VLV / PC,PIP	CS	2	2-2-11	PT		
II-CS-001CS-FW-197	PC,PIP / PC,VLV	CS	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CS-001CS-FW-217	PBCC,T / PC,PIP	CS	2		PT		
II-CS-001CS-FW-218	PC,PIP / PC,VLV	CS	2	2-2-11	PT		
II-CS-001CS-FW-219	PC,VLV / PC,PIP	CS	2	2-2-11	PT		
II-CS-001CS-SW-A3	PBCC,T / PC,PIP	CS	2		PT		
II-CS-001CS-SW-A4	PC,PIP / PBCC,T	CS	2		PT		
II-CS-001CS-SW-A7	PC,PIP / PE,SR	CS	2		PT		
II-CS-001CS-SW-B4	PC,PIP / PBCC,T	CS	2		PT		
II-CS-001CS-SW-B6	PC,PIP / PC,PIP	CS	2		PT		
II-CS-001CS-SW-C3	PC,PIP / PE,SR	CS	2		PT		
II-CS-001CS-SW-C4	PE,LR / PC,PIP	CS	2	2-2-11	PT		
II-CS-001CS-SW-C5	PC,PIP / PE,LR	CS	2	2-2-11	PT		
II-CS-001CS-SW-C6	PE,LR / PC,PIP	CS	2		PT		
II-CS-001CS-SW-C7	PC,PIP / PE,LR	CS	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CS-001CS-SW-C8	PE,LR / PC,PIP	CS	2	2-2-10	PT		
II-CS-001CS-SW-D3	PBCC,T / PC,PIP	CS	2		PT		
II-CS-001CS-SW-D4	PC,PIP / PBCC,T	CS	2	2-1-08	PT		
II-CS-001CS-SW-E3	PE,LR / PC,PIP	CS	2		PT		
II-CS-001CS-SW-E4	PC,PIP / PE,LR	CS	2		PT		
II-CS-001CS-SW-E5	PE,LR / PC,PIP	CS	2		PT		
II-CS-001CS-SW-G3	PE,SR / PC,PIP	CS	2		PT		
II-CS-001CS-SW-G4	PC,PIP / PE,SR	CS	2		PT		
II-CS-001CS-SW-G5	PE,LR / PC,PIP	CS	2		PT		
II-CS-001CS-SW-G6	PC,PIP / PE,LR	CS	2	2-2-10	PT		
II-CS-001CS-SW-H10	PBCC,T / PF,B	CS	2		PT		
II-CS-001CS-SW-H3	PC,PIP / PF,WN	CS	2		PT		
II-CS-001CS-SW-H5	PC,PIP / PBCC,T	CS	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION						
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM						
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments	
II-CS-001CS-SW-H7	PC,PIP / PE,SR	CS	2		PT			
II-CS-001CS-SW-H8	PE,LR / PC,PIP	CS	2		PT			
II-CS-001CT-16-19-SW-1	PC,PIP / PC,PIP	CT	2		PT			
II-CS-001CT-16-19-SW-1A	PLSW,P /	CT	2		PT			
II-CS-001CT-16-19-SW-1B	PLSW,P /	CT	2		PT			
II-CS-001CT-FW-100	PC,PIP / PE,LR	CT	2	2-1-08	PT			
II-CS-001CT-FW-100A	PLSW,P /	CT	2	2-1-08	PT			
II-CS-001CT-FW-101	PC,PIP / PC,PIP	CT	2		PT			
II-CS-001CT-FW-101A	PLSW,P /	CT	2		PT			
II-CS-001CT-FW-101B	PLSW,P /	CT	2		PT			
II-CS-001CT-FW-102	PC,PIP / PC,VLV	CT	2		PT			
II-CS-001CT-FW-102A	PLSW,P /	CT	2		PT			
II-CS-001CT-SW-111	PC,PIP / PC,PIP	CT	2		PT			

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CS-001CT-SW-I11A	PLSW,P /	CT	2		PT		
II-CS-001CT-SW-I11B	PLSW,P /	CT	2		PT		
II-CS-001CT-SW-I3	PE,LR / PC,PIP	CT	2		PT		
II-CS-001CT-SW-I3A	PLSW,P /	CT	2		PT		
II-CS-001CT-SW-I4	PC,PIP / PE,LR	CT	2		PT		
II-CS-001CT-SW-I4A	PLSW,P /	CT	2		PT		
II-CS-001CT-SW-J3	PE,LR / PC,PIP	CT	2		PT		
II-CS-001CT-SW-J3A	PLSW,P /	CT	2		PT		
II-CS-002CS-SW-I3	PC,PIP / PE,LR	CS	2	2-2-11	PT		
II-CS-002CS-SW-I4	PE,LR / PC,PIP	CS	2	2-2-11	PT		
II-CS-002CS-SW-I5	PC,PIP / PE,LR	CS	2		PT		
II-CS-002CS-SW-I6	PE,LR / PC,PIP	CS	2		PT		
II-CS-002CS-SW-I7	PC,PIP / PE,LR	CS	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CS-002CS-SW-I8	PE,LR / PC,PIP	CS	2		PT		
II-CS-002CS-SW-I9	PC,PIP / PE,SR	CS	2	2-2-10	PT		
II-CS-002RH-25-1-SW-1	PC,PIP / PC,PIP	RH	2		PT		
II-CS-002RH-25-1-SW-1A	PLSW,P /	RH	2		PT		
II-CS-002RH-25-1-SW-1B	PLSW,P /	RH	2		PT		
II-CS-002RH-25-2-SW-1	PC,PIP / PC,PIP	RH	2		PT		
II-CS-002RH-25-2-SW-2	PF,RFW / PC,PIP	RH	2		PT		
II-CS-002RH-25-2-SW-2A	PLSW,P /	RH	2		PT		
II-CS-002RH-25-2-SW-3	PC,PIP / PC,PIP	RH	2		PT		
II-CS-002RH-25-2-SW-3A	PLSW,P /	RH	2		PT		
II-CS-002RH-FW-70	PC,PIP / PE,LR	RH	2	2-1-08	PT		
II-CS-002RH-FW-70A	PC,PIP / PC,PIP	RH	2		PT		
II-CS-002RH-FW-70ALA	PLSW,P /	RH	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CS-002RH-FW-70ALB	PLSW,P /	RH	2		PT		
II-CS-002RH-FW-70LA	PLSW,P /	RH	2	2-1-08	PT		
II-CS-002RH-FW-81	PC,PIP / PC,VLV	RH	2		PT		
II-CS-002RH-FW-81A	PLSW,P /	RH	2		PT		
II-CS-002RH-FW-82	PC,VLV / PC,PIP	RH	2	2-1-08	PT		
II-CS-002RH-FW-82A	PLSW,P /	RH	2	2-1-08	PT		
II-CS-002RH-FW-85	PE,LR / PC,PIP	RH	2		PT		
II-CS-002RH-FW-85A	PLSW,P /	RH	2		PT		
II-CS-002RH-FW-86	PC,PIP / PC,VLV	RH	2		PT		
II-CS-002RH-FW-86A	PLSW,P /	RH	2		PT		
II-CS-002RH-FW-87	PC,VLV / PC,PIP	RH	2		PT		
II-CS-002RH-FW-87A	PLSW,P /	RH	2		PT		
II-CS-002RH-FW-88	PC,PIP / VNOZ1	RH	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY SER SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION
ITEM NO. 250.1S SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CS-002RH-FW-88A	PLSW,P /	RH	2		PT		
II-CS-002RH-FW-89	PBCC,T / PC,PIP	RH	2		PT		
II-CS-002RH-FW-89A	PLSW,P /	RH	2		PT		
II-CS-002RH-FW-90	PC,PIP / PC,VLV	RH	2		PT		
II-CS-002RH-FW-91	PC,VLV / PC,PIP	CS	2		PT		
II-CS-002RH-FW-92	VNOZ1 / PC,PIP	RH	2		PT		
II-CS-002RH-FW-92A	PLSW,P /	RH	2		PT		
II-CS-002RH-SW-A10	PC,PIP / PE,LR	RH	2		PT		
II-CS-002RH-SW-A10A	PLSW,P /	RH	2		PT		
II-CS-002RH-SW-A11	PE,LR / PC,PIP	RH	2		PT		
II-CS-002RH-SW-A11A	PLSW,P /	RH	2		PT		
II-CS-002RH-SW-A12	PC,PIP / PE,LR	RH	2	2-2-11	PT		
II-CS-002RH-SW-A12A	PLSW,P /	RH	2	2-2-11	PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION						
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM						
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments	
II-CS-002RH-SW-A13	PE,LR / PC,PIP	RH	2		PT			
II-CS-002RH-SW-A13A	PLSW,P /	RH	2		PT			
II-CS-002RH-SW-A14	PC,PIP / PE,LR	RH	2		PT			
II-CS-002RH-SW-A14A	PLSW,P /	RH	2		PT			
II-CS-002RH-SW-A3	PC,PIP / PF,RFW	RH	2		PT			
II-CS-002RH-SW-A3A	PLSW,P /	RH	2		PT			
II-CS-002RH-SW-A4	PBCC,T / PC,PIP	RH	2		PT			
II-CS-002RH-SW-A4A	PLSW,P /	RH	2		PT			
II-CS-002RH-SW-A5	PBCC,T / PC,PIP	RH	2		PT			
II-CS-002RH-SW-A5A	PLSW,P /	RH	2		PT			
II-CS-002RH-SW-A6	PC,PIP / PC,RED	RH	2		PT			
II-CS-002RH-SW-A6A	PLSW,P /	RH	2		PT			
II-CS-002RH-SW-A7	PC,RED / PC,PIP	RH	2	2-2-11	PT			

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CS-002RH-SW-A8	PC,PIP / PBCC,T	RH	2	2-2-11	PT		
II-CS-002RH-SW-A8A	PLSW,P /	RH	2	2-2-11	PT		
II-CS-002RH-SW-A9	PE,LR / PC,PIP	RH	2	2-2-11	PT		
II-CS-002RH-SW-A9A	PLSW,P /	RH	2	2-2-11	PT		
II-CS-002RH-SW-B10	PE,LR / PC,PIP	RH	2		PT		
II-CS-002RH-SW-B11	PC,PIP / PE,LR	RH	2		PT		
II-CS-002RH-SW-B3	PC,PIP / PBCC,T	RH	2		PT		
II-CS-002RH-SW-B3A	PLSW,P /	RH	2		PT		
II-CS-002RH-SW-B4	PF,RFW / PC,PIP	RH	2	2-2-11	PT		
II-CS-002RH-SW-B4A	PLSW,P /	RH	2	2-2-11	PT		
II-CS-002RH-SW-B5	PC,PIP / PBCC,T	RH	2		PT		
II-CS-002RH-SW-B6	PE,LR / PC,PIP	RH	2		PT		
II-CS-002RH-SW-B7	PC,PIP / PE,LR	RH	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CS-002RH-SW-B8	PE,LR / PC,PIP	RH	2		PT		
II-CS-002RH-SW-B9	PC,PIP / PE,LR	RH	2		PT		
II-CS-002RH-SW-C10	PC,PIP / PE,LR	RH	2	2-2-11	PT		
II-CS-002RH-SW-C10A	PLSW,P /	RH	2	2-2-11	PT		
II-CS-002RH-SW-C3	PE,LR / PC,PIP	RH	2		PT		
II-CS-002RH-SW-C33	PC,PIP / PC,PIP	RH	2		PT		
II-CS-002RH-SW-C33A	PLSW,P /	RH	2		PT		
II-CS-002RH-SW-C33B	PLSW,P /	RH	2		PT		
II-CS-002RH-SW-C3A	PLSW,P /	RH	2		PT		
II-CS-002RH-SW-C4	PC,PIP / PE,LR	RH	2		PT		
II-CS-002RH-SW-C4A	PLSW,P /	RH	2		PT		
II-CS-002RH-SW-C5	PE,LR / PC,PIP	RH	2		PT		
II-CS-002RH-SW-C5A	PLSW,P /	RH	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CS-002RH-SW-C6	PC,PIP / PE,LR	RH	2		PT		
II-CS-002RH-SW-C6A	PLSW,P /	RH	2		PT		
II-CS-002RH-SW-C7	PE,LR / PC,PIP	RH	2		PT		
II-CS-002RH-SW-C7A	PLSW,P /	RH	2		PT		
II-CS-002RH-SW-C8	PC,PIP / PE,LR	RH	2		PT		
II-CS-002RH-SW-C8A	PLSW,P /	RH	2		PT		
II-CS-002RH-SW-C9	PE,LR / PC,PIP	RH	2	2-2-11	PT		
II-CS-002RH-SW-C9A	PLSW,P /	RH	2	2-2-11	PT		
II-CS-002RH-SW-D5	PC,PIP / PC,PIP	RH	2		PT		
II-CS-002RH-SW-D5A	PLSW,P /	RH	2		PT		
II-CS-002RH-SW-D5B	PLSW,P /	RH	2		PT		
II-CS-002RH-SW-E3	PC,PIP / PBCC,T	RH	2		PT		
II-CS-002RH-SW-E3A	PLSW,P /	RH	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CS-002RH-SW-E4	PBCC,T / PC,PIP	RH	2		PT		
II-CS-002RH-SW-E4A	PLSW,P /	RH	2		PT		
II-CS-002RH-SW-E5	PBCC,T / PC,PIP	RH	2	2-1-08	PT		
II-CS-002RH-SW-E6	PC,PIP / PE,LR	RH	2	2-1-08	PT		
II-CS-002RH-SW-E7	PE,LR / PC,PIP	RH	2		PT		
II-CS-002RH-SW-E8	PC,PIP / PF,RFW	RH	2		PT		
II-CS-002RH-SW-G3	PE,LR / PC,PIP	RH	2	2-1-08	PT		
II-CS-002RH-SW-G3A	PLSW,P /	RH	2	2-1-08	PT		1.5" OF LONGSEAM EXAMINED
II-CS-002RH-SW-G4	PC,PIP / PE,LR	RH	2		PT		
II-CS-002RH-SW-G4A	PLSW,P /	RH	2		PT		
II-CS-021CS-127-FW-223	PC,PIP / PC,VLV	CS	2		PT		
II-CS-021CS-127-FW-224	PC,VLV / PC,PIP	CS	2		PT		
II-CS-021CS-129-3-SW-1	PE,SR / PC,PIP	CS	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CS-021CS-129-3-SW-2	PC,PIP / PBCC,T	CS	2		PT		
II-CS-021CS-129-3-SW-3	PC,PIP / PF,RFW	CS	2		PT		
II-CS-021CS-132-4-SW-1	PE,LR / PC,PIP	CS	2	2-3-13	PT		
II-CS-021CS-FW-107	PC,PIP / PC,VLV	CS	2	2-2-11	PT		
II-CS-021CS-FW-108	PC,VLV / PC,PIP	CS	2	2-2-11	PT		
II-CS-021CS-FW-109	PC,VLV / PC,PIP	CS	2		PT		
II-CS-021CS-FW-109A	PLSW,P /	CS	2		PT		
II-CS-021CS-FW-110	PBCC,T / PC,PIP	CS	2		PT		
II-CS-021CS-FW-111	PC,PIP / PE,LR	CS	2		PT		
II-CS-021CS-FW-111A	PLSW,P /	CS	2		PT		
II-CS-021CS-FW-198	PC,VLV / PC,PIP	CS	2		PT		
II-CS-021CS-FW-198A	PLSW,P /	CS	2		PT		
II-CS-021CS-FW-209	PC,PIP / PC,VLV	CS	2	2-2-11	PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY SER SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION
ITEM NO. 250.1S SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CS-021CS-FW-209A	PLSW,P /	CS	2	2-2-11	PT		
II-CS-021CS-FW-210	PC,VLV / PC,PIP	CS	2	2-2-11	PT		
II-CS-021CS-FW-210A	PLSW,P /	CS	2	2-2-11	PT		
II-CS-021CS-FW-211	PC,PIP / PC,VLV	CS	2		PT		
II-CS-021CS-FW-211A	PLSW,P /	CS	2		PT		
II-CS-021CS-FW-212	PE,LR / PC,PIP	CS	2		PT		
II-CS-021CS-FW-212A	PLSW,P /	CS	2		PT		
II-CS-021CS-FW-213	PBCC,T / PC,PIP	CS	2	2-1-08	PT		
II-CS-021CS-FW-214	PC,PIP / PC,VLV	CS	2		PT		
II-CS-021CS-FW-215	PC,VLV / PC,PIP	CS	2		PT		
II-CS-021CS-FW-216	PBCC,T / PC,PIP	CS	2		PT		
II-CS-021CS-FW-216A	PLSW,P /	CS	2		PT		
II-CS-021CS-FW-220	PC,PIP / PC,PIP	CS	2	2-2-11	PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CS-021CS-FW-221	PC,PIP / PBCC,T	CS	2		PT		
II-CS-021CS-FW-222	PC,VLV / PC,PIP	CS	2		PT		
II-CS-021CS-SW-C3	PC,PIP / PC,PIP	CS	2		PT		
II-CS-021CS-SW-C3A	PLSW,P /	CS	2		PT		
II-CS-021CS-SW-C3B	PLSW,P /	CS	2		PT		
II-CS-021CS-SW-C4	PE,LR / PC,PIP	CS	2	2-2-11	PT		
II-CS-021CS-SW-C4A	PLSW,P /	CS	2	2-2-11	PT		
II-CS-021CS-SW-C5	PC,PIP / PE,LR	CS	2	2-2-11	PT		
II-CS-021CS-SW-C5A	PLSW,P /	CS	2	2-2-11	PT		
II-CS-021CS-SW-C6	PC,RED / PC,PIP	CS	2		PT		
II-CS-021CS-SW-C6A	PLSW,P /	CS	2		PT		
II-CS-021CS-SW-D3	PC,PIP / PBCC,T	CS	2	2-2-11	PT		
II-CS-021CS-SW-D3A	PLSW,P /	CS	2	2-2-11	PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CS-021CS-SW-D4	PBCC,T / PC,PIP	CS	2	2-2-11	PT		
II-CS-021CS-SW-D4A	PLSW,P /	CS	2	2-2-11	PT		
II-CS-021CS-SW-D5	PC,PIP / PBCC,T	CS	2	2-2-11	PT		
II-CS-021CS-SW-D5A	PLSW,P /	CS	2	2-2-11	PT		
II-CS-021CS-SW-D6	PC,PIP / PBCC,T	CS	2		PT		
II-CS-021CS-SW-D6A	PLSW,P /	CS	2		PT		
II-CS-021CS-SW-D7	PC,PIP / PBCC,T	CS	2		PT		
II-CS-021CS-SW-D7A	PLSW,P /	CS	2		PT		
II-CS-021CS-SW-D8	PE,LR / PC,PIP	CS	2		PT		
II-CS-021CS-SW-D8A	PLSW,P /	CS	2		PT		
II-CS-021CS-SW-E3	PC,PIP / PE,LR	CS	2		PT		
II-CS-021CS-SW-E4	PE,LR / PC,PIP	CS	2		PT		
II-CS-021CS-SW-F10	PC,PIP / PF,RFW	CS	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CS-021CS-SW-F3	PC,PIP / PF,RFW	CS	2		PT		
II-CS-021CS-SW-F4	PC,PIP / PC,PIP	CS	2		PT		
II-CS-021CS-SW-F5	PC,PIP / PC,PIP	CS	2		PT		
II-CS-021CS-SW-F7	PC,PIP / PE,SR	CS	2		PT		
II-CS-021CS-SW-F8	PE,LR / PC,PIP	CS	2		PT		
II-CS-021CS-SW-F9	PC,PIP / PE,LR	CS	2		PT		
II-CS-021CS-SW-I3	PC,PIP / PE,LR	CS	2		PT		
II-CS-021CS-SW-I3A	PLSW,P /	CS	2		PT		
II-CS-021CS-SW-I4	PE,LR / PC,PIP	CS	2		PT		
II-CS-021CS-SW-I4A	PLSW,P /	CS	2		PT		
II-CS-021CS-SW-I5	PC,PIP / PE,LR	CS	2		PT		
II-CS-021CS-SW-I5A	PLSW,P /	CS	2		PT		
II-CS-021CS-SW-I6	PE,LR / PC,PIP	CS	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CS-021CS-SW-I6A	PLSW,P /	CS	2		PT		
II-CS-021CS-SW-I7	PC,PIP / PE,LR	CS	2		PT		
II-CS-021CS-SW-I7A	PLSW,P /	CS	2		PT		
II-CS-021CS-SW-I8	PBCC,T / PC,PIP	CS	2	2-3-13	PT		
II-CS-021CS-SW-I8A	PLSW,P /	CS	2	2-3-13	PT		
II-CS-021CS-SW-I9	PC,PIP / PBCC,T	CS	2	2-3-13	PT		
II-CS-021CS-SW-I9A	PLSW,P /	CS	2	2-3-13	PT		
II-CS-021CS-SW-J3	PE,LR / PC,PIP	CS	2		PT		
II-CS-021CS-SW-J4	PC,PIP / PE,LR	CS	2		PT		
II-CS-021CS-SW-J5	PE,LR / PC,PIP	CS	2		PT		
II-CS-021CS-SW-J6	PC,PIP / PE,LR	CS	2		PT		
II-CS-021CS-SW-K10	PBCC,T / PF,RFW	CS	2		PT		
II-CS-021CS-SW-K4	PBCC,T / PC,PIP	CS	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CS-021CS-SW-K7	PC,PIP / PE,SR	CS	2		PT		
II-CS-021CS-SW-K8	PE,LR / PC,PIP	CS	2	2-2-11	PT		
II-CS-021CS-SW-K9	PC,PIP / PE,LR	CS	2	2-2-11	PT		
II-CS-021CS-SW-L3	PC,PIP / PBCC,T	CS	2		PT		
II-CS-021CS-SW-L9	PC,PIP / PC,PIP	CS	2		PT		
II-CS-021CS-SW-M3	PC,PIP / PC,PIP	CS	2	2-2-11	PT		
II-CS-021RH-FW-159	PE,LR / PC,PIP	RH	2		PT		
II-CS-021RH-FW-159A	PLSW,P /	RH	2		PT		
II-CS-021RH-FW-83	PC,PIP / PC,PIP	RH	2		PT		
II-CS-021RH-FW-83A	PLSW,P /	RH	2		PT		
II-CS-021RH-FW-83B	PLSW,P /	RH	2		PT		
II-CS-021RH-FW-84	PC,PIP / PE,LR	RH	2		PT		
II-CS-021RH-FW-84A	PLSW,P /	RH	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CS-021RH-SW-A3	PE,LR / PC,PIP	RH	2		PT		
II-CS-021RH-SW-A3A	PLSW,P /	RH	2		PT		
II-CS-021RH-SW-A4	PC,PIP / PE,LR	RH	2		PT		
II-CS-021RH-SW-A4A	PLSW,P /	RH	2		PT		
II-CS-021RH-SW-B6	PC,PIP / PE,LR	RH	2	2-2-10	PT		
II-CS-021RH-SW-B6A	PLSW,P /	RH	2	2-2-10	PT		
II-CS-021RH-SW-B7	PE,LR / PC,PIP	RH	2	2-2-10	PT		
II-CS-021RH-SW-B7A	PLSW,P /	RH	2	2-2-10	PT		
II-CT-001CT-6-1-SW-1	PC,PIP / PC,PIP	CT	2		PT		
II-CT-001CT-6-1-SW-1A	PLSW,P /	CT	2		PT		
II-CT-001CT-6-1-SW-1B	PLSW,P /	CT	2		PT		
II-CT-001CT-6-3-SW-1	PC,PIP / PC,PIP	CT	2	2-2-11	PT		
II-CT-001CT-FW-1	VNOZ1 / PC,PIP	CT	2	2-1-08	PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CT-001CT-FW-10	PC,PIP / PP,FHS	CT	2	2-3-13	PT		
II-CT-001CT-FW-11	PC,PIP / PC,VLV	CT	2		PT		
II-CT-001CT-FW-16	PC,PIP / PC,VEN	CT	2	2-3-13	PT		
II-CT-001CT-FW-16A	PLSW,P /	CT	2	2-3-13	PT		
II-CT-001CT-FW-17	PC,VEN / PC,PIP	CT	2	2-3-13	PT		
II-CT-001CT-FW-17A	PLSW,P /	CT	2		PT		
II-CT-001CT-FW-1A	PLSW,P /	CT	2	2-1-08	PT		
II-CT-001CT-FW-3	PE,LR / PC,PIP	CT	2		PT		
II-CT-001CT-FW-4	PC,PIP / PE,LR	CT	2		PT		
II-CT-001CT-FW-5	PC,PIP / PE,LR	CT	2		PT		
II-CT-001CT-FW-6	PC,PIP / PE,LR	CT	2		PT		
II-CT-001CT-FW-7	PE,LR / PC,PIP	CT	2		PT		
II-CT-001CT-FW-8	PC,PIP / PC,VLV	CT	2	2-3-13	PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CT-001CT-FW-9	PC,VLV / PC,PIP	CT	2	2-3-13	PT		
II-CT-001CT-SW-A3	PC,PIP / PE,LR	CT	2	2-1-08	PT		
II-CT-001CT-SW-A3A	PLSW,P /	CT	2	2-1-08	PT		
II-CT-001CT-SW-A4	PE,LR / PC,PIP	CT	2		PT		
II-CT-001CT-SW-A4A	PLSW,P /	CT	2		PT		
II-CT-001CT-SW-A5	PC,PIP / PE,LR	CT	2		PT		
II-CT-001CT-SW-A5A	PLSW,P /	CT	2		PT		
II-CT-001CT-SW-A6	PE,LR / PC,PIP	CT	2		PT		
II-CT-001CT-SW-A6A	PLSW,P /	CT	2		PT		
II-CT-001CT-SW-A7	PC,PIP / PE,LR	CT	2		PT		
II-CT-001CT-SW-A7A	PLSW,P /	CT	2		PT		
II-CT-001CT-SW-A8	PE,LR / PC,PIP	CT	2		PT		
II-CT-001CT-SW-A8A	PLSW,P /	CT	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CT-001CT-SW-B14	PC,PIP / PC,PIP	CT	2		PT		
II-CT-001CT-SW-B14A	PLSW,P /	CT	2		PT		
II-CT-001CT-SW-B14B	PLSW,P /	CT	2		PT		
II-CT-001CT-SW-B3	PC,PIP / PE,LR	CT	2		PT		
II-CT-001CT-SW-B3A	PLSW,P /	CT	2		PT		
II-CT-001CT-SW-B4	PC,PIP / PC,PIP	CT	2	2-3-13	PT		
II-CT-001CT-SW-B4A	PLSW,P /	CT	2	2-3-13	PT		
II-CT-001CT-SW-B4B	PLSW,P /	CT	2	2-3-13	PT		
II-CT-001CT-SW-C3	PC,PIP / PC,PIP	CT	2		PT		
II-CT-001CT-SW-C4	PC,PIP / PBCC,T	CT	2	2-2-11	PT		
II-CT-001CT-SW-C5	PBCC,T / PC,PIP	CT	2	2-2-11	PT		
II-CT-001CT-SW-C6	PBCC,T / PC,PIP	CT	2		PT		
II-CT-001CT-SW-C7	PC,PIP / PE,LR	CT	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION						
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM						
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments	
II-CT-001CT-SW-C8	PE,LR / PC,PIP	CT	2	2-3-13	PT			
II-CT-001CT-SW-D3	PE,LR / PC,PIP	CT	2	2-2-11	PT			
II-CT-001CT-SW-D4	PC,PIP / PE,LR	CT	2		PT			
II-CT-001CT-SW-D5	PE,LR / PC,PIP	CT	2		PT			
II-CT-001CT-SW-E3	PE,LR / PC,PIP	CT	2		PT			
II-CT-001CT-SW-E4	PC,PIP / PC,PIP	CT	2	2-2-11	PT			
II-CT-001CT-SW-F3	PC,PIP / PE,LR	CT	2		PT			
II-CT-001CT-SW-F4	PE,LR / PC,PIP	CT	2		PT			
II-CT-001CT-SW-F5	PC,PIP / PE,LR	CT	2		PT			
II-CT-001CT-SW-F6	PE,LR / PC,PIP	CT	2		PT			
II-CT-001CT-SW-G3	PE,LR / PC,PIP	CT	2	2-3-13	PT			
II-CT-001CT-SW-G4	PC,PIP / PE,LR	CT	2		PT			
II-CT-002CT-1-1-SW-1	PC,PIP / PC,PIP	CT	2	2-3-13	PT			



Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CT-002CT-1-1-SW-1A	PLSW,P /	CT	2	2-3-13	PT		
II-CT-002CT-1-1-SW-1B	PLSW,P /	CT	2	2-3-13	PT		
II-CT-002CT-1-1-SW-2	PC,PIP / PC,PIP	CT	2		PT		
II-CT-002CT-1-1-SW-2A	PLSW,P /	CT	2		PT		
II-CT-002CT-1-1-SW-2B	PLSW,P /	CT	2		PT		
II-CT-002CT-1-3-SW-1	PC,PIP / PC,PIP	CT	2	2-3-13	PT		
II-CT-002CT-1-3-SW-2	PBCC,T / PC,PIP	CT	2		PT		
II-CT-002CT-1-3-SW-3	PE,LR / PC,PIP	CT	2		PT		
II-CT-002CT-1-3-SW-4	PC,PIP / PE,LR	CT	2	2-1-08	PT		
II-CT-002CT-FW-12	VNOZ1 / PC,PIP	CT	2		PT		
II-CT-002CT-FW-12A	PLSW,P /	CT	2		PT		
II-CT-002CT-FW-14	PE,LR / PC,PIP	CT	2		PT		
II-CT-002CT-FW-15	PC,PIP / PE,LR	CT	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CT-002CT-FW-16	PC,PIP / PE,LR	CT	2		PT		
II-CT-002CT-FW-16A	PLSW,P /	CT	2		PT		
II-CT-002CT-FW-17	PC,PIP / PE,LR	CT	2		PT		
II-CT-002CT-FW-18	PE,LR / PC,PIP	CT	2		PT		
II-CT-002CT-FW-19	PC,PIP / PC,VLV	CT	2	2-3-13	PT		
II-CT-002CT-FW-20	PC,VLV / PC,PIP	CT	2	2-3-13	PT		
II-CT-002CT-FW-20A	PLSW,P /	CT	2	2-3-13	PT		
II-CT-002CT-FW-21	PC,PIP / PP,FHS	CT	2	2-3-13	PT		
II-CT-002CT-FW-21A	PLSW,P /	CT	2	2-3-13	PT		
II-CT-002CT-FW-22	PC,PIP / PC,VLV	CT	2		PT		
II-CT-002CT-FW-22A	PC,VEN / PC,PIP	CT	2		PT		
II-CT-002CT-FW-22ALA	PLSW,P /	CT	2		PT		
II-CT-002CT-FW-22B	PC,PIP / PC,VEN	CT	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CT-002CT-FW-22BLA	PLSW,P /	CT	2		PT		
II-CT-002CT-SW-A3	PC,PIP / PE,LR	CT	2		PT		
II-CT-002CT-SW-A3A	PLSW,P /	CT	2		PT		
II-CT-002CT-SW-A4	PE,LR / PC,PIP	CT	2	2-1-08	PT		
II-CT-002CT-SW-A4A	PLSW,P /	CT	2	2-1-08	PT		
II-CT-002CT-SW-A5	PC,PIP / PE,LR	CT	2	2-1-08	PT		
II-CT-002CT-SW-A5A	PLSW,P /	CT	2	2-1-08	PT		
II-CT-002CT-SW-A6	PE,LR / PC,PIP	CT	2		PT		
II-CT-002CT-SW-A6A	PLSW,P /	CT	2		PT		
II-CT-002CT-SW-B24	PC,PIP / PC,PIP	CT	2		PT		
II-CT-002CT-SW-B24A	PLSW,P /	CT	2		PT		
II-CT-002CT-SW-B3	PC,PIP / PE,LR	CT	2		PT		
II-CT-002CT-SW-B3A	PLSW,P /	CT	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CT-002CT-SW-B4	PE,LR / PC,PIP	CT	2		PT		
II-CT-002CT-SW-B4A	PLSW,P /	CT	2		PT		
II-CT-002CT-SW-B5	PC,PIP / PE,LR	CT	2		PT		
II-CT-002CT-SW-B6	PC,PIP / PC,PIP	CT	2		PT		
II-CT-002CT-SW-C3	PC,PIP / PC,PIP	CT	2		PT		
II-CT-002CT-SW-C4	PC,PIP / PBCC,T	CT	2		PT		
II-CT-002CT-SW-C5	PBCC,T / PC,PIP	CT	2		PT		
II-CT-002CT-SW-D3	PE,LR / PC,PIP	CT	2		PT		
II-CT-002CT-SW-D3A	PLSW,P /	CT	2		PT		
II-CT-002CT-SW-D4	PC,PIP / PE,LR	CT	2		PT		
II-CT-002CT-SW-D4A	PLSW,P /	CT	2		PT		
II-CT-002CT-SW-D5	PE,LR / PC,PIP	CT	2		PT		
II-CT-002CT-SW-D5A	PLSW,P /	CT	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY SER
ITEM NO. 250.1S

SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION
SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CT-002CT-SW-D8	PC,PIP / PC,PIP	CT	2		PT		
II-CT-002CT-SW-D8A	PLSW,P /	CT	2		PT		
II-CT-002CT-SW-D8B	PLSW,P /	CT	2		PT		
II-CT-002CT-SW-E3	PE,LR / PC,PIP	CT	2		PT		
II-CT-002CT-SW-E4	PC,PIP / PC,PIP	CT	2		PT		
II-CT-002CT-SW-F3	PC,PIP / PE,LR	CT	2		PT		
II-CT-002CT-SW-F3A	PLSW,P /	CT	2		PT		
II-CT-002CT-SW-F4	PE,LR / PC,PIP	CT	2		PT		
II-CT-002CT-SW-F4A	PLSW,P /	CT	2		PT		
II-CT-002CT-SW-F5	PC,PIP / PE,LR	CT	2		PT		
II-CT-002CT-SW-F5A	PLSW,P /	CT	2		PT		
II-CT-002CT-SW-F6	PE,LR / PC,PIP	CT	2		PT		
II-CT-002CT-SW-F6A	PLSW,P /	CT	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CT-002CT-SW-G3	PE,LR / PC,PIP	CT	2	2-3-13	PT		
II-CT-002CT-SW-G4	PC,PIP / PE,LR	CT	2		PT		
II-CT-007CT-FW-97	PC,PIP / PE,LR	CT	2		PT		
II-CT-007CT-FW-97A	PLSW,P /	CT	2		PT		
II-CT-007CT-FW-98	PC,PIP / PE,LR	CT	2		PT		
II-CT-007CT-FW-98A	PLSW,P /	CT	2		PT		
II-CT-007CT-SW-P6	PBC,S / PC,PIP	CT	2		PT		
II-CT-007CT-SW-P6A	PLSW,P /	CT	2		PT		
II-CT-007CT-SW-U3	PE,LR / PC,PIP	CT	2	2-3-13	PT		
II-CT-007CT-SW-U3A	PLSW,P /	CT	2	2-3-13	PT		
II-CT-008CT-16-17-SW-1	PC,PIP / PC,PIP	CT	2		PT		
II-CT-008CT-16-17-SW-1A	PLSW,P /	CT	2		PT		
II-CT-008CT-16-17-SW-1B	PLSW,P /	CT	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY ITEM NO.	SER 250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CT-008CT-FW-99	PC,PIP / PC,PIP	CT	2		PT		
II-CT-008CT-FW-99A	PLSW,P /	CT	2		PT		
II-CT-008CT-SW-J27	PBCC,T / PC,PIP	CT	2		PT		
II-CT-008CT-SW-J27A	PLSW,P /	CT	2		PT		
II-CT-008CT-SW-K11	PC,PIP / PC,PIP	CT	2		PT		
II-CT-008CT-SW-K11A	PLSW,P /	CT	2		PT		
II-CT-008CT-SW-K11B	PLSW,P /	CT	2		PT		
II-CT-008CT-SW-K3	PC,PIP / PE,LR	CT	2		PT		
II-CT-008CT-SW-K3A	PLSW,P /	CT	2		PT		
II-CT-008CT-SW-K4	PE,LR / PC,PIP	CT	2		PT		
II-CT-008CT-SW-K4A	PLSW,P /	CT	2		PT		
II-CT-014CT-FW-174	PP,FHS / PE,LR	CT	2		PT		
II-CT-014CT-FW-175	PC,PIP / PC,VLV	CT	2	2-2-10	PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CT-014CT-FW-176	PC,VLV / PC,PIP	CT	2		PT		
II-CT-014CT-FW-178	PC,PIP / PC,PB	CT	2		PT		
II-CT-014CT-FW-179	PC,PB / PC,PIP	CT	2		PT		
II-CT-014CT-FW-185	PC,PIP / PC,VLV	CT	2		PT		
II-CT-014CT-M24-PW-1	PP,FHS / NTERN	CT	2		SUR		
II-CT-014CT-SW-A3	PE,LR / PC,PIP	CT	2		PT		
II-CT-014CT-SW-B3	PC,PIP / PE,LR	CT	2	2-2-10	PT		
II-CT-014CT-SW-B4	PE,LR / PC,PIP	CT	2	2-2-10	PT		
II-CT-014CT-SW-B6	PC,PIP / PC,PIP	CT	2		PT		
II-CT-014CT-SW-C3	PC,PB / PC,PB	CT	2		PT		
II-CT-014CT-SW-D3	PBCC,T / PC,PIP	CT	2		PT		
II-CT-014CT-SW-D4	PC,PIP / PBCC,T	CT	2		PT		
II-CT-014CT-SW-D5	PBCC,T / PF,RFW	CT	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CT-016CT-2-FW-154	PC,PIP / PC,VLV	CT	2		PT		
II-CT-016CT-FW-143	PP,FHS / PE,LR	CT	2		PT		
II-CT-016CT-FW-144	PC,PIP / PC,VLV	CT	2		PT		
II-CT-016CT-FW-145	PC,VLV / PC,PIP	CT	2	2-2-10	PT		
II-CT-016CT-FW-146	PC,PIP / PC,PB	CT	2		PT		
II-CT-016CT-FW-148	PC,PB / PC,PIP	CT	2		PT		
II-CT-016CT-M23-PW-1	PP,FHS / NTERN	CT	2		SUR		
II-CT-016CT-SW-A3	PE,LR / PC,PIP	CT	2		PT		
II-CT-016CT-SW-B3	PC,PIP / PE,LR	CT	2		PT		
II-CT-016CT-SW-B4	PE,LR / PC,PIP	CT	2		PT		
II-CT-016CT-SW-B6	PC,PIP / PC,PIP	CT	2		PT		
II-CT-016CT-SW-C3	PC,PB / PC,PIP	CT	2		PT		
II-CT-016CT-SW-C8	PC,PIP / PC,PB	CT	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CT-016CT-SW-D3	PBCC,T / PC,PIP	CT	2	2-1-08	PT		
II-CT-016CT-SW-D4	PC,PIP / PBCC,T	CT	2	2-1-08	PT		
II-CT-016CT-SW-D5	PBCC,T / PF,RFW	CT	2		PT		
II-RH-001RH-2-2-SW-1	PC,PIP / PC,PIP	RH	2		PT		
II-RH-001RH-2-2-SW-1A	PLSW,P /	RH	2		PT		
II-RH-001RH-2-2-SW-1B	PLSW,P /	RH	2		PT		
II-RH-001RH-2-5-SW-1	PC,PIP / PC,PIP	RH	2		PT		
II-RH-001RH-2-5-SW-1A	PLSW,P /	RH	2		PT		
II-RH-001RH-2-5-SW-1B	PLSW,P /	RH	2		PT		
II-RH-001RH-24-1-SW-1	PC,PIP / PC,PIP	RH	2	2-2-11	PT		
II-RH-001RH-24-1-SW-1A	PLSW,P /	RH	2	2-2-11	PT		
II-RH-001RH-24-1-SW-1B	PLSW,P /	RH	2	2-2-11	PT		
II-RH-001RH-24-1-SW-2	PC,PIP / PC,PIP	RH	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-RH-001RH-24-1-SW-2A	PLSW,P /	RH	2		PT		
II-RH-001RH-24-1-SW-2B	PLSW,P /	RH	2		PT		
II-RH-001RH-FW-3	PP,FHS / PC,PB	RH	2	2-1-08	PT		
II-RH-001RH-FW-3A	PLSW,P /	RH	2	2-1-08	PT		
II-RH-001RH-FW-4	PC,PIP / PE,LR	RH	2		PT		
II-RH-001RH-FW-4A	PLSW,P /	RH	2		PT		
II-RH-001RH-FW-5	PC,PIP / PC,PIP	RH	2		PT		
II-RH-001RH-FW-5A	PLSW,P /	RH	2		PT		
II-RH-001RH-FW-5B	PLSW,P /	RH	2		PT		
II-RH-001RH-FW-6	PE,LR / PC,PIP	RH	2		PT		
II-RH-001RH-FW-68	VNOZ1 / PC,RED	RH	2		PT		
II-RH-001RH-FW-69	PC,PIP / PE,LR	RH	2		PT		
II-RH-001RH-FW-69A	PLSW,P /	RH	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY SER SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION
ITEM NO. 250.1S SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-RH-001RH-FW-6A	PLSW,P /	RH	2		PT		
II-RH-001RH-FW-7	PE,LR / PC,PIP	RH	2		PT		
II-RH-001RH-FW-7A	PLSW,P /	RH	2		PT		
II-RH-001RH-SW-A3	PE,LR / PC,PIP	RH	2	2-1-08	PT		
II-RH-001RH-SW-A3A	PLSW,P /	RH	2	2-1-08	PT		
II-RH-001RH-SW-A4	PC,PB / PE,LR	RH	2	2-1-09	PT		
II-RH-001RH-SW-A4A	PLSW,P /	RH	2	2-1-09	PT		
II-RH-001RH-SW-A8	PC,PIP / PC,PIP	RH	2		PT		
II-RH-001RH-SW-A8A	PLSW,P /	RH	2		PT		
II-RH-001RH-SW-A8B	PLSW,P /	RH	2		PT		
II-RH-001RH-SW-B17	PC,PIP / PC,PIP	RH	2		PT		
II-RH-001RH-SW-B17A	PLSW,P /	RH	2		PT		
II-RH-001RH-SW-B17B	PLSW,P /	RH	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-RH-001RH-SW-B6	PE,LR / PC,PIP	RH	2		PT		
II-RH-001RH-SW-B6A	PLSW,P /	RH	2		PT		
II-RH-001RH-SW-C5	PC,PIP / PE,LR	RH	2		PT		
II-RH-001RH-SW-C5A	PLSW,P /	RH	2		PT		
II-RH-001RH-SW-D11	PC,PIP / PC,PIP	RH	2		PT		
II-RH-001RH-SW-D11A	PLSW,P /	RH	2		PT		
II-RH-001RH-SW-D11B	PLSW,P /	RH	2		PT		
II-RH-001RH-SW-D3	PC,PIP / PE,LR	RH	2		PT		
II-RH-001RH-SW-D3A	PLSW,P /	RH	2		PT		
II-RH-001RH-SW-D4	PE,LR / PC,PIP	RH	2		PT		
II-RH-001RH-SW-D4A	PLSW,P /	RH	2		PT		
II-RH-001RH-SW-D5	PC,PIP / PE,LR	RH	2		PT		
II-RH-001RH-SW-D5A	PLSW,P /	RH	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-RH-001RH-SW-E34	PC,PIP / PC,PIP	RH	2		PT		
II-RH-001RH-SW-E34A	PLSW,P /	RH	2		PT		
II-RH-001RH-SW-E34B	PLSW,P /	RH	2		PT		
II-RH-001RH-SW-E9	PC,PIP / PBCC,T	RH	2		PT		
II-RH-001RH-SW-E9A	PLSW,P /	RH	2		PT		
II-RH-001RH-SW-L3	PC,RED / PC,PIP	RH	2	2-1-09	PT		
II-RH-001RH-SW-L3A	PLSW,P /	RH	2	2-1-09	PT		
II-RH-001RH-SW-L4	PC,PIP / PE,LR	RH	2		PT		
II-RH-001RH-SW-L4A	PLSW,P /	RH	2		PT		
II-RH-001RH-SW-L5	PE,LR / PC,PIP	RH	2		PT		
II-RH-001RH-SW-L5A	PLSW,P /	RH	2		PT		
II-RH-001RH-SW-M3	PE,LR / PC,PIP	RH	2		PT		
II-RH-001RH-SW-M3A	PLSW,P /	RH	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-RH-001RH-SW-M3B	PLSW,P /	RH	2		PT		
II-RH-001RH-SW-M4	PC,PIP / PE,LR	RH	2		PT		
II-RH-001RH-SW-M4A	PLSW,P /	RH	2		PT		
II-RH-001RH-SW-M4B	PLSW,P /	RH	2		PT		
II-RH-001RH-SW-M5	PE,LR / PC,PIP	RH	2		PT		
II-RH-001RH-SW-M5A	PLSW,P /	RH	2		PT		
II-RH-001RH-SW-M5B	PLSW,P /	RH	2		PT		
II-RH-001RH-SW-M6	PC,PIP / PF,WN	RH	2		PT		
II-RH-001RH-SW-M6A	PLSW,P /	RH	2		PT		
II-RH-001RH-SW-N3	PF,WN / PC,PIP	RH	2		PT		
II-RH-001RH-SW-N3A	PLSW,P /	RH	2		PT		
II-RH-001RH-SW-N4	PC,PIP / PE,LR	RH	2		PT		
II-RH-001RH-SW-N4A	PLSW,P /	RH	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION						
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM						
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments	
II-RH-001RH-SW-N5	PE,LR / PC,PIP	RH	2		PT			
II-RH-001RH-SW-N5A	PLSW,P /	RH	2		PT			
II-RH-002RH-11-1-SW-1	PC,PIP / PC,PIP	RH	2		PT			
II-RH-002RH-11-1-SW-1A	PLSW,P /	RH	2		PT			
II-RH-002RH-11-2-SW-1	PE,LR / PC,PIP	RH	2		PT			
II-RH-002RH-11-2-SW-1A	PLSW,P /	RH	2		PT			
II-RH-002RH-5-2-SW-1	PC,PIP / PC,PIP	RH	2		PT			
II-RH-002RH-5-2-SW-1A	PLSW,P /	RH	2		PT			
II-RH-002RH-5-2-SW-1B	PLSW,P /	RH	2		PT			
II-RH-002RH-5-3-SW-1	PC,PIP / PC,PIP	RH	2		PT			
II-RH-002RH-5-3-SW-1A	PLSW,P /	RH	2		PT			
II-RH-002RH-5-3-SW-1B	PLSW,P /	RH	2		PT			
II-RH-002RH-FW-16	PP,FHS / PC,PB	RH	2	2-3-13	PT			

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-RH-002RH-FW-16A	PLSW,P /	RH	2	2-3-13	PT		
II-RH-002RH-FW-17	PC,PIP / PE,LR	RH	2		PT		
II-RH-002RH-FW-17A	PLSW,P /	RH	2		PT		
II-RH-002RH-FW-18	PC,PIP / PC,PIP	RH	2		PT		
II-RH-002RH-FW-18A	PLSW,P /	RH	2		PT		
II-RH-002RH-FW-18B	PLSW,P /	RH	2		PT		
II-RH-002RH-FW-19	PE,LR / PC,PIP	RH	2	2-3-13	PT		
II-RH-002RH-FW-19A	PLSW,P /	RH	2	2-3-13	PT		
II-RH-002RH-FW-20	PE,LR / PC,PIP	RH	2	2-3-13	PT		
II-RH-002RH-FW-20A	PLSW,P /	RH	2	2-3-13	PT		
II-RH-002RH-FW-63	VNOZ1 / PC,RED	RH	2		PT		
II-RH-002RH-FW-64	PC,PIP / PE,LR	RH	2		PT		
II-RH-002RH-FW-64A	PLSW,P /	RH	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY SER SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION
ITEM NO. 250.1S SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-RH-002RH-FW-65	PE,LR / PC,PIP	RH	2		PT		
II-RH-002RH-FW-65A	PLSW,P /	RH	2		PT		
II-RH-002RH-SW-A3	PC,PIP / PE,LR	RH	2	2-3-13	PT		
II-RH-002RH-SW-A3A	PLSW,P /	RH	2	2-3-13	PT		
II-RH-002RH-SW-A4	PE,LR / PC,PIP	RH	2		PT		
II-RH-002RH-SW-A4A	PLSW,P /	RH	2		PT		
II-RH-002RH-SW-B5	PE,LR / PC,PIP	RH	2		PT		
II-RH-002RH-SW-B5A	PLSW,P /	RH	2		PT		
II-RH-002RH-SW-C19	PC,PIP / PC,PIP	RH	2		PT		
II-RH-002RH-SW-C19A	PLSW,P /	RH	2		PT		
II-RH-002RH-SW-C19B	PLSW,P /	RH	2		PT		
II-RH-002RH-SW-C6	PC,PIP / PE,LR	RH	2		PT		
II-RH-002RH-SW-C6A	PLSW,P /	RH	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-RH-002RH-SW-D19	PC,PIP / PC,PIP	RH	2		PT		
II-RH-002RH-SW-D19A	PLSW,P /	RH	2		PT		
II-RH-002RH-SW-D19B	PLSW,P /	RH	2		PT		
II-RH-002RH-SW-D3	PC,PIP / PE,LR	RH	2		PT		
II-RH-002RH-SW-D3A	PLSW,P /	RH	2		PT		
II-RH-002RH-SW-D4	PE,LR / PC,PIP	RH	2		PT		
II-RH-002RH-SW-D4A	PLSW,P /	RH	2		PT		
II-RH-002RH-SW-D5	PC,PIP / PE,LR	RH	2		PT		
II-RH-002RH-SW-D5A	PLSW,P /	RH	2		PT		
II-RH-002RH-SW-D6	PC,PIP / PC,PIP	RH	2	2-3-13	PT		
II-RH-002RH-SW-D6A	PLSW,P /	RH	2	2-3-13	PT		
II-RH-002RH-SW-D6B	PLSW,P /	RH	2	2-3-13	PT		
II-RH-002RH-SW-E8	PC,PIP / PBCC,T	RH	2	2-2-11	PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY SER SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION
ITEM NO. 250.1S SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-RH-002RH-SW-E8A	PLSW,P /	RH	2	2-2-11	PT		
II-RH-002RH-SW-L3	PE,LR / PC,PIP	RH	2	2-2-11	PT		
II-RH-002RH-SW-L3A	PLSW,P /	RH	2	2-2-11	PT		
II-RH-002RH-SW-L4	PC,PIP / PE,LR	RH	2	2-3-13	PT		
II-RH-002RH-SW-L4A	PLSW,P /	RH	2	2-3-13	PT		
II-RH-002RH-SW-L5	PC,RED / PC,PIP	RH	2		PT		
II-RH-002RH-SW-L5A	PLSW,P /	RH	2		PT		
II-RH-002RH-SW-M4	PC,PIP / PE,LR	RH	2		PT		
II-RH-002RH-SW-M4A	PLSW,P /	RH	2		PT		
II-RH-002RH-SW-M5	PE,LR / PC,PIP	RH	2		PT		
II-RH-002RH-SW-M5A	PLSW,P /	RH	2		PT		
II-RH-002RH-SW-M6	PC,PIP / PF,WN	RH	2		PT		
II-RH-002RH-SW-M6A	PLSW,P /	RH	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-RH-002RH-SW-N3	PF,WN / PC,PIP	RH	2		PT		
II-RH-002RH-SW-N3A	PLSW,P /	RH	2		PT		
II-RH-002RH-SW-N4	PC,PIP / PE,LR	RH	2		PT		
II-RH-002RH-SW-N4A	PLSW,P /	RH	2		PT		
II-RH-004RH-12-1-SW-1	PBCC,T / PC,PIP	RH	2	2-2-10	PT		
II-RH-004RH-12-1-SW-1A	PLSW,P /	RH	2	2-2-10	PT		
II-RH-004RH-12-2-SW-3	PC,PIP / PE,LR	RH	2		PT		
II-RH-004RH-12-2-SW-4	PF,RFW / PC,PIP	RH	2	2-2-11	PT		
II-RH-004RH-FW-66	PE,LR / PC,PIP	RH	2	2-2-11	PT		
II-RH-004RH-FW-66A	PLSW,P /	RH	2	2-2-11	PT		
II-RH-004RH-FW-67	PC,PIP / PC,VLV	RH	2		PT		
II-RH-004RH-FW-67A	PLSW,P /	RH	2		PT		
II-RH-004RH-FW-73	PC,PIP / PC,VLV	RH	2	2-3-13	PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-RH-004RH-FW-73A	PLSW,P /	RH	2	2-3-13	PT		
II-RH-004RH-FW-74	PC,PIP / PE,LR	RH	2		PT		
II-RH-004RH-FW-74A	PLSW,P /	RH	2		PT		
II-RH-004RH-FW-75	PC,PIP / PBCC,T	RH	2	2-2-10	PT		
II-RH-004RH-FW-76	PC,VLV / PC,PIP	RH	2		PT		
II-RH-004RH-FW-76A	PLSW,P /	RH	2		PT		
II-RH-004RH-FW-77	PC,PIP / VNOZ1	RH	2	2-2-10	PT		
II-RH-004RH-FW-77A	PLSW,P /	RH	2	2-2-10	PT		
II-RH-004RH-FW-78	VNOZ1 / PC,PIP	RH	2		PT		
II-RH-004RH-FW-78A	PLSW,P /	RH	2		PT		
II-RH-004RH-FW-79	PC,PIP / PBCC,T	RH	2		PT		
II-RH-004RH-FW-79A	PLSW,P /	RH	2		PT		
II-RH-004RH-FW-80	PC,PIP / PC,VLV	RH	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-RH-004RH-SW-A3	PC,PIP / PE,LR	RH	2		PT		
II-RH-004RH-SW-A3A	PLSW,P /	RH	2		PT		
II-RH-004RH-SW-A4	PE,LR / PC,PIP	RH	2		PT		
II-RH-004RH-SW-A4A	PLSW,P /	RH	2		PT		
II-RH-004RH-SW-A5	PC,PIP / PE,LR	RH	2		PT		
II-RH-004RH-SW-A5A	PLSW,P /	RH	2		PT		
II-RH-004RH-SW-A6	PE,LR / PC,PIP	RH	2	2-2-11	PT		
II-RH-004RH-SW-A6A	PLSW,P /	RH	2	2-2-11	PT		
II-RH-004RH-SW-A7	PC,PIP / PE,LR	RH	2		PT		
II-RH-004RH-SW-A7A	PLSW,P /	RH	2		PT		
II-RH-004RH-SW-A8	PE,LR / PC,PIP	RH	2		PT		
II-RH-004RH-SW-A8A	PLSW,P /	RH	2		PT		
II-RH-004RH-SW-B3	PC,PIP / PF,RFW	RH	2	2-2-11	PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION						
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM						
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments	
II-RH-004RH-SW-B3A	PLSW,P /	RH	2	2-2-11	PT			
II-RH-004RH-SW-B4	PBCC,T / PC,PIP	RH	2		PT			
II-RH-004RH-SW-B4A	PLSW,P /	RH	2		PT			
II-RH-004RH-SW-B5	PBCC,T / PC,PIP	RH	2		PT			
II-RH-004RH-SW-B5A	PLSW,P /	RH	2		PT			
II-RH-004RH-SW-B6	PC,PIP / PC,RED	RH	2		PT			
II-RH-004RH-SW-B6A	PLSW,P /	RH	2		PT			
II-RH-004RH-SW-B7	PC,RED / PC,PIP	RH	2	2-3-13	PT			
II-RH-004RH-SW-C3	PBCC,T / PC,PIP	RH	2		PT			
II-RH-004RH-SW-C3A	PLSW,P /	RH	2		PT			
II-RH-004RH-SW-C4	PC,PIP / PBCC,T	RH	2		PT			
II-RH-004RH-SW-C4A	PLSW,P /	RH	2		PT			
II-RH-004RH-SW-C5	PF,RFW / PC,PIP	RH	2		PT			

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION						
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM						
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments	
II-RH-004RH-SW-C5A	PLSW,P /	RH	2		PT			
II-RH-004RH-SW-D14	PC,PB / PC,PIP	RH	2		PT			
II-RH-004RH-SW-D14A	PLSW,P /	RH	2		PT			
II-RH-004RH-SW-D14B	PLSW,P /	RH	2		PT			
II-RH-004RH-SW-D3	PE,LR / PC,PIP	RH	2		PT			
II-RH-004RH-SW-D3A	PLSW,P /	RH	2		PT			
II-RH-004RH-SW-D4	PC,PIP / PE,LR	RH	2		PT			
II-RH-004RH-SW-D4A	PLSW,P /	RH	2		PT			
II-RH-004RH-SW-D5	PE,LR / PC,PB	RH	2		PT			
II-RH-004RH-SW-D5A	PLSW,P /	RH	2		PT			
II-RH-004RH-SW-D6	PC,PIP / PE,LR	RH	2		PT			
II-RH-004RH-SW-D6A	PLSW,P /	RH	2		PT			
II-RH-004RH-SW-D7	PE,LR / PC,PIP	RH	2		PT			

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION						
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM						
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments	
II-RH-004RH-SW-D7A	PLSW,P /	RH	2		PT			
II-RH-004RH-SW-D8	PC,PIP / PE,LR	RH	2	2-2-11	PT			
II-RH-004RH-SW-D8A	PLSW,P /	RH	2	2-2-11	PT			
II-RH-004RH-SW-D9	PE,LR / PC,PIP	RH	2	2-3-13	PT			
II-RH-004RH-SW-D9A	PLSW,P /	RH	2	2-3-13	PT			
II-RH-004RH-SW-E3	PC,PIP / PBCC,T	RH	2		PT			
II-RH-004RH-SW-E3A	PLSW,P /	RH	2		PT			
II-RH-004RH-SW-E5	PBCC,T / PC,PIP	RH	2		PT			
II-RH-004RH-SW-E6	PC,PIP / PE,LR	RH	2		PT			
II-RH-004RH-SW-E7	PE,LR / PC,PIP	RH	2		PT			
II-RH-004RH-SW-E8	PC,PIP / PF,RFW	RH	2		PT			
II-RH-004RH-SW-G3	PC,PIP / PE,LR	RH	2		PT			
II-RH-004RH-SW-G3A	PLSW,P /	RH	2		PT			

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-RH-004RH-SW-G4	PE,LR / PC,PIP	RH	2		PT		
II-RH-004RH-SW-G4A	PLSW,P /	RH	2		PT		
II-RH-004RH-SW-G5	PC,PIP / PE,LR	RH	2		PT		
II-RH-004RH-SW-G5A	PLSW,P /	RH	2		PT		
II-RH-004RH-SW-H5	PE,LR / PC,PIP	RH	2		PT		
II-RH-004RH-SW-H6	PC,PIP / PE,LR	RH	2		PT		
II-RH-004RH-SW-H7	PE,LR / PC,PIP	RH	2		PT		
II-RH-004RH-SW-H8	PC,PIP / PE,LR	RH	2		PT		
II-RH-004RH-SW-H9	PE,LR / PC,PIP	RH	2		PT		
II-RH-009RH-FW-14	PC,VLV / PC,PIP	RH	2	2-2-10	PT		
II-RH-009RH-FW-15	PC,PIP / PP,FHS	RH	2	2-2-10	PT		
II-RH-009RH-FW-15A	PLSW,P /	RH	2	2-2-10	PT		
II-RH-009RH-M16-PW-1	PP,FHS / NTERN	RH	2		SUR		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-RH-009RH-SW-F3	PC,PIP / PC,PIP	RH	2	2-2-10	PT		
II-RH-009RH-SW-F3A	PLSW,P /	RH	2	2-2-10	PT		
II-RH-010RH-FW-193	PC,VLV / PC,PIP	RH	2	2-2-10	PT		
II-RH-010RH-FW-2	PC,PIP / PP,FHS	RH	2	2-2-10	PT		
II-RH-010RH-FW-2A	PLSW,P /	RH	2	2-2-10	PT		
II-RH-010RH-M15-PW-1	PP,FHS / NTERN	RH	2		SUR		
II-RH-010RH-SW-F3	PC,PIP / PC,PIP	RH	2		PT		
II-RH-010RH-SW-F3A	PLSW,P /	RH	2		PT		
II-SI-008RH-FW-71	PC,PIP / PE,LR	SI	2		PT		
II-SI-008RH-FW-71A	PLSW,P /	SI	2		PT		
II-SI-008RH-FW-72	PC,VLV / PC,PIP	RH	2		PT		
II-SI-008RH-FW-72A	PLSW,P /	RH	2		PT		
II-SI-008RH-SW-K3	PC,PIP / PE,LR	RH	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-SI-008RH-SW-K3A	PLSW,P /	RH	2		PT		
II-SI-008RH-SW-K4	PE,LR / PC,PIP	RH	2	2-2-11	PT		
II-SI-008RH-SW-K4A	PLSW,P /	RH	2	2-2-11	PT		
II-SI-008RH-SW-K5	PC,PIP / PF,WN	RH	2	2-3-13	PT		
II-SI-008RH-SW-K5A	PLSW,P /	RH	2	2-3-13	PT		
II-SI-008RH-SW-K7	PC,PIP / PC,PIP	RH	2		PT		
II-SI-008RH-SW-K7A	PLSW,P /	RH	2		PT		
II-SI-008RH-SW-K7B	PLSW,P /	RH	2		PT		
II-SI-008RH-SW-L3	PE,LR / PC,PIP	SI	2		PT		
II-SI-008RH-SW-L3A	PLSW,P /	SI	2		PT		
II-SI-008RH-SW-L4	PC,PIP / PE,LR	SI	2		PT		
II-SI-008RH-SW-L4A	PLSW,P /	SI	2		PT		
II-SI-008RH-SW-L5	PF,WN / PC,PIP	SI	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY SER SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION
ITEM NO. 250.1S SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-SI-008RH-SW-L5A	PLSW,P /	SI	2		PT		
II-SI-008RH-SW-M3	PC,PIP / PF,WN	RH	2		PT		
II-SI-008RH-SW-M3A	PLSW,P /	RH	2		PT		
II-SI-008RH-SW-M6	PC,PIP / PC,PIP	RH	2	2-2-11	PT		
II-SI-008RH-SW-M6A	PLSW,P /	RH	2	2-2-11	PT		
II-SI-008RH-SW-M6B	PLSW,P /	RH	2	2-2-11	PT		
II-SI-008SI-96-1-SW-1	PC,PIP / PC,PIP	SI	2		PT		
II-SI-008SI-96-1-SW-1A	PLSW,P /	SI	2		PT		
II-SI-008SI-96-1-SW-1B	PLSW,P /	SI	2		PT		
II-SI-008SI-FW-446	PC,PIP / PBCC,T	SI	2	2-2-11	PT		
II-SI-008SI-FW-446A	PLSW,P /	SI	2	2-2-11	PT		
II-SI-008SI-FW-451	PC,PIP / PC,VLV	SI	2	2-2-11	PT		
II-SI-008SI-FW-452	PE,LR / PC,PIP	SI	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION						
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM						
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments	
II-SI-008SI-FW-452A	PLSW,P /	SI	2		PT			
II-SI-008SI-FW-453	PE,LR / PC,PIP	SI	2	2-1-09	PT			
II-SI-008SI-FW-453A	PLSW,P /	SI	2	2-1-09	PT			
II-SI-008SI-FW-454	PC,PIP / PC,VLV	SI	2		PT			
II-SI-008SI-FW-454A	PLSW,P /	SI	2		PT			
II-SI-008SI-FW-455	PC,VLV / PC,PIP	SI	2		PT			
II-SI-008SI-FW-455A	PLSW,P /	SI	2		PT			
II-SI-008SI-FW-458	PC,PIP / PC,VLV	SI	2		PT			
II-SI-008SI-FW-459	PC,PIP / PE,LR	SI	2	2-2-11	PT			
II-SI-008SI-FW-459A	PLSW,P /	SI	2	2-2-11	PT			
II-SI-008SI-FW-460	PC,PIP / PE,LR	SI	2		PT			
II-SI-008SI-FW-460A	PLSW,P /	SI	2		PT			
II-SI-008SI-FW-461	PC,VLV / PC,PIP	SI	2		PT			

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-SI-008SI-FW-461A	PLSW,P /	SI	2		PT		
II-SI-008SI-FW-462	PC,PIP / PC,VLV	SI	2	2-2-11	PT		
II-SI-008SI-FW-462A	PLSW,P /	SI	2	2-2-11	PT		
II-SI-008SI-SW-B3	PC,PIP / PE,LR	SI	2		PT		
II-SI-008SI-SW-B3A	PLSW,P /	SI	2		PT		
II-SI-008SI-SW-B4	PE,LR / PC,PIP	SI	2	2-3-13	PT		
II-SI-008SI-SW-C3	PC,PIP / PE,LR	SI	2		PT		
II-SI-008SI-SW-C3A	PLSW,P /	SI	2		PT		
II-SI-008SI-SW-C4	PC,PIP / PC,PIP	SI	2		PT		
II-SI-008SI-SW-C4A	PLSW,P /	SI	2		PT		
II-SI-008SI-SW-C4B	PLSW,P /	SI	2		PT		
II-SI-008SI-SW-C5	PBCC,T / PC,PIP	SI	2		PT		
II-SI-008SI-SW-C5A	PLSW,P /	SI	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-SI-008SI-SW-C6	PBCC,T / PC,PIP	SI	2		PT		
II-SI-008SI-SW-C6A	PLSW,P /	SI	2		PT		
II-SI-008SI-SW-C7	PC,PIP / PE,LR	SI	2		PT		
II-SI-008SI-SW-C7A	PLSW,P /	SI	2		PT		
II-SI-008SI-SW-C8	PC,PIP / PBCC,T	SI	2	2-2-11	PT		
II-SI-008SI-SW-C8A	PLSW,P /	SI	2	2-2-11	PT		
II-SI-008SI-SW-C9	PE,LR / PC,PIP	SI	2		PT		
II-SI-008SI-SW-C9A	PLSW,P /	SI	2		PT		
II-SI-008SI-SW-D3	PC,PIP / PE,LR	SI	2		PT		
II-SI-008SI-SW-D3A	PLSW,P /	SI	2		PT		
II-SI-008SI-SW-D4	PE,LR / PC,PIP	SI	2		PT		
II-SI-008SI-SW-D4A	PLSW,P /	SI	2		PT		
II-SI-008SI-SW-E3	PC,PIP / PC,PIP	SI	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-SI-008SI-SW-E3A	PLSW,P /	SI	2		PT		
II-SI-008SI-SW-E3B	PLSW,P /	SI	2		PT		
II-SI-008SI-SW-E4	PE,LR / PC,PIP	SI	2	2-1-08	PT		
II-SI-008SI-SW-E4A	PLSW,P /	SI	2	2-1-08	PT		
II-SI-008SI-SW-E5	PE,LR / PE,LR	SI	2	2-3-13	PT		
II-SI-008SI-SW-E6	PC,PIP / PE,LR	SI	2		PT		
II-SI-008SI-SW-E6A	PLSW,P /	SI	2		PT		
II-SI-008SI-SW-F3	PC,PIP / PC,PIP	SI	2		PT		
II-SI-008SI-SW-F3A	PLSW,P /	SI	2		PT		
II-SI-008SI-SW-F3B	PLSW,P /	SI	2		PT		
II-SI-008SI-SW-F5	PBCC,T / PC,PIP	SI	2		PT		
II-SI-008SI-SW-F5A	PLSW,P /	SI	2		PT		
II-SI-008SI-SW-F6	PBCC,T / PE,LR	SI	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-SI-008SI-SW-F7	PE,LR / PC,PIP	SI	2		PT		
II-SI-008SI-SW-F7A	PLSW,P /	SI	2		PT		
II-SI-008SI-SW-F8	PC,PIP / PE,LR	SI	2		PT		
II-SI-008SI-SW-F8A	PLSW,P /	SI	2		PT		
II-SI-008SI-SW-F9	PE,LR / PC,PIP	SI	2		PT		
II-SI-008SI-SW-F9A	PLSW,P /	SI	2		PT		
II-SI-008SI-SW-G3	PE,LR / PC,PIP	SI	2	2-1-08	PT		
II-SI-008SI-SW-G3A	PLSW,P /	SI	2	2-1-08	PT		
II-SI-008SI-SW-H10	PE,LR / PC,PIP	SI	2		PT		
II-SI-008SI-SW-H10A	PLSW,P /	SI	2		PT		
II-SI-008SI-SW-H11	PC,PIP / PE,LR	SI	2		PT		
II-SI-008SI-SW-H11A	PLSW,P /	SI	2		PT		
II-SI-008SI-SW-H12	PF,WN / PC,PIP	SI	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY SER SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION
ITEM NO. 250.1S SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-SI-008SI-SW-H12A	PLSW,P /	SI	2		PT		
II-SI-008SI-SW-H20	PC,PIP / PC,PIP	SI	2		PT		
II-SI-008SI-SW-H20A	PLSW,P /	SI	2		PT		
II-SI-008SI-SW-H20B	PLSW,P /	SI	2		PT		
II-SI-008SI-SW-H3	PE,LR / PC,PIP	SI	2	2-2-11	PT		
II-SI-008SI-SW-H3A	PLSW,P /	SI	2	2-2-11	PT		
II-SI-008SI-SW-H4	PC,PIP / PE,LR	SI	2		PT		
II-SI-008SI-SW-H4A	PLSW,P /	SI	2		PT		
II-SI-008SI-SW-H5	PBCC,T / PC,PIP	SI	2	2-2-11	PT		
II-SI-008SI-SW-H5A	PLSW,P /	SI	2	2-2-11	PT		
II-SI-008SI-SW-H6	PBCC,T / PC,PIP	SI	2	2-2-11	PT		
II-SI-008SI-SW-H6A	PLSW,P /	SI	2	2-2-11	PT		
II-SI-008SI-SW-H7	PC,PIP / PBCC,T	SI	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-SI-008SI-SW-H7A	PLSW,P /	SI	2		PT		
II-SI-008SI-SW-H8	PE,LR / PC,PIP	SI	2		PT		
II-SI-008SI-SW-H8A	PLSW,P /	SI	2		PT		
II-SI-008SI-SW-H9	PC,PIP / PE,LR	SI	2		PT		
II-SI-008SI-SW-H9A	PLSW,P /	SI	2		PT		
II-SI-008SI-SW-I3	PE,LR / PC,PIP	SI	2		PT		
II-SI-008SI-SW-I5	PC,PIP / PC,PIP	SI	2		PT		
II-SI-009CT-16-14-SW-1	PC,PIP / PC,PIP	CT	2		PT		
II-SI-009CT-FW-95	PC,VLV / PC,PIP	CT	2		PT		
II-SI-009CT-FW-96	PE,LR / PC,PIP	CT	2		PT		
II-SI-009CT-SW-H3	PC,PIP / PE,LR	CT	2	2-2-11	PT		
II-SI-009CT-SW-H4	PE,LR / PC,PIP	CT	2		PT		
II-SI-009CT-SW-H5	PC,PIP / PE,LR	CT	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-SI-009CT-SW-I3	PC,PIP / PE,LR	CT	2		PT		
II-SI-009CT-SW-I3A	PLSW,P /	CT	2		PT		
II-SI-009SI-94-2-SW-1	PC,PIP / PC,PIP	SI	2		PT		
II-SI-009SI-94-2-SW-1A	PLSW,P /	SI	2		PT		
II-SI-009SI-94-2-SW-1B	PLSW,P /	SI	2		PT		
II-SI-009SI-FW-277	PC,PIP / PC,PIP	SI	2	2-2-11	PT		
II-SI-009SI-FW-277A	PLSW,P /	SI	2	2-2-11	PT		
II-SI-009SI-FW-277B	PLSW,P /	SI	2	2-2-11	PT		
II-SI-009SI-FW-278	PC,PIP / PC,VLV	SI	2	2-1-08	PT		
II-SI-009SI-FW-281	PC,PIP / PE,LR	SI	2	2-2-11	PT		
II-SI-009SI-FW-281A	PLSW,P /	SI	2	2-2-11	PT		
II-SI-009SI-FW-282	PE,LR / PC,PIP	SI	2		PT		
II-SI-009SI-FW-282A	PLSW,P /	SI	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION						
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM						
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments	
II-SI-009SI-FW-283	PE,LR / PC,PIP	SI	2		PT			
II-SI-009SI-FW-283A	PLSW,P /	SI	2		PT			
II-SI-009SI-FW-284	PC,PIP / PC,VLV	SI	2	2-2-11	PT			
II-SI-009SI-FW-447	PC,PIP / PC,PIP	SI	2		PT			
II-SI-009SI-FW-447A	PLSW,P /	SI	2		PT			
II-SI-009SI-FW-447B	PLSW,P /	SI	2		PT			
II-SI-009SI-FW-448	PC,PIP / PE,LR	SI	2		PT			
II-SI-009SI-FW-448A	PLSW,P /	SI	2		PT			
II-SI-009SI-SW-B5	PE,LR / PC,PIP	SI	2	2-1-08	PT			
II-SI-009SI-SW-B6	PC,PIP / PE,LR	SI	2		PT			
II-SI-009SI-SW-B6A	PLSW,P /	SI	2		PT			
II-SI-009SI-SW-B7	PC,PIP / PC,PIP	SI	2	2-2-11	PT			
II-SI-009SI-SW-B7A	PLSW,P /	SI	2	2-2-11	PT			

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY SER SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION
ITEM NO. 250.1S SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-SI-009SI-SW-B7B	PLSW,P /	SI	2	2-2-11	PT		
II-SI-009SI-SW-C8	PC,PIP / PC,PIP	SI	2		PT		
II-SI-009SI-SW-C8A	PLSW,P /	SI	2		PT		
II-SI-009SI-SW-C8B	PLSW,P /	SI	2		PT		
II-SI-009SI-SW-C9	PE,LR / PC,PIP	SI	2	2-2-11	PT		
II-SI-009SI-SW-C9A	PLSW,P /	SI	2	2-2-11	PT		
II-SI-009SI-SW-D13	PC,PIP / PC,PIP	SI	2		PT		
II-SI-009SI-SW-D13A	PLSW,P /	SI	2		PT		
II-SI-009SI-SW-D13B	PLSW,P /	SI	2		PT		
II-SI-009SI-SW-D3	PE,LR / PC,PIP	SI	2		PT		
II-SI-009SI-SW-D3A	PLSW,P /	SI	2		PT		
II-SI-009SI-SW-D4	PC,PIP / PE,LR	SI	2		PT		
II-SI-009SI-SW-D4A	PLSW,P /	SI	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY SER SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION
ITEM NO. 250.1S SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-SI-009SI-SW-D5	PC,PIP / PC,PIP	SI	2		PT		
II-SI-009SI-SW-D5A	PLSW,P /	SI	2		PT		
II-SI-009SI-SW-D5B	PLSW,P /	SI	2		PT		
II-SI-009SI-SW-D6	PE,LR / PC,PIP	SI	2		PT		
II-SI-009SI-SW-D6A	PLSW,P /	SI	2		PT		
II-SI-009SI-SW-D7	PC,PIP / PE,LR	SI	2		PT		
II-SI-009SI-SW-D7A	PLSW,P /	SI	2		PT		
II-SI-009SI-SW-E3	PC,PIP / PBCC,T	SI	2		PT		
II-SI-009SI-SW-E3A	PLSW,P /	SI	2		PT		
II-SI-009SI-SW-E4	PBCC,T / PC,PIP	SI	2	2-2-11	PT		
II-SI-009SI-SW-E4A	PLSW,P /	SI	2	2-2-11	PT		
II-SI-009SI-SW-E5	PC,PIP / PE,LR	SI	2	2-2-11	PT		
II-SI-009SI-SW-E5A	PLSW,P /	SI	2	2-2-11	PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION						
ITEM NO.	250.1S	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM						
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments	
II-SI-009SI-SW-E6	PBCC,T / PC,PIP	SI	2	2-2-11	PT			
II-SI-009SI-SW-E7	PC,PIP / PE,LR	SI	2		PT			
II-SI-009SI-SW-E8	PE,LR / PC,PIP	SI	2		PT			
II-SI-009SI-SW-F3	PC,PIP / PE,LR	SI	2	2-2-11	PT			
II-SI-009SI-SW-F3A	PLSW,P /	SI	2	2-2-11	PT			
II-SI-009SI-SW-F4	PE,LR / PC,PIP	SI	2		PT			
II-SI-009SI-SW-F4A	PLSW,P /	SI	2		PT			
II-SI-009SI-SW-F5	PE,LR / PE,LR	SI	2		PT			
II-SI-009SI-SW-F6	PC,PIP / PE,LR	SI	2		PT			
II-SI-009SI-SW-F6A	PLSW,P /	SI	2		PT			
II-SI-009SI-SW-F7	PE,LR / PC,PIP	SI	2		PT			
II-SI-009SI-SW-F7A	PLSW,P /	SI	2		PT			
II-SI-009SI-SW-G3	PC,PIP / PC,PIP	SI	2		PT			

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY SER
ITEM NO. 250.1S

SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION
SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - SURFACE EXAM

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-SI-009SI-SW-G3A	PLSW,P /	SI	2		PT		
II-SI-009SI-SW-G3B	PLSW,P /	SI	2		PT		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION						
ITEM NO.	250.1V	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - VOLUMETRIC EXAM						
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments	
II-CT-001CT-6-1-SW-1	PC,PIP / PC,PIP	CT	2		UT-45S			
II-CT-001CT-6-1-SW-1A	PLSW,P /	CT	2		UT-45S			
II-CT-001CT-6-1-SW-1B	PLSW,P /	CT	2		UT-45S			
II-CT-001CT-6-3-SW-1	PC,PIP / PC,PIP	CT	2	2-2-11	UT-45S			
II-CT-001CT-FW-1	VNOZ1 / PC,PIP	CT	2	2-1-08	UT-45S			
II-CT-001CT-FW-10	PC,PIP / PP,FHS	CT	2	2-3-13	UT-45S			
II-CT-001CT-FW-16	PC,PIP / PC,VEN	CT	2	2-3-13	UT-45S			
II-CT-001CT-FW-16A	PLSW,P /	CT	2	2-3-13	UT-45S			
II-CT-001CT-FW-17	PC,VEN / PC,PIP	CT	2	2-3-13	UT-45S			
II-CT-001CT-FW-17A	PLSW,P /	CT	2		UT-45S			
II-CT-001CT-FW-1A	PLSW,P /	CT	2	2-1-08	UT-45S			
II-CT-001CT-FW-3	PE,LR / PC,PIP	CT	2		UT-45S			
II-CT-001CT-FW-4	PC,PIP / PE,LR	CT	2		UT-45S			

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY SER SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION
ITEM NO. 250.1V SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - VOLUMETRIC EXAM

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CT-001CT-FW-5	PC,PIP / PE,LR	CT	2		UT-45S		
II-CT-001CT-FW-6	PC,PIP / PE,LR	CT	2		UT-45S		
II-CT-001CT-FW-7	PE,LR / PC,PIP	CT	2		UT-45S		
II-CT-001CT-FW-8	PC,PIP / PC,VLV	CT	2	2-3-13	UT-45S		
II-CT-001CT-FW-9	PC,VLV / PC,PIP	CT	2	2-3-13	UT-45S		
II-CT-001CT-SW-A3	PC,PIP / PE,LR	CT	2	2-1-08	UT-45S		
II-CT-001CT-SW-A3A	PLSW,P /	CT	2	2-1-08	UT-45S		
II-CT-001CT-SW-A4	PE,LR / PC,PIP	CT	2		UT-45S		
II-CT-001CT-SW-A4A	PLSW,P /	CT	2		UT-45S		
II-CT-001CT-SW-A5	PC,PIP / PE,LR	CT	2		UT-45S		
II-CT-001CT-SW-A5A	PLSW,P /	CT	2		UT-45S		
II-CT-001CT-SW-A6	PE,LR / PC,PIP	CT	2		UT-45S		
II-CT-001CT-SW-A6A	PLSW,P /	CT	2		UT-45S		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1V	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - VOLUMETRIC EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CT-001CT-SW-A7	PC,PIP / PE,LR	CT	2		UT-45S		
II-CT-001CT-SW-A7A	PLSW,P /	CT	2		UT-45S		
II-CT-001CT-SW-A8	PE,LR / PC,PIP	CT	2		UT-45S		
II-CT-001CT-SW-A8A	PLSW,P /	CT	2		UT-45S		
II-CT-001CT-SW-B14	PC,PIP / PC,PIP	CT	2		UT-45S		
II-CT-001CT-SW-B14A	PLSW,P /	CT	2		UT-45S		
II-CT-001CT-SW-B14B	PLSW,P /	CT	2		UT-45S		
II-CT-001CT-SW-B3	PC,PIP / PE,LR	CT	2		UT-45S		
II-CT-001CT-SW-B3A	PLSW,P /	CT	2		UT-45S		
II-CT-001CT-SW-B4	PC,PIP / PC,PIP	CT	2	2-3-13	UT-45S		
II-CT-001CT-SW-B4A	PLSW,P /	CT	2	2-3-13	UT-45S		
II-CT-001CT-SW-B4B	PLSW,P /	CT	2	2-3-13	UT-45S		
II-CT-001CT-SW-C3	PC,PIP / PC,PIP	CT	2		UT-45S		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION						
ITEM NO.	250.1V	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - VOLUMETRIC EXAM						
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments	
II-CT-001CT-SW-C4	PC,PIP / PBCC,T	CT	2	2-2-11	UT-45S			
II-CT-001CT-SW-C5	PBCC,T / PC,PIP	CT	2	2-2-11	UT-45S			
II-CT-001CT-SW-D3	PE,LR / PC,PIP	CT	2	2-2-11	UT-45S			
II-CT-001CT-SW-D4	PC,PIP / PE,LR	CT	2		UT-45S			
II-CT-001CT-SW-D5	PE,LR / PC,PIP	CT	2		UT-45S			
II-CT-001CT-SW-E3	PE,LR / PC,PIP	CT	2		UT-45S			
II-CT-001CT-SW-E4	PC,PIP / PC,PIP	CT	2	2-2-11	UT-45S			
II-CT-001CT-SW-F3	PC,PIP / PE,LR	CT	2		UT-45S			
II-CT-001CT-SW-F4	PE,LR / PC,PIP	CT	2		UT-45S			
II-CT-001CT-SW-F5	PC,PIP / PE,LR	CT	2		UT-45S			
II-CT-001CT-SW-F6	PE,LR / PC,PIP	CT	2		UT-45S			
II-CT-001CT-SW-G3	PE,LR / PC,PIP	CT	2	2-3-13	UT-45S			
II-CT-001CT-SW-G4	PC,PIP / PE,LR	CT	2		UT-45S			

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY SER SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION
ITEM NO. 250.1V SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - VOLUMETRIC EXAM

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CT-002CT-1-1-SW-1	PC,PIP / PC,PIP	CT	2	2-3-13	UT-45S		
II-CT-002CT-1-1-SW-1A	PLSW,P /	CT	2	2-3-13	UT-45S		
II-CT-002CT-1-1-SW-1B	PLSW,P /	CT	2	2-3-13	UT-45S		
II-CT-002CT-1-1-SW-2	PC,PIP / PC,PIP	CT	2		UT-45S		
II-CT-002CT-1-1-SW-2A	PLSW,P /	CT	2		UT-45S		
II-CT-002CT-1-1-SW-2B	PLSW,P /	CT	2		UT-45S		
II-CT-002CT-1-3-SW-1	PC,PIP / PC,PIP	CT	2	2-3-13	UT-45S		
II-CT-002CT-FW-12	VNOZ1 / PC,PIP	CT	2		UT-45S		
II-CT-002CT-FW-12A	PLSW,P /	CT	2		UT-45S		
II-CT-002CT-FW-14	PE,LR / PC,PIP	CT	2		UT-45S		
II-CT-002CT-FW-15	PC,PIP / PE,LR	CT	2		UT-45S		
II-CT-002CT-FW-16	PC,PIP / PE,LR	CT	2		UT-45S		
II-CT-002CT-FW-16A	PLSW,P /	CT	2		UT-45S		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION						
ITEM NO.	250.1V	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - VOLUMETRIC EXAM						
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments	
II-CT-002CT-FW-17	PC,PIP / PE,LR	CT	2		UT-45S			
II-CT-002CT-FW-18	PE,LR / PC,PIP	CT	2		UT-45S			
II-CT-002CT-FW-19	PC,PIP / PC,VLV	CT	2	2-3-13	UT-45S			
II-CT-002CT-FW-20	PC,VLV / PC,PIP	CT	2	2-3-13	UT-45S			
II-CT-002CT-FW-20A	PLSW,P /	CT	2	2-3-13	UT-45S			
II-CT-002CT-FW-21	PC,PIP / PP,FHS	CT	2	2-3-13	UT-45S			
II-CT-002CT-FW-21A	PLSW,P /	CT	2	2-3-13	UT-45S			
II-CT-002CT-FW-22A	PC,VEN / PC,PIP	CT	2		UT-45S			
II-CT-002CT-FW-22ALA	PLSW,P /	CT	2		UT-45S			
II-CT-002CT-FW-22B	PC,PIP / PC,VEN	CT	2		UT-45S			
II-CT-002CT-FW-22BLA	PLSW,P /	CT	2		UT-45S			
II-CT-002CT-SW-A3	PC,PIP / PE,LR	CT	2		UT-45S			
II-CT-002CT-SW-A3A	PLSW,P /	CT	2		UT-45S			

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1V	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - VOLUMETRIC EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CT-002CT-SW-A4	PE,LR / PC,PIP	CT	2	2-1-08	UT-45S		
II-CT-002CT-SW-A4A	PLSW,P /	CT	2	2-1-08	UT-45S		
II-CT-002CT-SW-A5	PC,PIP / PE,LR	CT	2	2-1-08	UT-45S		
II-CT-002CT-SW-A5A	PLSW,P /	CT	2	2-1-08	UT-45S		
II-CT-002CT-SW-A6	PE,LR / PC,PIP	CT	2		UT-45S		
II-CT-002CT-SW-A6A	PLSW,P /	CT	2		UT-45S		
II-CT-002CT-SW-B24	PC,PIP / PC,PIP	CT	2		UT-45S		
II-CT-002CT-SW-B24A	PLSW,P /	CT	2		UT-45S		
II-CT-002CT-SW-B3	PC,PIP / PE,LR	CT	2		UT-45S		
II-CT-002CT-SW-B3A	PLSW,P /	CT	2		UT-45S		
II-CT-002CT-SW-B4	PE,LR / PC,PIP	CT	2		UT-45S		
II-CT-002CT-SW-B4A	PLSW,P /	CT	2		UT-45S		
II-CT-002CT-SW-B5	PC,PIP / PE,LR	CT	2		UT-45S		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1V	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - VOLUMETRIC EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CT-002CT-SW-B6	PC,PIP / PC,PIP	CT	2		UT-45S		
II-CT-002CT-SW-C3	PC,PIP / PC,PIP	CT	2		UT-45S		
II-CT-002CT-SW-C4	PC,PIP / PBCC,T	CT	2		UT-45S		
II-CT-002CT-SW-C5	PBCC,T / PC,PIP	CT	2		UT-45S		
II-CT-002CT-SW-D3	PE,LR / PC,PIP	CT	2		UT-45S		
II-CT-002CT-SW-D3A	PLSW,P /	CT	2		UT-45S		
II-CT-002CT-SW-D4	PC,PIP / PE,LR	CT	2		UT-45S		
II-CT-002CT-SW-D4A	PLSW,P /	CT	2		UT-45S		
II-CT-002CT-SW-D5	PE,LR / PC,PIP	CT	2		UT-45S		
II-CT-002CT-SW-D5A	PLSW,P /	CT	2		UT-45S		
II-CT-002CT-SW-D8	PC,PIP / PC,PIP	CT	2		UT-45S		
II-CT-002CT-SW-D8A	PLSW,P /	CT	2		UT-45S		
II-CT-002CT-SW-D8B	PLSW,P /	CT	2		UT-45S		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY SER SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION
ITEM NO. 250.1V SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - VOLUMETRIC EXAM

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CT-002CT-SW-E3	PE,LR / PC,PIP	CT	2		UT-45S		
II-CT-002CT-SW-E4	PC,PIP / PC,PIP	CT	2		UT-45S		
II-CT-002CT-SW-F3	PC,PIP / PE,LR	CT	2		UT-45S		
II-CT-002CT-SW-F3A	PLSW,P /	CT	2		UT-45S		
II-CT-002CT-SW-F4	PE,LR / PC,PIP	CT	2		UT-45S		
II-CT-002CT-SW-F4A	PLSW,P /	CT	2		UT-45S		
II-CT-002CT-SW-F5	PC,PIP / PE,LR	CT	2		UT-45S		
II-CT-002CT-SW-F5A	PLSW,P /	CT	2		UT-45S		
II-CT-002CT-SW-F6	PE,LR / PC,PIP	CT	2		UT-45S		
II-CT-002CT-SW-F6A	PLSW,P /	CT	2		UT-45S		
II-CT-002CT-SW-G3	PE,LR / PC,PIP	CT	2	2-3-13	UT-45S		
II-CT-002CT-SW-G4	PC,PIP / PE,LR	CT	2		UT-45S		
II-CT-014CT-FW-174	PP,FHS / PE,LR	CT	2		UT-45S		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY SER SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION
ITEM NO. 250.1V SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - VOLUMETRIC EXAM

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CT-014CT-FW-175	PC,PIP / PC,VLV	CT	2	2-2-10	UT-45S		
II-CT-014CT-FW-176	PC,VLV / PC,PIP	CT	2		UT-45S		
II-CT-014CT-FW-178	PC,PIP / PC,PB	CT	2		UT-45S		
II-CT-014CT-FW-179	PC,PB / PC,PIP	CT	2		UT-45S		
II-CT-014CT-FW-185	PC,PIP / PC,VLV	CT	2		UT-45S		
II-CT-014CT-SW-A3	PE,LR / PC,PIP	CT	2		UT-45S		
II-CT-014CT-SW-B3	PC,PIP / PE,LR	CT	2	2-2-10	UT-45S		
II-CT-014CT-SW-B4	PE,LR / PC,PIP	CT	2	2-2-10	UT-45S		
II-CT-014CT-SW-B6	PC,PIP / PC,PIP	CT	2		UT-45S		
II-CT-014CT-SW-C3	PC,PB / PC,PB	CT	2		UT-45S		
II-CT-014CT-SW-D3	PBCC,T / PC,PIP	CT	2		UT-45S		
II-CT-014CT-SW-D4	PC,PIP / PBCC,T	CT	2		UT-45S		
II-CT-016CT-2-FW-154	PC,PIP / PC,VLV	CT	2		UT-45S		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1V	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - VOLUMETRIC EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-CT-016CT-FW-143	PP,FHS / PE,LR	CT	2		UT-45S		
II-CT-016CT-FW-144	PC,PIP / PC,VLV	CT	2		UT-45S		
II-CT-016CT-FW-145	PC,VLV / PC,PIP	CT	2	2-2-10	UT-45S		
II-CT-016CT-FW-146	PC,PIP / PC,PB	CT	2		UT-45S		
II-CT-016CT-FW-148	PC,PB / PC,PIP	CT	2		UT-45S		
II-CT-016CT-SW-A3	PE,LR / PC,PIP	CT	2		UT-45S		
II-CT-016CT-SW-B3	PC,PIP / PE,LR	CT	2		UT-45S		
II-CT-016CT-SW-B4	PE,LR / PC,PIP	CT	2		UT-45S		
II-CT-016CT-SW-B6	PC,PIP / PC,PIP	CT	2		UT-45S		
II-CT-016CT-SW-C3	PC,PB / PC,PIP	CT	2		UT-45S		
II-CT-016CT-SW-C8	PC,PIP / PC,PB	CT	2		UT-45S		
II-CT-016CT-SW-D3	PBCC,T / PC,PIP	CT	2	2-1-08	UT-45S		
II-CT-016CT-SW-D4	PC,PIP / PBCC,T	CT	2	2-1-08	UT-45S		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1V	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - VOLUMETRIC EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-RH-001RH-2-2-SW-1	PC,PIP / PC,PIP	RH	2		UT-45S		
II-RH-001RH-2-2-SW-1A	PLSW,P /	RH	2		UT-45S		
II-RH-001RH-2-2-SW-1B	PLSW,P /	RH	2		UT-45S		
II-RH-001RH-2-5-SW-1	PC,PIP / PC,PIP	RH	2		UT-45S		
II-RH-001RH-2-5-SW-1A	PLSW,P /	RH	2		UT-45S		
II-RH-001RH-2-5-SW-1B	PLSW,P /	RH	2		UT-45S		
II-RH-001RH-FW-3	PP,FHS / PC,PB	RH	2	2-1-08	UT-45S		
II-RH-001RH-FW-3A	PLSW,P /	RH	2	2-1-08	UT-45S		
II-RH-001RH-FW-4	PC,PIP / PE,LR	RH	2		UT-45S		
II-RH-001RH-FW-4A	PLSW,P /	RH	2		UT-45S		
II-RH-001RH-FW-5	PC,PIP / PC,PIP	RH	2		UT-45S		
II-RH-001RH-FW-5A	PLSW,P /	RH	2		UT-45S		
II-RH-001RH-FW-5B	PLSW,P /	RH	2		UT-45S		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION						
ITEM NO.	250.1V	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - VOLUMETRIC EXAM						
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments	
II-RH-001RH-FW-6	PE,LR / PC,PIP	RH	2		UT-45S			
II-RH-001RH-FW-6A	PLSW,P /	RH	2		UT-45S			
II-RH-001RH-FW-7	PE,LR / PC,PIP	RH	2		UT-45S			
II-RH-001RH-FW-7A	PLSW,P /	RH	2		UT-45S			
II-RH-001RH-SW-A3	PE,LR / PC,PIP	RH	2	2-1-08	UT-45S			
II-RH-001RH-SW-A3A	PLSW,P /	RH	2	2-1-08	UT-45S			
II-RH-001RH-SW-A4	PC,PB / PE,LR	RH	2	2-1-09	UT-45S			
II-RH-001RH-SW-A4A	PLSW,P /	RH	2	2-1-09	UT-45S			
II-RH-001RH-SW-A8	PC,PIP / PC,PIP	RH	2		UT-45S			
II-RH-001RH-SW-A8A	PLSW,P /	RH	2		UT-45S			
II-RH-001RH-SW-A8B	PLSW,P /	RH	2		UT-45S			
II-RH-001RH-SW-B17	PC,PIP / PC,PIP	RH	2		UT-45S			
II-RH-001RH-SW-B17A	PLSW,P /	RH	2		UT-45S			

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1V	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - VOLUMETRIC EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-RH-001RH-SW-B17B	PLSW,P /	RH	2		UT-45S		
II-RH-001RH-SW-B6	PE,LR / PC,PIP	RH	2		UT-45S		
II-RH-001RH-SW-B6A	PLSW,P /	RH	2		UT-45S		
II-RH-001RH-SW-C5	PC,PIP / PE,LR	RH	2		UT-45S		
II-RH-001RH-SW-C5A	PLSW,P /	RH	2		UT-45S		
II-RH-001RH-SW-D11	PC,PIP / PC,PIP	RH	2		UT-45S		
II-RH-001RH-SW-D11A	PLSW,P /	RH	2		UT-45S		
II-RH-001RH-SW-D11B	PLSW,P /	RH	2		UT-45S		
II-RH-001RH-SW-D3	PC,PIP / PE,LR	RH	2		UT-45S		
II-RH-001RH-SW-D3A	PLSW,P /	RH	2		UT-45S		
II-RH-001RH-SW-D4	PE,LR / PC,PIP	RH	2		UT-45S		
II-RH-001RH-SW-D4A	PLSW,P /	RH	2		UT-45S		
II-RH-001RH-SW-D5	PC,PIP / PE,LR	RH	2		UT-45S		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION						
ITEM NO.	250.1V	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - VOLUMETRIC EXAM						
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments	
II-RH-001RH-SW-D5A	PLSW,P /	RH	2		UT-45S			
II-RH-001RH-SW-E34	PC,PIP / PC,PIP	RH	2		UT-45S			
II-RH-001RH-SW-E34A	PLSW,P /	RH	2		UT-45S			
II-RH-001RH-SW-E34B	PLSW,P /	RH	2		UT-45S			
II-RH-001RH-SW-E9	PC,PIP / PBCC,T	RH	2		UT-45S			
II-RH-001RH-SW-E9A	PLSW,P /	RH	2		UT-45S			
II-RH-002RH-5-2-SW-1	PC,PIP / PC,PIP	RH	2		UT-45S			
II-RH-002RH-5-2-SW-1A	PLSW,P /	RH	2		UT-45S			
II-RH-002RH-5-2-SW-1B	PLSW,P /	RH	2		UT-45S			
II-RH-002RH-5-3-SW-1	PC,PIP / PC,PIP	RH	2		UT-45S			
II-RH-002RH-5-3-SW-1A	PLSW,P /	RH	2		UT-45S			
II-RH-002RH-5-3-SW-1B	PLSW,P /	RH	2		UT-45S			
II-RH-002RH-FW-16	PP,FHS / PC,PB	RH	2	2-3-13	UT-45S			

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY ITEM NO.	SER 250.1V	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - VOLUMETRIC EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-RH-002RH-FW-16A	PLSW,P /	RH	2	2-3-13	UT-45S		
II-RH-002RH-FW-17	PC,PIP / PE,LR	RH	2		UT-45S		
II-RH-002RH-FW-17A	PLSW,P /	RH	2		UT-45S		
II-RH-002RH-FW-18	PC,PIP / PC,PIP	RH	2		UT-45S		
II-RH-002RH-FW-18A	PLSW,P /	RH	2		UT-45S		
II-RH-002RH-FW-18B	PLSW,P /	RH	2		UT-45S		
II-RH-002RH-FW-19	PE,LR / PC,PIP	RH	2	2-3-13	UT-45S		
II-RH-002RH-FW-19A	PLSW,P /	RH	2	2-3-13	UT-45S		
II-RH-002RH-FW-20	PE,LR / PC,PIP	RH	2	2-3-13	UT-45S		
II-RH-002RH-FW-20A	PLSW,P /	RH	2	2-3-13	UT-45S		
II-RH-002RH-SW-A3	PC,PIP / PE,LR	RH	2	2-3-13	UT-45S		
II-RH-002RH-SW-A3A	PLSW,P /	RH	2	2-3-13	UT-45S		
II-RH-002RH-SW-A4	PE,LR / PC,PIP	RH	2		UT-45S		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION					
ITEM NO.	250.1V	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - VOLUMETRIC EXAM					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-RH-002RH-SW-A4A	PLSW,P /	RH	2		UT-45S		
II-RH-002RH-SW-B5	PE,LR / PC,PIP	RH	2		UT-45S		
II-RH-002RH-SW-B5A	PLSW,P /	RH	2		UT-45S		
II-RH-002RH-SW-C19	PC,PIP / PC,PIP	RH	2		UT-45S		
II-RH-002RH-SW-C19A	PLSW,P /	RH	2		UT-45S		
II-RH-002RH-SW-C19B	PLSW,P /	RH	2		UT-45S		
II-RH-002RH-SW-C6	PC,PIP / PE,LR	RH	2		UT-45S		
II-RH-002RH-SW-C6A	PLSW,P /	RH	2		UT-45S		
II-RH-002RH-SW-D19	PC,PIP / PC,PIP	RH	2		UT-45S		
II-RH-002RH-SW-D19A	PLSW,P /	RH	2		UT-45S		
II-RH-002RH-SW-D19B	PLSW,P /	RH	2		UT-45S		
II-RH-002RH-SW-D3	PC,PIP / PE,LR	RH	2		UT-45S		
II-RH-002RH-SW-D3A	PLSW,P /	RH	2		UT-45S		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	SER	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION						
ITEM NO.	250.1V	SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - VOLUMETRIC EXAM						
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments	
II-RH-002RH-SW-D4	PE,LR / PC,PIP	RH	2		UT-45S			
II-RH-002RH-SW-D4A	PLSW,P /	RH	2		UT-45S			
II-RH-002RH-SW-D5	PC,PIP / PE,LR	RH	2		UT-45S			
II-RH-002RH-SW-D5A	PLSW,P /	RH	2		UT-45S			
II-RH-002RH-SW-D6	PC,PIP / PC,PIP	RH	2	2-3-13	UT-45S			
II-RH-002RH-SW-D6A	PLSW,P /	RH	2	2-3-13	UT-45S			
II-RH-002RH-SW-D6B	PLSW,P /	RH	2	2-3-13	UT-45S			
II-RH-009RH-FW-15	PC,PIP / PP,FHS	RH	2	2-2-10	UT-45S			
II-RH-009RH-FW-15A	PLSW,P /	RH	2	2-2-10	UT-45S			
II-RH-009RH-SW-F3	PC,PIP / PC,PIP	RH	2	2-2-10	UT-45S			
II-RH-009RH-SW-F3A	PLSW,P /	RH	2	2-2-10	UT-45S			
II-RH-010RH-FW-193	PC,VLV / PC,PIP	RH	2	2-2-10	UT-50S			
II-RH-010RH-FW-2	PC,PIP / PP,FHS	RH	2	2-2-10	UT-45S			

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY SER SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION
ITEM NO. 250.1V SAFETY EVALUATION REPORT, SAFETY REVIEW QUESTION #250.1 - VOLUMETRIC EXAM

ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-RH-010RH-FW-2A	PLSW,P /	RH	2	2-2-10	UT-45S		
II-RH-010RH-SW-F3	PC,PIP / PC,PIP	RH	2		UT-45S		
II-RH-010RH-SW-F3A	PLSW,P /	RH	2		UT-45S		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	RG1.14	REACTOR COOLANT PUMP FLYWHEEL INTEGRITY EXAMINATION					
ITEM NO.	BORE	REACTOR COOLANT PUMP FLYWHEEL BORE - UT					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-RCP-02RCP-A-FLYWHEEL	TFLYW /	RC	1	2-1-08	UT-00		
II-RCP-02RCP-A-FLYWHEEL	TFLYW /	RC	1	2-2-10	UT-00		
II-RCP-02RCP-A-FLYWHEEL	TFLYW /	RC	1	2-3-12	UT-00		
II-RCP-02RCP-B-FLYWHEEL	TFLYW /	RC	1	2-1-08	UT-00		
II-RCP-02RCP-B-FLYWHEEL	TFLYW /	RC	1	2-2-10	UT-00		
II-RCP-02RCP-B-FLYWHEEL	TFLYW /	RC	1	2-3-12	UT-00		
II-RCP-02RCP-C-FLYWHEEL	TFLYW /	RC	1	2-1-08	UT-00		
II-RCP-02RCP-C-FLYWHEEL	TFLYW /	RC	1	2-2-10	UT-00		
II-RCP-02RCP-C-FLYWHEEL	TFLYW /	RC	1	2-3-12	UT-00		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY	RG1.14	REACTOR COOLANT PUMP FLYWHEEL INTEGRITY EXAMINATION					
ITEM NO.	FLYWHL	REACTOR COOLANT PUMP FLYWHEEL - SURFACE AND UT					
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments
II-RCP-02RCP-A-FLYWHEEL	TFLYW /	RC	1	2-3-12	PT		
II-RCP-02RCP-A-FLYWHEEL	TFLYW /	RC	1	2-3-12	UT-00		
II-RCP-02RCP-B-FLYWHEEL	TFLYW /	RC	1	2-3-12	PT		
II-RCP-02RCP-B-FLYWHEEL	TFLYW /	RC	1	2-3-12	UT-00		
II-RCP-02RCP-C-FLYWHEEL	TFLYW /	RC	1	2-3-12	PT		
II-RCP-02RCP-C-FLYWHEEL	TFLYW /	RC	1	2-3-12	UT-00		

Carolina Power and Light Company
Harris Nuclear Power Plant - Unit 1
ISI Component/Examination Listing for 2nd 10-Year Interval

CATEGORY ITEM NO.	Augmented Augmented	SUCCESSIVE EXAMS LOOSE BOLTING						
ISI Component/Exam Number	Description	System	Class	Outage	Exam Type	Relief Request	Comments	
II-RC-010RC-52-F-01	FLGCO /	RC	1	2-1-08	VT-1		ACR 91-165, dated 4/5/91. Successive exams due to loose bolting.	
II-RC-010RC-52-F-01	FLGCO /	RC	1	2-2-10	VT-1		ACR 91-165, dated 4/5/91. Successive exams due to loose bolting.	
II-RC-010RC-52-F-01	FLGCO /	RC	1	2-3-12	VT-1		ACR 91-165, dated 4/5/91. Successive exams due to loose bolting.	
II-RC-011RC-41-F-01	FLGCO /	RC	1	2-1-08	VT-1		ACR 91-165, dated 4/5/91. Successive exams due to loose bolting.	
II-RC-011RC-41-F-01	FLGCO /	RC	1	2-2-10	VT-1		ACR 91-165, dated 4/5/91. Successive exams due to loose bolting.	
II-RC-011RC-41-F-01	FLGCO /	RC	1	2-3-12	VT-1		ACR 91-165, dated 4/5/91. Successive exams due to loose bolting.	

PRESSURE TEST PROGRAM PLAN

GENERAL

System pressure tests shall be conducted in accordance with the rules of IWA-5000 "System Pressure Tests" to the extent practical. Where such impracticalities exist, relief has been requested and alternate testing requirements have been proposed. Relief requests are outlined in Section 7. Table IWA-5210-1 references the appropriate Subsection and subsubarticles for Class 1, 2 and 3 components.

SYSTEM TEST REQUIREMENT (IWA-5200)

TEST (IWA-5210)

TEST DESCRIPTION (IWA-5211)

The pressure retaining components within each system boundary shall be subject to system pressure tests under which conditions visual examination VT-2 is performed in accordance with IWA-5240 to detect leakages. The required system pressure tests and examinations, as referenced in Table IWA-5210-1 may be performed in conjunction with one or more of the following system tests or operations:

- (a) a system leakage test conducted following opening and reclosing of a component in the system after pressurization to nominal operating pressure;
- (b) a system functional test conducted to verify operability in systems (or components) not required to operate during normal plant operation while under system operating pressure;
- (c) a system inservice test conducted to performed visual examination VT-2 while the system is in service under operating pressure;
- (d) a system hydrostatic test conducted during a plant shutdown at a pressure above nominal operating pressure or system pressure for which overpressure protection is provided;
- (e) a system pneumatic test conducted in lieu of a hydrostatic pressure test for components within the scope of IWC and IWD.

System leakage tests and system hydrostatic tests shall be conducted at the test conditions of pressure and temperature specified in IWB-5000, IWC-5000, and IWD-5000.

The holding time after pressurization to test conditions, before the visual examinations commence, shall be in accordance with IWA-5213 as applicable.

PRESSURE TEST PROGRAM PLAN

TEST DESCRIPTION (IWA-5211) continued:

A component repair or replacement shall be pressure tested prior to resumption of service if required by IWA-440 and IWA-4600 and meet the additional requirements of IWA-5214.

The boundary subject to test pressurization during a system leakage test [IWA-5211(a)] shall extend to the pressure retaining components within the system boundary containing pressurized reactor coolant under the plant mode of normal reactor startup.

The boundary subject to test pressurization during a system functional test [IWA-5211(b)] shall include only those pressure retaining components within the system boundary pressurized under the test mode required during the performance of a periodic system (or component) functional test.

The boundary subject to test pressurization during a system inservice test [IWA-5211(c)] shall extend to those pressure retaining components under operating pressures during normal system service.

The boundary subject to test pressurization during a system hydrostatic test [IWA-5211(d)] shall be defined by the system boundary (or each portion of the boundary) within which the components have the same minimum required classification and are designed to the same primary pressure rating as governed by the system function and the internal fluid operating conditions, respectively, and meet the additional requirements of IWA-5224. Code Case N-498-1 and N-416-1 may be used as applicable.

VISUAL EXAMINATION (IWA-5240)

Noninsulated Components (IWA-5241)

(a) The visual examination VT-2 shall be conducted by examining the accessible external exposed surfaces of pressure retaining components for evidence of leakage.

(b) For components whose external surfaces are inaccessible for direct visual examination VT-2, only the examination of surrounding area (including floor areas or equipment surfaces located underneath the components) for evidence of leakage shall be required.

PRESSURE TEST PROGRAM PLAN

Insulated Components (IWA-5242)

(a) For systems borated for the purpose of controlling reactivity, insulation shall be removed from pressure retaining bolted connections for visual examination VT-2. For other components, visual examination VT-2 may be conducted without the removal of insulation by examining the accessible and exposed surfaces and joints of the insulation. Essentially vertical surfaces of insulation need only be examined at the lowest elevation where leakage may be detectable. Essentially horizontal surfaces of insulation shall be examined at each insulation joint.

(b) When examining insulated components, the examination of surrounding area (including floor areas or equipment surfaces located underneath the components) for evidence of leakage, or other areas to which such leakage may be channeled, shall be required.

(c) Discoloration or residue on surfaces examined shall be given particular attention to detect evidence of boric acid accumulations from borated reactor coolant leakage.

NOTE: Code Case N-533 (2R1-010) may be used as applicable.

Components With Leakage Collection Systems (IWA-5243)

Where leakages from components are normally expected and collected (such as valve stems, pump seals, or vessel flange gaskets) the visual examination VT-2 shall be conducted by verifying that the leakage collection system is operative.

Buried Components (IWA-5244)

(a) In nonredundant systems where the buried components are isolable by means of valves, the visual examination VT-2 shall consist of a leakage test that determines the rate of pressure loss. Alternatively, the test may determine the change in flow between the ends of the buried components. The acceptable rate of pressure loss or flow shall be established by the responsible engineer or his designee.

(b) In redundant systems where the buried components are nonisolable, the visual examination VT-2 shall consist of a test that determines the change in flow between the ends of the buried components. In cases where an annulus surrounds the buried components, the areas at each end of the buried components shall be visually examined for evidence of leakage in lieu of a flow test.

(c) In nonredundant systems where the buried components are nonisolable, such as return lines to the heat sink, the visual examination VT-2 shall consist only of a verification that the flow during operation is not impaired.

PRESSURE TEST PROGRAM PLAN

Elevated Temperature Tests (IWA-5245)

The visual examination of system components requiring a test temperature above 200 Deg.F during the system pressure test may be conducted after the pressure test holding period or IWA-5213 is satisfied, and the pressure is lowered to the level corresponding with a temperature of 200 Deg.F, in accordance with allowable cooldown rates established by fracture prevention criteria.

Repaired or Replaced Components and Alteration of a System

The visual examination VT-2 following a repair or replacement of a component, or the alteration of a system, may be limited to the repaired or replaced components, or the altered portion of the system, but shall include any connections made to the existing system.

CORRECTIVE MEASURES (IWA-5250)

(a) The source of leakages detected during the conduct of a system pressure test shall be located and evaluated for corrective measures as follows:

1. Buried components with leakage losses in excess of limits acceptable for continued service shall be repaired or replaced;
2. If leakage occurs at a bolted connection, the bolting shall be removed, VT-3 visually examined for corrosion, and evaluated in accordance with IWA-3100;
3. Repairs or replacements of components shall be performed in accordance with IWA-4000 or IWA-7000, respectively.

(b) If boric acid residues are detected on components, the leakage source and the areas of general corrosion shall be located. Components with local areas of general corrosion that reduce the wall thickness by more than 10% shall be evaluated to determine whether the component may be acceptable for continued service, or whether repair or replacement is required.

PRESSURE TEST PROGRAM PLAN

CLASS 1 SYSTEM PRESSURE TESTING (IWB-5000)

SYSTEM TEST REQUIREMENTS (IWB-5200)

TEST (IWB-5210)

(a) The pressure retaining components shall be tested at the frequency stated and visually examined by the method specified in Table IWB-2500-1, Examination Category B-P:

- (1) system leakage test, IWA-5211(a);
- (2) system hydrostatic test, IWA-5211(d).

(b) The system pressure tests and visual examinations shall be conducted in accordance with IWA-5000 and Article IWB-5000. Code Case N-498-1 and N-416-1 may be applied for the system hydrostatic test, as applicable. Reactor coolant shall be used as the pressurizing medium.

NOTE: Code Case N-533 (2R1-010) may be used as applicable.

CLASS 2 SYSTEM PRESSURE TESTING (IWC-5000)

SYSTEM TEST REQUIREMENTS (IWC-5200)

TEST (IWC-5210)

(a) The pressure retaining components within each system boundary shall be subjected to the following system pressure tests and visually examined by the method specified in Table IWC-2500-1, Examination Category C-H:

- (1) a system pressure test conducted during a system functional test of those [IWA-5211(b)] systems (or components) not required to operate during normal plant operation but for which periodic system (or component) functional tests are performed to meet CP&L requirements;
- (2) a system pressure test conducted during a system inservice test [IWA-5211(c)] for those systems required to operate during normal plant operation;
- (3) a system hydrostatic pressure test [IWA-5211(d)] for each system or portion of systems. Code Case N-498-1 and N-416-1 may be applied as applicable.

(b) The system pressure tests and visual examination shall be conducted in accordance with IWA-5000 and Article IWC-5000. The contained fluid in the system shall serve as the pressurizing medium, except that in steam systems either water or air may be used. Where air is used, the test procedure shall permit the detection and location of through-wall leakages in components of the system tested.

PRESSURE TEST PROGRAM PLAN

- (c) Code Case N-522 may be applied as alternative rules for the pressure testing and visual VT-2 examination of Class 2 Containment Penetration piping when only the piping and isolation valves are Class 2, but the balance of the piping system is outside the scope of Section XI. This Code Case substitutes the 10CFR50 Appendix J Local Leak Rate Testing (LLRT) for the ASME Section XI Class 2 testing.

CLASS 3 SYSTEM PRESSURE TESTING (IWD-5000)

SYSTEM TEST REQUIREMENTS (IWD-5200)

TEST (IWD-5210)

(a) The pressure retaining components within the boundary of each system specified in the Examination Categories of Table IWD-2500-1 shall be pressure tested and examined in accordance with Table IWD-2500-1 during the following tests:

- (1) system inservice test, IWA-5211(c);
- (2) system functional test, IWA-5211(b);
- (3) system hydrostatic test, IWA-5211(d).

(b) The system hydrostatic test shall be conducted in accordance with IWA-5000. Code Case N-498-1 and N-416-1 may be applied, as applicable. The contained fluid in the system shall serve as the pressurizing medium.

PRESSURE TEST PROGRAM PLAN

EXAM CAT.	ITEM NO.	PARTS EXAMINED	SYSTEM	CLASS	P&ID	RELIEF REQUEST
B-P	B15.10 B15.11	REACTOR VESSEL	RC SI CS	I	2165-G-052 2165-G-800 2165-G-801 2165-G-803 2165-G-808 2165-G-809 2165-G-810 2165-G-824 2165-G-844	CC N-498 CC N-416-1 RR 2RG-001 CC N-533 RR 2R1-010
B-P	B15.20 B15.21	PRESSURIZER				
B-P	B15.30 B15.31	STEAM GENERATORS				
B-P	B15.40 B15.41	HEAT EXCHANGERS				
B-P	B15.50 B15.51	PIPING				
B-P	B15.60 B15.61	PUMPS				
B-P	B15.70 B15.71	VALVES				

PRESSURE TEST PROGRAM PLAN

EXAM CAT.	ITEM NO.	PARTS EXAMINED	SYSTEM	CLASS	P&ID	RELIEF REQUEST
C-H	C7.10 C7.20	PRESSURE VESSELS	BD MS SW SI RC CS CT CCW CVCS CB CM RHR AFW RVLIS RAD MON. SAMP. WASTE LIQUID LT WG IA SP SA DW MD FP	2	2165-G-042 2165-G-044 2165-G-047 2165-G-050 2165-G-051 2165-G-052 2165-G-105 2165-G-166 2165-G-800 2165-G-801 2165-G-803 2165-G-804 2165-G-805 2165-G-806 2165-G-807 2165-G-808 2165-G-809 2165-G-810 2165-G-813 2165-G-821 2165-G-824 2165-G-844 2158-G-517	CC N-498 CC N-522 RR 2R2-006 CC N-416-1 RR 2RG-001
C-H	C7.30 C7.40	PIPING				
C-H	C7.50 C7.60	PUMPS				
C-H	C7.70 C7.80	VALVES				

PRESSURE TEST PROGRAM PLAN

EXAM CAT.	ITEM NO.	PARTS EXAMINED	SYSTEM	CLASS	P&ID	RELIEF REQUEST
D-A	D1.10	Pressure Retaining Components	AS BD CE CX CS SW FW MS SI CW RC CCW AFW ESW FO EA WL PM NI CVCS SPENT FUEL COOL. HYD. ANALYZER	3	2165-G-008	CC N-498-1 RR 2RG-002 CC N-416-1 RR 2RG-001
					2165-G-042	
					2165-G-044	
					2165-G-045	
					2165-G-047	
					2165-G-051	
					2165-G-063	
					2165-G-088	
					2165-G-105	
					2165-G-133	
					2165-G-189	
					2165-G-299	
					2165-G-305	
					2165-G-308	
					2165-G-436	
					2165-G-801	
					2165-G-804	
					2165-G-805	
					2165-G-806	
					2165-G-807	
					2165-G-809	
					2165-G-813	
					2165-G-819	
					2165-G-820	
					2164-G-821	
D-B	D2.10	Pressure Retaining Components			2165-G-822	
					2165-G-829	
D-C	D3.10	Pressure Retaining Components			2168-G-498	
					2168-G-499	

CALIBRATION BLOCKS

CAL. BLK.	SIZE	MAT. TYP.	PIPE SCH.	THICK.	HEAT NO.
UT-001-1	VESS. BLK.	CS CLAD	N/A	9"	R2304-1
UT-002-1	VESS. BLK.	CS CLAD	N/A	8.25"	124S447
UT-003-1	VESS. BLK.	CS CLAD	N/A	5"	C4533-1
UT-004-1	NOZZLE	CS CLAD	N/A	15"	123Y317
UT-005-1	VESS. HEAD	CS CLAD	N/A	7"	C4533-1
UT-006-1	NOZZLE	SS SA351	32"	2.5"	28841-6
UT-007-1	NOZ. SAFE	SS A508	16"	2.5"	15812
UT-007-2	NOZ. SAFE	SS A508	16"	2.5"	15812
UT-008-1	RC PIPE	SS SA376	N/A	2.5"	L1286
UT-010-1	2.5"	CS SA106	80	.276"	N76472
UT-010-2	2.5"	CS SA106	80	.276"	N76472
UT-011-1	3.0"	SS SA312	40	.216"	M4563
UT-011-2	3.0"	SS SA312	40	.216"	M4563
UT-012-1	3.0"	CS SA106	80	.300"	165044
UT-012-2	3.0"	SA SA106	80	.300"	165044
UT-013-1	3.0"	CS SA106	160	.438"	X5489
UT-013-2	3.0"	CS SA106	160	.438"	X5489
UT-014-1	3.0"	SS SA376	160	.438"	M2760
UT-014-2	3.0"	SS SA376	160	.438"	M2760
UT-015-1	4.0"	CS SA106	40	.237"	N16094
UT-015-2	4.0"	CS SA106	40	.237"	N16094
UT-016-1	4.0"	CS SA106	80	.337"	L25198
UT-016-2	4.0"	CS SA106	80	.337"	L25198
UT-017-1	4.0"	SS SA376	160	.531"	C7199
UT-017-2	4.0"	SS SA376	160	.531"	C7199
UT-018-1	6.0"	CS SA106	80	.432"	264788
UT-018-2	6.0"	CS SA106	80	.432"	264788
UT-019-1	6.0"	CS SA106	120	.562"	N73583
UT-019-2	6.0"	CS SA106	120	.562"	N73583
UT-020-1	6.0"	SS SA376	160	.719"	630-13-3
UT-020-2	6.0"	SS SA376	160	.719"	630-13-3
UT-021-1	8.0"	SS SA312	40	.322"	11-430
UT-021-2	8.0"	SS SA312	40	.322"	11-430
UT-022-1	8.0"	CS SA106	80	.500"	917335
UT-022-2	8.0"	CS SA106	80	.500"	917335
UT-023-1	10.0"	SS SA376	140	1.0"	1081-2-2-1
UT-023-2	10.0"	SS SA376	140	1.0"	1081-2-2-1
UT-024-1	12.0"	SS SA312	STD.	.375"	7-105/1210-40-2
UT-024-2	12.0"	SS SA312	STD.	.375"	7-105/1210-40-2
UT-025-1	12.0"	CS SA106	60	.562"	26590

CALIBRATION BLOCKS

CAL. BLK.	SIZE	MAT. TYP.	PIPE SCH.	THICK.	HEAT NO.
UT-025-2	12.0"	CS SA106	60	.562"	26590
UT-026-1	12.0"	SS SA376	140	1.125"	534193
UT-026-2	12.0"	SS SA376	140	1.125"	534193
UT-027-1	14.0"	SS SA358	STD.	.375"	30190
UT-027-2	14.0"	SS SA358	STD.	.375"	30190
UT-028-1	14.0"	SS SA376	160	1.406"	J2619
UT-028-2	14.0"	SS SA376	160	1.406"	J2619
UT-029-1	16.0"	CS SA106	.688"/.750"	.851"	L4517
UT-029-2	16.0"	CS SA106	.688"/.750"	.851"	L4517
UT-030-1	16.0"	CS SA106	13.750" ID	1.006"	L4489
UT-030-2	16.0"	CS SA106	13.750" ID	1.006"	L4489
UT-031-1	32.0"	CS SA106	1.052"/1.267"	1.340"	L4497
UT-031-2	32.0"	CS SA106	1.052"/1.267"	1.340"	L4497
UT-032-1	44.0"	CS SA106	1.447"/1.765"	1.790"	J7371
UT-032-2	44.0"	CS SA106	1.447"/1.765"	1.790"	J7371
UT-034-1	50.0"	CS A155	SPEC.	3.40"	D20265-J848
UT-035-1	50.0"	CS A155	SPEC.	1.71"	D20265-J848
UT-036-1	12.0"	CS SA106	80	.562"	61868
UT-037-1	14.0"	SS SA376	160	1.406"	636144
UT-037-2	14.0"	SS SA376	160	1.406"	636144
UT-038-1	N/A	SS SA516	N/A	1.250"	66987
UT-039-1	N/A	SS SA240	N/A	1.125"	26220
UT-040-1	N/A	SS SA376	N/A	.375"	M5914
UT-040-2	N/A	SS SA376	N/A	.375"	M5914
UT-041-1	30.0"	CS A106	SPEC.	1.886"	L4484
UT-042-1	10.0"	SS SA376	140	1.0"	11-956
UT-050-1	PRESS.	SS SA533	N/A	3.50"	D8366
UT-051-1	STM.GEN.	SS SA533	N/A	5.00"	D8366
UT-052-1	STM.GEN.	SS SA533	N/A	3.50"	D8366
UT-053-1	SPEC.BLK.	SS SA351	N/A	.900"	28841-6
UT-054-1	N/A	SS SA204	N/A	.800"	803145
UT-055-1	10.0"	SS SA312	SPEC.	.740"	1080-14-1
UT-056-1	N/A	SS SA204	N/A	2.00"	895101
UT-057-1	8.0"	CS SA106	40	.322"	N16583

COLOR-CODED BOUNDARY DRAWINGS

CLASS 1 = Pink CLASS 2 = Blue CLASS 3 - Green

FLOW DIAGRAM	REVISION	DESCRIPTION
CAR-2165-G-042	30	MAIN STEAM SYSTEM
CAR-2165-G-044	34	FEEDWATER & AUXILARY FEEDWATER SYSTEM
CAR-2165-G-045	51	CONDENSATE & AIR EVACUATION SYSTEMS
CAR-2165-G-047	44	CIRCULATING & SERVICE WATER SYSTEMS
CAR-2165-G-050	24	CONTAINMENT SPRAY SYSTEM
CAR-2165-G-051	26	STEAM GENERATOR BLOWDOWN SYSTEM
CAR-2165-G-052	23	SAMPLING SYSTEM NUCLEAR
CAR-2165-G-063	15	DIESEL FUEL OIL SYSTEM
CAR-2165-G-088	24	MISCELLANEOUS SYSTEMS
CAR-2165-G-105	18	RADIATION MONITOR AND HYDROGEN ANALYZER SYSTEMS
CAR-2165-G-133	12	DIESEL GENERATOR SYSTEMS
CAR-2165-G-166	12	CONTAINMENT PENETRATION PRESSURIZATION SYSTEMS
CAR-2165-G-189	14	AUXILARY STEAM SYSTEM
CAR-2165-G-299	14	PRIMARY & DEMINERALIZER WATER SYSTEMS (RAB)
CAR-2165-G-300	16	SERVICE AIR SYSTEM
CAR-2165-G-301	30	INSTRUMENT AIR SYSTEM
CAR-2165-G-305	14	FUEL POOLS COOLING SYSTEM
CAR-2165-G-307	10	FUEL POOLS COOLING SYSTEM
CAR-2165-G-308	22	COOLING TOWER BLOWDOWN, MAKE-UP & INTAKE STRUCTURES SCREENWASH SYSTEMS
CAR-2165-G-388	13	FIRE PROTECTION SYSTEM
CAR-2165-G-436	24	INTAKE STRUCTURES PUMP SEAL, BEARING LUBRICATION AND MOTOR COOLING WATER SYSTEMS
CAR-2165-G-800	27	REACTOR COOLANT SYSTEM
CAR-2165-G-801	18	REACTOR COOLANT SYSTEM
CAR-2165-G-803	20	CHEMICAL & VOLUME CONTROL SYSTEM
CAR-2165-G-804	22	CHEMICAL & VOLUME CONTROL SYSTEM
CAR-2165-G-805	22	CHEMICAL & VOLUME CONTROL SYSTEM
CAR-2165-G-806	18	CHEMICAL & VOLUME CONTROL SYSTEM
CAR-2165-G-807	16	CHEMICAL & VOLUME CONTROL SYSTEM
CAR-2165-G-808	22	SAFETY INJECTION SYSTEM
CAR-2165-G-809	22	SAFETY INJECTION SYSTEM
CAR-2165-G-810	21	SAFETY INJECTION SYSTEM
CAR-2165-G-811	23	BORON RECYCLE SYSTEM

COLOR-CODED BOUNDARY DRAWINGS

CLASS 1 = Pink CLASS 2 = Blue CLASS 3 - Green

CAR-2165-G-812	21	BORON RECYCLE SYSTEM
CAR-2165-G-813	10	CONTAINMENT BUILDING WASTE PROCESSING SYSTEM
CAR-2165-G-817	25	WASTE PROCESSING SYSTEM GAS DECAY STORAGE
CAR-2165-G-818	22	WASTE PROCESSING SYSTEM WASTE GAS COMPR. & RECOMBINER
CAR-2165-G-819	22	COMPONENT COOLING WATER SYSTEM
CAR-2165-G-820	11	COMPONENT COOLING WATER SYSTEM
CAR-2165-G-821	16	COMPONENT COOLING WATER SYSTEM
CAR-2165-G-822	15	COMPONENT COOLING WATER SYSTEM
CAR-2165-G-824	19	RESIDUAL HEAT REMOVAL SYSTEM
CAR-2165-G-829	14	RAB FILTER BACKWASH SYSTEM
CAR-2165-G-844	5	REACTOR COOLANT SYSTEM REACTOR VESSEL LEVEL INSTRUMENTATION (RVLIS)