

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

SUBJECT: Forwards mid-cycle rev 1 to "Harris Unit 1 COLR." Rev
revises MTC surveillance limit from -36.4 pcm/F to -37.65
pcm/F using NRC reviewed & approved methodology.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2+12
TITLE: OR Submittal: General Distribution

NOTES:Application for permit renewal filed.

05000400E

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME	LTTR	ENCL	ID CODE/NAME		LTTR	ENCL		
	PD2-1 LA	1	1		PD2-1 PD	1	1		
	FLANDERS, S	1	1						
INTERNAL:	ACRS	1	1		FILE CENTER 01	1	1		
	NRR/DE/ECGB/A	1	1		NRR/DE/EMCB	1	1		
	NRR/DRCH/HICB	1	1		NRR/DSSA/SPLB	1	1		
	NRR/DSSA/SRXB	1	1		NUDOCS-ABSTRACT	1	1		
	OGC/HDS2	1	0						
EXTERNAL:	NOAC	1	1		NRC PDR	1	1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 13

MA4



Carolina Power & Light Company
PO Box 165
New Hill NC 27562

James Scarola
Vice President
Harris Nuclear Plant

SERIAL: HNP-98-138
10CFR50.90

SEP 21 1998

United States Nuclear Regulatory Commission
ATTENTION: Document Control Desk
Washington, DC 20555

SHEARON HARRIS NUCLEAR POWER PLANT
DOCKET NO. 50-400/LICENSE NO. NPF-63
REQUEST FOR LICENSE AMENDMENT
CYCLE 8 CORE OPERATING LIMITS REPORT - REVISION 1


Dear Sir or Madam:

In accordance with Technical Specifications (TS) 6.9.1.6.4, Carolina Power & Light Company (CP&L) hereby submits a mid-cycle revision to the Harris Nuclear Plant (HNP) Cycle 8 Core Operating Limits Report (COLR).

Revision 1 to the COLR revises the Moderator Temperature Coefficient (MTC) Surveillance Limit from -36.4 pcm/°F to -37.65 pcm/°F using an NRC reviewed and approved methodology. The previous MTC Surveillance Limit was calculated using an analytical method that was not specifically reviewed and approved by the NRC. However, the results of the previous MTC Surveillance Limit calculation were more conservative than the revised MTC Surveillance Limit calculation using the NRC approved analytical method.

Please refer any questions regarding this submittal to Mr. J. H. Eads at (919) 362-2646.

Sincerely,



James Scarola

MSE/mse
Attachment

c: Mr. J. B. Brady, NRC Sr. Resident Inspector
Mr. S. C. Flanders, NRC Project Manager
Mr. L. A. Reyes, NRC Regional Administrator

9809290170 980921 77
PDR ADDCK 05000400
P PDR

11
A001

Harris Unit 1 Cycle 8
Core Operating Limits Report - Rev. 1

Attachment 9 to HNP Procedure PLP-106
"Technical Specification Equipment List Program and
Core Operating Limits Report," Rev. 18