

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9810160203 DOC. DATE: ~~98/09/30~~ NOTARIZED: NO DOCKET #
 FACIL: 50-400 Shearon Harris Nuclear Power Plant, Unit 1, Carolina 05000400
 AUTH. NAME AUTHOR AFFILIATION
 ROGERS, S. Carolina Power & Light Co.
 VANDENBURGH, C. Carolina Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Sept 1998 for Harris Nuclear
 Power Plant. With 981012 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4
 TITLE: Monthly Operating Report (per Tech Specs)

NOTES: Application for permit renewal filed.

05000400

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-1 PD	1 1	FLANDERS, S	1 1
INTERNAL:	ACRS	1 1	AEOD/SPD/RRAB	1 1
	<u>FILE CENTER 01</u>	1 1	OC/DBA/PAD	1 1
	RGN2	1 1		
EXTERNAL:	LITCO BRYCE, J H	1 1	NOAC	1 1
	NRC PDR	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTTR 10 ENCL 10

mr



Carolina Power & Light Company
Harris Nuclear Plant
PO Box 165
New Hill NC 27562

OCT 12 1998

United States Nuclear Regulatory Commission
ATTENTION: Document Control Desk
Washington, DC 20555

Serial: HNP-98-148

SHEARON HARRIS NUCLEAR POWER PLANT
DOCKET NO. 50-400/LICENSE NO. NPF-63
MONTHLY OPERATING REPORT

Dear Sir or Madam:

In accordance with Carolina Power & Light Company's Harris Nuclear Plant Technical Specification 6.9.1.5, the report of operating statistics and shutdown experience for the month of September 1998 is provided.

Sincerely,

C. A. VanDenburgh
Manager Regulatory Affairs
Harris Plant

SGR

Enclosure

c: Mr. J. B. Brady - NRC Senior Resident Inspector
Mr. S. C. Flanders - NRC Project Manager
Mr. L. A. Reyes - NRC Regional Administrator

9810160203 980930
PDR ADDCK 05000400
R PDR

CP&L CO.
RUN DATE 10/05/98
RUN TIME 12:44:00

PLANT PERFORMANCE DATA SYSTEM
OPERATING DATA REPORT
HARRIS UNIT 1

PAGE 1
RPD36-000

DOCKET NO. 050-400
COMPLETED BY SHEILA ROGERS
TELEPHONE (919)362-2573

OPERATING STATUS

1. UNIT NAME: HARRIS UNIT 1
2. REPORTING PERIOD: SEPTEMBER 98
3. LICENSED THERMAL POWER (MWT): 2775
4. NAMEPLATE RATING (GROSS MWE): 950.9
5. DESIGN ELECTRICAL RATING (NET MWE): 900.0
6. MAX DEPENDABLE CAPACITY (GROSS MWE): 920.0
7. MAX DEPENDABLE CAPACITY (NET MWE): 860.0
8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS 3 THRU 7) SINCE LAST REPORT, GIVE REASONS:

9. POWER LEVEL TO WHICH RESTRICTED IF ANY (NET MWE):
10. REASONS FOR RESTRICTION IF ANY:

	THIS MONTH	YR TO DATE	CUMUL ATIVE
11. HOURS IN REPORTING PERIOD	720.00	6551.00	100080.00
12. NUMBER OF HOURS REACTOR CRITICAL	720.00	6551.00	84860.71
13. REACTOR RESERVE SHUTDOWN HRS	.00	.00	.00
14. HOURS GENERATOR ON LINE	720.00	6551.00	84044.54
15. UNIT RESERVE SHUTDOWN HOURS	.00	.00	.00
16. GROSS THERMAL ENERGY GEN. (MWH)	1956101.94	18006821.82	225841599.00
17. GROSS ELEC. ENERGY GEN (MWH)	640567.00	5965847.00	75147651.00
18. NET ELEC. ENERGY GENERATED (MWH)	600833.00	5602536.00	70127841.00
19. UNIT SERVICE FACTOR	100.00	100.00	83.98
20. UNIT AVAILABILITY FACTOR	100.00	100.00	83.98
21. UNIT CAP. FACTOR (USING MDC NET)	97.03	99.44	81.48
22. UNIT CAP. FACTOR (USING DER NET)	92.72	95.02	77.86
23. UNIT FORCED OUTAGE RATE	.00	.00	3.14
24. SHUTDOWNS SCHED. OVER NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH):			

Plant Refueling Outage number 8 is planned to begin October 24, 1998
and is scheduled for a duration of 34 days.

25. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF START UP:
26. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION): FORECAST ACHIEVED

INITIAL CRITICALITY

INITIAL ELECTRICITY

COMMERCIAL OPERATION

Enclosure to
Serial: HNP-98-148
Sheet 2 of 3

CP&L CO.
RUN DATE 10/05/98
RUN TIME 12:43:59

PLANT PERFORMANCE DATA SYSTEM
APPENDIX B - AVERAGE DAILY POWER LEVEL
HARRIS UNIT 1

PAGE 1
RPD39-000

DOCKET NO. 050-400
COMPLETED BY SHEILA ROGERS
TELEPHONE (919) 362-2573

SEPTEMBER 1998

DAY	AVG. DAILY POWER LEVEL (MWE-NET)	DAY	AVG. DAILY POWER LEVEL (MWE-NET)
1	849	17	851
2	849	18	850
3	852	19	852
4	851	20	853
5	851	21	851
6	850	22	847
7	847	23	861
8	854	24	869
9	833	25	862
10	781	26	855
11	771	27	854
12	762	28	845
13	734	29	853
14	713	30	854
15	831		
16	851		



11/11/11

11/11/11

11/11/11

11/11/11

11/11/11

11/11/11

11/11/11

11/11/11

11/11/11

11/11/11

11/11/11

11/11/11

11/11/11

11/11/11

11/11/11

11/11/11

11/11/11

UNIT SHUTDOWNS AND POWER REDUCTION

UNIT NAME: Harris
DATE: 09/30/98
COMPLETED BY: S. G. Rogers
TELEPHONE: (919) 362-2573

REPORT MONTH: September 1998

NUMBER	DATE	TYPE 1	DURATION (HOURS)	REASON 2	METHOD OF SHUTTING DOWN REACTOR 3	LICENSEE EVENT REPORT #	SYSTEM CODE 4	COMPONENT CODE 5	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
98-003	09/10/98	F	0.0	A	5	N/A	HH	PUMPXX	Power reduced to 90% on 9/10/98 @ 03:40 due to 1A Heater Drain Pump trip. Work was performed on Feedwater Heater level control columns and plant was returned to 100% power on 9/15/98 @ 10:00.

1
F: Forced
S: Scheduled

2
Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

3
Method:
1-Manual
2-Manual Scram
3-Automatic Scram
4-Continued
5-Reduced Load
6-Other

4
Exhibit G-Instructions
for Preparation of Data
Entry Sheets for Licensee Event
Report (LER) File
(NUREG-0161)

5
Exhibit I - Same Source


