

NRC FORM 195
(2-76)

U.S. NUCLEAR REGULATORY COMMISSION

DOCKET NUMBER

50-237

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER

INCIDENT REPORT

TO:

Mr. J. G. Keppler

FROM:

Commonwealth Edison Company
Morris, Illinois
B. B. Stephenson

DATE OF DOCUMENT

7/14/77

DATE RECEIVED

8/1/77

☐ LETTER

☐ NOTORIZED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED

☒ ORIGINAL
☒ COPY

☒ UNCLASSIFIED

1 signed

DESCRIPTION

ENCLOSURE

DO NOT REMOVE

PLANT NAME:

Dresden Unit No. 2
RJL 8/2/77

ACKNOWLEDGED

(1-P)

(3-P)

Licensee Event Report (RO 50-237/77-24) on
6/30/77 concerning the 2/3 diesel tripping
during the first two attempts due to
overspeed when the unit 2/3 diesel was being
tested for operability as required by tech
specs.....

NOTE: IF PERSONNEL EXPOSURE IS INVOLVED
SEND DIRECTLY TO KREGER/J. COLLINS

1 CY ENCL Rec'd

FOR ACTION/INFORMATION

BRANCH CHIEF:

Davis

W/ 3 CYS FOR ACTION

LIC ASST.:

Diggs

INTERNAL DISTRIBUTION

REG FILE

NRC PDR

T & E (2)

MIPC

SCHROEDER/IPPOLITO

HOUSTON

NOVAK/CHECK

GRIMES

KNIGHT

BUTLER

HANAUER

TEDESCO

EISENHUT

BAER

SHAO

VOLLMER/BUNCH

KREGER/ J. COLLINS

ROSA

EXTERNAL DISTRIBUTION

CONTROL NUMBER

LPDR: Morris, J. ELL

TIC:

NSIC:

ACRS (16) SENT AS CAT. B

PO
4

772140211

1212

1212 1212 1212

1212 1212

1212 1212

1212 1212



Commonwealth Edison
Dresden Nuclear Power Station
R.R. #1
Morris, Illinois 60450
Telephone 815/942-2920

D. Lanham IE

BBS Ltr. #77-635

July 14, 1977

Mr. James G. Keppler, Regional Director
Directorate of Regulatory Operations - Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Regulatory Docket File



Enclosed please find Reportable Occurrence report number 50-237/77-24.
This report is being submitted to your office in accordance with the Dresden
Nuclear Power Station Technical Specifications, Section 6.6.B.

for Arthur M Roberts
B. B. Stephenson
Station Superintendent
Dresden Nuclear Power Station

BBS:sm

Enclosure

cc: Director of Inspection & Enforcement
Director of Management Information & Program Control
File/NRC

772140211

JUL 18 1977

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 1 1 1 1 6

[PLEASE PRINT ALL REQUIRED INFORMATION]

LICENSEE NAME														LICENSE NUMBER														LICENSE TYPE						EVENT TYPE			
01	I	L	D	R	S	2	0	0	-	0	0	0	0	0	-	0	0	4	1	1	1	1	0	1													
7	8	9				14	15										25	26						30	31	32											

CATEGORY				REPORT TYPE		REPORT SOURCE		DOCKET NUMBER								EVENT DATE						REPORT DATE					
01	CONT			T	L	0	5	0	-	0	2	3	7	0	6	3	0	7	7	0	7	1	4	7	7		
7	8			57	58	59	60	61				68	69						74	75					80		

EVENT DESCRIPTION

02	While the Unit-3 diesel generator was out of service for an annual inspection, the	80
03	unit 2/3 diesel was being tested daily for operability as required by Tech. Spec.	80
04	3.9.B.2. On 6/30/77 the 2/3 diesel tripped during the first two attempts due to	80
05	overspeed. After the injector control lever was exercised, the diesel started	80
06	successfully three consecutive times and was returned to service. The unit 2/3 diesel	80

SYSTEM CODE		CAUSE CODE		COMPONENT CODE				PRIME COMPONENT SUPPLIER		COMPONENT MANUFACTURER				VIOLATION		(continued)	
07	E	E	F	E	N	G	I	N	E	A	W	0	9	7	Y		
7	8	9	10	11	12				17	43	44			47	48		

CAUSE DESCRIPTION

08	An investigation to determine the cause of this event is in progress. A supplemental	80
09	report will be submitted when it is determined.	80
10		80

FACILITY STATUS		% POWER		OTHER STATUS				METHOD OF DISCOVERY		DISCOVERY DESCRIPTION					
11	E	0	7	4	NA				B	NA					
7	8	9	10	12	13			44	45	46				80	

FORM OF ACTIVITY RELEASED		CONTENT OF RELEASE		AMOUNT OF ACTIVITY				LOCATION OF RELEASE					
12	Z	Z	NA				NA						
7	8	9	10	11			44	45					80

PERSONNEL EXPOSURES

NUMBER			TYPE		DESCRIPTION									
13	0	0	0	Z	NA									
7	8	9	11	12	13								80	

PERSONNEL INJURIES

NUMBER			DESCRIPTION										
14	0	0	0	NA									
7	8	9	11	12									80

OFFSITE CONSEQUENCES

15	NA	80
----	----	----

LOSS OR DAMAGE TO FACILITY

TYPE		DESCRIPTION										
16	Z	NA										
7	8	9	10									80

PUBLICITY

17	NA	80
----	----	----

ADDITIONAL FACTORS

18	NA	80
----	----	----

19		80
----	--	----

NAME: Jeff Martin PHONE: Ext. 421

EVENT DESCRIPTION (continued)

had been started successfully on each of the three days prior to the failure.

The unit 2/3 diesel generator was inoperable for a relatively short period of time (25 minutes) and off site power remained available during the interval. Therefore, the safety significance of this event was minimal. (50-237/1977-24)

TO: Regional Director
Directorate of Regulatory Operations
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

DATE: 6-30-77
Telecoms Date 6-30-77
or
Telegrammed GE 6-1-30
DC _____
By _____

cc:
Director
Office of Management Information and Program Control
U.S. Nuclear Regulatory Commission
Washington, DC 20555

SUBJECT: DPR-_____, Dresden Nuclear Power Station, Unit 2.

This will confirm a conversation with Mr. Wayne Shafer of your office at 1000 hrs this date concerning 2 1/3 Diesel Generator. With #3 Diesel Generator O&S for the Annual inspection the 2 1/3 Diesel Generator was placed in run for the daily surveillance at 0320 - (6-30-77) the 2 1/3 Diesel Generator tripped on over speed. The Gov. was manually operated a number of times to free it up. At 0345 the 2 1/3 D/G was started and placed in service on bus 33-1. It was in service until 0415.

The 2 1/3 was tested started at 0535 and again at 0625.

To Call:
GE - 7-858-2660x16
DC - 9-1-301-492-7617 (auto)
WU - 815-942-4449/4321

Station Dist: Originator (copy)
Incident File (copy)
Telegram File (orig)

B. B. Stephenson, Superintendent
Dresden Nuclear Power Station
Commonwealth Edison Company
R.R. #1
Morris, IL 60450

Telephone: 815-942-2920/2921x212
(telecopy x262)

Rev. 12-75

RECEIVED DOCUMENT
PROCESSING UNIT

1977 AUG 1 AM 11 59

12-77-159