

ENCLOSURE 2

RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION (RAI) item 1.a

Safety Related MOV PM List by Component

| Component ID | Component Description         | PM Description                        | Notes | PM Frequency |
|--------------|-------------------------------|---------------------------------------|-------|--------------|
| ALHV0005     | MDAFP B TO S/G D HV           | REPLACE GASKETS AND                   |       | 4 Refuels    |
|              |                               | BRUSH INSPECTION                      |       | 4 Refuels    |
|              |                               | Lubricate Valve Stem                  | 1, 2  | 18 Months    |
|              |                               | SERVICE LIMITORQUE OPERATOR           |       | 6 Years      |
|              |                               | PERFORM MOV DIAGNOSTIC TEST           |       | 6 Years      |
|              |                               | CHANGE GREASE IN ACTUATOR ALHV0005O   |       | On Demand    |
|              |                               | Replace controller card for ALHV0005. |       | 4 Refuels    |
| ALHV0007     | MDAFP B TO S/G A HV           | REPLACE GASKETS AND                   |       | 4 Refuels    |
|              |                               | BRUSH INSPECTION                      |       | 4 Refuels    |
|              |                               | SERVICE LIMITORQUE OPERATOR           |       | 6 Years      |
|              |                               | PERFORM MOV DIAGNOSTIC TEST           |       | 6 Years      |
|              |                               | CHANGE GREASE IN ACTUATOR ALHV0007O   |       | On Demand    |
|              |                               | Replace controller card for ALHV0007. |       | 4 Refuels    |
|              |                               |                                       |       |              |
| ALHV0009     | MDAFP TO S/G B HV             | LUBRICATE VALVE STEM                  | 1, 2  | 18 Months    |
|              |                               | REPLACE GASKETS AND                   |       | 4 Refuels    |
|              |                               | BRUSH INSPECTION                      |       | 4 Refuels    |
|              |                               | TDS: SERVICE LIMITORQUE OPER.         |       | 6 Years      |
|              |                               | Periodic Verification Test            |       | 6 Years      |
|              |                               | CHANGE GREASE IN ACTUATOR ALHV0009O   |       | On Demand    |
|              |                               | Replace controller card for ALHV0009. |       | 4 Refuels    |
| ALHV0011     | MDAFP TO S/G C HV             | Replace gaskets and inspect valve     |       | 4 Refuels    |
|              |                               | BRUSH INSPECTION                      |       | 4 Refuels    |
|              |                               | TDS: SERVICE LIMITORQUE OPER.         |       | 6 Years      |
|              |                               | Periodic Verification Test            |       | 6 Years      |
|              |                               | CHANGE GREASE IN ACTUATOR ALHV0011O   |       | On Demand    |
|              |                               | Replace controller card for ALHV0011. |       | 4 Refuels    |
|              |                               |                                       |       |              |
| ALHV0030     | ESW TO MD AFP B HAND CTRL VLV | TDS: SERVICE LIMITORQUE OPERATOR      |       | 6 Years      |
|              |                               | PERIODIC VERIFICATION MOV TEST        |       | 6 Years      |
|              |                               | Overhaul Limitorque actuator          |       | On Demand    |
| ALHV0031     | ESW TO MD AFP A HAND CTRL VLV | INSPECT/SERVICE LIMITORQUE OPERATOR   |       | 6 Years      |
|              |                               | Periodic Verification Test            |       | 6 Years      |
|              |                               | CHANGE GREASE IN ACTUATOR ALHV0031O   |       | On Demand    |

Note 1: Same PM performs maintenance on multiple components

Note 2: Performance of this PM does not require a valve stroke

Safety Related MOV PM List by Component

| Component ID | Component Description                                    | PM Description                                       | Notes | PM Frequency |
|--------------|--|--|-------|--------------|
| ALHV0032     | ESW TO TD AFP HAND CTRL VLV                              | INSPECT/SERVICE LIMITORQUE OPERATOR                  |       | 6 Years      |
|              |  | PERFORM PERIODIC VERIFICATION MOV TEST               |       | 6 Years      |
|              |  | CHANGE GREASE IN ACTUATOR ALHV0032O                  |       | On Demand    |
| ALHV0033     | ESW TO TD AFP HAND CTRL VLV                              | SERVICE LIMITORQUE OPERATOR                          |       | 6 Years      |
|              |  | PERFORM MOV DIAGNOSTIC TEST                          |       | 6 Years      |
|              |  | ON-DEMAND GREASE CHANGE OUT                          |       | On Demand    |
| ALHV0034     | CST TO MD AFP B ISO HAND CTRL VLV                        | TDS: SERVICE LIMITORQUE OPERATOR                     |       | 6 Years      |
|              |  | Periodic Verification Test                           |       | 6 Years      |
|              |  | CHANGE GREASE IN ACTUATOR ALHV0034O                  |       | On Demand    |
| ALHV0035     | CST TO MD AFP A ISO HAND CTRL VLV                        | TDS: SERVICE LIMITORQUE OPERATOR                     |       | 6 Years      |
|              |  | TDS: PERIODIC VERIFICATION MOV TEST                  |       | 6 Years      |
|              |  | CHANGE GREASE IN ACTUATOR ALHV0035O                  |       | On Demand    |
| ALHV0036     | CST TO TD AFP HV   | ALHV0036 (Train T) stem lubrication                  | 2     | 18 Months    |
|              |  | SERVICE LIMITORQUE OPERATOR                          |       | 6 Years      |
|              |  | INSPECT/SERVICE TDS: PERIODIC VERIFICATION MOV TEST  |       | 6 Years      |
|              |  | CHANGE GREASE IN ACTUATOR ALHV0036O                  |       | On Demand    |
| BBHV0013     | RCP A THRM BAR COOL COIL COOL WTR OUT HV                 | LUBE BBHV0013 AND OTHER VALVE STEM THREADS (A Train) | 1,2   | 72 Weeks     |
|              |  | SERVICE LIMITORQUE OPERATOR BBHV0013O                |       | 4 Refuels    |
|              |  | LIMITORQUE GREASE INSPECTIONS, Rx BLDG "A" TRAIN     | 1,2   | 18 Months    |
|              |  | PERIODIC VERIFICATION MOV TEST ON BBHV0013           |       | 4 Refuels    |
|              |  | CHANGE GREASE IN ACTUATOR BBHV0013O                  |       | On Demand    |
| BBHV0014     | RCP B THRM BAR COOL COIL COOL WTR OUT HAND CTRL VLV OPER | SERVICE LIMITORQUE OPERATOR BBHV0014                 |       | 4 Refuels    |
|              |  | PERIODIC VERIFICATION MOV TEST BBHV0014              |       | 4 Refuels    |
|              |  | CHANGE GREASE IN ACTUATOR BBHV0014O                  |       | On Demand    |

Note 1: Same PM performs maintenance on multiple components

Note 2: Performance of this PM does not require a valve stroke

Safety Related MOV PM List by Component

| Component ID | Component Description                                     | PM Description  | Notes | PM Frequency |
|--------------|---|---|-------|--------------|
| BBHV0015     | RCP C THRM BAR COOL<br>COIL COOL WTR OUT<br>HAND CTRL VLV | SERVICE LIMITORQUE<br>OPERATOR BBHV0015O                                  |       | 4 Refuels    |
|              |   | PERIODIC VERIFICATION MOV<br>TEST BBHV0015                                |       | 4 Refuels    |
|              |   | CHANGE GREASE IN ACTUATOR<br>BBHV0015O                                    |       | On Demand    |
| BBHV0016     | RCP D THRM BAR COOL<br>COIL COOL WTR OUT<br>HAND CTRL VLV | SERVICE LIMITORQUE<br>OPERATOR BBHV0016O                                  |       | 4 Refuels    |
|              |   | PERIODIC VERIFICATION MOV<br>TEST BBHV0016                                |       | 4 Refuels    |
|              |   | CHANGE GREASE IN MOV<br>ACTUATOR BBHV0016O                                |       | On Demand    |
| BBHV8000A    | RCS PZR OUT PORV HND<br>CTRL VLV                          | SERVICE LIMITORQUE<br>OPERATORINSPECT/SERVICE                             |       | 4 Refuels    |
|              |   | PERFORM MOV PERIODIC<br>DIAGNOSTIC TEST                                   |       | 4 Refuels    |
|              |   | CHANGE GREASE IN ACTUATOR<br>BBHV8000AO                                   |       | On Demand    |
| BBHV8000B    | RCS PZR OUT PORV HND<br>CTRL VLV                          | TDS: SERVICE LIMITORQUE<br>OPERATOR                                       |       | 4 Refuels    |
|              |   | CAR 201205543 LIMITORQUE<br>GREASE INSPECTIONS,<br>REACTOR BLDG "B" TRAIN | 1, 2  | 18 Months    |
|              |   | Periodic Verification Test  |       | 4 Refuels    |
|              |   | CHANGE GREASE IN MOV<br>ACTUATOR BBHV8000BO                               |       | On Demand    |
| BBHV8037A    | RCS PRT OUT TO CTMT<br>NORM SMP ISO HV                    | LUBE VALVE STEM THREADS   | 1, 2  | 72 Weeks     |
|              |   | TDS: SERVICE LIMITORQUE<br>OPERATOR                                       |       | 4 Refuels    |
|              |   | TDS: PERIODIC VERIFICATION<br>MOV TEST                                    |       | 4 Refuels    |
|              |   | CHANGE GREASE IN MOV<br>ACTUATOR BBHV8037AO                               |       | On Demand    |
| BBHV8037B    | RCS PRT OUT TO CTMT<br>NORM SMP ISO HV                    | Lubricate stem threads  | 2     | 72 Weeks     |
|              |   | SERVICE LIMITORQUE<br>OPERATOR  |       | 4 Refuels    |
|              |   | PERFORM MOV DIAGNOSTIC<br>TESTING   |       | 4 Refuels    |
|              |   | CHANGE GREASE IN MOV<br>ACTUATOR BBHV8037BO                               |       | On Demand    |

Note 1: Same PM performs maintenance on multiple components

Note 2: Performance of this PM does not require a valve stroke

Safety Related MOV PM List by Component

| Component ID | Component Description                  | PM Description  | Notes | PM Frequency |
|--------------|--|---|-------|--------------|
| BBHV8351A    | RCP A SEAL WTR SPLY ISO HV             | CAR 201205543 LIMITORQUE GREASE INSPECTIONS, AUX BLDG "B" TRAIN | 2     | 18 Months    |
|              |  | TDS: SERVICE LIMITORQUE OPERATOR                                |       | 4 Refuels    |
|              |  | PERFORM PERIODIC VERIFICATION MOV TEST                          |       | 4 Refuels    |
|              |  | CHANGE GREASE IN MOV ACTUATOR BBHV8351AO                        |       | On Demand    |
| BBHV8351B    | RCP B SEAL WATER SUPPLY HAND CTRL VLV  | SERVICE LIMITORQUE OPERATORINSPECT/SERVICE LIMITORQUE OPERATOR  |       | 4 Refuels    |
|              |  | Periodic Verification Test                                      |       | 4 Refuels    |
|              |  | CHANGE GREASE IN MOV ACTUATOR BBHV8351BO                        |       | On Demand    |
| BBHV8351C    | RCP C SEAL WATER SUPPLY HAND CTRL VLV  | SERVICE LIMITORQUE OPERATORINSPECT/SERVICE LIMITORQUE OPERATOR  |       | 4 Refuels    |
|              |  | Periodic Verification Test                                      |       | 4 Refuels    |
|              |  | CHANGE GREASE IN MOV ACTUATOR BBHV8351CO                        |       | On Demand    |
| BBHV8351D    | RCP D SEAL WATER SUPPLY HAND CTRL VLV  | TDS: SERVICE LIMITORQUE OPERATOR                                |       | 4 Refuels    |
|              |  | TDS: PERIODIC VERIFICATION MOV TEST                             |       | 4 Refuels    |
|              |  | CHANGE GREASE IN MOV ACTUATOR BBHV8351DO                        |       | On Demand    |
| BBPV8702A    | RCS LOOP 1 HOT LEG TO RHR PMPS PCV ISO | LUBE VALVE STEM & INSP GEARBOX GREASE                           | 2     | Every Refuel |
|              |  | SERVICE LIMITORQUE OPERATOR BBPV8702AO                          |       | 4 Refuels    |
|              |  | PERIODIC VERIFICATION MOV TEST BBPV8702A                        |       | 4 Refuels    |
|              |  | CHANGE GREASE IN ACTUATOR BBPV8702AO                            |       | On Demand    |

Note 1: Same PM performs maintenance on multiple components

Note 2: Performance of this PM does not require a valve stroke

Safety Related MOV PM List by Component

| Component ID | Component Description                            | PM Description                          | Notes | PM Frequency |
|--------------|--|---|-------|--------------|
| BBPV8702B    | RCS LOOP 4 HOT LEG TO RHR PMPS PCV ISO           | LUBE VALVE STEM & INSP GEARBOX GREASE   | 2     | Every Refuel |
|              |  | SERVICE LIMITORQUE OPERATOR             |       | 4 Refuels    |
|              |  | TDS: PERIODIC VERIFICATION MOV TEST     |       | 4 Refuels    |
|              |  | CHANGE GREASE IN ACTUATOR BBPV8702BO    |       | On Demand    |
| BGHV8100     | SEAL WTR RTN OUTER CTMT ISO                      | LUBE CTMT ISO VALVE STEM THREADS        | 2     | Every Refuel |
|              |  | SERVICE LIMITORQUE OPERATOR             |       | 4 Refuels    |
|              |  | TDS: PERIODIC VERIFICATION MOV TEST     |       | 4 Refuels    |
|              |  | CHANGE GREASE IN MOV ACTUATOR BGHV8100O |       | On Demand    |
| BGHV8104     | EMERG BORATE TO CCP A & B HDR ISO HV             | LUBE VALVE STEM THREADS                 | 2     | 18 Months    |
|              |  | TDS: SERVICE LIMITORQUE OPERATOR        |       | 6 Years      |
|              |  | TDS: PERIODIC VERIFICATION MOV TEST     |       | 6 Years      |
|              |  | CHANGE GREASE IN MOV ACTUATOR BGHV8104O |       | On Demand    |
| BGHV8105     | CVCS CHARGING HDR TO REGEN HX OUTER CTMT ISO VLV | LUBE CTMT ISO VALVE STEM THREADS        | 2     | Every Refuel |
|              |  | SERVICE LIMITORQUE OPERATOR             |       | 4 Refuels    |
|              |  | TDS: PERIODIC VERIFICATION MOV TEST     |       | 4 Refuels    |
|              |  | CHANGE GREASE IN MOV ACTUATOR BGHV8105O |       | On Demand    |
| BGHV8106     | CVCS CHARGING HDR TO REGEN HX OUTER CTMT ISO VLV | LUBE VALVE STEM THREADS                 | 2     | Every Refuel |
|              |  | SERVICE LIMITORQUE OPERATOR             |       | 4 Refuels    |
|              |  | Periodic Verification Test              |       | 4 Refuels    |
|              |  | CHANGE GREASE IN MOV ACTUATOR BGHV8106O |       | On Demand    |

Note 1: Same PM performs maintenance on multiple components

Note 2: Performance of this PM does not require a valve stroke

Safety Related MOV PM List by Component

| Component ID | Component Description                      | PM Description   | Notes | PM Frequency |
|--------------|--|--|-------|--------------|
| BGHV8109     | CVCS NCP RECIRC HV                         | Replace valve disc and inspect body internals.                               |       | 8 Years      |
|              |  | Lubricate stem threads   | 2     | 18 Months    |
|              |  | TDS: SERVICE LIMITORQUE OPERATOR   |       | 6 Years      |
|              |  | PERIODIC VERIFICATION MOV TEST PERIODIC VERIFICATION MOV TEST AS REQUIRED BY |       | 6 Years      |
|              |  | CHANGE GREASE IN MOV ACTUATOR BGHV8109O                                      |       | On Demand    |
| BGHV8110     | A CCP DISCH MINIFLOW TO SEAL WTR HX ISO    | LUBE VALVE STEM THREADS  | 2     | 18 Months    |
|              |  | TDS: SERVICE LIMITORQUE OPERATOR   |       | 6 Years      |
|              |  | TDS: PERIODIC VERIFICATION MOV TEST  |       | 6 Years      |
|              |  | CHANGE GREASE IN MOV ACTUATOR BGHV8110O                                      |       | On Demand    |
| BGHV8111     | CCP B DISCH MINIFLOW ISO VLV               | LUBE VALVE STEM THREADS  | 2     | 18 Months    |
|              |  | SERVICE LIMITORQUE OPERATOR  |       | 6 Years      |
|              |  | PERFORM MOV DIAGNOSTIC TEST  |       | 6 Years      |
|              |  | CHANGE GREASE IN MOV ACTUATOR BGHV8111O                                      |       | On Demand    |
| BGHV8112     | SEAL WTR RTN INNER CTMT ISO HV             | LUBE VALVE STEM THREADS  | 2     | Every Refuel |
|              |  | SERVICE LIMITORQUE OPERATOR  |       | 6 Refuels    |
|              |  | Periodic Verification Test   |       | 4 Refuels    |
|              |  | CHANGE GREASE IN MOV ACTUATOR BGHV8112O                                      |       | On Demand    |
| BGHV8357A    | CVCS CCP A DISCH TO RCP SEALS THROTTLE VLV | LUBE VALVE STEM THREADS  | 2     | 18 Months    |
|              |  | SERVICE LIMITORQUE OPERATOR  |       | 6 Years      |
|              |  | PERFORM MOV DIAGNOSTIC TEST  |       | 6 Years      |
|              |  | CHANGE GREASE IN MOV ACTUATOR BGHV8357AO                                     |       | On Demand    |

Note 1: Same PM performs maintenance on multiple components

Note 2: Performance of this PM does not require a valve stroke

Safety Related MOV PM List by Component

| Component ID | Component Description                   | PM Description                             | Notes | PM Frequency |
|--------------|---|--|-------|--------------|
| BGHV8357B    | CVCS CCP B DISCH TO RCP SEALS THROT VLV | LUBE VALVE STEM THREADS                    | 2     | 18 Months    |
|              |   | SERVICE LIMITORQUE OPER                    |       | 6 Years      |
|              |   | PERIODIC VERIFIC. MOV TEST BGHV8357        |       | 6 Years      |
|              |   | CHANGE GREASE IN MOV ACTUATOR BGHV8357BO   |       | On Demand    |
| BGLCV0112B   | CVCS VCT OUT UPSTRM ISO                 | LUBE VALVE STEM THREADS                    | 2     | Every Refuel |
|              |   | SERVICE LIMITORQUE OPERATORINSPECT/SERVICE |       | 4 Refuels    |
|              |   | Periodic Verification Test                 |       | 4 Refuels    |
|              |   | CHANGE GREASE IN MOV ACTUATOR BGLCV0112BO  |       | On Demand    |
| BGLCV0112C   | CVCS VCT OUT DNSTRM ISO                 | LUBE VALVE STEM THREADS                    | 2     | Every Refuel |
|              |   | SERVICE LIMITORQUE OPERATOR                |       | 4 Refuels    |
|              |   | Periodic Verification Test                 |       | 4 Refuels    |
|              |   | CHANGE GREASE IN MOV ACTUATOR BGLCV0112CO  |       | On Demand    |
| BNHV0003     | RWST TO CTMT SPRY PMP B HV              | LUBE VALVE STEM THREADS                    | 2     | 18 Months    |
|              |   | SERVICE LIMITORQUE OPERATOR                |       | 6 Years      |
|              |   | INSPECT/REPLACE T&B CONNECTORS             |       | 28 Years     |
|              |   | Periodic Verification Test                 |       | 6 Years      |
|              |   | CHANGE GREASE IN MOV ACTUATOR BNHV0003O    |       | On Demand    |

Note 1: Same PM performs maintenance on multiple components

Note 2: Performance of this PM does not require a valve stroke



Safety Related MOV PM List by Component

| Component ID | Component Description              | PM Description                                   | Notes | PM Frequency |
|--------------|------------------------------------|--|-------|--------------|
| BNHV0004     | RWST TO CTMT SPRY PMP A HV         | LUBE VALVE STEM THREADS                          | 2     | 18 Months    |
|              |                                    | SERVICE LIMITORQUE OPERATOR                      |       | 6 Years      |
|              |                                    | INSPECT/REPLACE T&B CONNECTORS                   |       | 28 Years     |
|              |                                    | TDS: PERIODIC VERIFICATION MOV TEST              |       | 6 Years      |
|              |                                    | CHANGE GREASE IN MOV ACTUATOR BNHV0004O          |       | On Demand    |
| BNHV8806A    | SI PMP A SUCT FROM RWST ISO        | LUBE VALVE STEM THREADS                          | 2     | 18 Months    |
|              |                                    | SERVICE LIMITORQUE OPER.                         |       | 6 Years      |
|              |                                    | TDS: PERIODIC VERIFICATION MOV TEST              |       | 6 Years      |
|              |                                    | CHANGE GREASE IN ACTUATOR BNHV8806AO             |       | On Demand    |
| BNHV8806B    | RWST TO SI PMPS HAND CTRL VLV OPER | TDS: SERVICE LIMITORQUE OPERATOR                 |       | 6 Years      |
|              |                                    | LUBE VALVE STEM THREADS                          | 2     | 18 Months    |
|              |                                    | Periodic Verification Test                       |       | 6 Years      |
|              |                                    | CHANGE GREASE IN MOV ACTUATOR BNHV8806BO         |       | On Demand    |
| BNHV8812A    | RWST TO RHR PMP A SUCT ISO VLV     | LIMITORQUE GREASE INSPECTIONS A-TRAIN Non-Outage | 2     | 18 Months    |
|              |                                    | LUBE VALVE STEM THREADS                          | 2     | 18 Months    |
|              |                                    | SERVICE LIMITORQUE OPERATOR                      |       | 6 Years      |
|              |                                    | Periodic Verification Test                       |       | 6 Years      |
|              |                                    | CHANGE GREASE IN ACTUATOR BNHV8812AO             |       | On Demand    |

Note 1: Same PM performs maintenance on multiple components

Note 2: Performance of this PM does not require a valve stroke

Safety Related MOV PM List by Component

| Component ID | Component Description                                  | PM Description                               | Notes | PM Frequency |
|--------------|--|--|-------|--------------|
| BNHV8812B    | RWST TO RHR PMP B<br>SUCT ISO VLV                      | LUBE VALVE STEM THREADS                      | 2     | 18 Months    |
|              |  | TDS: SERVICE LIMITORQUE<br>OPERATOR          |       | 6 Years      |
|              |  | TDS: PERIODIC VERIFICATION<br>MOV TEST       |       | 6 Years      |
|              |  | CHANGE OUT GREASE IN SB-1<br>ACTUATOR. 89-10 |       | On Demand    |
| BNHV8813     | SI PMPS MINIFLOW TO<br>RWST ISO VLV (3.0.3)            | LUBE VALVE STEM THREADS                      | 2     | 18 Months    |
|              |  | SERVICE LIMITORQUE<br>OPERATOR               |       | 4 Refuels    |
|              |  | Periodic Verification Test                   |       | 4 Refuels    |
|              |  | CHANGE GREASE IN ACTUATOR<br>BNHV8813O       |       | On Demand    |
| BNLCV0112D   | CCP A SUCT FROM RWST<br>ISO VLV                        | LUBE VALVE STEM THREADS                      | 2     | 18 Months    |
|              |  | SERVICE LIMITORQUE<br>OPERATOR               |       | 6 Years      |
|              |  | TDS: PERIODIC VERIFICATION<br>MOV TEST       |       | 6 Years      |
|              |  | CHANGE GREASE IN MOV<br>ACTUATOR BNLCV0112DO |       | On Demand    |
| BNLCV0112E   | CCP B SUCT FROM RWST<br>ISO VLV                        | LUBE VALVE STEM THREADS                      | 2     | 18 Months    |
|              |  | SERVICE LIMITORQUE<br>OPERATOR               |       | 6 Years      |
|              |  | PERFORM MOV DIAGNOSTIC<br>TEST               |       | 6 Years      |
|              |  | CHANGE GREASE IN MOV<br>ACTUATOR BNLCV0112EO |       | On Demand    |
| ECHV0011     | FUEL POOL COOLING HX A<br>SHELL SIDE CCW OUTLET<br>ISO | TDS: SERVICE LIMITORQUE<br>OPERATOR          |       | 6 Years      |
|              |  | TDS: PERIODIC VERIFICATION<br>MOV TEST       |       | 6 Years      |
|              |  | CHANGE GREASE IN ACTUATOR<br>ECHV0011O       |       | On Demand    |
| ECHV0012     | FUEL POOL COOLING HX B<br>SHELL SIDE CCW OUTLET<br>ISO | SERVICE LIMITORQUE<br>OPERATOR               |       | 6 Years      |
|              |  | Periodic Verification Test                   |       | 6 Years      |
|              |  | CHANGE GREASE IN ACTUATOR<br>ECHV0012O       |       | On Demand    |

Note 1: Same PM performs maintenance on multiple components

Note 2: Performance of this PM does not require a valve stroke

Safety Related MOV PM List by Component

| Component ID | Component Description                                     | PM Description                             | Notes | PM Frequency |
|--------------|---|--|-------|--------------|
| EFHV0023     | SERV WTR TO ESW TRN A<br>UPSTRM HV                        | LEAK CHECK ESW-SW X-<br>CONNECTS 'A' TRAIN |       | 18 Months    |
|              |   | SERVICE LIMITORQUE<br>OPERATOR             |       | 6 Years      |
|              |   | PERFORM MOV DIAGNOSTIC<br>TEST             |       | 6 Years      |
|              |   | CHANGE GREASE IN ACTUATOR<br>EFHV0023O     |       | On Demand    |
| EFHV0024     | SERV WTR TO ESW TRN B<br>UPSTRM HV                        | LEAK CHECK ESW-SW X-<br>CONNECTS 'B' TRAIN |       | 18 Months    |
|              |   | SERVICE LIMITORQUE<br>OPERATOR EFHV0024    |       | 6 Years      |
|              |   | PERIODIC VERIFICATION MOV<br>TEST EFHV0024 |       | 6 Years      |
|              |   | CHANGE GREASE IN ACTUATOR<br>EFHV0024O     |       | On Demand    |
| EFHV0025     | SERV WTR/ESW TRN A<br>XCONN HAND CTRL VLV                 | SERVICE LIMITORQUE<br>OPERATOR             |       | 6 Years      |
|              |   | PERFORM MOV DIAGNOSTIC<br>TEST             |       | 6 Years      |
|              |   | CHANGE GREASE IN ACTUATOR<br>EFHV0025O     |       | On Demand    |
| EFHV0026     | SERV WTR TO ESW TRN B<br>DNSTRM HV                        | STROKE TEST OF EFHV0026                    |       | 18 Months    |
|              |   | SERVICE LIMITORQUE<br>OPERATOR             |       | 6 Years      |
|              |   | PERFORM MOV DIAGNOSTIC<br>TEST             |       | 6 Years      |
|              |   | CHANGE GREASE IN ACTUATOR<br>EFHV0026O     |       | On Demand    |
| EFHV0031     | ESW TRN A TO CTMT AIR<br>CLRS OUTER CTMT HAND<br>CTRL VLV | SERVICE LIMITORQUE OPER                    |       | 4 Refuels    |
|              |   | Periodic Verification Test                 |       | 4 Refuels    |
|              |   | ON-DEMAND GREASE CHANGE<br>OUT             |       | On Demand    |
|              |   |  |       |              |

Note 1: Same PM performs maintenance on multiple components

Note 2: Performance of this PM does not require a valve stroke

Safety Related MOV PM List by Component

| Component ID | Component Description                               | PM Description                          | Notes | PM Frequency |
|--------------|---|---|-------|--------------|
| EFHV0032     | ESW TRN B TO CTMT AIR CLRS OUTER CTMT HV            | TDS: PERIODIC VERIFICATION MOV TEST     |       | 4 Refuels    |
|              |   | TDS: SERVICE LIMITORQUE OPER            |       | 4 Refuels    |
|              |   | CHANGE GREASE IN MOV ACTUATOR EFHV0032O |       | On Demand    |
| EFHV0033     | ESW TRN A TO CTMT AIR CLRS INNER CTMT HAND CTRL VLV | SERVICE LIMITORQUE OPER                 |       | 4 Refuels    |
|              |   | Periodic Verification Test              |       | 4 Refuels    |
|              |   | CHANGE GREASE IN MOV ACTUATOR EFHV0033O |       | On Demand    |
| EFHV0034     | ESW TRN B TO CTMT AIR CLRS INNER CTMT HAND CTRL VLV | TDS: SERVICE LIMITORQUE OPER            |       | 4 Refuels    |
|              |   | TDS: PERIODIC VERIFICATION MOV TEST     |       | 4 Refuels    |
|              |   | CHANGE GREASE IN MOV ACTUATOR EFHV0034O |       | On Demand    |
| EFHV0037     | ESW TRN A TO UHS HV                                 | T-Ring Replacement                      |       | 6 Refuels    |
|              |   | TDS: SERVICE LIMITORQUE OPERATOR        |       | 6 Years      |
|              |   | TDS: PERIODIC VERIFICATION MOV TEST     |       | 6 Years      |
|              |   | CHANGE GREASE IN MOV ACTUATOR EFHV0037O |       | On Demand    |
| EFHV0038     | ESW TRN B TO UHS HV                                 | STROKE TEST OF EFHV0038                 |       | 18 Months    |
|              |   | T-Ring Replacement                      |       | 6 Refuels    |
|              |   | SERVICE LIMITORQUE OPERATOR             |       | 6 Years      |
|              |   | TDS: PERIODIC VERIFICATION MOV TEST     |       | 6 Years      |
|              |   | CHANGE GREASE IN MOV ACTUATOR EFHV0038O |       | On Demand    |
| EFHV0039     | ESW TRN A TO SERV WTR UPSTRM HAND CTRL VLV          | SERVICE LIMITORQUE OPERATOR             |       | 6 Years      |
|              |   | PERFORM MOV DIAGNOSTIC TEST             |       | 6 Years      |
|              |   | CHANGE GREASE IN MOV ACTUATOR EFHV0039O |       | On Demand    |

Note 1: Same PM performs maintenance on multiple components

Note 2: Performance of this PM does not require a valve stroke

Safety Related MOV PM List by Component

| Component ID | Component Description                                       | PM Description   | Notes | PM Frequency |
|--------------|---|--|-------|--------------|
| EFHV0040     | ESW TRN B TO SERV WTR<br>UPSTRM HAND CTRL VLV               | SERVICE LIMITORQUE<br>OPERATOR                                       |       | 6 Years      |
|              |   | PERFORM MOV DIAGNOSTIC<br>TEST                                       |       | 6 Years      |
|              |   | CHANGE GREASE IN MOV<br>ACTUATOR EFHV0040O                           |       | On Demand    |
| EFHV0041     | ESW TRN A TO SERV WTR<br>DNSTRM HAND CTRL VLV               | SERVICE LIMITORQUE<br>OPERATOR                                       |       | 6 Years      |
|              |   | PERFORM MOV DIAGNOSTIC<br>TEST                                       |       | 6 Years      |
|              |   | CHANGE GREASE IN MOV<br>ACTUATOR EFHV0041O                           |       | On Demand    |
| EFHV0042     | ESW TRN B TO SERV WTR<br>DNSTRM HAND CTRL VLV               | SERVICE LIMITORQUE<br>OPERATORINSPECT/SERVICE<br>LIMITORQUE OPERATOR |       | 6 Years      |
|              |   | Periodic Verification Test   |       | 6 Years      |
|              |   | CHANGE GREASE IN MOV<br>ACTUATOR EFHV0042O                           |       | On Demand    |
| EFHV0045     | ESW TRN A FROM CTMT<br>AIR CLRS INNER CTMT<br>HAND CTRL VLV | SERVICE LIMITORQUE OPER  |       | 4 Refuels    |
|              |   | Periodic Verification Test   |       | 4 Refuels    |
|              |   | CHANGE GREASE IN MOV<br>ACTUATOR EFHV0045O                           |       | On Demand    |
| EFHV0046     | ESW TRN B FROM CTMT<br>AIR CLRS INNER CTMT<br>HAND CTRL VLV | TDS: SERVICE LIMITORQUE<br>OPER                                      |       | 4 Refuels    |
|              |   | TDS: PERIODIC VERIFICATION<br>MOV TEST                               |       | 4 Refuels    |
|              |   | CHANGE GREASE IN MOV<br>ACTUATOR EFHV0046O                           |       | On Demand    |
| EFHV0047     | ESW TRN A FROM CTMT<br>AIR CLRS BYP ISO HAND<br>CTRL VLV    | SERVICE LIMITORQUE OPER  |       | 4 Refuels    |
|              |   | Periodic Verification Test   |       | 4 Refuels    |
|              |   | CHANGE GREASE IN MOV<br>ACTUATOR EFHV0047O                           |       | On Demand    |

Note 1: Same PM performs maintenance on multiple components

Note 2: Performance of this PM does not require a valve stroke

Safety Related MOV PM List by Component

| Component ID | Component Description                                       | PM Description                             | Notes | PM Frequency |
|--------------|---|--|-------|--------------|
| EFHV0048     | ESW TRN B FROM CTMT<br>AIR CLRS BYP ISO HAND<br>CTRL VLV    | SERVICE LIMITORQUE OPER                    |       | 4 Refuels    |
|              |   | TDS: PERIODIC VERIFICATION<br>MOV TEST     |       | 4 Refuels    |
|              |   | CHANGE GREASE IN MOV<br>ACTUATOR EFHV0048O |       | On Demand    |
| EFHV0049     | ESW TRN A FROM CTMT<br>AIR CLRS OUTER CTMT<br>HAND CTRL VLV | SERVICE LIMITORQUE<br>OPERATOR             |       | 4 Refuels    |
|              |   | PERIODIC VERIFICATION MOV<br>TEST          |       | 4 Refuels    |
|              |   | CHANGE GREASE IN MOV<br>ACTUATOR EFHV0049O |       | On Demand    |
| EFHV0050     | ESW TRN B FROM CTMT<br>AIR CLRS OUTER CTMT<br>HAND CTRL VLV | SERVICE LIMITORQUE<br>OPERATOR             |       | 4 Refuels    |
|              |   | TDS: PERIODIC VERIFICATION<br>MOV TEST     |       | 4 Refuels    |
|              |   | CHANGE GREASE IN MOV<br>ACTUATOR EFHV0050O |       | On Demand    |
| EFHV0051     | ESW TRN A TO CCW HX A<br>HAND CTRL VLV                      | SERVICE LIMITORQUE<br>OPERATOR EFHV0051    |       | 6 Years      |
|              |   | Periodic Verification Test                 |       | 6 Years      |
|              |   | CHANGE GREASE IN MOV<br>ACTUATOR EFHV0051O |       | On Demand    |
| EFHV0052     | ESW TRN B TO CCW HX B<br>HAND CTRL VLV                      | TDS: SERVICE LIMITORQUE<br>OPER            |       | 6 Years      |
|              |   | PERIODIC VERIFICATION MOV<br>TEST          |       | 6 Years      |
|              |   | CHANGE GREASE IN MOV<br>ACTUATOR EFHV0052O |       | On Demand    |
| EFHV0059     | ESW TRN A FROM CCW<br>HX A HAND CTRL VLV                    | SERVICE LIMITORQUE OPER                    |       | 6 Years      |
|              |   | TDS: PERIODIC VERIFICATION<br>MOV TEST     |       | 6 Years      |
|              |   | CHANGE GREASE IN MOV<br>ACTUATOR EFHV0059O |       | On Demand    |
| EFHV0060     | ESW TRN B FROM CCW<br>HX B HAND CTRL VLV                    | SERVICE LIMITORQUE OPER.                   |       | 6 Years      |
|              |   | TDS: PERIODIC VERIFICATION<br>MOV TEST     |       | 6 Years      |
|              |   | CHANGE GREASE IN MOV<br>ACTUATOR EFHV0060O |       | On Demand    |

Note 1: Same PM performs maintenance on multiple components

Note 2: Performance of this PM does not require a valve stroke

Safety Related MOV PM List by Component

| Component ID | Component Description                            | PM Description                             | Notes | PM Frequency |
|--------------|--|--|-------|--------------|
| EFHV0065     | ESW UHS COOL TOWER<br>TRN A BYP HAND CTRL<br>VLV | TDS: SERVICE LIMITORQUE<br>OPERATOR        |       | 6 Years      |
|              |  | TDS: PERIODIC VERIFICATION<br>MOV TEST     |       | 6 Years      |
|              |  | CHANGE GREASE IN MOV<br>ACTUATOR EFHV0065O |       | On Demand    |
| EFHV0066     | ESW UHS COOL TOWER<br>TRN B BYP HAND CTRL<br>VLV | TDS: SERVICE LIMITORQUE<br>OPERATOR        |       | 6 Years      |
|              |  | PERIODIC VERIFICATION MOV<br>TEST          |       | 6 Years      |
|              |  | CHANGE GREASE IN MOV<br>ACTUATOR EFHV0066O |       | On Demand    |
| EFHV0097     | ESW PMP A DISCH<br>RECIRC HV                     | LUBE VALVE STEM THREADS                    | 2     | 18 Months    |
|              |  | TDS: SERVICE LIMITORQUE<br>OPER            |       | 6 Years      |
|              |  | TDS: PERIODIC VERIFICATION<br>MOV TEST     |       | 6 Years      |
|              |  | CHANGE GREASE IN ACTUATOR<br>EFHV0097O     |       | On Demand    |
| EFHV0098     | ESW PMP B DISCH<br>RECIRC HV                     | LUBE VALVE STEM THREADS                    | 2     | 18 Months    |
|              |  | TDS: SERVICE LIMITORQUE<br>OPER            |       | 6 Years      |
|              |  | TDS: PERIODIC VERIFICATION<br>MOV TEST     |       | 6 Years      |
|              |  | CHANGE GREASE IN ACTUATOR<br>EFHV0098O     |       | On Demand    |
| EFPDV0019    | ESW S-C STR A DRN DP<br>CTRL VLV                 | LUBE VALVE STEM THREADS                    | 2     | 18 Months    |
|              |  | SERVICE LIMITORQUE<br>OPERATOR             |       | 6 Years      |
|              |  | TDS: PERIODIC VERIFICATION<br>MOV TEST     |       | 6 Years      |
|              |  | CHANGE GREASE IN ACTUATOR<br>EFPDV0019O    |       | On Demand    |
| EFPDV0020    | ESW S-C STR B DRN DP<br>CTRL VLV                 | LUBE VALVE STEM THREADS                    | 2     | 18 Months    |
|              |  | SERVICE LIMITORQUE<br>OPERATOR             |       | 6 Years      |
|              |  | PERIODIC VERIFICATION MOV<br>TEST          |       | 6 Years      |
|              |  | CHANGE GREASE IN ACTUATOR<br>EFPDV0020O    |       | On Demand    |

Note 1: Same PM performs maintenance on multiple components

Note 2: Performance of this PM does not require a valve stroke

Safety Related MOV PM List by Component

| Component ID | Component Description                    | PM Description                             | Notes | PM Frequency |
|--------------|--|--|-------|--------------|
| EGHV0011     | ESW TO CCW TRN A<br>UPSTRM HV            | LUBE VALVE STEM THREADS                    | 1, 2  | 18 Months    |
|              |  | TDS: SERVICE LIMITORQUE<br>OPER            |       | 6 Years      |
|              |  | TDS: PERIODIC VERIFICATION<br>MOV TEST     |       | 6 Years      |
|              |  | CHANGE GREASE IN MOV<br>ACTUATOR EGHV0011O |       | On Demand    |
| EGHV0012     | ESW TO CCW TRN B<br>UPSTRM HV            | LUBE VALVE STEM THREADS                    | 1, 2  | 18 Months    |
|              |  | SERVICE LIMITORQUE<br>OPERATOR             |       | 6 Years      |
|              |  | PERFORM MOV DIAGNOSTIC<br>TEST             |       | 6 Years      |
|              |  | CHANGE GREASE IN MOV<br>ACTUATOR EGHV0012O |       | On Demand    |
| EGHV0013     | ESW TO CCW TRN A<br>DNSTRM HAND CTRL VLV | TDS: SERVICE LIMITORQUE<br>OPER            |       | 6 Years      |
|              |  | TDS: PERIODIC VERIFICATION<br>MOV TEST     |       | 6 Years      |
|              |  | CHANGE GREASE IN MOV<br>ACTUATOR EGHV0013O |       | On Demand    |
| EGHV0014     | ESW TO CCW TRN B<br>DNSTRM HAND CTRL VLV | SERVICE LIMITORQUE<br>OPERATOR             |       | 6 Years      |
|              |  | PERFORM MOV DIAGNOSTIC<br>TEST             |       | 6 Years      |
|              |  | CHANGE GREASE IN MOV<br>ACTUATOR EGHV0014O |       | On Demand    |
| EGHV0015     | CCW TRN A SPLY/RTN ISO<br>HV             | T-Ring Replacement                         |       | 6 Refuels    |
|              |  | TDS: SERVICE LIMITORQUE<br>OPER            |       | 6 Years      |
|              |  | PERFORM MOV DIAGNOSTIC<br>TEST             |       | 6 Years      |
|              |  | CHANGE GREASE IN MOV<br>ACTUATOR EGHV0015O |       | On Demand    |

Note 1: Same PM performs maintenance on multiple components

Note 2: Performance of this PM does not require a valve stroke



Safety Related MOV PM List by Component

| Component ID | Component Description       | PM Description                          | Notes | PM Frequency |
|--------------|-----------------------------|---|-------|--------------|
| EGHV0016     | CCW TRN B SPLY/RTN ISO HV   | T-Ring Replacement                      |       | 6 Refuels    |
|              |                             | SERVICE LIMITORQUE OPER                 |       | 6 Years      |
|              |                             | TDS: PERIODIC VERIFICATION MOV TEST     |       | 6 Years      |
|              |                             | CHANGE GREASE IN MOV ACTUATOR EGHV0016O |       | On Demand    |
| EGHV0053     | CCW TRN A SPLY ISO HV       | T-Ring Replacement                      |       | 6 Refuels    |
|              |                             | TDS: SERVICE LIMITORQUE OPERATOR        |       | 6 Years      |
|              |                             | TDS: PERIODIC VERIFICATION MOV TEST     |       | 6 Years      |
|              |                             | CHANGE GREASE IN MOV ACTUATOR EGHV0053O |       | On Demand    |
| EGHV0054     | CCW TRN B SPLY ISO HV       | T-Ring Replacement                      |       | 6 Refuels    |
|              |                             | SERVICE LIMITORQUE OPERATOR             |       | 6 Years      |
|              |                             | PERFORM MOV DIAGNOSTIC TEST             |       | 6 Years      |
|              |                             | CHANGE GREASE IN MOV ACTUATOR EGHV0054O |       | On Demand    |
| EGHV0058     | CCW TO CTMT OUTER ISO HV    | LUBE VALVE STEM THREADS                 | 2     | 18 Months    |
|              |                             | TDS: SERVICE LIMITORQUE OPER            |       | 4 Refuels    |
|              |                             | TDS: PERIODIC VERIFICATION MOV TEST     |       | 4 Refuels    |
|              |                             | CHANGE GREASE IN MOV ACTUATOR EGHV0058O |       | On Demand    |
| EGHV0059     | CCW FROM CTMT OUTER ISO VLV | LUBE VALVE STEM THREADS                 | 2     | 18 Months    |
|              |                             | TDS: SERVICE LIMITORQUE OPER            |       | 4 Refuels    |
|              |                             | TDS: PERIODIC VERIFICATION MOV TEST     |       | 4 Refuels    |
|              |                             | CHANGE GREASE IN MOV ACTUATOR EGHV0059O |       | On Demand    |

Note 1: Same PM performs maintenance on multiple components

Note 2: Performance of this PM does not require a valve stroke

Safety Related MOV PM List by Component

| Component ID | Component Description                | PM Description                          | Notes | PM Frequency |
|--------------|--------------------------------------|---|-------|--------------|
| EGHV0060     | CCW FROM RCS IN CTMT ISO HV          | LUBE VALVE STEM THREADS                 | 2     | 18 Months    |
|              |                                      | TDS: SERVICE LIMITORQUE OPERATOR        |       | 6 Refuels    |
|              |                                      | Periodic Verification Test              |       | 4 Refuels    |
|              |                                      | CHANGE GREASE IN MOV ACTUATOR EGHV0060O |       | On Demand    |
| EGHV0061     | CCW FROM RCP THRM BAR OUTER CTMT ISO | LUBE VALVE STEM THREADS                 | 2     | 18 Months    |
|              |                                      | TDS: SERVICE LIMITORQUE OPER            |       | 4 Refuels    |
|              |                                      | TDS: PERIODIC VERIFICATION MOV TEST     |       | 4 Refuels    |
|              |                                      | CHANGE GREASE IN MOV ACTUATOR EGHV0061O |       | On Demand    |
| EGHV0062     | CCW FROM RCS IN CTMT ISO HV          | LUBE VALVE STEM THREADS                 | 2     | 18 Months    |
|              |                                      | SERVICE LIMITORQUE OPER                 |       | 4 Refuels    |
|              |                                      | Periodic Verification Test              |       | 4 Refuels    |
|              |                                      | CHANGE GREASE IN MOV ACTUATOR EGHV0062O |       | On Demand    |
| EGHV0071     | CCW TO CTMT OUTER ISO VLV            | Perform stem lubrication                | 2     | 18 Months    |
|              |                                      | SERVICE LIMITORQUE OPERATOR             |       | 4 Refuels    |
|              |                                      | PERFORM MOV DIAGNOSTIC TEST             |       | 4 Refuels    |
|              |                                      | CHANGE GREASE IN MOV ACTUATOR EGHV0071O |       | On Demand    |
| EGHV0101     | CCW TO RHR HX A ISO HAND CTRL VLV    | SERVICE LIMITORQUE OPER                 |       | 6 Years      |
|              |                                      | Periodic Verification Test              |       | 6 Years      |
|              |                                      | CHANGE GREASE IN MOV ACTUATOR EGHV0101O |       | On Demand    |

Note 1: Same PM performs maintenance on multiple components

Note 2: Performance of this PM does not require a valve stroke

Safety Related MOV PM List by Component

| Component ID | Component Description                    | PM Description                                   | Notes | PM Frequency |
|--------------|--|--|-------|--------------|
| EGHV0102     | CCW TO RHR HX B ISO<br>HAND CTRL VLV     | SERVICE LIMITORQUE<br>OPERATOR                   |       | 6 Years      |
|              |  | TDS: PERIODIC VERIFICATION<br>MOV TEST           |       | 6 Years      |
|              |  | CHANGE OUT GREASE IN SMB-<br>000 ACTUATOR. 89-10 |       | On Demand    |
| EGHV0126     | CCW TO CTMT BYP VLV                      | LUBE VALVE STEM THREADS                          | 2     | 18 Months    |
|              |  | SERVICE LIMITORQUE<br>OPERATOR                   |       | 4 Refuels    |
|              |  | PERFORM MOV DIAGNOSTIC<br>TEST                   |       | 4 Refuels    |
|              |  | CHANGE GREASE IN MOV<br>ACTUATOR EGHV0126O       |       | On Demand    |
| EGHV0127     | CCW TO CTMT BYP ISO HV                   | LUBE VALVE STEM THREADS                          | 2     | 18 Months    |
|              |  | SERVICE LIMITORQUE<br>OPERATOR                   |       | 4 Refuels    |
|              |  | Periodic Verification Test                       |       | 4 Refuels    |
|              |  | CHANGE GREASE IN MOV<br>ACTUATOR EGHV0127O       |       | On Demand    |
| EGHV0130     | CCW FROM RCS CTMT<br>EGHV0060 BYP ISO HV | LUBE VALVE STEM THREADS                          | 2     | 18 Months    |
|              |  | SERVICE LIMITORQUE<br>OPERATOR                   |       | 4 Refuels    |
|              |  | PERFORM MOV DIAGNOSTIC<br>TEST                   |       | 4 Refuels    |
|              |  | CHANGE GREASE IN MOV<br>ACTUATOR EGHV0130O       |       | On Demand    |
| EGHV0131     | CCW FROM CTMT<br>EGHV0059 BYP ISO        | LUBE VALVE STEM THREADS                          | 2     | 18 Months    |
|              |  | SERVICE LIMITORQUE<br>OPERATOR                   |       | 4 Refuels    |
|              |  | PERFORM MOV DIAGNOSTIC<br>TEST                   |       | 4 Refuels    |
|              |  | CHANGE GREASE IN MOV<br>ACTUATOR EGHV0131O       |       | On Demand    |

Note 1: Same PM performs maintenance on multiple components

Note 2: Performance of this PM does not require a valve stroke

Safety Related MOV PM List by Component

| Component ID | Component Description                       | PM Description   | Notes | PM Frequency |
|--------------|---|--|-------|--------------|
| EGHV0132     | CCW FROM RCS CTMT<br>EGHV0062 BYP ISO HV    | LUBE VALVE STEM THREADS  | 2     | 18 Months    |
|              |   | SERVICE LIMITORQUE<br>OPERATOR                                       |       | 4 Refuels    |
|              |   | Periodic Verification Test   |       | 4 Refuels    |
|              |   | CHANGE GREASE IN MOV<br>ACTUATOR EGHV0132O                           |       | On Demand    |
| EGHV0133     | CCW FROM RCP THRM<br>BAR EGHV0061 BYP ISO   | LUBE CONT. ISO. VALVE STEM<br>THREADS                                | 2     | 18 Months    |
|              |   | TDS: SERVICE LIMITORQUE<br>OPER                                      |       | 4 Refuels    |
|              |   | Periodic Verification Test   |       | 4 Refuels    |
|              |   | CHANGE GREASE IN MOV<br>ACTUATOR EGHV0133O                           |       | On Demand    |
| EJFCV0610    | A RHR PMP MINI FLOW<br>RECIRC FLOW CTRL VLV | CAR 201205543 LIMITORQUE<br>GREASE INSPECTIONS A-TRAIN<br>Non-Outage | 2     | 18 Months    |
|              |   | LUBE VALVE STEM THREADS  | 2     | 18 Months    |
|              |   | SERVICE LIMITORQUE<br>OPERATORINSPECT/SERVICE                        |       | 6 Years      |
|              |   | Periodic Verification Test   |       | 6 Years      |
|              |   | CHANGE GREASE IN ACTUATOR<br>EJFCV0610O                              |       | On Demand    |
| EJFCV0611    | RHR PUMP B MINIMUM<br>FLOW CTRL VLV         | LUBE VALVE STEM THREADS  | 2     | 18 Months    |
|              |   | TDS: SERVICE LIMITORQUE<br>OPERATOR.                                 |       | 6 Years      |
|              |   | TDS: PERIODIC VERIFICATION<br>MOV TEST                               |       | 6 Years      |
|              |   | CHANGE GREASE IN ACTUATOR<br>EJFCV0611O                              |       | On Demand    |
| EJHV8701A    | RHR PUMP A SUCT ISO                         | TDS: REPACK & STROKE VALVE   |       | On Demand    |
|              |   | LUBE VALVE STEM THREADS  | 2     | Every Refuel |
|              |   | PERIODIC VERIFICATION MOV<br>TEST PERIODIC VERIFICATION              |       | 4 Refuels    |
|              |   | TDS: SERVICE LIMITORQUE<br>OPERATOR                                  |       | 4 Refuels    |
|              |   | CHANGE GREASE IN ACTUATOR<br>EJHV8701AO                              |       | On Demand    |

Note 1: Same PM performs maintenance on multiple components

Note 2: Performance of this PM does not require a valve stroke

Safety Related MOV PM List by Component

| Component ID | Component Description                       | PM Description   | Notes | PM Frequency |
|--------------|---|--|-------|--------------|
| EJHV8701B    | RHR PUMP B SUCT ISO                         | TDS: REPACK & STROKE VALVE                             |       | On Demand    |
|              |   | LUBE VALVE STEM THREADS                                | 2     | Every Refuel |
|              |   | TDS: SERVICE LIMITORQUE OPERATOR                       |       | 4 Refuels    |
|              |   | TDS: PERIODIC VERIFICATION MOV TEST                    |       | 4 Refuels    |
|              |   | CHANGE GREASE IN ACTUATOR EJHV8701BO                   |       | On Demand    |
| EJHV8716A    | RHR TRN A SI SYS HOT LEG RECIRC ISO (3.0.3) | TDS: REPACK & STROKE VALVE                             |       | On Demand    |
|              |   | TDS: SERVICE LIMITORQUE OPERATOR                       |       | 4 Refuels    |
|              |   | LUBE VALVE STEM THREADS                                | 2     | Every Refuel |
|              |   | Periodic Verification Test                             |       | 4 Refuels    |
|              |   | CHANGE GREASE IN ACTUATOR EJHV8716AO                   |       | On Demand    |
| EJHV8716B    | RHR TRN B SI SYS HOT LEG RECIRC ISO (3.0.3) | TDS: PACKING REPLACEMENT,LUBRICATE,CYCL                |       | On Demand    |
|              |   | TDS: SERVICE LIMITORQUE OPERATOR                       |       | 4 Refuels    |
|              |   | LUBE VALVE STEM THREADS                                | 2     | Every Refuel |
|              |   | Periodic Verification Test                             |       | 4 Refuels    |
|              |   | CHANGE GREASE IN ACTUATOR EJHV8716BO                   |       | On Demand    |
| EJHV8804A    | RHR TRN A CHARGING PUMPS SPLY ISO           | TDS: REPACK & STROKE VALVE                             |       | On Demand    |
|              |   | LUBE VALVE STEM THREADS                                | 2     | 18 Months    |
|              |   | SERVICE LIMITORQUE OPERATORINSPECT AND                 |       | 4 Refuels    |
|              |   | PERIODIC VERIFICATION MOV TESTPERIODIC VERIFICATION ON |       | 4 Refuels    |
|              |   | CHANGE GREASE IN ACTUATOR EJHV8804AO                   |       | On Demand    |
|              |   |  |       |              |
| EJHV8804B    | RHR TRN B SI PUMPS SPLY ISO                 | TDS: PACKING REPLACEMENT LUBRICATE CYCLE               |       | On Demand    |
|              |   | LUBE VALVE STEM THREADS                                | 2     | 18 Months    |
|              |   | SERVICE LIMITORQUE OPERATOR                            |       | 6 Refuels    |
|              |   | PERFORM MOV DIAGNOSTIC TEST                            |       | 4 Refuels    |
|              |   | CHANGE GREASE IN ACTUATOR EJHV8804BO                   |       | On Demand    |

Note 1: Same PM performs maintenance on multiple components

Note 2: Performance of this PM does not require a valve stroke

Safety Related MOV PM List by Component

| Component ID | Component Description                     | PM Description   | Notes | PM Frequency |
|--------------|---|--|-------|--------------|
| EJHV8809A    | RHR TRN A ACC INJ SPLY ISO (3.0.3)        | TDS: PACKING REPLACEMENT,LUBRICATE,CYCL                        |       | On Demand    |
|              |   | LUBE VALVE STEM THREADS  | 2     | Every Refuel |
|              |   | PERFORM MOV DIAGNOSTIC TEST                                    |       | 4 Refuels    |
|              |   | SERVICE LIMITORQUE OPERATOR                                    |       | 6 Refuels    |
|              |   | CHANGE GREASE IN ACTUATOR EJHV8809AO                           |       | On Demand    |
|              |   |  |       |              |
| EJHV8809B    | RHR TRN B ACC INJ SPLY ISO (3.0.3)        | TDS: PACKING REPLACEMENT LUBRICATE CYCLE                       |       | On Demand    |
|              |   | TDS: SERVICE LIMITORQUE OPER                                   |       | 4 Refuels    |
|              |   | LUBE VALVE STEM THREADS  | 2     | Every Refuel |
|              |   | PERIODIC VERIFICATION MOV TEST                                 |       | 4 Refuels    |
|              |   | CHANGE GREASE IN ACTUATOR EJHV8809BO                           |       | On Demand    |
|              |   |  |       |              |
| EJHV8811A    | CTMT RECIRC SUMP A TO RHR PUMP A SUCT ISO | TDS: REPACK & STROKE VALVE                                     |       | On Demand    |
|              |   | LUBE VALVE STEM INSP GEARBOX GREASE                            | 2     | 2 Refuels    |
|              |   | SERVICE LIMITORQUE OPERATORINSPECT/SERVICE LIMITORQUE OPERATOR |       | 4 Refuels    |
|              |   | PERIODIC VERIFICATION MOV TEST                                 |       | 4 Refuels    |
|              |   | CHANGE GREASE IN ACTUATOR EJHV8811AO                           |       | On Demand    |
|              |   |  |       |              |
| EJHV8811B    | CTMT RECIRC SUMP B TO RHR PUMP B SUCT ISO | TDS: REPACK & STROKE VALVE                                     |       | On Demand    |
|              |   | SERVICE LIMITORQUE OPERATOR                                    |       | 4 Refuels    |
|              |   | LUBE VALVE STEM INSP GEARBOX GREASE                            | 2     | 2 Refuels    |
|              |   | PERIODIC VERIFICATION MOV TEST                                 |       | 4 Refuels    |
|              |   | CHANGE GREASE IN ACTUATOR EJHV8811BO                           |       | On Demand    |
|              |   |  |       |              |

Note 1: Same PM performs maintenance on multiple components

Note 2: Performance of this PM does not require a valve stroke

Safety Related MOV PM List by Component

| Component ID | Component Description                                   | PM Description                             | Notes | PM Frequency |
|--------------|---|--|-------|--------------|
| EJHV8840     | RHR TRAIN A & B SI SYS<br>HOT LEG RECIRC ISO<br>(3.0.3) | LUBE VALVE STEM THREADS                    | 2     | Every Refuel |
|              |   | TDS: SERVICE LIMITORQUE<br>OPERATOR        |       | 4 Refuels    |
|              |   | TDS: PERIODIC VERIFICATION<br>MOV TEST     |       | 4 Refuels    |
|              |   | CHANGE GREASE IN ACTUATOR<br>EJHV8840O     |       | On Demand    |
| EMHV8801A    | BORON INJ HDR TRAIN A<br>OUT TO COLD LEGS ISO           | LUBE VALVE STEM THREADS                    | 2     | 18 Months    |
|              |   | SERVICE LIMITORQUE<br>OPERATOR             |       | 6 Refuels    |
|              |   | PERFORM MOV DIAGNOSTIC<br>TEST             |       | 4 Refuels    |
|              |   | CHANGE GREASE IN ACTUATOR<br>EMHV8801AO    |       | On Demand    |
| EMHV8801B    | BORON INJ HDR TRN B<br>OUT TO COLD LEGS ISO             | LUBE VALVE STEM THREADS                    | 2     | 18 Months    |
|              |   | TDS: SERVICE LIMITORQUE<br>OPER EMHV8801BO |       | 4 Refuels    |
|              |   | PERIODIC VERIFICATION MOV<br>TEST          |       | 4 Refuels    |
|              |   | CHANGE GREASE IN ACTUATOR<br>EMHV8801BO    |       | On Demand    |
| EMHV8802A    | SI PMP A DISCH TO HOT<br>LEG INJ ISO (3.0.3)            | LUBE VALVE STEM THREADS                    | 2     | 18 Months    |
|              |   | TDS: SERVICE LIMITORQUE<br>OPERATOR        |       | 4 Refuels    |
|              |   | PERFORM MOV DIAGNOSTIC<br>TESTING          |       | 4 Refuels    |
|              |   | CHANGE GREASE IN ACTUATOR<br>EMHV8802AO    |       | On Demand    |
| EMHV8802B    | SI PMP B DISCH TO HOT<br>LEG INJ ISO (3.0.3)            | LUBE VALVE STEM THREADS                    | 2     | 18 Months    |
|              |   | SERVICE LIMITORQUE<br>OPERATOR             |       | 4 Refuels    |
|              |   | Periodic Verification Test                 |       | 4 Refuels    |
|              |   | CHANGE GREASE IN ACTUATOR<br>EMHV8802BO    |       | On Demand    |

Note 1: Same PM performs maintenance on multiple components

Note 2: Performance of this PM does not require a valve stroke

Safety Related MOV PM List by Component

| Component ID | Component Description                     | PM Description                              | Notes | PM Frequency |
|--------------|---|---|-------|--------------|
| EMHV8803A    | BORON INJ HDR SPLY FROM CCP A ISO         | LUBE VALVE STEM THREADS                     | 2     | 18 Months    |
|              |   | TDS: SERVICE LIMITORQUE OPERATOR            |       | 6 Years      |
|              |   | TDS: PERIODIC VERIFICATION MOV TEST         |       | 6 Years      |
|              |   | CHANGE GREASE IN ACTUATOR EMHV8803AO        |       | On Demand    |
| EMHV8803B    | BORON INJ HDR SPLY FROM CCP B ISO         | NON-OUTAGE "B" TRAIN GREASE INSPECTION      | 1, 2  | 18 Months    |
|              |   | PERFORM STEM THREAD LUBRICATION EMHV8803B   | 2     | 18 Months    |
|              |   | SERVICE LIMITORQUE OPERATOR                 |       | 6 Years      |
|              |   | PERFORM MOV DIAGNOSTIC TEST                 |       | 6 Years      |
|              |   | CHANGE GREASE IN ACTUATOR EMHV8803BO        |       | On Demand    |
| EMHV8807A    | RHR HX A TO SI PMPS SUCT DNSTRM ISO VLV A | LUBE VALVE STEM THREADS                     | 2     | 18 Months    |
|              |   | TDS: SERVICE LIMITORQUE OPERATOR            |       | 6 Years      |
|              |   | PERIODIC VERIFICATION MOV TEST              |       | 6 Years      |
|              |   | CHANGE GREASE IN ACTUATOR EMHV8807AO        |       | On Demand    |
| EMHV8807B    | RHR HX A TO SI PMPS SUCT DNSTRM ISO VLV B | LUBE VALVE STEM THREADS                     | 1, 2  | 18 Months    |
|              |   | TDS: SERVICE LIMITORQUE OPERATOR            |       | 6 Years      |
|              |   | TDS: PERIODIC VERIFICATION MOV TEST         |       | 6 Years      |
|              |   | CHANGE GREASE IN ACTUATOR EMHV8807BO        |       | On Demand    |
| EMHV8814A    | SI PMP A RECIRC TO RWST ISO               | LUBE VALVE STEM THREADS                     | 2     | 18 Months    |
|              |   | TDS: SERVICE LIMITORQUE OPER                |       | 6 Years      |
|              |   | TDS: PERIODIC VERIFICATION MOV TEST         |       | 6 Years      |
|              |   | CHANGE OUT GREASE IN SMB-00 ACTUATOR. 89-10 |       | On Demand    |

Note 1: Same PM performs maintenance on multiple components

Note 2: Performance of this PM does not require a valve stroke



Safety Related MOV PM List by Component

| Component ID | Component Description                     | PM Description                             | Notes | PM Frequency |
|--------------|---|--|-------|--------------|
| EMHV8814B    | SI PMP B RECIRC TO RWST ISO               | LUBE EMHV8814B VALVE STEM                  | 2     | 18 Months    |
|              |   | TDS: SERVICE LIMITORQUE OPERATOR           |       | 6 Years      |
|              |   | TDS: PERIODIC VERIFICATION MOV TEST        |       | 6 Years      |
|              |   | CHANGE GREASE IN ACTUATOR EMHV8814BO       |       | On Demand    |
| EMHV8821A    | SI PMP A DISCH TO COLD LEG INJ ISO        | LUBE VALVE STEM THREADS                    | 2     | 18 Months    |
|              |   | SERVICE LIMITORQUE OPERATOR                |       | 6 Years      |
|              |   | Periodic Verification Test                 |       | 6 Years      |
|              |   | CHANGE GREASE IN ACTUATOR EMHV8821AO       |       | On Demand    |
| EMHV8821B    | SI PMP B DISCH TO COLD LEG INJ ISO        | LUBE VALVE STEM THREADS                    | 2     | 18 Months    |
|              |   | SERVICE LIMITORQUE OPER                    |       | 6 Years      |
|              |   | Periodic Verification Test                 |       | 6 Years      |
|              |   | CHANGE GREASE IN ACTUATOR EMHV8821BO       |       | On Demand    |
| EMHV8835     | SI PMPS DISCH TO COLD LEG INJ ISO (3.0.3) | LUBE VALVE STEM THREADS                    | 2     | Every Refuel |
|              |   | SERVICE LIMITORQUE OPERATOR                |       | 4 Refuels    |
|              |   | Periodic Verification Test                 |       | 4 Refuels    |
|              |   | CHANGE GREASE IN ACTUATOR EMHV8835O        |       | On Demand    |
| EMHV8923A    | RWST TO SI PMP A SUCT ISO HV              | LUBE VALVE STEM THREADS                    | 2     | 18 Months    |
|              |   | SERVICE LIMITORQUE OPERATORINSPECT/SERVICE |       | 4 Refuels    |
|              |   | Periodic Verification Test                 |       | 4 Refuels    |
|              |   | CHANGE GREASE IN ACTUATOR EMHV8923AO       |       | On Demand    |

Note 1: Same PM performs maintenance on multiple components

Note 2: Performance of this PM does not require a valve stroke

Safety Related MOV PM List by Component

| Component ID | Component Description                                   | PM Description                              | Notes | PM Frequency |
|--------------|---|---|-------|--------------|
| EMHV8923B    | RWST TO SI PMP B SUCT ISO HV                            | LUBE VALVE STEM THREADS                     | 2     | 18 Months    |
|              |   | TDS: SERVICE LIMITORQUE OPERATOR            |       | 6 Years      |
|              |   | PERFORM MOV DIAGNOSTIC TEST                 |       | 6 Years      |
|              |   | CHANGE GREASE IN SAFETY RELATED TYPE SMB-00 |       | On Demand    |
| ENHV0001     | CTMT RECIRC SMP TO CTMT SPRY PMP A HV                   | LUBE STEM & INSPECT GEARBOX GREASE          | 2     | 2 Refuels    |
|              |   | SERVICE LIMITORQUE OPERATOR                 |       | 4 Refuels    |
|              |   | Periodic Verification Test                  |       | 4 Refuels    |
|              |   | CHANGE GREASE IN MOV ACTUATOR ENHV0001O     |       | On Demand    |
| ENHV0006     | CTMT SPRY PMP A DISCH HV                                | LUBE VALVE STEM THREADS                     | 2     | 18 Months    |
|              |   | SERVICE LIMITORQUE OPERATOR                 |       | 6 Years      |
|              |   | PERFORM MOV DIAGNOSTIC TEST                 |       | 6 Years      |
|              |   | CHANGE GREASE IN MOV ACTUATOR ENHV0006O     |       | On Demand    |
| ENHV0007     | CTMT RECIRC SUMP TO CTMT SPRAY PMP B HAND CTRL VLV OPER | SERVICE LIMITORQUE OPERATOR                 |       | 4 Refuels    |
|              |   | LUBE STEM & INSPECT GEARBOX GREASE          | 2     | 2 Refuels    |
|              |   | PERFORM MOV DIAGNOSTIC TEST                 |       | 4 Refuels    |
|              |   | CHANGE GREASE IN MOV ACTUATOR ENHV0007O     |       | On Demand    |
| ENHV0012     | CTMT SPRY PMP B DISCH HV                                | LUBE VALVE STEM THREADS                     | 2     | 18 Months    |
|              |   | TDS: SERVICE LIMITORQUE OPERATOR            |       | 6 Years      |
|              |   | Periodic Verification Test                  |       | 6 Years      |
|              |   | CHANGE GREASE IN MOV ACTUATOR ENHV0012O     |       | On Demand    |
| EPHV8808A    | SI ACC TK A OUT ISO                                     | LUBE VALVE STEM THREADS                     | 1, 2  | 72 Weeks     |
|              |   | SERVICE LIMITORQUE                          |       | 6 Refuels    |
|              |   | PERFORM MOV DIAGNOSTIC                      |       | 4 Refuels    |
|              |   | CHANGE GREASE IN MOV                        |       | On Demand    |

Note 1: Same PM performs maintenance on multiple components

Note 2: Performance of this PM does not require a valve stroke

Safety Related MOV PM List by Component

| Component ID | Component Description       | PM Description  | Notes | PM Frequency |
|--------------|-----------------------------|---|-------|--------------|
| EPHV8808B    | SI ACC TK B OUT ISO         | Perform stem thread lubrication                       | 1, 2  | 18 Months    |
|              |                             | TDS: SERVICE LIMITORQUE                               |       | 4 Refuels    |
|              |                             | TDS: PERIODIC VERIFICATION                            |       | 4 Refuels    |
|              |                             | CHANGE GREASE IN MOV                                  |       | On Demand    |
| EPHV8808C    | SI ACC TK C OUT ISO         | SERVICE LIMITORQUE                                    |       | 7 Refuels    |
|              |                             | PERIODIC VERIFICATION MOV                             |       | 4 Refuels    |
|              |                             | CHANGE GREASE IN MOV                                  |       | On Demand    |
| EPHV8808D    | SI ACC TK D OUT ISO         | TDS: SERVICE LIMITORQUE                               |       | 4 Refuels    |
|              |                             | TDS: PERIODIC VERIFICATION                            |       | 4 Refuels    |
|              |                             | CHANGE GREASE IN MOV ACTUATOR EPHV8808DO.             |       | On Demand    |
|              |                             |   |       |              |
| FCHV0312     | AFP TURB MECH TRIP/THROT HV | REPLACE VALVE   |       | 3 Refuels    |
|              |                             | LUBRICATE FCHV0312                                    |       | Every Refuel |
|              |                             | BRUSH INSPECTION                                      |       | 6 Refuels    |
|              |                             | LUBRICATE FCHV0312                                    |       | 18 Months    |
|              |                             | Time-based replacement on trip solenoid for FCHV0312. |       | 6 Refuels    |
|              |                             | SERVICE LIMITORQUE OPERATOR                           |       | 6 Years      |
|              |                             | PERFORM MOV DIAGNOSTIC TEST                           |       | Every Refuel |
|              |                             | CHANGE GREASE IN MOV ACTUATOR FCHV0312O               |       | On Demand    |
|              |                             | Replace FCHV0312 actuator with rebuilt actuator       |       | 6 Refuels    |
|              |                             |   |       |              |
| GSHV0020     | H2 PURGE INNER CTMT ISO HV  | TDS: SERVICE LIMITORQUE OPERATOR                      |       | 4 Refuels    |
|              |                             | TDS: PERIODIC VERIFICATION MOV TEST                   |       | 4 Refuels    |
|              |                             | CHANGE GREASE IN MOV ACTUATOR GSHV0020O               |       | On Demand    |
| GSHV0021     | H2 PURGE OUTER CTMT ISO HV  | TDS: SERVICE LIMITORQUE OPERATOR                      |       | 4 Refuels    |
|              |                             | TDS: PERIODIC VERIFICATION MOV TEST                   |       | 4 Refuels    |
|              |                             | CHANGE GREASE IN MOV ACTUATOR GSHV0021O               |       | On Demand    |

Note 1: Same PM performs maintenance on multiple components

Note 2: Performance of this PM does not require a valve stroke

Safety Related MOV PM List by Component

| Component ID | Component Description                             | PM Description  | Notes | PM Frequency |
|--------------|---|---|-------|--------------|
| KAHV0030     | HYDROGEN CTRL SYS<br>MAKE-UP AIR HAND CTRL<br>VLV | SERVICE LIMITORQUE OPER   |       | 4 Refuels    |
|              |   | Periodic Verification Test  |       | 4 Refuels    |
|              |   | CHANGE GREASE IN MOV<br>ACTUATOR  |       | On Demand    |
| KCHV0253     | F-PROT LOOP TO RX BLD<br>OUTER CTMT DNSTRM ISO    | LUBE VALVE STEM THREADS   | 2     | Every Refuel |
|              |   | CLEAN VALVE INTERNALS   |       |              |
|              |   | DISASSEMBLE AND CLEAN VALVE<br>DISCS AND SEATING AREA.<br>REPLACE DISC RETAINING CLIP |       | 6 Refuels    |
|              |   | SERVICE LIMITORQUE<br>OPERATORINSPECT/SERVICE   |       | 4 Refuels    |
|              |   | TDS: PERIODIC VERIFICATION<br>MOV TEST  |       | 4 Refuels    |
|              |   | CHANGE GREASE IN MOV<br>ACTUATOR KCHV0253O  |       | On Demand    |
| LFFV0095     | CTMT NORM SMP PMPS<br>DISCH HDR CTMT FV           | LUBE VALVE STEM THREADS   | 2     | 18 Months    |
|              |   | SERVICE LIMITORQUE<br>OPERATOR  |       | 6 Refuels    |
|              |   | PERFORM MOV DIAGNOSTIC<br>TEST  |       | 4 Refuels    |
|              |   | CHANGE GREASE IN MOV<br>ACTUATOR LFFV0095O  |       | On Demand    |
| LFHV0105     | DRW SMPS DISCH HDR<br>DNSTRM HV                   | Perform stem thread lubrication   | 2     | 18 Months    |
|              |   | TDS: SERVICE LIMITORQUE<br>OPERATOR   |       | 6 Years      |
|              |   | INSPECT/REPLACE T&B<br>CONNECTORS   |       | 28 Years     |
|              |   | PERIODIC VERIFICATION MOV<br>TEST   |       | 6 Years      |
|              |   | CHANGE GREASE IN MOV<br>ACTUATOR LFHV0105O  |       | On Demand    |

Note 1: Same PM performs maintenance on multiple components

Note 2: Performance of this PM does not require a valve stroke

Safety Related MOV PM List by Component

| Component ID | Component Description           | PM Description                             | Notes | PM Frequency |
|--------------|---------------------------------|--|-------|--------------|
| LFHV0106     | DRW SMPS DISCH HDR<br>UPSTRM HV | LUBE LF SYSTEM MOV STEM<br>THREADS         | 2     | 18 Months    |
|              |                                 | SERVICE LIMITORQUE<br>OPERATOR             |       | 6 Years      |
|              |                                 | INSPECT/REPLACE T&B<br>CONNECTORS          |       | 28 Years     |
|              |                                 | PERIODIC VERIFICATION MOV<br>TEST          |       | 6 Years      |
|              |                                 | CHANGE GREASE IN MOV<br>ACTUATOR LFHV0106O |       | On Demand    |

Note 1: Same PM performs maintenance on multiple components

Note 2: Performance of this PM does not require a valve stroke