

LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	Y	N	M	P	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4		5				
7	8	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	4	57	CAT 58		5

CON'T

0	1
---	---

7 8

REPORT SOURCE

L	(6)	0	5	0	0	0	2	2	0	(7)	0	3	0	6	7	9	(8)	0	3	2	0	7	9	(9)
---	-----	---	---	---	---	---	---	---	---	-----	---	---	---	---	---	---	-----	---	---	---	---	---	---	-----

60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80

DOCKET NUMBER

EVENT DATE

REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During the refuel outage, inservice inspection of an Emergency Condenser

0 3 | Steam Supply Line, six reportable indications were found..They are on the

0 4 | elbow side in the heat affected zone, elbow to safe-end weld.

0 5 | They were found using ultrasonic testing. This has minimal safety

0 6 | implications.

0 7 |

0 8 |

0	9	SYSTEM CODE C J		CAUSE CODE X	CAUSE SUBCODE Z	COMPONENT CODE P I P E X X				COMP. SUBCODE D	VALVE SUBCODE Z		
7	8	9	10	11	12	13	14	15	16	17	18	19	20
LER/RO REPORT NUMBER		EVENT YEAR			SEQUENTIAL REPORT NO.			OCCURRENCE CODE		REPORT TYPE		REVISION NO.	
7 9		7 9		—	0 0 2		/	0 1 1		T		0	
21		22		23	24		26	28		30		32	
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT	SHUTDOWN METHOD		HOURS	ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER	
A		Z		Z	Z		0 0 0 0	Y		N		L	
33		34		35	36		37	40		42		43	
18		19		20	21		22	23		24		25	
33		34		35	36		37	40		42		43	
T 3 3 0													
44		47											

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Inter Granular stress corrosion cracking is the probable cause. The

1 1 elbow and safe end will be replaced during this outage.

1 2

1 3

1 4

8 9
FACILITY STATUS (1) (5) (H) (28) % POWER (0) (0) (0) (29) OTHER STATUS (30) NA METHOD OF DISCOVERY (B) (31) DISCOVERY DESCRIPTION (32)

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60
ACTIVITY CONTENT RELEASED OF RELEASE (1) (6) (Z) (33) (Z) (34) AMOUNT OF ACTIVITY (35) NA LOCATION OF RELEASE (36)

PERSONNEL EXPOSURES		DESCRIPTION	
NUMBER	TYPE		
1 7	0 0 (37) Z (38)	NA (39)	

PERSONNEL INJURIES		NUMBER		DESCRIPTION	
1	8	0	0	0	NA

LOSS OF OR DAMAGE TO FACILITY (43)
TYPE DESCRIPTION
1 9 Z (42) NA

PUBLICITY
 ISSUED 20 DESCRIPTION 45 7903260272 NRC USE ONLY
 7 8 9 N44 10 NA 68 69 70 71 72 73 74 75 76 77 78 79 80

NAME OF PREPARER

PHONE:

25 300-000

