

**LICENSEE EVENT REPORT**

CONTROL BLOCK: 

--	--	--	--	--	--

 ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	Y	N	M	P	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	1	1	4			5			
7	8	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE						30	57	CAT	58			59

CON'T

REPORT SOURCE L 6 0 5 0 0 0 2 2 0 7 0 0 7 12 6 7 9 8 0 8 1 0 7 9 9

7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

### EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During steady state operation, a vacuum switch, 68-12B, in the Vacuum  
0 3 | Relief System, failed to open at its proper setpoint. This resulted in  
0 4 | minimal safety implications.  
0 5 |  
0 6 |  
0 7 |  
0 8 |

SYSTEM CODE S D (11)		CAUSE CODE E (12)		CAUSE SUBCODE E (13)		COMPONENT CODE I N S T R U (14)		COMP. SUBCODE S (15)		VALVE SUBCODE Z (16)	
7 8		9 10		11 12		13 18		19 20			
(17) LER/RO REPORT NUMBER		EVENT YEAR 7 9 (21) (22)		SEQUENTIAL REPORT NO. 0 1 8 (24) (25) (26)		OCCURRENCE CODE / (27)		REPORT TYPE L (30)		REVISION NO. 0 (32)	
ACTION TAKEN E (18)		FUTURE ACTION Z (19)		EFFECT ON PLANT Z (20)		SHUTDOWN METHOD Z (21)		HOURS 0 0 0 (22) (23) (24)		ATTACHMENT SUBMITTED N (25)	
33 34		35 36		37 38		39 40		41 42		43 44	
NPRD-4 FORM SUB. N (24)		PRIME COMP. SUPPLIER L (25)		COMPONENT MANUFACTURER M 2 3 5 (26) (27) (28) (29)							
45 46		47 48		49 50		51 52		53 54		55 56	

### CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | No cause has been identified for this occurrence, but the switch has been

1 1 | , adjusted to open at its proper setpoint.

1 2 |

1 3 |

1 4 |

7 8 9 80

FACILITY STATUS (1) 5 (2) E (28) % POWER (30) 0 9 0 (29) OTHER STATUS (30) NA  
 METHOD OF DISCOVERY (31) B (31) DISCOVERY DESCRIPTION (32) Calibration test  
 ACTIVITY CONTENT (33) 1 6 (33) Z (34) AMOUNT OF ACTIVITY (35) NA  
 RELEASED OF RELEASE (36) NA LOCATION OF RELEASE (36) NA

PERSONNEL EXPOSURES										
NUMBER				TYPE		DESCRIPTION				
1	7	0	0	37	Z	38	NA 39			

		PERSONNEL INJURIES			
		NUMBER	DESCRIPTION		(41)
1	2	0	0	0	(40) NA

7	8	9	11	12	80
LOSS OF OR DAMAGE TO FACILITY (43)					
TYPE		DESCRIPTION			
1	2	7	13	NA	

1	9	2	42	NR
7	8	9	10	
PUBLICATION				80
ISSUED - DESCRIPTION (45)				
790814				
NRC USE ONLY				

2 0 N (44) NA 0000140655

NAME OF PREPARER

E. Duda

PHONE:

(<sup>68</sup>315)<sup>69</sup>343-2110 Ext 1306<sup>80</sup>

CGO 917-926

