

## TELECOPY MESSAGE

TO: 215-337-5324 FROM: 315-343-2110 X1326 DATE/TIME 02/05/80  
 Telephone Number Telephone Number

84-7350315-343-2110 X1326

TO: BOYCE H. GRILL  
 Director of Regulatory Operation  
 USNRC Region I  
 631 Park Avenue  
 King of Prussia, PA. 19406

From: Niagara Mohawk Power Corporation  
Nine Mile Point Nuclear Station  
Unit #1  
P.O. Box #32  
Lycoming, New York 13093

SUBJECT: PROMPT REPORTABLE OCCURRENCE  
DOCKET NO. 50-220 LICENSE NO. DPR-63  
ASSIGNED LER NO. 00-05

EVENT DATE: 2/3/80 REPORT DATE: 2/4/80

EVENT DESCRIPTION: NMPC Engineering evaluation of G.R. 311.299 requires  
that the triple low level setpoint be raised 20" to account for differ-  
ences in indicated versus actual water level caused by a large increase  
in drywell temperature during a loss of coolant accident.

COMPONENTS INVOLVED: Rosemount Analog Trip Unit

CAUSE AND REMEDIAL ACTION: Due to the piping configuration of the  
instrument reference tap, and the possibility of indicated versus  
true vessel level difference being as much as 19", it is possible  
that actuation of triple low setpoint may not have occurred. There-  
fore, the setpoint was adjusted upward by 20" on 2/3/80.

FACILITY STATUS:

X THERMAL MW 96

c) Routine Startup \_\_\_\_\_  
 d) Routine Shutdown \_\_\_\_\_  
 e) Steady State Oper X \_\_\_\_\_  
 f) Load Change \_\_\_\_\_

g) Shutdown \_\_\_\_\_  
 h) Refueling \_\_\_\_\_  
 i) Other \_\_\_\_\_  
 j) Not Applicable \_\_\_\_\_

A written follow-up report will be sent within two weeks.

TELECOPY TO R. R. Schneider FROM T. J. Perkins DATE 2/5/80  
 NAME NAME  
Boyce Grill T J Perkins

80 02140

618

M007  
3/10



11