

**LICENSEE EVENT REPORT**

CONTROL BLOCK:            ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	Y	N	M	P	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	1	4			5
7	8	9						14	15	25										26	30					57	CAT	58		
		LICENSEE CODE							LICENSE NUMBER											LICENSE TYPE										

CON'T

0	1	REPORT SOURCE										DOCKET NUMBER										EVENT DATE										REPORT DATE									
7	6	L	6	0	5	0	0	10	2	2	0	7	0	4	1	9	8	0	8	0	8	0	1	8	0	9															
		60	61	68										69	74										75	80															

### EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During normal operation while performing surveillance

03 testing of the turbine anticipatory trip bypass, rx scram

04 switch 02-13A was found to be operating outside its setpoint

05 of 355 psi and tolerance of  $\pm 5$  psi as found at 362 psi.

06 Three other switches performing the same function

07 were found at proper setpoints and functioning as

08 designed.

SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP. SUBCODE		VALVE SUBCODE											
H	B	11	X	12	Z	13	I	N	S	T	R	U	14	15	S	16	Z	16					
LEADER REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.													
17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32								
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER							
E	18	X	19	Z	20	Z	21	0	0	0	0	22	N	23	Y	24	N	25	8	0	6	9	26

### CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1	0	This event is attributed to instrument drift. The
1	1	switch was immediately adjusted within setpoint limits
1	2	and is regularly tested on a monthly basis.
1	3	
1	4	

FACILITY STATUS		POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	
1	5	E	28	0	9	9	29	NA	30
ACTIVITY		CONT.		RELEASED		OF RELEASE		AMOUNT OF ACTIVITY	
1	6	Z	33	Z	34	NA		35	
PERSONNEL EXPOSURES		NUMBER		TYPE		DESCRIPTION		39	
1	7	0	0	0	37	Z	38	NA	
PERSONNEL INJURIES		NUMBER		DESCRIPTION		41			
1	8	0	0	0	40	NA			
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION		43			
1	9	Z	42	NA					
PUBLICITY		ISSUED		DESCRIPTION		45			
2	0	H	44	NA					
								NRC USE ONLY	

8008110344  
NAT

NAME OF PREPARER Paul Harrison

PHONE: (315) 343-2110 Ext. 1212.

