NRC FORM 366 (7-77) U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

Line	Field	Value
01	LICENSEE CODE (2)	N Y N M P 1
01	LICENSE NUMBER (3)	0 0 - 0 0 0 0 0 - 0 0
01	LICENSE TYPE (4)	4 1 1 1 1
01	CAT (5)	
CON'T 01	REPORT SOURCE (6)	L
01	DOCKET NUMBER (7)	0 5 0 0 0 2 2 0
01	EVENT DATE (8)	1 0 2 8 8 0
01	REPORT DATE (9)	1 1 2 4 8 0

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 SEE ATTACHED

Field	Value
SYSTEM CODE (11)	M C
CAUSE CODE (12)	A
CAUSE SUBCODE (13)	D
COMPONENT CODE (14)	I N S T R U
COMP. SUBCODE (15)	S
VALVE SUBCODE (16)	Z
LER/RO REPORT NUMBER (17) — EVENT YEAR	8 0
SEQUENTIAL REPORT NO.	0 2 5
OCCURRENCE CODE	0 3
REPORT TYPE	L
REVISION NO.	0
ACTION TAKEN (18)	X
FUTURE ACTION (19)	G
EFFECT ON PLANT (20)	Z
SHUTDOWN METHOD (21)	Z
HOURS (22)	0 0 0 0
ATTACHMENT SUBMITTED (23)	N
NPRD-4 FORM SUB. (24)	N
PRIME COMP. SUPPLIER (25)	N
COMPONENT MANUFACTURER (26)	G 0 8 0

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 SEE ATTACHED

Line	Field	Value
15	FACILITY STATUS (28)	E
15	% POWER (29)	0 9 8
15	OTHER STATUS (30)	N/A
15	METHOD OF DISCOVERY (31)	C
15	DISCOVERY DESCRIPTION (32)	SUPERVISIAL OBSERVATION
16	ACTIVITY RELEASED (33)	Z
16	CONTENT OF RELEASE (34)	Z
16	AMOUNT OF ACTIVITY (35)	N/A
16	LOCATION OF RELEASE (36)	N/A
17	PERSONNEL EXPOSURES NUMBER (37)	0 0 0
17	TYPE (38)	Z
17	DESCRIPTION (39)	N/A
18	PERSONNEL INJURIES NUMBER (40)	0 0 0
18	DESCRIPTION (41)	N/A
19	LOSS OF OR DAMAGE TO FACILITY TYPE (42)	Z
19	DESCRIPTION (43)	N/A
20	PUBLICITY ISSUED (44)	N
20	DESCRIPTION (45)	N/A

8012100 481

NRC USE ONLY

NAME OF PREPARER: Paul Harrison PHONE: (315)343-2110, X1549

GPO 917-926

EVENT DESCRIPTION AND PROBABLY CONSEQUENCES:

During steady state operation the Stack Gas Monitoring System was inadvertently left in the "Purge" mode of operation for approximately nine and one-half hours subsequent to testing. This rendered the equipment's only function of monitoring and high level alarms inoperable. Throughout this time period other monitoring systems were operational and indicated normal steady state release rates. These systems include the Off Gas Monitoring System, the Building Ventilation Constant Air Monitors and the Main Steam Line Radiation Monitors. This event resulted in no adverse environmental effect.

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS:

While completing the Daily Stack Purge and Background Determination Procedure, the technician left the test panel to perform another task, and failed to return to the panel to restore the system to normal operation in accordance with the procedure. This condition was identified during a general check by a Radiation Protection Supervisor whereupon the monitor was immediately returned to normal operation. To prevent future occurrences a procedure change will be made requiring the technician to remain at the test panel during the purge operation.