

CONTROL BLOCK: 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
N Y N M P 1 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 1 4 5
LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT 53

CON'T

0 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
REPORT SOURCE L 6 0 5 0 0 0 2 2 0 7 1 2 2 4 8 0 3 0 1 2 3 8 1 9
DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During normal operation, the loss of a 115KV auxiliary power feed to an
0 3 emergency power bus was experienced. The Emergency Diesel Generator
0 4 automatically came into service as required. This had no adverse affect
0 5 on safe operation since these components operated as designed.
0 6
0 7
0 8

0 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
E B 11 E 12 X 13 R E L A Y X 14 D 15 Z 16
EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CCODE REPORT TYPE REVISION NO.
8 0 0 3 3 0 3 L 0
ACTION FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRO-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
E 18 X 19 Z 20 Z 21 0 0 0 0 N 23 N 24 N 25 G 0 8 0 0

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 A calibration check of the over-frequency protective relay for the feeder breaker
1 1 revealed that the trip setpoint was found too conservatively close to the
1 2 nominal frequency, thus causing a spurious trip of the breaker. The relay was
1 3 properly recalibrated to prevent recurrence. This type of relay will be
1 4 calibrated on refuel cycle frequency for future preventative action.

1 5 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
FACILITY STATUS % POWER OTHER STATUS (30) METHOD OF DISCOVERY DISCOVERY DESCRIPTION (32)
B 29 0 8 8 29 N/A A 31 Event troubleshooting
ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)
Z 33 Z 34 N/A N/A
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39)
0 0 0 37 Z 38 N/A
PERSONNEL INJURIES NUMBER DESCRIPTION (41)
0 0 0 40 N/A
LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION (43)
Z 42 N/A
PUBLICATION ISSUED DESCRIPTION (45) NRC USE ONLY
2 0 N 44 N/A

8 102100629
NAME OF PREPARER Paul Harrison

PHONE: 315-343-2110 ext. 1212

