

NINE MILE POINT NUCLEAR STATION UNIT 2

DYNAMIC QUALIFICATION

COMPONENT NAME: HYDRAULIC CONTROL UNIT
MPL OR EDL ITEM NO.: C12D001
MPL REFERENCE: 239X239AF, REV. '23
EQUIPMENT CLASSIFICATION: ☒ ACTIVE ☐ PASSIVE

THE SEISMIC QUALIFICATION REPORT(S) IDENTIFIED HEREIN HAVE BEEN EVALUATED AND REQUALIFIED WHERE NECESSARY TO SHOW THAT THE ABOVE-MENTIONED COMPONENT IS CAPABLE OF MEETING THE NUCLEAR REGULATORY COMMISSION SEISMIC QUALIFICATION REVIEW TEAM (SQRT) REQUIREMENTS.

PREPARED BY: L. Y. CHANG *L. Y. Chang* DATE 6/26/85

ORGANIZATION GENERAL ELECTRIC CO. — NEBO

REVIEWED BY: R. W. HARDY *R. W. Hardy* DATE 6/26/85
SQRT PROGRAM MANAGER

VERIFIED BY: S. M. Schaffer *S. M. Schaffer* DATE 6/26/85

APPROVED BY: G. A. DEEVER *G. A. Deever* DATE 6/26/85
RESPONSIBLE DESIGN ENGINEER

GENERAL  ELECTRIC

8507170148

RESPONSES WITH - 1

Control Unit, Test Re-
and 330, HCU Mon. At 1:15
in a Qualification Room for
Control Unit with 3-

Qualification Review Team (QRT)
approach for re-evaluation of
equipment

Control Unit, Set, re-evaluate

Section: 1

QUALIFICATION SUMMARY

COMPONENT NAME: Hydraulic Control Unit

2. MPL OR EDL ITEM NO.: C12-D001

3. QUALIFICATION DOCUMENTATION (ENCLOSED WITH THIS REPORT)

A. QUALIFICATION SUMMARY OF EQUIPMENT (SORT FORM), INCLUDING REQUIRED RESPONSE SPECTRA WITH TRS PLOTTED ON RRS GRAPH, AS APPROPRIATE.

Enclosed

B. SORT EVALUATION FLOW CHARTS (MARKED TO SHOW DECISION PATH).

Enclosed

C. REFERENCE DOCUMENTS

REFERENCE NUMBER	DOCUMENT IDENTIFICATION	REVISION OR DATE	TITLE/SUBJECT
(1)	GE-761E500	Rev. 10	Hydraulic Control Unit Assembly Drawing
(2)	GE-384HA183	Rev. 0 (7/21/75)	Hydraulic Control Unit, Test Report
(3)	DRF C11-00089	Feb. 1985	Design Record File, HCU Model Analysis
(4)	NEDC-30927	Feb. 1985	Environmental Qualification Report for the Hydraulic Control Unit with 3-way ASCO SSPV
(5)	NEDE-24788	May 1980	Seismic Qualification Review Team (SQRT) Technical Approach for Re-evaluation of BWR4/5 Equipment
(6)	GE-383HA853	Rev. 0	Hydraulic Control Unit, Seismic Analysis

D. ADDITIONAL SUPPORTING DOCUMENTS

DOCUMENT IDENTIFICATION	REVISION OR DATE	TITLE/SUBJECT
GE-22A1342	Rev. 0	CRD System Design Specification

(UNCLASSIFIED)

0001

the dynamic behavior of the system. The HCU must be able to operate in a stand-alone mode.

Phase 1 of the test was conducted with the HCU and the HCU was able to operate in a stand-alone mode. The test results are shown in Figure 1.

CONCLUSIONS

However, the loading of the system and the

results are completely different. The system is not able to operate in a stand-alone mode. The test results are shown in Figure 2.

QUALIFICATION SUMMARY (CONTINUED)

MPL ITEM NO.: C12-D001

4. REQUIREMENTS

The Hydraulic Control Unit (HCU) is required to withstand the dynamic loads imposed at the HCU/structural interface locations. The HCU must maintain operability to the extent that a scram function can successfully be completed. The HCU must perform its required safety-related function (scram) during an emergency plant shutdown.

5. DEMONSTRATED CAPABILITY

The dynamic qualification of the installed HCU (761E500G004) is demonstrated by a test performed on a similar HCU (767E800G001) during the Phase III E.Q. Program (Ref. 4). Figure 1 and Figure 2 show the assembly of the installed HCU and the tested HCU. The TRSs obtained from the test are compared with the RRSs at the HCU mounting locations. These comparisons are shown in Figure 3 thru Figure 12. In all the cases, the TRS envelops the RRS by a significant margin. Also, the operability of the HCU scram function was demonstrated before, during and after test.

6. RATIONALE FOR QUALIFICATION CERTIFICATION

(INCLUDE DECISION ANALYSIS WITH COMPARISON TO ACCEPTANCE CRITERIA, APPROACH FOR DEMONSTRATING OPERABILITY, AND CONSIDERATION OF HIGH-FREQUENCY RESPONSE.)

The installed HCU and test HCU are similar, but not identical. However, the loading condition of the tested HCU envelops the installed HCU for the operability and structural integrity for the following reasons:

- 1) All the active components such as Scram Valves, Accumulator, etc. are completely identical. The main differences are in the N₂ bottle size and holddown hardware. Additionally, the low beam attachment hardware is also slightly different (bolts vs. clamps). Since all the differences are in the passive components, the operability of the HCU is considered to be fully demonstrated during the test due to the significant margins between the TRSs and RRSs.

1000

1000

1000

1000

1000

1000

1000

QUALIFICATION SUMMARY (CONTINUED)

6. RATIONALE FOR QUALIFICATION CERTIFICATION (CONTINUED)

- 2) Four test anomalies were recorded during the test (See Ref. 4, Pages 40 thru 43). However, the only safety-related item is the NOD No. 2, which is the fracture of the N₂ bottle hanger during the SRV aging test.

The fractured hanger was submitted to a metallographic examination, which showed that SRV fatigue was responsible for the fracture (See Ref. 4, Page A5-1). However, the SRV loads are negligible (<0.2 g) for the installed HCU due to its location. Note that the SRV TRSs are the limiting loads obtained from several BWR plants which are significantly higher than the SRV RRSs for the NMP2 HCUs.

- 3) An identical HCU in free-standing configuration has been tested in Wyle Laboratory in 1975 (Ref. 2). This HCU successfully passed all the tests without any failure. As a result of a finite elements model study (Ref. 2), the seismic capability of this HCU is further improved by attaching the HCU to the beam structures of the HCU upper and lower beam attachment locations. Therefore, the structural integrity of the beam mounted HCUs are demonstrated by the more severe free-standing test.

- 4) A similar analysis has been performed to further assure the acceptance of the HCU structural integrity considering the NMP2-unique mounting configuration. The RRS and TRS (1983 test) at the HCU internal key locations were generated from this task. A comparison of those response spectra was made which demonstrated that the TRS obtained from Reference 4 indeed bounded the NMP2 HCU for the faulted condition. The results are shown in the Reference 4, Figure 9 thru Figure 23.

In summary, the adequacy of the NMP2 HCUs are demonstrated by the tests performed on the comparable HCUs.

1971

1972

1973

1974

1975

1976

1977

1978

1979

1980

1981

1982

1983

1984

1985

1986

1987

1988

1989

1990

1991

1992

1993

1994

1995

1996

1997

1998

1999

2000




Figure 1 Hydraulic Control Unit,
Part No. 761E500






Figure 2. Hydraulic Control Unit, Part No. 767E800

100

100

1

301

1. *Chlorophyll a* (Chl a) and *Chlorophyll b* (Chl b) are the primary photosynthetic pigments in green plants. They are responsible for capturing light energy and converting it into chemical energy through the process of photosynthesis. Chl a is the most abundant pigment, while Chl b is present in smaller amounts. Both pigments are found in the chloroplasts of green plants.

RESPONSE SPECTRUM




Figure 3 RRS and TRS, Horizontal Direction, SRV Aging

RESPONSE SPECTRUM




Figure 4 RRS and TRS, Vertical Direction, SRV Aging



RESPONSE SPECTRUM




Figure 5, RRS and TRS, Horizontal Direction, Upset

RESPONSE SPECTRUM




Figure 6, RRS and TRS, Vertical Direction, Upset Condition

01
0
0
0
0
0



RESPONSE SPECTRUM




Figure 7, RRS and TRS, Horizontal Direction, Upset Condition



RESPONSE SPECTRUM




Figure 8, RRS and TRS, Vertical Direction, Upset Condition



RESPONSE SPECTRUM




Figure 9, RRS and TRS, Horizontal Direction, Faulted Condition

RESPONSE SPECTRUM




Figure 10 RRS and TRS, Vertical Direction, Faulted Condition




Figure 11, RRS and TRS, Horizontal Direction, Faulted Condition



RESPONSE SPECTRUM




Figure 12, RRS and TRS, Vertical Direction, Faulted Condition

MPL: C12-D001Seismic and Dynamic Qualification Summary of Equipment

- I. Plant Name: Nine Mile Point 2 Type: _____
1. Utility: Niagara Mohawk Power Corp. PWR _____
2. NSSS: General Electric BWR 5, Mark II
3. A/E: Stone & Webster Other _____

II. Component Name Hydraulic Control Unit

1. Scope: ☒ NSSS ☐ BOP ☐ Other
2. Model Number: 761E500G004 Quantity: 185
3. Size or Range: N/A
4. Vendor: N/A
5. If the component is a cabinet or panel, name and model number of the devices included: N/A
6. Physical Description:
- a. Appearance: Module assembly
- b. Dimensions: 102.38"x21.75"x17.00"
- c. Weight: 785 lb
7. Location: Building: Inside the Reactor Building, outside the containment.
Elevation: 261 feet
8. Field Mounting Conditions ☒ Bolt (No. 4, Size 1/2) ^{Floor Mounting}
☒ Weld (Length) ^{1/4 fillet weld, 2" long,}
^{* ☒ Two Special U-Clamps, made 5 places. (U.Bea}
^{from 3/16 St. Pl. for the Lower Beam}
^{Attachment (2"x2"x1-3/8")}
9. Mounting Orientation [e.g., on floor, cantilevered, suspended, etc.] Mounted on floor with the back side attached to beam structures
10. a. System in which located: CRD System
- b. Functional Description: To provide the stored accumulator energy to CRD during emergency shutdown
- c. Is the equipment required for ☐ Hot Standby ☐ Cold Shutdown ☒ Both ☐ Neither ☐ Other _____

* Each U-clamp is welded to the HCU supporting structures by 1/8" fillet weld at both longitudinal sides.



11. Pertinent Reference Design Specification for Qualification
Requirements: 22A1342

- | | |
|---|---|
| a. <input type="checkbox"/> Seismic Input | d. <input checked="" type="checkbox"/> Service Conditions |
| b. <input type="checkbox"/> Hydrodynamic Load Input | e. <input type="checkbox"/> Qualified Life |
| c. <input type="checkbox"/> Fatigue Considerations | |

III. Is Equipment Available for Inspection in the Plant:

☒ Yes ☐ No ☐ Partial or limited availability

IV. Equipment Qualification Method:

☒ Test ☐ Analysis ☐ Combination of Test and Analysis

Qualification Report*: Wyle Report 58870

(No., Title and Date): Seismic Qualification of One Hydraulic Control Unit

Company that Prepared Report: Wyle Laboratory

Company that Reviewed Report: GE

Where Report is filed or available: NEDC 30927, Vol. 2 (Ref. 4)

Applicable Codes and/or Standards: IEEE 344, 1975

V. Vibration Input:

1. Loads considered:
- | | |
|----|--|
| a. | <input type="checkbox"/> Seismic only |
| b. | <input type="checkbox"/> Hydrodynamic only |
| c. | <input type="checkbox"/> Vibration from normal operation |
| d. | <input checked="" type="checkbox"/> Combination of (a), (b), and (c) |

2. Method of Combining RRS:

☒ Absolute Sum ☐ SRSS ☐ _____
(other, specify)

- 3. Required Response Spectra** (attach the graphs): _____
See attached Figure 3 thru Figure 12

NOTE:

* If more than one report complete Items IV thru VII for each report.

** If other than RRS is used, describe methods.

RH:rm/A09104*-2



MPL: C12-D001

4. Damping Corresponding to RRS: OBE 2% SSE 3%
5. Required Acceleration in Each Direction:
☐ ZPA ☐ Other _____ (specify)
 OBE S/S = _____ F/B = _____ V = _____
 SSE S/S = _____ F/B = _____ V = _____

6. Were fatigue effects considered:

☒ Yes ☐ No

If yes, describe how they were treated in overall

qualification program: Prior to the OBE and SSE tests, the HCU was subjected to 90 minutes vibration aging at 0.75g sinusoidal input for each axis. The frequency was varied from 5 to 100 Hz at a rate of two octaves per minute, plus two 15-minute SRV cycling fatigue aging tests (biaxial, multi-frequency, random test).

VI. If Qualification by Test, then Complete:

1. ☐ Single Frequency ☐ Multi-Frequency ☒ random
☐ sine beat
☐ _____
2. ☐ Single Axis ☒ Multi-Axis (Bi-axial)
☒ Independent Axis ☐ In-phase motions
3. Number of Qualifications Tests:
 OBE 5 SSE 1 Other _____
 (specify)
4. Frequency Range: 1 to 100 Hz
5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):
 S/S = _____ F/B = _____ V = _____
6. Method of Determining Natural Frequencies:
☐ Lab Test ☐ In-Situ Test ☐ Analysis
7. TRS enveloping RRS using Multi-Frequency Test:
☐ Yes (Attach TRS & RRS graphs)
☐ No



MPL: C12-D001

8. Maximum Input g Level Test: See attached Figure 3 thru Figure 12.

OBE S/S = _____ F/B = _____ V = _____

SSE S/S = _____ F/B = _____ V = _____

9. Laboratory Mounting:

A. * ☒ Bolt (No. 4, Size 1/2) Floor

☐ Weld (Length _____) ☐ _____

B. Orientation and Fixturing: _____

10. Functional operability verified:

☒ Yes ☐ No ☐ Not Applicable

11. Test Results including modifications made:

Wiring Trough Assembly supporting bracket (NOD No.1) and
N₂ Bottle and Accumulator hold down hardware (NOD No.2).

12. Other tests performed (such as aging or fragility test,
 including results):

Vibration aging - no failure.

SRV aging test - NOD No.1 & 2 occurred during this test.

13. Failure Modes (If appropriate) N/A

14. Margins Available: ☐ Input Spectrum ☐ Fragility

VII. If Qualification by Analysis, then complete: N/A

1. Method of Analysis:

☐ Static Analysis ☐ Equivalent Static Analysis

☐ Dynamic Analysis ☐ Time-History ☐ Response
 Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back,
 Vertical):

S/S = _____ F/B = _____ V = _____

3. Model Type: ☐ 3D ☐ 2D ☐ 1D
☐ Finite Element ☐ Beam
☐ Closed Form Solution ☐ Other _____

*Total number of seven 3/8" bolts were used for the beam attachment locations.
 Four bolts are located at the upper beam and three bolts are located at lower beam.

MPL: _____

4. ☐ Computer Codes: _____
 Frequency Range and No. of modes _____
☐ Hand Calculations
5. Method of Combining Dynamic Responses from Seismic and Other
 Dynamic Loads:
☐ Absolute Sum ☐ SRSS ☐ Other: _____
 (specify)
6. Damping:
 OBE _____ SSE _____ Basis for damping used: _____
7. Support Considerations in the model: _____
8. Critical Structural Elements:

		Governing Load			
		or Response	Seismic	Total	Stress
A.	<u>Identification Location</u>	<u>Combination</u>	<u>Stress</u>	<u>Stress</u>	<u>Allowable</u>

B.	<u>Maximum Critical</u>		<u>Maximum Allowable Deflection</u>
	<u>Deflection</u>	<u>Location</u>	<u>to Assure Functional Operability</u>

9. Failure Modes: _____
10. Margins Available: ☐ Input Spectrum
☐ Stress or Deflection



EQUIPMENT: Hydraulic Control Unit

MPL NO: C11-D001

DECISION POINT	DECISION and/or BASIS FOR DECISION
1) Is equipment same or dynamically similar to equipment already, or soon to be, qualified to SQRT requirement?	Yes
2) Operability demonstrated?	Yes
3) Qualified to SQRT?	Yes



EQUIPMENT: Hydraulic Control Unit

MPL NO: C12-D001

DECISION POINT	DECISION and/or BASIS FOR DECISION
<p>1) Is equipment same or dynamically similar to equipment already, or soon to be, qualified to SQRT requirement?</p> <p>2) Operability demonstrated?</p> <p>3) Qualified to SQRT?</p>	<p>Yes</p> <p>Yes</p> <p>Yes</p>






Figure1A, SQRT Re-Evaluation Flow Chart

QUALIFICATION SUMMARY

1. Component Name: Intermediate Range Detector
2. A. MPL or EDL Item No.: C51-N002 A-H
B. GE Drawing No.: 112C3144
3. Qualification Documentation
 - A. Qualification Summary of Equipment (SQRT Form Attached)
 - B. Reference Documents

<u>Reference Number</u>	<u>Document Identification</u>	<u>Date</u>	<u>Title</u>
1 *	Sensor Products Engineering Memo 994-79-007	5-14-1979	"Seismic Qualification Test Report, Intermediate Range Detector"
2 **	DRF NO. 943-C515120N*3	7-11-78	"IRM Detector Seismic Analysis"

4. Requirements

This device is classified as active and thus must maintain structural and functional operability when subjected to a seismic event.

5. Demonstrated Capability

A combination of test and analysis has been used to demonstrate qualification of this device to BWR seismic requirements.

Reference 1 documents testing performed on an intermediate range detector assembly in which BWR-6 fuel seismic motion was simulated. The electrical and nuclear performance of the detectors were checked before and after the seismic testing, the detectors were electrically monitored during the test.

The test data before, during and after the seismic testing show no appreciable change in the functional performance of the detector as a result of the seismic test.

Reference 2 contains an analysis of the IRM detector which determines the maximum allowable g loading for the detectors based on structural parameters only. This maximum allowable g - loading is then compared to a calculated load based on BWR-6 SSE fuel behavior and physical parameters. Results of this analysis show that the IRM detector can withstand 2 times the SSE seismic loading for the horizontal direction, and 21.0 g's in the vertical direction.

* See Attachment 4 for copy.

** See Attachment 3 for copy.



6. Rationale for Qualification

This equipment is qualified for both seismic and hydrodynamic conditions based on its ability to withstand a simulated seismic environment without compromise of structural or functional integrity. This qualification is based on the following:

- (1) Analysis of BWR fuel seismic response shows that the detector assemblies will be driven at the natural frequency of the fuel assemblies (4.5 Hz). During seismic testing the detector assembly was impacted between two stops on a skotch yoke mechanism thereby subjecting the detector assemblies to a broad range of frequencies as in shock testing.
- (2) The detector part of the IRM assembly is a rigid component.
- (3) The most severe accelerations experienced by the device are those associated with impact as is the case when the IRM detector tube impacts the inside wall of the dry tube.
- (4) The most severe acceleration will be met or exceeded provided the displacement experienced during testing exceeds that which the device will actually see inside the reactor vessel. The values of OBE = 2.0" and SSE = 3.0" exceed those displacements which will actually occur under OBE, SSE or either load in combination with the appropriate hydrodynamic loadings.
- (5) The test was run at 7.0 Hz to account for operating temperature strength as described in attachment 4, Appendix B paragraph 3.0. Peak to peak displacement of the tests were 2.0" for OBE and 3.0" for SSE. Calculation of tested g-levels gives 5.0g OBE and 7.5g SSE. Comparison of test levels with the requirements of attachment 2 show that this device is qualified for application at NMP-2.



Seismic and Dynamic Qualification Summary of Equipment

- I. Plant Name: Nine Mile Point 2 Type:
1. Utility: Niagara Mohawk Power Corp. PWR
2. NSSS: General Electric Co. BWR- 5, MK II
3. A/E: SWEC Other
- II. Component Name Intermediate Range Detector
1. Scope: [x] NSSS [] BOP [] Other
2. Model Number: 112C3144 Quantity: 8
3. Size or Range:
4. Vendor: General Electric
5. If the component is a cabinet or panel, name and model number of the devices included: N/A
6. Physical Description:
- a. Appearance: see attachment 1
- b. Dimensions: see attachment 1
- c. Weight: N/A
7. Location: Building: Primary Containment
Elevation: Inside Reactor Pressure Vessel
8. Field Mounting Conditions [] Bolt (No. __, Size __)
[] Weld (Length __)
[x] threaded connector
9. Mounting Orientation [e.g., on floor, cantilevered, suspended, etc.]
dry tube
10. a. System in which located: Neutron Monitoring
- b. Functional Description: active, Class 1E
- c. Is the equipment required for [] Hot Standby [] Cold Shutdown [] Both [x] Neither [] Other



11. Pertinent Reference Design Specification for Qualification

Requirements: As specified on GE drawing

- | | |
|--|--|
| a. <input checked="" type="checkbox"/> Seismic Input | d. <input type="checkbox"/> Service Conditions |
| b. <input checked="" type="checkbox"/> Hydrodynamic Load Input | e. <input type="checkbox"/> Qualified Life |
| c. <input type="checkbox"/> Fatigue Considerations | |

III. Is Equipment Available for Inspection in the Plant:☐ Yes ☐ No ☒ Partial or limited availabilityIV. Equipment Qualification Method:☒ Test ☐ Analysis ☐ Combination of Test and AnalysisQualification Report*: Sensor Products Engineering Memo(No., Title and Date): No. 994 79-007 "Seismic Qualification Test Report
Intermediate Range Detector"Company that Prepared Report: General ElectricCompany that Reviewed Report: General ElectricWhere Report is filed or available: GE

Applicable Codes and/or Standards: _____

V. Vibration Input:

1. Loads considered: (Note: a and b combined)

- a. ☐ Seismic only
b. ☐ Hydrodynamic only
c. ☐ Vibration from normal operation
d. ☒ Combination of (a), (b), and (c)

2. Method of Combining RRS:

☐ Absolute Sum ☐ SRSS ☒ N/A

(other, specify)

3. Required Response Spectra** (attach the graphs): Attachment 2NOTE:

* If more than one report complete Items IV thru VII for each report.

** If other than RRS is used, describe methods.



4. Damping Corresponding to RRS: OBE 2.0% SSE 3.0%
5. Required Acceleration in Each Direction:
☐ ZPA ☒ Other ZPA at top of reactor pedestal
 OBE S/S = 0.30 F/B = 0.30 V = 0.20
 SSE S/S = 0.80 F/B = 0.80 V = 0.40
6. Were fatigue effects considered:
☐ Yes ☒ No
 If yes, describe how they were treated in overall qualification program: _____

VI. If Qualification by Test, then Complete:

1. ☒ Single Frequency ☐ Multi-Frequency ☐ random
☐ sine beat
☐ _____
2. ☒ Single Axis ☐ Multi-Axis
☐ Independent Axis ☐ In-phase motions
3. Number of Qualifications Tests:
 OBE 5 SSE 1 Other _____
 (specify)
4. Frequency Range: N/A
5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical) Detector assemblies are driven by fuel seismic motion which has been determined to have a horizontal natural frequency of 4.5Hz
 S/S = N/A F/B = N/A V = N/A
6. Method of Determining Natural Frequencies:
☐ Lab Test ☐ In-Situ Test ☒ Analysis (analysis of BWR 6 fuel assemblies)
7. TRS enveloping RRS using Multi-Frequency Test:
☐ Yes (Attach TRS & RRS graphs)
☒ No (TRS not applicable)



- VII. If Qualification by Analysis, then complete: See Attachment 3

- * Analysis of IRM detector shows that the device vertical capability is 21 g's (See attachment 3 page A-15); OBE and SSE g levels calculated from frequency and displacement of tests.



- 



9. Failure Modes: _____
10. Margins Available: [] Input Spectrum
 [] Stress or Deflection



ATTACHMENT 1

GE DRAWING NO. 112C3144




MULTIPLE SPECIFICATIONS USE THE FOLLOWING:		GENERAL ELECTRIC		112C3144	
APPLIED PRACTICES	125	PL 15550	DETECTOR		
TOLERANCES UNLESS OTHERWISE SPECIFIED		PL 15550			

NUCLEAR SAFETY RELATED OVERALL REVISION 35 SUMMARY

MRL:CS1-N001/N002

REV	DATE	BY
1	35	
2	35	
3	35	



NOTES:
 1. BEFORE ASSEMBLY PROCESS AS FOLLOWS:
 1.1 ITEMS 4, 6 PER 175A7418
 1.2 ITEMS 3, 8, 9, 13, 14, 21 PER 272A6904
 1.3 OUTGAS ITEMS 8, 9, 21 PER 272A6905P2
 2. CLEAN AREA TO BE WELDED WITH ITEM 29.
 3. CAPTURE SST BRAID (ITEM 3) BETWEEN ITEMS 2, 21 AND WELD ALL AROUND
 4. USE ITEM 19 TO CEMENT ITEM 18 IN PLACE. ITEM 18 SHALL BE CEMENTED AT ALL INTERFACES. AT JUNCTION OF ITEM 18 WITH ITEM 19 THE OD. SHALL BE ± 0.015 . THERE SHALL NOT BE ANY UNDERCUT OR RECESS EXCEEDING ± 0.015
 5. ITEM 3 MIN. COILING DIA IS 66.00.

- 6. OUTGAS GROUPS 1, 3, 5, 6, 7, 9, 12, 13, 15, 16, 17, 19, PER 175A7419P001. OUTGAS GROUPS 2, 4, 8, 10, 11, 14, 18, PER 175A7419P002.
- 7. SHALL MEET THE REQUIREMENTS OF THE PRODUCT SPECIFICATION (SEE SHEET 2).
- 8. "NUCLEAR SAFETY RELATED" APPLIES ONLY TO GROUPS 2, 4, 8, 10, 11, 14, 18.
- 9. CRIMP BEFORE TRIMMING AND WELDING.
- 10. AFTER WELDING, ASSEMBLY OF ITEM 9, ITEM 8, AND ITEM 21 MUST PASS THROUGH A ± 0.015 DIA. X 2.75 MIN LONG TEST FIXTURE.
- 11. ATTACH ITEM 20 TO ITEM 9 AS FOLLOWS:
 11.1 WRAP ITEM 25 AROUND ITEM 3.
 11.2 PULL ITEM 20 OVER ITEM 9 UP TO COLLAR OF ITEM 3.
 11.3 WRAP ITEM 25 OVER ITEM 20 TO SECURE ITEM 20 TO ITEM 3.
 11.4 GENTLY SMOOTH ITEM 20 TOWARD DETECTOR ELEMENT END TO SNUG ITEM 20 AGAINST ITEM 3, INCLUDING PINCHOFF TUBE.
 11.5 PASS END OF ITEM 20 THROUGH ITEM 28. CRIMP ITEM 28 PER FIG. 1. ALIGN LONG DIAMETER OF ITEM 28 PARALLEL WITH FLATTENED END OF PINCHOFF TUBE OF ITEM 3. SLIDE ITEM 28 OVER PINCHOFF AND SEAT ITEM 28 AGAINST END OF ITEM 3. CRIMP ITEM 28 IN PLACE PER SECTION CC.
 11.6 CRIMP ITEM 28 TO A CONICAL POINT. TRIM EXCESS ITEM 20 BEYOND ITEM 28. COMPLETED ASSEMBLY MUST PASS FREELY THROUGH TUP: 175A7278P019.
- 12. ELECTROLYTICALLY ETCH ITEMS 16, 17 IN LOCATION SHOWN USING MATERIALS PER 408H119.
- 13. DIMENSIONS OF SECTION C-C AND FIG. 1 ARE TOOL-CONTROLLED, AND ARE SHOWN FOR REFERENCE ONLY.

D. S. STARRINGER		N. J. 31492		N. J. 31492		N. J. 31492	
CHK BY: L. FRENCH		CHK BY: L. FRENCH		CHK BY: L. FRENCH		CHK BY: L. FRENCH	
ENGR: J. P. STARRINGER		ENGR: J. P. STARRINGER		ENGR: J. P. STARRINGER		ENGR: J. P. STARRINGER	
RE: 112C3144		RE: 112C3144		RE: 112C3144		RE: 112C3144	
DATE: 3/15/66		DATE: 3/15/66		DATE: 3/15/66		DATE: 3/15/66	
SAN JOSE		SAN JOSE		SAN JOSE		SAN JOSE	




GENERAL ELECTRIC

112C314-4
3 2

SPECIFICATIONS TO BE FOLLOWED				
APPLIED PRACTICES	SURFACES	FINISHES	COATINGS	OTHER
	✓			

DETECTOR
PART MADE FOR N/A

GROUP NO.	L 1.00 INCHES	PRODUCT SPECIFICATIONS	GROUP NO.	L 21.00 INCHES	PRODUCT SPECIFICATIONS
1	471.14	175A8239	12	503.84	175A8239
2	471.14	175A8240	13	558.44	175A8239
3	459.64	175A8239	14	558.44	175A8240
4	459.64	175A8240	15	120.44	175A8239
5	480.74	175A8239	16	381.34	175A8239
6	269.44	175A8239	17	380.44	175A8239
7	465.64	175A8239	18	380.44	175A8240
8	465.64	175A8240	19	423.54	175A8239
9	559.64	175A8239			
10	559.64	175A8240			
11	600.44	175A8240			



REVISED	FORM 30
32 NJ18333	
33 NJ12985	
4-1-73	




GENERAL ELECTRIC

112C3144

3

APPLIED PRACTICES	QUANTITIES	REVISIONS
✓	✓	✓

DETECTOR
FIRST MADE FOR N/A



SECTION A-A
ENLARGED






FIG. 1 ITEM 28 ENLARGED



SECTION B-B
ENLARGED
ITEMS 20 & 28 OMITTED



SECTION C-C
ENLARGED
(ITEM 20 OMITTED)

REVISIONS	DATE	BY	CHKD	APPROVED
12		NJ14353		
33		NJ22289		
35		NJ42985		



ATTACHMENT 2



PERPECTAR VER Q1 LEV 00

SRVENV OF ALL (BY CASES)

22 OCT 1942

NIRAGRA NOKAMX-NINE MILES POINT UNIT-2 J.8.12/77 NS-1729-1
RMS OF ACCELERATION PEDestal TOP (ELEV. 299.84 FT) (253.15 64)

MICHAEL K 00


DISK CURVE SET NO-42

NOR DIRECTION

DAMPING VALUES

0.020

NOTE: MULTIPLE OF TWO CURVES WITH DAMPING IS 22 6 42
THESE CURVES REPRESENT A SPREAD OF +10% AND -10%



PERPECTAR VER N1 LEV 00

SRVENV OF ALL (BY CASES)

22 OCT 1942

NIRAGRA NOKAMX-NINE MILES POINT UNIT-2 J.8.12/77 NS-1729-1
RMS OF ACCELERATION PEDestal TOP (ELEV. 299.84 FT) (253.15 64)

MICHAEL K 00


DISK CURVE SET NO-42

VER DIRECTION

DAMPING VALUES

0.020

NOTE: MULTIPLE OF TWO CURVES WITH DAMPING IS 22 6 42
THESE CURVES REPRESENT A SPREAD OF +10% AND -10%





PSPECTRA VER 01 LEV 00 CHUOING LOAD CASES
 NIAGARA MOHAWK-NINE MILES POINT UNIT-2 J.0.12177 ME-1719-1
 RAS OF ACCELERATION PEDESTAL TOP (ELEV.268.64 { 255.13 57)


22 SEP 1982

SIX CURVE SET NO.42

NOR DIRECTION

MICHAEL K 00
 DAMPING VALUES = 0.030

NOTE: MULTIPLY OF TWO CURVES WITH NORMAL DAMPING 22 SE 4 42
 THESE CURVES REPRESENT A SPREAD OF +10% AND -10%



PSPECTRA VER 01 LEV 00 CHUOING LOAD CASES
 NIAGARA MOHAWK-NINE MILES POINT UNIT-2 J.0.12177 ME-1719-1
 RAS OF ACCELERATION PEDESTAL TOP (ELEV.268.64 { 255.13 57)


22 SEP 1982

SIX CURVE SET NO.42


VER DIRECTION

MICHAEL K 00
 DAMPING VALUES = 0.030


NOTE: MULTIPLY OF TWO CURVES WITH NORMAL DAMPING 22 SE 4 42
 THESE CURVES REPRESENT A SPREAD OF +10% AND -10%









530000338



530000338







ATTACHMENT 3

IRM DETECTOR SEISMIC ANALYSIS



Extracted
DRF# 943-C515120N#3

For axial capability
on the TRM detector

U.S. Atomic Energy Commission
Nuclear Energy Division

ENGINEERING CALCULATION SHEET

DRF 84-88, 15 131120-1-

N#3 A-10

NUMBER

DATE

SUBJECT

BY

SHEET

OF


Detector Asm 112 C 3144

Detector Element 112 C 3107 C18

Anode 248A 9149 B001


~~248A 9149 B001~~~~159A 2478 X~~

Anode 248A 9148 P001 - Titanium



Dimensions are for worst case - Heaviest center and weakest end.

For loading on end, use the following simulation



Titanium density, ~~0.163 lb/in³~~

per Metals Handbook, 0.163 lb/in³

Yield strength, per 167A2983 = 50,000 psi

at Room Temp, 16,000 psi at 500°F per RMI, Inc.

$$\begin{aligned} P_1 &= 0.163 \left(\frac{\pi}{4} \right) (0.040)^2 (0.030) = 6.145 E-6 \text{ lb} \\ P_2 &= 0.163 \left(\frac{\pi}{4} \right) (0.115)^2 (1.005) = 1.7015 E-3 \text{ lb} \\ P_3 &= 0.163 \left(\frac{\pi}{4} \right) (0.040)^2 (0.070) = 1.4338 E-5 \text{ lb} \end{aligned} \quad \left\{ \begin{array}{l} \text{Based on} \\ 1 \text{ g acceleration} \end{array} \right.$$

$$\begin{aligned} R_1 &= [(1.130 - 0.015)P_1 + (1.130 - 1.5325)P_2 + (1.130 - 1.070)P_3] / 1.130 = 9.065 E-4 \text{ lb} \\ R_2 &= [0.015P_1 + 1.5325P_2 + 1.070P_3] / 1.130 = 8.155 E-4 \text{ lb} \end{aligned}$$



GENERAL ELECTRIC CO.
Nuclear Energy Division

A-11

ENGINEERING CALCULATION SHEET

NUMBER _____ DATE 7/13/78
 SUBJECT IRM Detector Seismic Analysis BY AC/Chilton SHEET 2 OF _____

Check bending moment at right end (worst case)

$$M = .070 R_2 - .035 P_3 = \frac{5.6582 E-5}{\cancel{4.2592 E-5}} \text{ in lb}$$

$$\text{Stress}, \sigma = \frac{Mc}{I}$$

$$\frac{I}{c} = \frac{\pi}{64} [0.04]^4 / .020 = 6.2832 E-6$$

$$\sigma = 5.6582 E-5 / 6.2832 E-6 = 9.005 \text{ psi at } 1g$$


Stress concentration factor = 3.4
 (See DRF B13-167, section 7)

$$\sigma = 3.4 (9.005) = 30.618 \text{ psi at } 1g$$

Consider yield strength at 800°F to get allowable
 g's
 $g's = \frac{16000}{30.618} = \frac{522.6}{\cancel{2.7179}} g's$

At 600°F, per RMI spec., yield str = 19,000 psi
 $g's = \frac{19000}{30.618} = 620.5 g's$

Consider bending of at center section



Per Roark, Case 13, Page 106

$$M = \frac{1}{8} W L \text{ at center}$$

$$M = \frac{1}{8} P_2 L = \frac{1}{8} (1.0015 E-3) (1.005) = 2.1375 E-4$$

$$\frac{I}{c} = \frac{\pi}{64} (.115)^4 / .115/2 = \frac{\pi}{32} (.115)^3 = 1.4931 E-4$$

$$\sigma = \frac{Mc}{I} = \frac{2.1375 E-4}{1.4931 E-4} = 1.43 \text{ psi/g}$$

This is much lower than at right end, so
 the end value is limiting.



Nuclear Energy Division
ENGINEERING CALCULATION SHEET

A-12

NUMBER _____ DATE 7/13/78
 SUBJECT IRM Detector Seismic Analysis BY J. H. Whitman SHEET 3 OF 3

The maximum acceleration of the fuel in a BWR-6 at the elevation of the IRM (See 384HA137 and 385HA603) is 3.405 g (SSE.)

~~The~~ The IRM detector is mounted inside ~~a~~ a tube of 0.187 OD x .016 wall.

This in turn is installed inside a fiberglass "sock" inside the shuttle tube. The shuttle tube is inside the IRM Dry Tube and has a diameter of 0.375. This gives a radial clearance of 0.0625" between the 0.5" ID of the Dry Tube and the O.D. of the Shuttle tube.

The wall of the shuttle tube is .028, giving an ID of 0.319 and a radial clearance of .066 between the ID of the shuttle tube and the O.D. of the detector tube. The fiberglass "sock" fills this space and serves as a shock absorber to protect the detector.

Considering maximum acceleration of the fuel over the distance from the fuel to the dry tube, the fuel would reach a velocity of:

$$V_f = \sqrt{2as} = \sqrt{2(3.405 \times 386.4)(.237)} = 24.97 \text{ m/sec}$$

(use 25 m/sec)

(Fuel water gap is as below for BWR-6)
 See 762E82.1
~~From Figure 6~~

Now diametral gap is 1.164
 Now Dry tube OD is 0.69
 $\Delta \text{ gap} = \frac{1}{2}(1.164 - .69) = 0.237$

Impact with the dry tube, assuming elastic impact will give double the velocity to the dry tube because the fuel is essentially infinite mass,
 $V_{dt} = 2 \times 25 = 50 \text{ in/sec}$



GENERAL ELECTRIC CO.
Nuclear Energy Division

A-13

ENGINEERING CALCULATION SHEET

NUMBER _____ DATE 7/14/78
 SUBJECT IRM Seismic Analysis BY W. R. Koster SHEET 4 OF _____

The dry tube will travel 0.0625 inches and then impact the shuttle tube. Assuming elastic impact and conservation of momentum, the velocities will have a relationship in accordance with the section areas.

$$M_{dt} v_{dt} = M_{dt} v_{dt}' + M_{st} v_{st} \quad (\text{Cons. Momentum})$$

$$M_{dt} v_{dt}^2 = M_{dt} (v_{dt}')^2 + M_{st} v_{st}^2 \quad (\text{Cons. Energy})$$

$$M_{dt} (v_{dt} - v_{dt}') = M_{st} v_{st}$$

$$M_{dt} (v_{dt}^2 - v_{dt}'^2) = M_{st} v_{st}^2$$

$$\cancel{v_{dt}} v_{dt} + v_{dt}' = v_{st}$$

$$v_{dt} - v_{dt}' = \frac{M_{st}}{M_{dt}} v_{st}$$

$$2 v_{dt} = v_{st} \left[1 + \frac{M_{st}}{M_{dt}} \right]$$

$$v_{st} = \frac{2 v_{dt} M_{dt}}{M_{dt} + M_{st}} = \frac{2(50) \left[.69^2 - .50^2 \right]}{\left[.69^2 - .50^2 + .375^2 - .319^2 \right]} = 85.3 \text{ in/sec}$$

The fiberglass "sock" (175A8979) will compress by at least .02 inches to accelerate the detector tube. Also, the velocity of the shuttle tube will be reduced by picking up the detector tube and detector.

$$85.3 \left(.375^2 - .319^2 \right) = v \left(.375^2 - .319^2 + .188^2 - .154^2 \right)$$

$$v = 65.7 \text{ in/sec}$$

(By neglecting the weight of the detector, cable and "sock", this figure is conservative).

The acceleration is then, from $v = 2.45$

$$a = \frac{v^2}{\Delta s} = \frac{(65.7)^2}{2(.02)} = 107912.25 \text{ m/sec}^2$$



Nuclear Energy Division

A-14

ENGINEERING CALCULATION SHEET

NUMBER _____ DATE 7/14/78
 SUBJECT IRM Seismic Analysis BY J. B. B. B. SHEET 5 OF _____

Convert acceleration in m/sec^2 to g 's by dividing by 386.4

$$a = \frac{107912.25}{386.4} = 279 \text{ } g\text{'s (use 280 } g\text{'s)}$$

This figure is very conservative because of the following:

1. Fuel acceleration was held at its maximum. SSE value for the velocity calculation when actually the average acceleration would be less.
2. Elastic impacts were assumed for all cases except the fiberglass "rock" impact. Actually, some plastic deformation could be expected in the fuel channel surface which would reduce the resulting velocities.
3. No damping effect of the water was considered for the dry tube. Actually, the water would provide an accelerating force on the dry tube before impact by the fuel so the net velocity difference at impact would be less, making the resulting velocity less and the water would slow the dry tube so the velocity at the point of contact with the shield tube would be lower for that reason also.

The actual operating temperature of the IRM detector, if considered as 800°F, would give an allowable acceleration of 522.6 g 's (sheet 2)

This gives a safety factor of:

$$SF = \frac{522.6}{280} = 1.87$$

for 600°F operation, the safety factor is $\frac{620.5}{280} = 2.22$





GENERAL ELECTRIC CO.
Nuclear Energy Division

A-16

ENGINEERING CALCULATION SHEET

NUMBER _____ DATE 7/17/78
SUBJECT IRM Seismic Analysis BY W. H. Hutton SHEET 7 OF _____

There is no discrete resonant frequency for the IRM in the longitudinal direction due to the gearing. However, the IRM cable will give a resonant frequency of greater than 90 Hz.

Figure 6.20 of 384 HA 137 gives a vertical response for resonance about 33 Hz. of 1.5 g for SSE, 1.0 g for OBE.

Therefore, the 21 g capability greatly exceeds the requirements.



ATTACHMENT 4



B-10

SENSOR PRODUCTS

ENGINEERING MEMO

NUMBER

994-79-007

SEISMIC QUALIFICATION TEST REPORT
INTERMEDIATE RANGE DETECTOR 112C3144G008

BY

R. J. Culbertson
R. J. CULBERTSON

DATE

May 14, 1979

REVIEWED BY:

L. C. Wimpee 14 May 1979
L. C. WIMPEE

APPROVED BY:

Y. J. Dayal
Y. J. DAYAL 14 May 1979



TABLE OF CONTENTS

ITEM	PAGE
1.0 SCOPE	1
2.0 REFERENCES	1
3.0 SUMMARY & CONCLUSIONS	1
4.0 TEST DESCRIPTION	2
FIGURE 1	4
APPENDIX A (TEST DATA)	5
APPENDIX B (TEST JUSTIFICATION)	18



DISTRIBUTION

R. Culbertson

I. Layne

J. Terhune

L. Wimpee



1.0 SCOPE

This report documents the seismic qualification tests and test results of the 112C3144G008 intermediate range detector assembly.

2.0 REFERENCES

2.1 General Electric Documents

2.1.1 384HA137 Seismic Design, BWRSD Supplied Equipment

2.1.2 385HA603 Seismic Design BWRSD Supplied Equipment

2.1.3 385HA777 Dynamic Load Methods and Criteria-NSSS Equipment, Piping, RPV & Internals

2.1.4 175A8240 Final Product Spec. Incore Mean Square Fission Detector Assembly.

2.1.5 SPE Memo 994-76-017 Tolerance Analysis

2.1.6 SPE Memo 994-79-005 Seismic Qualification Test Plan - Intermediate Range Detector, 112C3144G008.

2.1.7 Letter, R. L. Crowther, 9/24/74, BWR-6 Reference Core & Fuel Design

2.1.8 22A1473 (*) Neutron Monitoring System Spec.

2.1.9 22A2843 (*) Neutron Monitoring System Spec.

2.1.10 22A3167 (*) Neutron Monitoring System Spec.

2.1.11 22A3789 (*) Neutron Monitoring System Spec.

2.1.12 Test Instruction T.I. 700

2.1.13 762E821 Reactor Core Interfaces

*All Suffixes

3.0 SUMMARY & CONCLUSIONS

3.1 Summary

The current output of the test detector with operating voltage applied was monitored during the seismic test with no measureable current due to OBE seismic conditions observed and with less than 0.2×10^{-6} Amperes as occasional excursions at SSE seismic conditions.

The electrical and nuclear performance parameters of the detector before and after the seismic tests, together with the specification values, are listed below. BWR-6 fuel seismic motion was the basis for the seismic test.



Test Parameter	Specification Value	Test Values	
		Before Seismic	After Seismic
Detector Serial Number 6,612,88			
Insulation Resistance	$>1 \times 10^{12} \Omega$	$>1 \times 10^{12} \Omega$	$>1 \times 10^{13} \Omega$
Breakdown Voltage	500-800 Vdc	540 Vdc	546 Vdc
Neutron Sensitivity, dc	$6.6-8.4 \times 10^{-18} \text{ A/nv}$	$7.11 \times 10^{-18} \text{ A/nv}$	$7.06 \times 10^{-18} \text{ A/nv}$
Neutron Sensitivity, MSV	$3.75-6.25 \times 10^{-31} \text{ A}^2/\text{Hz/nv}$	$4.7 \times 10^{-31} \text{ A}^2/\text{Hz/nv}$	$4.95 \times 10^{-31} \text{ A}^2/\text{Hz}$

3.2 Conclusions

The test data before, during and after the seismic testing show no appreciable change in the functional performance of the detector as a result of the seismic test. Therefore, it is concluded that the detector was not damaged or otherwise affected by being subject to seismic conditions.

4.0 TEST DESCRIPTION

The tests reported in this document are run to confirm qualification of the 112C3144G008 intermediate range detector assembly for seismic conditions in its application in a nuclear power generating station. BWR-6 seismic requirements are used because they are the most stringent. Detector electrical and nuclear performance was tested before and after the seismic tests and the detector was electrically monitored during the seismic tests to determine the seismic effects on the detector.

4.1 Test Procedure

The test procedure used followed the test plan given in reference 2.1.6 and the test set-up is described in Figure 1.

4.2 Test Detector Selection

The test detector assembly was selected at random from available production units.

4.3 Pre-and Post-Seismic Tests

The tests of insulation resistance, voltage breakdown, and neutron sensitivity were run by Quality Control personnel in the prescribed manner, with the data being recorded in accordance with T.I. 700.

4.4 Seismic Test Facility

The seismic test fixture is a Scotch yoke machine with motion amplitude set by the radius of the drive pin location on the drive wheel. Drive speed is set by the adjustment of a variable speed drive motor (Ski #599 drill). Drive speed is monitored during the test with a General Radio Strobotac and constant speed is maintained by manual adjustment of the drive motor speed control. The Strobotac was calibrated prior to the tests with a 60Hz reference and the Shimpo tachometer. During the seismic tests, the




4.4 detector assembly was connected to a high voltage power supply, set at the detector operating voltage (100 Vdc), and the Keithly Picoammeter. The picoammeter output was recorded by the Brush recorder.

4.5 Test Data and Equipment Used

Justification of the test plan and procedure are contained in Appendix B.







Appendix A

In accordance with the test plan, SPE Memo 994-79-005, the following is recorded.

Detector serial number 6,612,688

Detector diameter (over fiberglass) 0.263 inch

Pre-seismic data for insulation resistance, voltage breakdown and neutron sensitivity is given on the attached Quality Assurance data sheets (T.I.-700).

Insulation Resistance	Voltage Breakdown	Neutron Sensitivity D.C.	Neutron Sensitivity Mean Square
$>1 \times 10^{12} \Omega$	540 Vdc	$7.11 \times 10^{-18} \text{ A/nv}$	$4.7 \times 10^{-31} \text{ A}^2/\text{Hz/nv}$

Seismic Test duration, sec.	OBE #1	OBE #2	OBE #3	OBE #4	OBE #5
RPM	21.3	21.4	20.8	21.2	21.2
	425-430	423-428	424-427	422-426	422-428

Seismic Test duration, sec.	SSE
RPM	20.9
	421-429

Post seismic data for insulation resistance, breakdown voltage, and neutron sensitivity is given on the attached Quality Assurance data sheets (T.I.-700).

Insulation Resistance	Voltage Breakdown	Neutron Sensitivity D.C.	Neutron Sensitivity Mean Square
$>1 \times 10^{13}$	546 Vdc	$7.06 \times 10^{-18} \text{ A/nv}$	$4.95 \times 10^{-31} \text{ A}^2/\text{Hz/nv}$

The deviation from initial values is:

Insulation Resistance	Voltage Breakdown	Neutron Sensitivity D.C.	Neutron Sensitivity Mean Square
---	+1.11%	-0.70%	+5.32%

Equipment used in seismic test:

Keithly #445 Picoammeter S/N 9015 Calibrated March 21, 1979

High voltage power supply - made by GE, SPE Engrg. laboratory. Voltage checked by comparison with Fluke #341A power supply. I.D. No. 60430, calibrated Nov. 26, 1978 (at 100 volts, actual voltage is 100.2 Vdc).

Gould Brush #220 chart recorder. - Calibrated in lab 4/25/79.
Serial No. 14659

Shimpo #DT-103, S/N 760620 Tachometer

General Radio #631-A Strobotach



Equipment used in seismic test (continued):

Tachometer and Strobotac check by comparison with 60Hz AC power line

Variable speed motor-Skil #599 3/8 drill

The seismic fixture had the following measurements:

Detector-driver gap 1.118 inches

OBE Peak-to-peak travel 2.002 inches

SSE Peak-to-peak travel 3.006 inches

Suspended length of detector 58 inches



TEST DATA SHEETS

Pro-Seismic

IRM DETECTOR

DRAWING NO. 112C3144 GR. 008 REV. PA/ING 34 SERIAL NO. 6612685
 PROJECT STOCK T NO. TRKJ7 H NO. N9001

4.0 TEST PROCEDURES

4.1 Heat Run

4.1.2 Insulation Resistance @ 100 \pm 5 VDC = $>10^{12}$ ohms (Before heat run) (I.R. shall be greater than 1×10^{12} ohms).

TESTED BY [19] DATE 3/28/79

4.1.3 Insulation Resistance @ 100 \pm 5 VDC = $>10^8$ ohms (at 600 \pm 20 °F. (I.R. shall be greater than 1×10^8 ohms).

4.1.4 Insulation Resistance @ 100 \pm 5 VDC = $>1 \times 10^{13}$ ohms (After heat run) (I.R. shall be greater than 1×10^{12} ohms).

TESTED BY [19] DATE 3/28/79

4.1.5 Voltage Breakdown = 530 VDC (VBD shall be between 500-800 VDC)

TESTED BY [19] DATE 3/28/79

4.2 Capacitance

4.2.1 Capacitance 867PF 22 PFD/FT (Capacitance shall be 25PF/ft. + 10% — no lower limit).

TESTED BY [19] DATE 3/28/79

4.3 Neutron Sensitivity

4.3.1 Preliminary at NTR

4.3.1.5 Null C_x = 1.875 Pfd. (Instrument)

4.3.1.6 Null C_x = 1740 Pfd. (Inst. and Cable)

4.3.1.7 Null C_x = 890 Pfd. (Inst., Cable & Detector)

4.3.1.8 Assembly Capacitance = 850 Pfd.

3/30/79

666

 $11.06 \times 10^{-8} a$

NO.	TI 700
REV.	10
PAGE	1 OF 2



4.3.2 Chamber Testing

4.3.2.1 Peak Flux 7.43×10^{11} NV (using standard detector)

3/30/79

4.3.2.3	HIGH VOLTAGE	FREQ RANGE	MSV OUTPUT
SIG	5.28 $\times 10^{-6}$	8-16 Khz	6.5×10^{-31}
NTR	5.00	8-16 Khz	3.7 **
		8-16 Khz	11.25
		300-600 Khz	1.3
		300-600 Khz	1.2
		300-600 Khz	1.15

Sensi = 7.11×10^{-18} A/nv** (Chamber must read $3.75-6.25 \times 10^{-31}$ amps 2/hz/nv with these settings)

TESTED BY

327

DATE

3/30/79

4.4 Insulating Tube

4.4.1 Visual Inspection

INSPECTED BY

10

DATE

4-5-79

4.5 Final Inspection

4.5.1 Insulation resistance @ 100 ± 5 VDC = 7.1×10^{12} ohms
(I.R. shall be greater than 1×10^{12} ohms).

4.5.2 Voltage breakdown = 540 VDC (VBD shall be between 500-800 VDC).

TESTED BY

10

DATE

4-5-79

4.5.3 Visual Inspection performed by
Date APR 5 1979

10

4.6 Packaging Inspection

4.6.1 Bagging Inspection performed by
Date APR 5 1979

10

4.6.2 I.D. Requirements verified by
Date APR 5 1979

10

4.6.3 Neutron Sensitivity recorded by
Date APR 5 1979

10

4.6.4 Coiling Inspection performed by
Date

S/N 6.612, 689 7/1/79

NO.	TI 700
REV.	10
PAGE	2 of 2



B-21
Aug spec.

TEST DATA SHEETS

IRM DETECTOR

Post-seismic

DRAWING NO. 112C3144 GR. 008 REV. 34/31 SERIAL NO. 6612688PROJECT STOCK T NO. TKKJ7 N NO. N9001

4.0 TEST PROCEDURES

4.1 Heat Run

4.1.1 Insulation Resistance @ 100 Vdc \pm 5 Vdc = N/A ohms
(Before heat at room temperature I.R. shall be $\geq 1 \times 10^{12}$ ohm).TESTED BY N/A DATE N/A4.1.2 Insulation Resistance @ 100 Vdc \pm 5 Vdc = N/A ohms.
(At 600 \pm 30°F -0°F.) (I.R. shall be $\geq 1 \times 10^8$ ohm).TESTED BY N/A DATE N/A4.1.3 Insulation Resistance @ 100 Vdc \pm 5 Vdc = N/A ohms.
(Room temperature after heat run) (I.R. shall be $\geq 1 \times 10^{12}$ ohm).4.1.4 Voltage Breakdown = N/A Vdc (VBD shall be 500-800 Vdc).TESTED BY N/A DATE N/A

4.2 Capacitance Test

4.2.1 Capacitance = N/A pF Total.
Capacitance = N/A pF /FT (Calculate per Dwg. GP. No.)
(Capacitance shall be 25 pF /FT. + 10% - No Lower Limit).TESTED BY N/A DATE N/A

4.3 Gamma Sensitivity Standard

4.3.2 Peak current @ 164 Vdc = 7.55×10^{-8} Amp. Std. S/N A126
 1.40×10^{-14} Std. Sensitivity = 5.37×10^{-6} A/R/HR Flux = 5.39×10^6 R/HR.
 2.8×10^{-14} TESTED BY 321 DATE 5/8/79

TESTED 5/4/79

S/N 6612688

APPENDIX A

NO. TI 700
REV. 11
PAGE 1 OF 1



TEST DATA SHEET

IRM DETECTOR

4.3.7 (Chamber under test)

Peak Current @ 100 \pm 5 Vdc 10.15×10^{-8} AMP.Gamma Sensitivity = $\frac{10.15 \times 10^{-8} \text{ AMP}}{5.39 \times 10^6 \text{ R/HR}} = 1.88 \times 10^{-14} \text{ A/R}$ (Gamma Sensitivity $\leq 3.0 \times 10^{-14} \text{ A/R/HR}$)TESTED BY 327

DATE

5/8/79

4.4 Neutron Sensitivity

TESTED 5/4/79

4.4.1 Preliminary at NTR

4.4.1.5 Null $C_x = 1871$ pF. (Instrument only)4.4.1.6 Null $C_x = 1751$ pF. (Instrument and cable)4.4.1.7 Null $C_x = 880$ pF. (Instrument, Cable & Detector)4.4.1.8 Assembly Capacitance 871 pF.

4.4.2 Neutron Standard

4.4.2.1 Peak Current @ 164 Vdc 15.60×10^{-6} Std. S/N 02Std. Sensitivity 2.03×10^{-17} A/nv. NTR #1 = 5.11×10^{-17} Peak Flux = $\frac{2.03 \times 10^{-17} \text{ AMP}}{\text{A/nv}} = 7.68 \times 10^{-18} \text{ n.}$

4.4.3 Chamber Testing

4.4.3.1 Peak Current @ 100 Vdc 5.38×10^{-6} AMP.NTR #1 @ 100 Vdc 5.01×10^{-6} AMP.Calculated Flux = $\frac{\text{CURRENT OF NTR\#1 (para. 4.4.3.1)}}{\text{CURRENT OF NTR\#1 (para. 4.4.2.1)}}$ X Flux of (para. 4.4.2.1) = 7.62×10^{-18} A/nv.DC Neutron Sensitivity = $\frac{\text{PEAK CURRENT (para. 4.4.3.1)}}{\text{CALCULATED FLUX (para. 4.4.3.1)}}$
 7.06×10^{-18} A/nv.DC Neutron Sensitivity shall be $6.6-8.4 \times 10^{-18} \text{ A/nv.}$ S/N 6612688

APPENDIX A

NO. TI 700REV. 11PAGE 2 OF 3



TEST DATA SHEET

IRM DETECTOR

4.4.3.2 MSV Meter Reads = 4.95×10^{-31} A²/Hz/nv @ 100V 8-16 kHz(MSV Sensitivity shall be $3.75-6.25 \times 10^{-31}$ A²/Hz/nv).TESTED BY 327 DATE 5/8/79

4.5 Insulating Tube

4.5.1 Visual Inspection

INSPECTED BY N/A DATE N/A

4.6 Final Inspection

4.6.1 Insulation Resistance @100 ± 5 Vdc = > 10¹³ ohms.
(I.R. shall be $\geq 1 \times 10^{12}$ ohms).4.6.2 Voltage Breakdown = 546 Vdc.
(VBD shall be 500-800 Vdc).TESTED BY III DATE 5/8/794.6.3 Assembly Inspection performed by N/A Date N/A

4.7 Packaging Inspection

4.7.1 Bagging Inspection performed by N/A Date N/A4.7.2 I.D. Requirements verified by N/A Date N/A4.7.3 Neutron Sensitivity Recorded by N/A Date N/A4.7.4 Coiling Inspection Performed by N/A Date N/A

4.8 Accumulate Records for Records Package

S/N 6612688

APPENDIX A

NO.	TI 700
REV.	11
PAGE	3 OF 3



ENGINEERING CALCULATION SHEET

NUMBER _____




DATE May 2, 1979

SUBJECT IPM Seismic Test

BY Phil Whitten

SHEET _____

OF _____



Cleveland, Ohio Printed in U.S.A.

No measurable signal at this sensitivity




Test duration 21.3 sec



GENERAL ELECTRIC CO.
Nuclear Energy Division
ENGINEERING CALCULATION SHEET

B-75

NUMBER _____ DATE May 2, 1979
SUBJECT IRM Sensitivity Test BY [Signature] SHEET _____ OF _____



Test duration 21.4 sec





ENGINEERING CALCULATION SHEET

NUMBER _____




DATE May 2, 1979SUBJECT IRM Seismic TestBY John B. Bill

SHEET _____

OF _____



25 PM/SEC
 4×10^{-4}
 5/2/79
 4,612,658
 OBE #3 IRM



No measurable
 signal at this
 sensitivity

Test duration 20.8 sec



ENGINEERING CALCULATION SHEET

B-37

NUMBER

DATE

May 2 1979

SUBJECT




IRM Seismic Test

BY

H. J. Vito

SHEET

OF



No measurable
signal at this
sensitivity

Test duration 21.2 sec



ENGINEERING CALCULATION SHEET

B-78

NUMBER _____ DATE May 2 1979
SUBJECT IRM Seismic Test BY B.R. Miller SHEET _____ OF _____

Printed in USA Cleveland Ohio			

25 mm/sec
 10.10 sec
 0.3
 5/2/79
 6, 612, 658
 OBE = 5 IRM

End

No measurable signal at this sensitivity

Test duration 21.2 sec



GENERAL ELECTRIC CO.
Nuclear Energy Division

ENGINEERING CALCULATION SHEET




B-29

NUMBER _____

DATE May 2, 1979SUBJECT IRM Sensitivity TestBY W. H. Hester

SHEET _____

OF _____



Max signal $< .2 \times 10^{-6} \text{ A}$
 at this sensitivity

Test duration 20.9 sec



APPENDIX B

Design of a Seismic Test for the Intermediate Range Detector, 112C3144G008

1.0 Seismic Motion

The BWR-6 seismic values will be used because they are more severe than those of earlier plant designs.

Fuel seismic motion will be used to govern the seismic conditions in the core region where the detectors are located. The great relative mass of the fuel assemblies, the low relative stiffness of the dry tube containing the intermediate range detector, and the small clearance between the fuel and the dry tube insures that the fuel motion will be followed by the dry tube and so by the detector.

Fuel natural frequency is 4.5 Hz.

References 2.1.1 and 2.1.2 list the following maximum accelerations for the fuel (g's).

Location	OBE	SSE
Top	0.895	1.342
Center	2.598	3.897
Bottom	0.585	0.878

This breaks into a uniform acceleration, a linearly varying acceleration, and a nodal acceleration.

Location	OBE Acceleration			SSE Acceleration		
	Uniform	Linear	Nodal	Uniform	Linear	Nodal
Top	0.585	0.310	0	0.878	0.464	0
Center	0.585	0.155	1.858	0.878	0.232	2.787
Bottom	0.585	0	0	0.878	0	0

The center deflection, relative to the end points, is due to the nodal acceleration (the linearly varying acceleration can be considered as a rotation).

With sinusoidal motion assumed, the deflection is proportional to the acceleration and inversely proportional to the square of frequency.

$$X = a/\omega^2 = a/(2\pi f)^2 \quad a = 386.4 \times g's$$

At the center, the maximum deflection is:

	OBE	SSE
X	0.898 in.	1.347 in.



2.0 Detector Clearance

From reference 2.1.5, the median space between full channels, neglecting channel bow, is 1.133 inches for the "C" lattice and 0.907 inches for the "D" lattice, at the center of the fuel. Also, the tolerances for both lattices, including bow of bow oriented fuel channels, are -0.306 inch and +0.131 inch. For the BWR-6, the space is 0.033 inch greater than the "C" lattice (see reference 2.1.7).

The worst case for impacting on the fuel comes with the greatest clearance. The values of maximum clearance are given below. The dry tube has the same diameter for each lattice (0.69 inch per 135139937).

Lattice	"C"	"D"	BWR-6
Max space	1.264	1.038	1.297
Dry Tube Dia	0.690	0.690	0.690
Net space	0.574	0.348	0.607

Additional spaces exist between the dry tube and shuttle tube and the shuttle tube and the detector. The dry tube has an I.D. of 0.500 inch and the shuttle tube (175A7278P019) has an O.D. of 0.375 inch and an I.D. of 0.305 inch. This provides a detector space of:

$$S = 0.305 + (0.500 - 0.375) = 0.430 \text{ inch}$$

This space is in addition to the space of the dry tube within the fuel. From the above, it is seen that the BWR-6 represents the greatest space and so the worst case. The total space about the detector is then $0.607 + 0.430 = 1.037$ inch.

This is the space to be used as a standard for the test.

3.0 Test Frequency

The fuel natural frequency is 4.5 Hz, so the test is to be run corresponding to that value.

The test is run at room temperature rather than at the detector operating temperature, so the test will have to be increased in severity to account for the greater strength of material at room temperature.

The reactor operating temperature is 552°F.

Detector material is titanium with room temperature yield strength of 50,000 psi (167A2983). At 552°F, the yield strength will be about 21,000 psi (Reactive Metals, Inc.). The strength ratio is then $50/21 = 2.38$ for room temperature vs. 552°F.



The impact energy is a function of velocity squared, so the square of the test frequency must equal the value of the square of the seismic frequency times the 2.38 factor.

$$(F_T)^2 = 2.38 (F_S)^2 = 2.38 (4.5)^2 = 48.195$$

$$F_T = 6.9 \text{ Hz or } 416.5 \text{ RPM}$$

4.0 Test Duration

The duration of the seismic event was determined by reviewing seismic durations for a number of plants.

Plant	Seismic duration, sec.
Perry	20
Black Fox	15
Clinton	10
Cofrentes	20

For conservatism, a 30 second duration is selected.

For the tests, the number of impacts should be kept the same as would be experienced in a seismic event. Since the tests are run at a higher frequency than actual, the test times can be shortened accordingly.

With the tests run at 420 RPM, the test duration should be:

$$T = \frac{(4.5\text{Hz}) \times (60 \text{ sec/min}) \times (30 \text{ sec})}{420 \text{ RPM}} = 19.29 \text{ seconds}$$

5.0 Recommended Test Parameters

The detector is to be run by a driver moving at the test frequency and amplitude and having a gap equal to the shuttle tube inside diameter and the other clearances. These values were determined above. For conservatism, the values will be increased to some recommended values.

Item	Calculated Value	Recommended Value
Driver Gap, in	1.037	1.125
OBE Travel*, in*	1.796	2.000
SSE Travel, in*	2.694	3.000
Test RPM	416.5	420
Test Duration, sec	19.29	20

*Travel is 2X calculated fuel deflection



6.0 Conservatism Factors

Conservatism factors can be divided into two categories: those that can be calculated and those that cannot readily have a value attached.

6.1 Calculated Conservatism Factors

6.1.1 Driver Gap

In this case, the impacting is proportional to the clearance between the driver and the detector. That value is the gap less the detector diameter (0.265 in).

$$C_{DG} = \frac{1.125 - 0.265}{1.037 - 0.265} = 1.114$$

6.1.2 Driver Travel

Here, impact is proportional to the amplitude of driver motion.

$$C_{DT,OBE} = \frac{2.000}{1.796} = 1.114$$

$$C_{DT,SSE} = \frac{3.000}{2.694} = 1.114$$

6.1.3 Driver Velocity

Impact energy is proportional to the square of the frequency (or RPM) of the driver.

$$C_{DV} = \left(\frac{420}{416.5} \right)^2 = 1.017$$

6.1.4 Detector Location

The calculation has been based on the maximum motion of the fuel at its center. The detector however is actually located 18 inches away from fuel center (references 2.18 through 2.1.11). Therefore, the actual movement is less. The fuel length is approximately 170 inches (Reference 2.1.13). Assuming a sinusoidal deflection curve, the fuel center is at 90° and the detector is located at:

$$90^\circ \pm \frac{18}{170} (180^\circ) = 90^\circ \pm 19.06^\circ$$

$$C_L = \frac{1}{\sin 109.06} = 1.058$$



17



6.1.5 Driver Material

The driver material is aluminum with an elastic modulus of 10×10^6 psi at room temperature. The actual driver is the fuel channel (zirconium) with an elastic modulus of 11×10^6 psi at operating temperature.

$$C_{DM} = \frac{10 \times 10^6}{11 \times 10^6} = 0.909$$

6.1.6 Test Duration

Based on a 30 second seismic event, the required test time is 19.29 seconds (above). The recommended test time is 20 seconds.

$$C_T = \frac{20.00}{19.29} = 1.037$$

6.1.7 Combination of Conservatism Factors

The total conservatism factor is the product of the above determined factors.

$$C = 1.114 \times 1.114 \times 1.017 \times 1.058 \times 0.909 \times 1.037 = 1.259$$

Therefore, it is concluded that the test is about 26% more severe than the actual seismic conditions.

6.2 Non-Calculated Conservatism Factors

6.2.1 Dry Tube and Shuttle Tube

The dry tube and shuttle tube are not included in the test, the impacting being done directly on the detector. Each of these parts, being between the detector and the fuel, serve to reduce the impact energy by absorbing a portion, rather than delivering it all to the detector. Also, because of the length of these parts, the dry tube will be in contact with the fuel at places along its length and will likewise be in contact with the shuttle tube. These points of contact will serve as a form of spring-shock absorber, reducing the actual impacts still further. These effects cannot be readily calculated and so are omitted from the test, adding to the conservatism.

6.2.2 Reactor Water

The presence of reactor water around the dry tube will provide damping of the fuel-dry tube impacts and on the dry tube motion. The test is run in air, so the damping effect is not present and not considered in the test. The damping would reduce impacts, so the test is more severe than the actual case from this standpoint.

The complex geometry of the system makes calculation of this effect difficult.



7.0 Aging Effects

7.1 Temperature

Temperature does not cause a long term change in any of the detector material properties, so temperature aging effects are non-existent.

Short term temperature effects (property changes due to temperature changes) are considered in the test.

7.2 Radiation

The effect of radiation is to increase material yield strength and reduce ductility. The increase in yield strength will improve the ability of the detector to withstand seismic conditions, but the ductility change will have no effect.

Therefore, radiation effects need not be considered.

7.3 Corrosion

The detector is not located in a corrosive environment, so corrosion need not be considered.

8.0 Electrical Test Parameters

8.1 Applied Voltage

The voltage applied to the detector during the seismic test is set at 100 Vdc, as that is the normal operating voltage.

8.2 Test Current Range

The current range in the test was set at a full scale value of 10×10^{-6} Amperes because that is reasonably close to detector operating currents in normal service.

8.3 Chart Recorder Chart Speed


The chart speed was set at a minimum of 10 inches travel for 20 seconds of time to spread data over a long enough chart to see time variant effects.



TITLE

SEISMIC TEST ARRANGEMENT

FIRST MADE FOR



DETECTOR IS HORIZONTAL

FIGURE 2

UNLESS OTHERWISE SPECIFIED USE	APPLIED PRACTICES	SURFACES	TOLERANCES ON MACHINED DIMENSIONS		
			FRACTIONS	DECIMALS	ANGLES
		✓	+	+	+
			-	-	-

REVISIONS

PRINTS TO

APPROVALS	DIV OR DEPT.	LOCATION	CONT ON SHEET	SH NO.

SWEC
PVORT

<u>Component</u> <u>No.</u>	<u>GE Part</u> <u>No.</u>	<u>FSAR</u> <u>P&ID</u>
2SWP*P1A	--	9.2-1
2CSH*P2	E22-C003	6.3-6
2RHS*P2	E12-C003	5.4-13
2SWP*MOV30A	--	9.2-1
2MSS*HYV6A	B22-F022A	10.1-3
2RHS*AOV16A	E12-F041A	5.4-13
2SWP-MOV1A	--	9.2-1
2RHS*MOV9B	E12-F047B	5.4-13
2CCP*AOV37B	--	9.2-3
2MSS*MOV112	B22-F019	10.1-3
2HVK*SOV36A	--	9.4-1
2SVV*RVV101	--	10.1-3
2RHS*MOV2A	E12-F006A	5.4-13



SWEC
SQRT

<u>Component No.</u>	<u>GE Part No.</u>	<u>FSAR P&ID</u>	<u>Remarks</u>
2CMS*PNL66A	--	6.2-71	Not on P&ID
2CES*PNL405	--	None	
2CES*RAK107	--	None	
2CCP*PSLX90A	--	9.2-3	
2CMS*TY131	--	6.2-71	
2HVP*TYV11A	--	9.4-15	Not on P&ID
2CEC*PWR828	--	None	
2EJS*PNL100A	--	None	
2ENS*SWG101	--	None	
2DMS*MCCA1	--	None	
2EGS*EG1	--	None	
2EGS*PNL11	--	None	
2VBA*UPS2A	--	None	
2HTS*PNL003	--	None	
2SWP*MOV30A	--	9.2-1	
2SWP*P1A & M1A	--	9.2-1	
2ICS*PS & M2	E51-C003	5.4-9	
2MSS*1PNL90A	--	None	
2RHS*MOV9A	E12-F047A	5.4-13	
2FWS*MOV21A	B22-F065A	10.1-6	
2HVC*ACU1A	--	9.4-1	
2HVC*CH11A	--	9.4-1	Noted on P&ID as CH1A (typographical error)



SPEC. NO. NMP2-E0150

SORT #10

NINE MILE POINT NUCLEAR STATION UNIT 2

EQUIPMENT DYNAMIC QUALIFICATION

COMPONENT NAME: 125V DC MOTOR CONTROL CENTER

MARK NUMBERS: 2DMS* MCCA1



STONE & WEBSTER

Acct# 3507170148

Ltr ID. 7/8/85

SEISMIC QUALIFICATION STATUS SUMMARY2DMS*MCCA1NMP2-E015Q

The subject equipment at present is not seismically qualified. During review of the vendor submitted qualification documents, it was discovered that a questionable amount of clearance exists between the MCC NEMA 1 enclosure and its encapsulating NEMA 3 enclosure. The MCC qualification was based on testing without a NEMA 3 enclosure. This condition was brought to the attention of the vendor, who in turn decided to perform a new seismic test on two MCC specimens each comprised of NEMA 1 and NEMA 3 enclosures. The test results of 5/23/85 showed that the existing NMP2 configuration of independently standing NEMA 1 and NEMA 3 enclosures (both enclosures are mounted on a common base) is unacceptable. The NEMA 1 and NEMA 3 enclosures of the test specimens were connected to each other with intermediate structural members and additional seismic testing was successfully performed. The seismic test report is being prepared and is scheduled to be submitted by 9/9/85. Field modification of this equipment will be necessary.

General and Physical Description Summary of Equipment

1. Name: White Pine Power Station - Unit 1

2. Manufacturer: White Pine Power Corporation

3. Model Number: 100-10100

4. A/E: White Pine Power Corporation

5. Company Name: White Pine Power Corporation

6. Location: White Pine Power Station

7. Quantity: 1

8. Date of Receipt: 10-1-60

9. Supplier: White Pine Power Corporation

10. This equipment is a component of panel, name and model number of the host are included:

11. SEE ATTACHMENT A

12. Description:

13. Rectangular block with 100-10100

14. 100-10100

15. 100-10100

16. 100-10100

17. 100-10100

18. 100-10100

19. 100-10100

20. 100-10100

21. 100-10100

22. 100-10100

23. 100-10100

24. 100-10100

25. 100-10100

26. 100-10100

27. 100-10100

28. 100-10100

29. 100-10100

Seismic and Dynamic Qualification Summary of EquipmentI. Plant Name: Nine Mile Point Nuclear Station - Unit 21. Utility: Niagara Mohawk Power Corporation2. NSSS: General Electric Co.BWR: 5 MK 23. A/E: Stone & Webster Engineering Corp. OtherII. Component Name: 125V DC MOTOR CONTROL CENTER

1. Scope: () NSSS (X) BOP () Other

2. Model Number: 5600 SERIES Quantity: 13. Size or Range: 125V DC4. Vendor: TELEMECANIQUE, INC.

5. If the component is a cabinet or panel, name and model number of the devices included: _____

SEE ATTACHMENT "A"

6. Physical Description:

a. Appearance: RECTANGULAR BLOCK WITH DOORS ON FRONTb. Dimensions: 120" WIDE X 40" DEEP X 90" HIGHc. Weight: 6060 LBS (MAX. ESTIMATED)7. Location: Building: AUX. BAY - NORTHElevation: 240 FT.

8. Field Mounting Conditions () Bolt (No. _____ - Size _____)

(X) Weld (Length *) SEE BELOW

() _____

9. Mounting Orientation (e.g., on floor, cantilevered, suspended, etc.)

FLOOR MOUNTED10. a. System in which located: MOTOR CONTROL CENTER DC-SYSTEMb. Functional Description: 125V DC POWER SUPPLY SYSTEM

c. Is the equipment required for () Hot Standby () Cold Shutdown (X) Both () Neither () Other _____

* WELDS ON FRONT AND BACK SIDES - 1/4" FILLET X 3" LONG AT EACH END AND CENTER OF EACH NEMA 3 ENCLOSURE; 1/4" FILLET X 1 1/2 IN. LONG ON EACH NEMA 3 ENCLOSURE AT EACH JOINT BETWEEN NEMA 3 ENCLOSURES.

WELDS ON THE CENTER CHANNEL BACK SIDE - 2 WELDS, 1/4" FILLET X 3" LONG, PER EACH 20" MCC SECTION.

1. The first step is to determine the type of data you are working with. This could be numerical, categorical, or a combination of both.

11. Pertinent Reference Design Specifications for Qualification Requirements: NMP2-EO15Q WITH ADDENDA

1 THRU 6

- | | |
|--|-----------------------|
| <input checked="" type="checkbox"/> a. Seismic Input | d. Service Conditions |
| b. Hydrodynamic Load Input | e. Qualified Life |
| c. Fatigue Considerations | |

III. Is Equipment Available for Inspection in the Plant:

☒ Yes () No () Partial or limited availability

IV. Equipment Qualification Method:

() Test () Analysis () Combination of Test and Analysis

Qualification Report*: SEISMIC TESTING WAS COMPLETED ON 5-23-85 AT WYLE LABORATORIES, HUNTSVILLE, ALABAMA.

(No., Title and Date): THE TEST REPORT WILL BE AVAILABLE BY 8-9-1985

Company that Prepared Report: _____

Company that Reviewed Report: _____

Where Report is filed or available: _____

Applicable Codes and/or Standards: _____

V. Vibration Input:

1. Loads considered:
- | | |
|----|--|
| a. | <input checked="" type="checkbox"/> Seismic only |
| b. | () Hydrodynamic only |
| c. | () Vibration from normal operation |
| d. | () Combination of (a), (b), and (c) |

2. Method of Combining RRS:

() Absolute Sum () SRSS () N/A
(other, specify)

3. Required Response Spectra** (attach the graphs): SEE ATTACHMENT 'B'

NOTE:

*If more than one report complete items IV thru VII for each report.

**If other than RRS is used, describe method.

...the ... of ...

...the ... of ...

...the ... of ...

...the ... of ...

...the ... of ...

...the ... of ...

...the ... of ...

...the ... of ...

...the ... of ...

...the ... of ...

...the ... of ...

...the ... of ...

...the ... of ...

...the ... of ...

...the ... of ...

...the ... of ...

...the ... of ...

...the ... of ...

...the ... of ...

...the ... of ...

...the ... of ...

...the ... of ...

...the ... of ...

...the ... of ...

...the ... of ...

...the ... of ...

...the ... of ...

...the ... of ...

...the ... of ...

4. Damping Corresponding to RRS: OBE 27. SSE 37.

5. Required Acceleration in Each Direct:

(X) ZPA () Other _____
 (specify)

OBE S/S = 0.20 F/B = 0.20 V = 0.15

SSE S/S = 0.36 F/B = 0.36 V = 0.20

6. Were fatigue effects considered?

() Yes (~~X~~) No

If yes, describe how they were treated in overall qualification program: N/A

VI. If Qualification by Test, then Complete: VENDOR'S TEST REPORT
WILL BE AVAILABLE ON 8-9-85

1. () Single Frequency () Multi-Frequency () Random
 () Sine Beat
 () _____

2. ☐ Single Axis ☐ Multi-Axis
 ☐ Independent Axis ☐ In-phase Motions

3. Number of Qualifications Tests:

OBE _____ SSE _____ Other _____
(specify)

4. Frequency Range: _____ . - .

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S= _____ F/B= _____ V= _____

6. Method of Determining Natural Frequencies
☐ Lab Test ☐ In-Situ Test ☐ Analysis

7. TRS Enveloping RRS Using Multi-Frequency Test

() Yes (Attach TRS & RRS graphs)
() No



8. Maximum Input g Level Test:

OBE S/S = _____ F/B = _____ V = _____

SSE S/S = _____ F/B = _____ V = _____

9. Laboratory Mounting:

A. ☐ Bolt (No. _____ Size _____)
☐ Weld (Length _____) ☐ _____

B. Orientation and Fixturing: _____

10. Functional Operability Verified:

☐ Yes ☐ No ☐ Not Applicable

11. Test Results Including Modifications Made: _____

12. Other Tests Performed (such as aging or fragility test, including results):

13. Failure Modes (If appropriate _____)

14. Margins Available: ☐ Input Spectrum ☐ Fragility

VII. If Qualification by Analysis, Then Complete: N/A

1. Method of Analysis:

☐ Static Analysis ☐ Equivalent Static Analysis
☐ Dynamic Analysis: ☐ Time-History ☐ Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = _____ F/B = _____ V = _____

3. Model Type: ☐ 3D ☐ 2D ☐ 1D
☐ Finite Element ☐ Beam
☐ Closed Form Solution ☐ Other



4. () Computer Codes: _____

Frequency Range and No. of Modes

() Hand Calculations

5. Method of Combining Dynamic Responses from Seismic and Other Dynamic Loads:

() Absolute Sum () SRSS () Other: _____
(specify)

6. Damping:

OBE _____ SSE _____ Basis for the Damping Used: _____

7. Support Considerations in the Model: _____

8. Critical Structural Elements:

	Governing Load or Response Combination	Seismic Stress	Total Stress	Stress Allowable
A. Identification Location				

B. Maximum Critical Deflection	Location	Maximum Allowable Deflection to Assure Functional Operability
-----------------------------------	----------	--

9. Failure Modes: _____

10. Margins Available: () Input Spectrum () Stress or Deflection

1000 1000

1000 1000

1000 1000

1000 1000

1000 1000

1000 1000

1000 1000

1000 1000

1000 1000

1000 1000

1000 1000

1000 1000

1000 1000

1000 1000

1000 1000

1000 1000

1000 1000

1000 1000

1000 1000

1000 1000

1000 1000

1000 1000

1000 1000

1000 1000

1000 1000

1000 1000

1000 1000

ATTACHMENT A

DEVICE LIST

- 1) DWG. NO. (SEW FILE) 0001.340-211-166C BILL OF MATERIALS (1 SHEET)
- 2) DWG. NO. MA-56593-02 SUPPLEMENTAL BILL OF MATERIALS




Rev	Date	DRN	By	Approved	Rev	Date	DRN	By	Approved
1	7-23-01	PER CUST. REQ	DN	<i>[Signature]</i>					
2	8-4-01	" " "	DN	<i>[Signature]</i>					
3	8-3-01	55676	JFH	<i>[Signature]</i>					

SPECIFIC NOTES

- 1) This unit requires voltmeter; 0-750V; voltmeter switch; 2- 100VA PT's; test block and kirk key interlock.
- 2) Provide 1 J10A3111 control relay, 3 NO - 1 NC contacts, 110V coil and a 12 pt terminal block mounted in rear of vertical in approximate same elevation as unit in front.
- 3) Provide 1 J10A4011 control relay, 4 NO contacts, 110V coil; 1- J10A2211 control relay, 2 NO and 2 NC contacts, 110V coil; and a 12 pt terminal block for each relay mounted in rear of vertical in approximate same elevation as unit in front.
- 4) Provide 1- J10A0411 control relay, 4 NC contacts 110V coil and a 12 pt terminal block mounted in rear of vertical in approximate same elevation as unit in front.
- 5) Could to provide bus-tie connection using 600 amp bus bar.
- 6) Provide 2- J10A2211 control relays, 2 NO and 2 NC contacts 110V coil and a 12 pt terminal block for each relay mounted in rear of vertical in approximate same elevation as unit in front.
- 7) Provide -1 J10A2211 control relay 2 NO and 2 NC contacts 110V coil and a 12 pt terminal block for each relay mounted in rear of vertical in approximate same elevation as unit in front.
- 8) Provide 1- TDB Agastat timer cat. #7014ABL 4 pole time delay pick up, 120V coil and a 12 pt terminal block for each mounted in rear of vertical in approximate same elevation as unit in front.

This drawing is the property of Gould Inc., and contains proprietary and confidential information which must not be duplicated, used or disclosed other than as expressly authorized by Gould.

Material:	Scale:	Prod. Code 5560	Niagara Mohawk Power Corp. Nine Mile Point Nuclear Station Stone & Webster Engineering Corp. P.O. #NMP2-B015Q Job #12177 84-56593	
Surface Treatment:	TOLERANCES Unless Otherwise Specified Sheet metal 1/8" to 1/2" 2.00 1/2" to 3/4" 2.00 Hole Punched 2.00 Angle 2.00 Per ASME Y14.5		GOULD Gould Inc., Distribution & Control Division Finksburg, Md. 21048	
NOTE: ALL DIMENSIONS TO BE AFTER PLATING	Drawn <i>NM</i> Date 1-20-01			
USED ON	Approved <i>[Signature]</i> Date 1-29-01		Sheet 1	Rev. 3
REFERENCE DRAWING:	Date 1/29/01		13 84-56593-02	



Rev	Date	DRN	By	Approved	Rev	Date	DRN	By	Approved
1	7-23-81	PER CUST. REQ.	DV	JLB	4	10-28-81	54603	DV	JLB
2	8-4-81	" " "	DV	JLB	5	11-16-81	54686	DV	JLB
3	8-19-81	54382	DV	JLB	6	12-7-81	54700	DV	JLB
					7	5-10-82	55026	DV	JLB
					8	4-22-82	55208	DV	JLB
					9	6-10-82	55861	DV	JLB
					10	7-15-82	55676	JFH	JLB

Specific Notes - continued

- 9) Provide 1- J11A2211 control relay 2 NO and 2 NC contacts 110V coil and a 12 pt terminal block for each relay mounted in rear of vertical in approximate same elevation as unit in front.
- 10) This unit requires kirk key interlock.
- 11) Provide 2- J10A3111 control relays 3 NO - 1 NC contacts 110V coil each with a 12 pt TB mounted in rear of vertical in approximate same elevation as starter.
- 12) This section requires ASCO switch Cat. B-940-3-150-X-9.
- 13) Provide 1- TDB Agastat 4 pole time delay drop out "TDDO", Cat. #7024AHT, 120V coil and a 12- point terminal block for each mounted in rear of vertical in approximate same elevation as in front.
- 14) Two circuit breakers in series - same frame size same trip setting.
- 15) Gould to provide provision bus tie lugs for customer 2- 350 KCM cables per phase.
- 16) Provide 4- J10A3111 control relays 3 NO - 1 NC contacts 110V coil and 1- J10A4211 control relay 4 NO - 2NC contacts, 110V coil and a 12 pt terminal block for each relay mounted in rear of vertical in approximate same elevation as units in front.
- 17) Same as note 8 except Cat. #7014ADL.
- 18) Same as note 8 except Cat. #7014AEL.
- 19) Same as note 8 except Cat. #7014ADLL.
- 20) Same as note 8 except Cat. #7014ACL.
- 21) Provide 1- J13P2212 control relay, 2 NC - 2 NO contacts, 125VDC coil; 1- J13P1312 control relay, 1 NO - 3 NC contacts, 125VDC and a 12 pt terminal block for each relay mounted in rear of vertical in approximate same elevation as unit in front.

This drawing is the property of Gould Inc., and contains proprietary and confidential information which must not be duplicated, used or disclosed other than as expressly authorized by Gould.


Material:	Scale:	Prod. Code	Niagara Mohawk Power Corp. Nine Mile Point Nuclear Station Stone & Webster Engineering Corp. P.O. #NMP2- E015Q Job. #12177 S.O. #84-56593
Surface Treatment:		5600	
NOTE: ALL DIMENSIONS TO BE AFTER PLATING	TOLERANCES (Unless Otherwise Specified) Sheet metal Up to 18" 2.00 18" to 30" 2.00 Hole Punching 2.00 Angle 2.00 Per RDS 1006		GOULD Gould Inc., Distribution & Control Division Finksburg, Md. 21048
USED ON	Drawn	Date	
	N.M.	7-28-81	Sheet 2 of 3 MA-56593-02
		129-81	
REFERENCE DRAWING:		1/29/84	Rev. 10

11-11-11



Rev	Date	DRN	By	Approved	Rev	Date	DRN	By	Approved

- 22) Same as Note 8 except Cat.#7014PRL.
- 23) (Not used.)
- 24) This unit contains: (1) contactor #P11C12, (1) Westinghouse resistor # and 1000 OHM 25W discharge resistor.
- 25) This unit contains: (1) contactor #P11C12, (1) Westinghouse resistor #R11SE2D80 (set at 2.8 OHM), and 1000 OHM 25W discharge resistor.
- 26) This unit contains: (1) contactor #P11C12, (1) Westinghouse resistor #R11SE1D80 (set at 1.5 OHM), and 1500 OHM 12W discharge resistor.
- 27) (Not used.)
- 28) Provide (1) 0-150 voltmeter.



This drawing is the property of Gould Inc., and contains proprietary and confidential information which must not be duplicated, used or disclosed other than as expressly authorized by Gould.

Material:		Scale:	Prod. Code 5600	Niagara Mohawk Power Corp. Nine Mile Point Nuclear Station Stone & Webster Engineering Corp. P.O. #NMP2- E015Q Job. #12177 S.O. #84-56593	
Surface Treatment:		TOLERANCES Unless Otherwise Specified Sheet metal Up to 18" 2.00 18" to 36" 2.00 Hole Punched 2.00 Angle 2.00 Per ASME Y92		GOULD Gould Inc., Distribution & Control Division Finksburg, Md. 21048	
NOTE: ALL DIMENSIONS TO BE AFTER PLATING		Drawn <i>NM</i> Date <i>7-13-82</i> Checked <i>[Signature]</i> Date <i>9-13-82</i> Approved <i>[Signature]</i> Date <i>9/15/82</i>			
USED ON		Sheet 3 of 3		Rev. 0 Des. MA-56593-02	
REFERENCE DRAWINGS:					

ATTACHMENT "B"

RRS FOR AUX. BAY NORTH (SECONDARY CONT.) EL. 240 FT.

DESCRIPTION

PAGE NO.

HORIZONTAL RRS-3% FAULTED CONDITION

81

VERTICAL RRS-3% FAULTED CONDITION

82

HORIZONTAL RRS-2% UPSET CONDITION

79

VERTICAL RRS-2% UPSET

80

77



PSPECTRA VER 01 LEV 08

CONDITION

24 JAN 1989

NINOGARA MONARK-NINE MILES POINT UNIT -2 J.O. 17 MS-1746-0
RRS OF ACCELERATION SECONDARY CONT.(ELEV. 240.0 FT)

MS 1746

MICHAEL K 88

DISK CURVE SET NO.29


HOR DIRECTION

DAMPING VALUES 0.010

0.020

0.040

NOTE: MULTIPLY OF RRS CURVES WITH DAMPING 1X 2X & 4X
THESE CURVES REPRESENT A SPREAD OF +15% AND -15%





PSPECTRA VER 01 LEV 08

CONDITION

24 JAN 1989

NIAONKA MONARK-NINE HILES POINT UNIT -2 J.O. 477 MS-1748-0
RRS OF ACCELERATION SECONDARY CONT.(ELEV. 240.0 FT)

MS 1746


MICHAEL R. CO

DISK CURVE SET NO.29

VER DIRECTION

DAMPING VALUES = 0.010
0.020
0.040

NOTE: MULTIPLET OF RRS CURVES WITH DAMPING 1X 2X & 4X
THESE CURVES REPRESENT A SPREAD OF +18% AND -18%



SPECTRA VER 01 LEV 08

FA CONDITION:

25 JAN 1985

NINOMAN, HONAN-NINE MILES POINT UNIT -2 J.L. 5.77 NS-1747-0
RMS OF ACCELERATION: SECONDARY CONT. (ELEV. 24010 FT)

MS 1743

MICHAEL R. DO

DISK CURVE SET NO. 20

HOR. DIRECTION


DAMPING VALUES = 0.020

NOTE: MULTIPLICATION OF RMS CURVES WITH DAMPING 22.52 & 42
THESE CURVES REPRESENT A SPREAD OF +15% AND -15%

0.030

0.040

ACCELERATION - G
0.00 0.40 0.80 1.20 1.60 2.00 2.40 2.80



FREQUENCY IN HZ



PSPECTRA VER 01 LEV 00

FAVOR CONDITION

25 JAN 1989

NIADARA ROMANK-NINE MILES POINT UNIT -2 J.O.12177 MS-1747-0
RAS OF ACCELERATION SECONDARY CONT.(ELEV. 240.0 FT)

MS 1747


MICHAEL K 00

DISK CURVE SET NO.29

VER DIRECTION

DAMPING VALUES = 0.020
0.030
0.040

NOTE: MULTIPLY OF RAS CURVES WITH DAWING 22 32 & 42
THESE CURVES REPRESENT A SPREAD OF +15% AND -15%





SPEC. NO. E031A

SQRT #11

NINE MILE POINT NUCLEAR STATION UNIT 2

EQUIPMENT DYNAMIC QUALIFICATION

COMPONENT NAME: DIESEL GENERATOR
MARK NUMBERS: 2 EGS * EG1



STONE & WEBSTER



Seismic and Dynamic Qualification Summary of Equipment

I. Plant Name: Nine Mile Point Nuclear Station - Unit 2

1. Utility: Niagara Mohawk Power Corporation

2. WSSS: General Electric Co. BWR: 5 MK 2

3. A/E: Stone & Webster Engineering Corp. Other

II. Component Name: Div I Diesel Generator. Mark # 2EG65*EG1

1. Scope: ☐ WSSS ☒ BOP ☐ Other

2. Model Number: KSV-16-T Quantity: 1

3. Size or Range: 43'-0" x 14'-0" x 15'-5"

4. Vendor: Cooper Energy Services

5. If the component is a cabinet or panel, name and model number of the devices included: All components except

the main Engine Structure (e.g. the Engine mounted systems manifolds, piping, governors, fuel, lube oil and starting air system) are

6. Physical Description: in attachment II

a. Appearance: Engine / Generator / piping assy.

b. Dimensions: 43'-0" x 14'-0" x 15'-5"

c. Weight: 200,000 lbs

7. Location: Building: DG Building.

Elevation: 261'-0" to 287'-6"

8. Field Mounting Conditions ☒ Bolt (No. 5/8 - Size *)
☐ Weld (Length)
☐

9. Mounting Orientation (e.g., on floor, cantilevered, suspended, etc.)

FLOOR MOUNTED

10. a. System in which located: EGP, EGS, EGA & EGF

b. Functional Description: SUPPLY POWER TO 4.16 KV EMERGENCY SWITCHGEAR

c. Is the equipment required for ☐ Hot Standby ☐ Cold Shutdown ☐ Both ☐ Neither ☒ Other LOSS OF OFFSITE POWER SUPPLY

* Different sizes as shown in DNG. EC-58BM-5



11. Pertinent Reference Design Specifications for Qualification Requirements: Spec EO3/A - Standby Diesel

generator systems. upto Add. 6

- a. Seismic Input d. Service Conditions
b. Hydrodynamic Load Input e. Qualified Life
c. Fatigue Considerations

III. Is Equipment Available for Inspection in the Plant:

☒ Yes ☐ No ☐ Partial or limited availability

IV. Equipment Qualification Method:

☐ Test ☐ Analysis ☒ Combination of Test and Analysis

Qualification Report*: *

(No., Title and Date): _____ *

Company that Prepared Report: Cooper Energy Services

Company that Reviewed Report: SWEC

Where Report is filed or available: KMP2 Site.

Applicable Codes and/or Standards: IEEE 344-1975

V. Vibration Input:

R.G. 1.100

1. Loads considered: a. ☒ Seismic only
b. ☐ Hydrodynamic only
c. ☐ Vibration from normal operation
d. ☐ Combination of (a), (b), and (c)

2. Method of Combining RRS:

() Absolute Sum () SRSS (X) $\frac{N/A}{(\text{other, specify})}$

3. Required Response Spectra** (attach the graphs): ATTACHMENT I

NOTE:

*If more than one report complete items IV thru VII for each report.

****If other than RRS is used, describe method.**

1. DOC. ID. NO. CES-0407-i RSTD Dated 9/11/80

2. IEEE 01-040-5010C Overview Cover Sheet. Dated 7/17/84

NOTE: — SEE ATTACHMENT II FOR THE DEVICE QUALIFICATION REPORTS —



4. Damping Corresponding to RRS: OBE 2% SSE 3%

5. Required Acceleration in Each Direct:

☒ ZPA () Other _____
(specify)

OBE S/S = 0.18g F/B = 0.18g V = 0.1g
SSE S/S = 0.32g F/B = 0.32g V = 0.19g } WORST
OF
THE TWO
ELEVATIONS

6. Were fatigue effects considered?

() Yes (X) No

If yes, describe how they were treated in overall qualification program: _____

VI. If Qualification by Test, then Complete: See attachment II

1. () Single Frequency () Multi-Frequency () Random
() Sine Beat
() _____

2. () Single Axis () Multi-Axis
() Independent Axis () In-phase Motions

3. Number of Qualifications Tests:

OBE _____ SSE _____ Other _____
(specify)

4. Frequency Range: _____

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S= _____ F/B= _____ V= _____

6. Method of Determining Natural Frequencies
() Lab Test () In-Situ Test () Analysis

7. TRS Enveloping RRS Using Multi-Frequency Test

() Yes (Attach TRS & RRS graphs)
() No



8. Maximum Input g Level Test:

OBE S/S = _____ F/B = _____ V = _____

SSE S/S = _____ F/B = _____ V = _____

9. Laboratory Mounting:

A. () Bolt (No. _____ Size _____)
() Weld (Length _____) () _____

B. Orientation and Fixturing: _____

10. Functional Operability Verified:

() Yes () No () Not Applicable

11. Test Results Including Modifications Made: _____

12. Other Tests Performed (such as aging or fragility test, including results):

13. Failure Modes (If appropriate _____)

14. Margins Available: () Input Spectrum () Fragility

VII. If Qualification by Analysis, Then Complete: MAIN ENGINE STRUCTURE
[SEE ATTACHMENT 'II' FOR COMPONENTS QUALIFIED BY ANALYSIS.]

1. Method of Analysis:

() Static Analysis

() Equivalent Static Analysis

(X) Dynamic Analysis:

() Time-History

(X) Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

MAIN ENGINE STRUCTURE S/S = 38.06 Hz F/B = 28.52 Hz V = 65.92 Hz

3. Model Type:

(X) 3D

() 2D

() 1D

() Finite Element

(X) Beam

() Closed Form Solution

() Other



4. () Computer Codes: 'MOSSY' - COOPER INHOUSE PROGRAM

Frequency Range and No. of Modes FREQ RANGE: 0-37 HZ.

☒ Hand Calculations

5. Method of Combining Dynamic Responses from Seismic and Other Dynamic Loads:

() Absolute Sum () SRSS (☒ Other: N/A
(specify)

6. Damping:

OBE 27. SSE 37. Basis for the Damping Used: FSAR

7. Support Considerations in the Model: Fixed at the Supports.

8. Critical Structural Elements:

		Governing Load or Response Combination	Seismic Stress	Total Stress	Stress Allowable
A. Identification Location					
Stator Foundation bolt	} seismic & operating	—	42.5 Ksi*	45.5 Ksi	
Outboard Bearing bolt		—	22.43 Ksi	45.5 Ksi	
Centerframe to Base bolt		—	27.2 Ksi	49.0 Ksi	
Turbocharger Support Saddle bolt		—	16.92 Ksi	25.2 Ksi	
B. Maximum Critical Deflection		Location	Maximum Allowable Deflection to Assure Functional Operability		
0.066 inch		Generator Shaft between Rotor and Stator	0.087		


9. Failure Modes: Structural failure

10. Margins Available: (☒ Input Spectrum (☒ Stress or Deflection

* This includes maximum short circuit torque on the generator


)





Attachment - I
 (8 Pages)







PSPECTRA VER 01 LEV 08

66E

6 JUL 1988

NIRAGARA MONARK-NINE MILE POINT 2 L CALCI2177-WNIC3-MS-1928 REV 83

RRS OF ACC.-CONTROL & DIESEL GENERATOR BLOBS.ELEVATION 261.0

JOB 2018


PEAK SPREAD = 15%

DISK CURVE SET NO.4

HOR DIRECTION

DAMPING VALUE = 0.030

ACCELERATION 0.005 0.25 0.50 0.75 1.00 1.25 1.50





PSPECTRA VER 01 LEV 00

88E

6 JUL 1983

NIAGARA MOHAWK-NINE MILE POINT 2 - CALC12177-NM(C)-MS-1928 REV(4)

JOB 2018


RRS OF ACC.-CONTROL & DIESEL GENERATOR BLOOD ELEVATION 261.0

PEAK SPREAD +/-15%

DISK CURVE SET NO. 4

VER DIRECTION

DAMPING VALUE = 0.050





PSPECTRA VER 01 LEV 09

DBE

6 JUL 1983

NIAGARA MOHAWK-NINE MILE POINT, 2. - CALC12177-WHIC1-MS-1928 REV(4)

RMS OF ACC.-CONTROL & DIESEL GENERATOR BLOOD ELEVATION 287.58:0


JOB 2090

PEAK SPREAD +-15%

DISK CURVE, SET NO.3

HOR DIRECTION

DAMPING VALUE = 0.020





PSPECTRA VER 01 LEV 09

08E

8 JUL 1965

NIAGARA MOHAWK-NINE MILE POINT 2 - CALC12177-WHIC)-MS-1920 REV(4)

RRS OF ACC.-CONTROL & DIESEL GENERATOR BLOOD ELEVATION 207.5010


JOB 2090

PEAK SPREAD +-15%

DISK CURVE SET NO.9

VER DIRECTION

DAMPING VALUE = .0.020





PSPECTRA VER 01 LEV 00

00E

8 JUL 1985

WINDMILL MONITORING MILE POINT 2 - CALC12177-MHIC1-MS-1988 REVER

RRS OF ACC.-CONTROL & DIESEL GENERATOR BLOOS ELEVATION 261.0


JOB 209D

PEAK SPREAD 9-15%

DISK CURVE SET NO.4

HOR DIRECTION

DAMPING VALUE 0.020





SPECTRA VER 01 LEV 09

08E

6 JUL 1985

NIAGARA MONARK-NINE MILE POINT 2 - CALC12177-MHIC1-MS-1928 REV143

RRS OF ACC-CONTROL & DIESEL GENERATOR BLOOS ELEVATION 261.0

JOB 2080


PEAK SPREAD 9-15%

DISK CURVE SET NO.4

VER DIRECTION

DAMPING VALUE = 0.020

ACCELERATION 0.00 0.08 0.16 0.24 0.32 0.40 0.48 0.56



FREQUENCY IN HZ



ITEM NO.	COMPONENT NAME/MODEL NO.	QUALIFICATION DOCUMENT NO.	QUALIFICATION METHOD		
			ANALYSIS		TEST
			STATIC	DYNAMIC	
1.	Engine Mounted Systems (This includes combustion air manifold, Exhaust manifold and shutdown butterfly valve, Jacket water headers, Governor Linkages, fuel oil and lube oil systems and starting air system)	CES-0407-2	✓		Attachment - II (10 pages)
2.	Air Intake Filter	CES-0407-3 Rev.1	✓		
3.	Air Intake Silencer	CES-0407-4 Rev.1	✓		
4.	Exhaust Silencer	CES-0407-5 and Spec. Calc. 12177-NM(c)-MS-RS2	✓		
5.	Engine driven Lube Oil Pump	CES-0407-6	✓		
6.	Jacket Water Standpipe	CES-0407-7 Rev.1		✓	
7.	Jacket Water Circulating pump Model: Crane-Deming. Model 4221 Size 2M	CES-0407-8	✓		



ITEM NO.	COMPONENT NAME/MODEL NO.	QUALIFICATION DOCUMENT NO.	QUALIFICATION METHOD		
			ANALYSIS		TEST
			STATIC	DYNAMIC	
8.	Fuel oil filter & Strainer	CES-0407-9 Rev. 1		✓	
9.	Turbo charger Lube Oil Filter	CES-0407-10		✓	
10.	3" Check Valve	CES-0407-11	✓		
11.	6" Check Valve	CES-0407-12	✓		
12.	Lube Oil and Jacket Water heater	CES-0407-14	✓		
13.	Auxiliary Skid Piping	CES-0407-15 Supplemented by SWEC Calc. 12177-NM(c)-MS-1870	✓	✓	



ITEM NO.	COMPONENT NAME/MODEL NO.	QUALIFICATION DOCUMENT NO.	QUALIFICATION METHOD		
			ANALYSIS		TEST
			STATIC	DYNAMIC	
14.	Exhaust Expansion Joint P/N 2-05P-102-002	CES-0407-16	✓		
15.	Intake Expansion Joint P/N 2-05P-102-101	CES-0407-17	✓		
16.	Governor Actuator and Overspeed Governor Model # EGB-50 P/LS Model # UG-8L (actuator) (Overspeed Governor)	CES-0407-18			✓
17.	Intercooler Water Piping P/N KSV-91-23	CES-0407-19	✓		
18.	Starting Air Tank P/N KSV-48-21	CES-0407-20	✓		
19.	Lube Oil Filter Model 25410-5113-27-6FGK2	CES-0407-21	✓		



ITEM NO.	COMPONENT NAME/MODEL NO.	QUALIFICATION DOCUMENT NO.	QUALIFICATION METHOD		
			ANALYSIS		TEST
			STATIC	DYNAMIC	
20.	Outboard Bearing P/N 2-05B-013-008	CES- 0407-22	✓		
21.	Jacket Water Cooler	CES -0407-23		✓	
22.	Lube Oil Heat Exchanger	CES - 0407-24		✓	
23..	Generator : 5500 kVA, 600 RPM - synchronous Generator and AC outlet box.	CES - 0407-25			
	Stator & Brush mounting Structure.			→ ✓	
	AC outlet Box				→ ✓
24..	Starting Air Separator P/N 2-07C-129-001		✓		
25.	Lube Oil Strainer Model: ZURN 6" SINLEX BASKET	CES- 0407-27 Rev.2	✓		



ITEM NO.	COMPONENT NAME/MODEL NO.	QUALIFICATION DOCUMENT NO.	QUALIFICATION METHOD		
			ANALYSIS		TEST
			STATIC	DYNAMIC	
26.	Jacket Water thermostatic Valve. Model: AMOT 4 BAS	CES-0407-28 Rev.B	✓		✓
27.	Lube Oil Thermostatic Valve Model: AMOT 5 HAS	CES-0407-29	✓		✓
28.	Standby Fuel Oil Booster Pump. Model: Delaval IMO Screw type N3DBS-137 & Westinghouse Motor	CES-0407-30 Rev. 4-6-83	✓		
29.	Lube Oil Circulating Pump Model: Delaval IMO Screw type NA3DVS275 & Westinghouse Motor	CES-0407-31 Rev. 4-6-83	✓		
30.	Starting Air Relief Valve on Compressor. MODEL: Crosby $\frac{3}{4}$ " x 1 JMB Assy # 62551	CES-0407-32 Rev. 1	✓		



ITEM NO.	COMPONENT NAME/MODEL NO.	QUALIFICATION DOCUMENT NO.	QUALIFICATION METHOD		
			ANALYSIS		TEST
			STATIC	DYNAMIC	
31.	Air Compressor Model: Kellogg American model B-352-SBT Compressor. Plus Reliance Motor 15HP, 1760 RPM, 575V, 3 ϕ , 60 Hz, 254T Frame, type PB	CES-0407-33 Rev. 11-16-82	✓		
32.	Engine Driven Water Pump Model: Allis-Chalmers 6X5X11 NR C16 Wet End Kit Pump	CES-0407-34 With Add. A	✓		
33	Intercooler Model: PERFEX # 500-L-242	CES-0407-35 with Add. 1	✓		
34.	Engine Driven Fuel Oil Booster Pump. Model: Roper Pump 17-AM-08	CES-0407-36	✓		



ITEM NO.	COMPONENT NAME/MODEL NO.	QUALIFICATION DOCUMENT NO.	QUALIFICATION METHOD		
			ANALYSIS		TEST
			STATIC	DYNAMIC	
35.	Jacket Water thermo regulating Valve Model: Robert Shaw Controls 6" Model RT-1007-A1	CES-0407-37 Rev. A	✓		
36.	Control System Components Control Valve Two Way Valve Excess Flow Check Valve Ratio Relay Pressure Switch Differential Pressure Switch Temperature Switch Choke Check Valve Pressure Switch Pressure Switch Differential Pressure Gauge with Switch Differential Pressure Gauge with Switch Differential Pressure Gauge with Switch Micro Switch Three Way Valve Two Way Valve 50 Micron Filter Differential Temperature Switch	CES-0407-38 including Wyle Report WR-83-06 as supplement 223-1-1#5 2-01V-044-001 2-01V-412-001 2-04C-094-003 2-04S-063-006-2 2-04S-385-001 2-04S-031-010 2-04S-001 2-04S-063-004 2-04S-063-006-1 2-04S-187-107 2-04S-187-108-1 2-04S-187-108-2 2-04S-378-001 2-05V-380-001 2-10C-016-001 2-06C-136-101 2-04S-031-012			✓



ITEM NO.	COMPONENT NAME/MODEL NO.	QUALIFICATION DOCUMENT NO.	QUALIFICATION METHOD		
			ANALYSIS		TEST
			STATIC	DYNAMIC	
	Diaphragm Valve Pressure Switch Pressure Switch Three Way Valve 10 Micron Filter Solenoid Valve Shuttle Valve Pressure Switch Solenoid Valve Pressure Switch Shuttle Valve Pressure Switch Pressure Switch Pressure Switch Ball Valve Ball Valve Pressure Gauge Pressure Gauge	2-01V-426-001 2-04S-399-001-1 2-04S-399-001-2 2-05V-396-001 2-06C-161-103 2-05V-399-001 2-04S-4540-9 2-04S-063-008-2 2-05V-399-002 2-04S-063-014 2-01V-077-002 2-04S-063-008-1 2-04S-063-005-1 2-04S-063-005-2 2-01V-411-004 2-01V-411-010 2-01J-709-068 2-01J-709-069			✓



ITEM NO.	COMPONENT NAME/MODEL NO.	QUALIFICATION DOCUMENT NO.	QUALIFICATION METHOD		
			ANALYSIS		TEST
			STATIC	DYNAMIC	
37.	Jacket Water Level Switches Model: Magnetrol International A103F-TDM-EP/VP-S1MD A103F-3X-TDM-EP/VP	CES-0407-39A Plus Letter dated 5/3/84 from Cooper to SWEC			✓
38.	Lube Oil Relief Valve Crosby 2J3 JO-25-WR, 2x3 Assy # N61878	CES-0407-40	✓		
39.	Fuel Oil Relief Valve Crosby 1x1½ JMB-WR Assy # N62581	CES-0407-41	✓		
40.	Starting Air Relief Valve Crosby ¾ x 1 JMBU-SPL Assy # N61877 N61876 N62550	CES-0407-42 Rev. 1	✓		



ITEM NO.	COMPONENT NAME/MODEL NO.	QUALIFICATION DOCUMENT NO.	QUALIFICATION METHOD		
			ANALYSIS		TEST
			STATIC	DYNAMIC	
41.	Fuel Oil Cooler Model : American Standard 5-241-05-024-001 CES P/N 2-024-730-001	CES-0407-44 Rev.1	✓		



SPEC. NO. NMP2-E031A

SQRT #12

NINE MILE POINT NUCLEAR STATION UNIT 2

EQUIPMENT DYNAMIC QUALIFICATION

COMPONENT NAME: HIGH VOLTAGE PANEL

MARK NUMBERS: 2EGS * PNL 11



STONE & WEBSTER

Seismic and Dynamic Qualification Summary of Equipment**I. Plant Name:** Nine Mile Point Nuclear Station - Unit 21. **Utility:** Niagara Mohawk Power Corporation2. **WSSS:** General Electric Co.**BWR:** 5 MK 23. **A/E:** Stone & Webster Engineering Corp. Other**II. Component Name:** STANDBY DIESEL GENERATOR SYSTEMS -
DIV. I HIGH VOLTAGE CUBICLE; MARK NO. 2EG5*PNL 111. **Scope:** () WSSS (X) BOP () Other2. **Model Number:** N/A **Quantity:** 13. **Size or Range:** N/A4. **Vendor:** COOPER ENERGY SERVICES5. **If the component is a cabinet or panel, name and model number of the devices included:**SEE ATTACHMENT "A"6. **Physical Description:**a. **Appearance:** RECTANGULAR BLOCKb. **Dimensions:** 80" WIDE X 48" DEEP X 84" HIGHc. **Weight:** 5520 LBS7. **Location:** **Building:** DIESEL GENERATOR BUILDING**Elevation:** 261 FT.8. **Field Mounting Conditions** (X) Bolt (No. 14 - Size 5/8")
() Weld (Length)
() 9. **Mounting Orientation (e.g., on floor, cantilevered, suspended, etc.)**FLOOR MOUNTED ON INTERMEDIATE SUPPORT
GENERATOR STANDBY SYSTEM &10. a. **System in which located:** GENERATOR STANDBY PROTECTION SYSTEM
POWER SUPPLY TO DIESEL GENERATOR
b. **Functional Description:** STATIC EXCITERc. **Is the equipment required for** () Hot Standby () Cold
Shutdown () Both () Neither (X) Other LOSS OF OFFSITE POWER
OR LOCA OR DURING
DIESEL GENERATOR TESTING



11. Pertinent Reference Design Specifications for Qualification Requirements: NMP2-E031A WITH ADDENDA

1 THRU 6

- | | |
|--|-----------------------|
| a. <input checked="" type="checkbox"/> Seismic Input | d. Service Conditions |
| b. Hydrodynamic Load Input | e. Qualified Life |
| c. Fatigue Considerations | |

III. Is Equipment Available for Inspection in the Plant:

☒ Yes () No () Partial or limited availability

IV. Equipment Qualification Method:

☒ Test () Analysis () Combination of Test and Analysis

Qualification Report*: SEW FILE NO. IEEE 01090-5012A,B
SEISMIC SIMULATION TEST PROGRAM ON A HIGH
(No., Title and Date): VOLTAGE CUBICLE, REPORT # CES-0407-45, 2-17-82

Company that Prepared Report: COOPER ENERGY SERVICES

Company that Reviewed Report: SWEC

Where Report is filed or available: NMP2 SITE

Applicable Codes and/or Standards: IEEE 344-1975, R.G. 1.100

V. Vibration Input:

1. Loads considered:
- | |
|---|
| a. <input checked="" type="checkbox"/> Seismic only |
| b. () Hydrodynamic only |
| c. () Vibration from normal operation |
| d. () Combination of (a), (b), and (c) |

2. Method of Combining RRS:

() Absolute Sum () SRSS () N/A
(other, specify)

3. Required Response Spectra** (attach the graphs): SEE ATTACHMENT "B"

NOTE:

*If more than one report complete items IV thru VII for each report.

**If other than RRS is used, describe method.



4. Damping Corresponding to RRS: OBE 2% SSE 3%

5. Required Acceleration in Each Direct:

☒ ZPA () Other _____
(specify)

OBE S/S = 0.13 F/B = 0.13 V = 0.10

SSE S/S = 0.24 F/B = 0.24 V = 0.19

6. Were fatigue effects considered?

() Yes ☒ No

If yes, describe how they were treated in overall qualification program: N/A

VI. If Qualification by Test, then Complete:

1. () Single Frequency ☒ Multi-Frequency ☒ Random
() Sine Beat
() _____

2. () Single Axis ☒ Multi-Axis
☒ Independent MOTION () In-phase Motions

3. Number of Qualifications Tests:

OBE 5 SSE 1 Other _____
(specify)

4. Frequency Range: 0.5 HZ TO 40 HZ

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = 6.2 HZ F/B = 6 HZ V = 16.5 HZ

6. Method of Determining Natural Frequencies
☒ Lab Test () In-Situ Test () Analysis

7. TRS Enveloping RRS Using Multi-Frequency Test

☒ Yes (Attach TRS & RRS graphs) SEE ATTACHMENT "C"
() No



8. Maximum Input g Level Test:

OBE S/S = 0.85 F/B = 0.8 V = 0.3

SSE S/S = 1.05 F/B = 1.0 V = 0.6

9. Laboratory Mounting:

A. ☒ Bolt (No. _____ Size 5/8-11) GRADE 2
() Weld (Length _____) () _____

B. Orientation and Fixturing: MOUNTED TO A BASE-MOUNT TEST FIXTURE WHICH WAS WELDED TO THE TEST TABLE

10. Functional Operability Verified:

☒ Yes () No () Not Applicable

11. Test Results Including Modifications Made: THE EQUIPMENT SUCCESSFULLY PASSED THE SEISMIC TEST

12. Other Tests Performed (such as aging or fragility test, including results):

NONE

13. Failure Modes (If appropriate) ELECTRICAL & STRUCTURAL

14. Margins Available: ☒ Input Spectrum () Fragility

VII. If Qualification by Analysis, Then Complete: N/A

1. Method of Analysis:

() Static Analysis () Equivalent Static Analysis
() Dynamic Analysis: () Time-History () Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = _____ F/B = _____ V = _____

3. Model Type: () 3D () 2D () 1D
() Finite Element () Beam
() Closed Form Solution () Other



4. () Computer Codes: _____

Frequency Range and No. of Modes

() Hand Calculations

5. Method of Combining Dynamic Responses from Seismic and Other Dynamic Loads:

() Absolute Sum () SRSS () Other: _____
(specify)

6. Damping:

OBE _____ SSE _____ Basis for the Damping Used: _____

7. Support Considerations in the Model: _____

8. Critical Structural Elements:

A. Identification Location	Governing Load or Response Combination	Seismic Stress	Total Stress	Stress Allowable
----------------------------	--	-------------------	-----------------	---------------------

B. Maximum Critical Deflection	Location	Maximum Allowable Deflection to Assure Functional Operability
-----------------------------------	----------	--

9. Failure Modes: _____

10. Margins Available: () Input Spectrum () Stress or Deflection



ATTACHMENT A"

DEVICE LIST

DESCRIPTION

PART NO.

FAN

DAYTON 2C100

SPACE HEATER

CHROMALOX 129374

THERMOSTAT

CHROMALOX 263185

POTENTIAL TRANSFORMER

W.H. TYPE PE60

PARALLELING CURRENT -

PORTEC AC1616-4

- TRANSFORMER

POTENTIAL TRANSFORMER

PORTEC CD1362

REACTORS

PORTEC CD1361

CURRENT TRANSFORMER

PORTEC CD1360



ATTACHMENT "B"RRS FOR DIESEL GENERATOR BUILDING EL. 261 FT.

<u>DESCRIPTION</u>	<u>PAGE NO.</u>
HORIZONTAL RRS - 3% SSE	49
VERTICAL RRS - 3% SSE	50
HORIZONTAL RRS - 2% OBE	97
VERTICAL RRS - 2% OBE	98



PSPECTRA VER 01 LEV 09

88E

8 JUL 1989

NINORRA ROMARK-NINE MILE POINT 2 L CALC12177-MHC1-M8-1928 REV(3)

RRS OF ACC.-CONTROL & DIESEL GENERATOR BLDGS. ELEVATION 251.0


JOB 2019

PEAK SPREAD 152

DISK CURVE SET NO. 4

HOR DIRECTION

DAMPING VALUE = 0.050





PSPECTRA VER D1 LEV 09

58E

6 JUL 1983

NICARAGUA MOHAWK-NINE MILE POINT 2 - CALC12177-WH(C)-MS-1028 REV(4)

RRS OF ACC.-CONTROL. & DIESEL GENERATOR BLOODS ELEVATION 281.0


JOB 2018

PEAK SPREAD 15%


DISK CURVE SET NO. 4

VER DIRECTION

DAMPING VALUE = 0.050









PSPECTRA VER 01 LEV 09

08E

8 JUL 1965

WISDOMA HOMMAK-NINE MILE POINT 2 - CALC12177-MH(C)-MS-1928 REV163

JOB 2080

RRS OF ACC-CONTROL & DIESEL GENERATOR BLDGS ELEVATION 261.01


PEAK SPREAD 9-15X

DISK CURVE SET NO.4

VER DIRECTION

DAMPING VALUE = 0.020

ACCELERATION G
0.00 0.08 0.16 0.24 0.32 0.40 0.48 0.56



FREQUENCY IN HZ



ATTACHMENT "C"TRS FROM TEST REPORT

<u>DESCRIPTION</u>	<u>PAGE NO.</u>
FRONT-TO-BACK 3% SSE	44
VERTICAL 3% SSE	45
SIDE-TO-SIDE 3% SSE	54
VERTICAL 3% SSE	55
FRONT-TO-BACK 2% OBE	—
VERTICAL 2% OBE	—
SIDE-TO-SIDE 2% OBE	—
VERTICAL 2% OBE	—




Report No. 45146-2

FULL SCALE SHOCK SPECTRUM (g Peak)

1.0 ☐ 10 ☐ 100 ☒ 1000 ☐

DAMPING 3 %



SPECIMEN _____

AXIS FB/V

LOCATION NO. HCA


TEST RUN NO. 8



Page No. 45
Report No. 45146-2
FULL SCALE SHOCK SPECTRUM (g Peak)

1.0 □ 10 □ 100 □ 1000 □

DAMPING 3 %



SPECIMEN

LOCATION NO. VCA


AXIS FB/V

TEST RUN NO. 8

FULL SCALE SHOCK SPECTRUM (g Peak)

1.0 ☐ 10 ☐ 100 ☒ 1000 ☐

DAMPING ☐ 3 % ☒



SPECIMEN

LOCATION NO. HCA

AXIS SS/U


TEST RUN NO. 15



FULL SCALE SHOCK SPECTRUM (g Peak)

1.0 ☐ 10 ☐ 100 ☒ 1000 ☐

DAMPING ☒ %



SPECIMEN

LOCATION NO. VCA

AXIS SS/V


TEST RUN NO. 15



FULL SCALE SHOCK SPECTRUM (g Peak)

1.0 ☐ 10 ☐ 100 ☒ 1000 ☐

DAMPING ☐ 2% ☒



SPECIMEN
AXIS FB/V

LOCATION NO. HCA
TEST RUN NO. 3



FULL SCALE SHOCK SPECTRUM (g Peak)

1.0 ☐ 10 ☐ 100 ☒ 1000 ☐

DAMPING ☒ 2%

LOGARITHMIC
3 X 3 CYCLES

Acceleration (g peak)

Frequency (Hz)

SPECIMEN

LOCATION NO. NCA

AXIS FB/V


TEST RUN NO. 3



FULL SCALE SHOCK SPECTRUM (g Peak)

1.0 ☐ 10 ☐ 100 ☒ 1000 ☐

DAMPING ☒ 2%



SPECIMEN

LOCATION NO. LCA

AXIS SS/√


TEST RUN NO. 10



FULL SCALE SHOCK SPECTRUM (g Peak)

1.0 ☐ 10 ☐ 100 ☒ 1000 ☐

DAMPING ☐ 2% ☒



LOGARITHMIC
5 X 3 CYCLES

SPECIMEN SS/V

AXIS SS/V

LOCATION NO. VCA

TEST RUN NO. 10



NINE MILE POINT NUCLEAR STATION UNIT 2

EQUIPMENT DYNAMIC QUALIFICATION

COMPONENT NAME: UNINTERRUPTIBLE POWER SUPPLY
MARK NUMBERS: 2VBA * UPS2A



STONE & WEBSTER

Seismic and Dynamic Qualification Summary of Equipment**I. Plant Name:** Nine Mile Point Nuclear Station - Unit 21. Utility: Niagara Mohawk Power Corporation2. MSSS: General Electric Co. BWR: 5 MK 23. A/E: Stone & Webster Engineering Corp. Other _____**II. Component Name:** UNINTERRUPTIBLE POWER SUPPLY; MARK NO. 2VBA*UPS2A

1. Scope: () MSSS (✓) BOP () Other

2. Model Number: UPS253-1-106 Quantity: 13. Size or Range: 25KVA4. Vendor: ELGAR CORPORATION

5. If the component is a cabinet or panel, name and model number of the devices included: _____

SEE ATTACHMENT "A"

6. Physical Description:

a. Appearance: RECTANGULAR BLOCK WITH DOORS ON FRONT,b. Dimensions: 102" WIDE x 32" DEEP x 77.75" HIGHc. Weight: 4400 LBS7. Location: Building: CONTROL BUILDINGElevation: 261 FT.

8. Field Mounting Conditions () Bolt (No. _____ - Size _____)

(X) Weld (Length *)

() _____

9. Mounting Orientation (e.g., on floor, cantilevered, suspended, etc.)

FLOOR MOUNTED10. a. System in which located: YBS SYSTEM - UNINTERRUPTIBLE 120VAC POWER SOURCE FOR CONTROL CIRCUITb. Functional Description: 120V AC POWER SUPPLY

c. Is the equipment required for () Hot Standby () Cold Shutdown (X) Both () Neither () Other _____

* - (10) $\frac{3}{16}$ " x 5' LONG ON SIDES OF THE MOUNTING LEGS PLUS $\frac{3}{16}$ " WELDS ON THE ENTIRE WIDTH OF THE FRONT OF EACH OF THE FOUR MOUNTING LEGS.

11. Pertinent Reference Design Specifications for Qualification Requirements: NMP2-E035A WITH ADDENDA[#]

1 THRU 4; E&DCR[#] P40,962

- | | |
|--|-----------------------|
| <input checked="" type="checkbox"/> a. Seismic Input | d. Service Conditions |
| b. Hydrodynamic Load Input | e. Qualified Life |
| c. Fatigue Considerations | |

III. Is Equipment Available for Inspection in the Plant:

☒ Yes () No () Partial or limited availability

IV. Equipment Qualification Method:

☒ Test () Analysis () Combination of Test and Analysis

Qualification Report*: SEE FILE NO. IEEE 01560-5011A
QUALIFICATION REPORT ELGAR DOCUMENT NO.
(No., Title and Date): 1006617 FOR ELGAR MODEL UPS-1-106, OCTOBER-1984

Company that Prepared Report: PROBABILISTIC SOFTWARE, INC.

Company that Reviewed Report: SWEC

Where Report is filed or available: NMP2 SITE

Applicable Codes and/or Standards: IEEE 344-1975, R.G.1.100

V. Vibration Input:

1. Loads considered:
- | |
|---|
| a. <input checked="" type="checkbox"/> Seismic only |
| b. () Hydrodynamic only |
| c. () Vibration from normal operation |
| d. () Combination of (a), (b), and (c) |

2. Method of Combining RRS:

() Absolute Sum () SRSS () N/A
(other, specify)

3. Required Response Spectra** (attach the graphs): SEE ATTACHMENT "B"

NOTE:

*If more than one report complete items IV thru VII for each report.

**If other than RRS is used, describe method.



4. Damping Corresponding to RRS: OBE 2% SSE 3%

5. Required Acceleration in Each Direct:

☒ ZPA () Other _____
(specify)

OBE S/S = 0.13 F/B = 0.13 V = 0.10

SSE S/S = 0.24 F/B = 0.24 V = 0.19

6. Were fatigue effects considered?

() Yes ☒ No

If yes, describe how they were treated in overall qualification program: N/A

VI. If Qualification by Test, then Complete:

1. () Single Frequency ☒ Multi-Frequency ☒ Random
() Sine Beat
() _____

2. () Single Axis ☒ Multi-Axis
☒ Independent MOTION () In-phase Motions

3. Number of Qualifications Tests:

OBE 5 SSE 1 Other _____
(specify)

4. Frequency Range: 1.25 Hz TO 35 Hz -

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = 8 Hz F/B = 12 Hz V = 13 Hz

6. Method of Determining Natural Frequencies
☒ Lab Test () In-Situ Test () Analysis

7. TRS Enveloping RRS Using Multi-Frequency Test

☒ Yes (Attach TRS & RRS graphs) SEE ATTACHMENT "C"
() No

8. Maximum Input g Level Test:

OBE S/S = 1.0g F/B = 0.9g V = 0.9g

SSE S/S = 1.7g F/B = 1.6g V = 2.0g

9. Laboratory Mounting:

A. ☐ Bolt (No. _____ Size _____)
☒ Weld (Length 4k) ☐ _____

* (10) $\frac{3}{16}$ x 5" LONG WELDS
ON SIDES OF LEGS + $\frac{3}{16}$ "
FILLET WELDS ACROSS
ENTIRE FRONT WIDTH OF
MOUNTING LEGS

B. Orientation and Fixturing: MOUNTED ON BASE-MOUNT FIXTURE WHICH IN TURN
WAS WELDED TO THE TEST TABLE.

10. Functional Operability Verified:

☒ Yes ☐ No ☐ Not Applicable

11. Test Results Including Modifications Made: THE EQUIPMENT
SUCCESSFULLY PASSED THE SEISMIC TEST WITH GREATER
THAN 10% MARGIN

12. Other Tests Performed (such as aging or fragility test,
including results):

ALL TEST PERTINENT TO IEEE 323-1974

13. Failure Modes (If appropriate) ELECTRICAL & STRUCTURAL

14. Margins Available: ☒ Input Spectrum ☐ Fragility

VII. If Qualification by Analysis, Then Complete: N/A

1. Method of Analysis:

☐ Static Analysis

☐ Equivalent Static Analysis

☐ Dynamic Analysis:

☐ Time-History ☐ Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back,
Vertical):

S/S = _____ F/B = _____ V = _____

3. Model Type: ☐ 3D ☐ 2D ☐ 1D
☐ Finite Element ☐ Beam
☐ Closed Form Solution ☐ Other



4. () Computer Codes: _____

Frequency Range and No. of Modes

() Hand Calculations

5. Method of Combining Dynamic Responses from Seismic and Other Dynamic Loads:

() Absolute Sum () SRSS () Other: _____
(specify)

6. Damping:

OBE _____ SSE _____ Basis for the Damping Used: _____

7. Support Considerations in the Model: _____

8. Critical Structural Elements:

A. Identification Location	Governing Load or Response Combination	Seismic Stress	Total Stress	Stress Allowable
----------------------------	--	-------------------	-----------------	---------------------

B. Maximum Critical Deflection	Location	Maximum Allowable Deflection to Assure Functional Operability
-----------------------------------	----------	--

9. Failure Modes: _____

10. Margins Available: () Input Spectrum () Stress or Deflection

ATTACHMENT 'A'DEVICE LISTS

<u>TABLE NO.</u>	<u>DESCRIPTION</u>	<u>PAGE NO</u>
1-A	COMPARISON TABLE OF ASSEMBLIES INSTALLED IN UPS253-1-106 & UPS253-1-101	A-11
2-A	MATRIX OF COMPARABLE ENGINEERING DRAWINGS FOR UPS253-1-106 & UPS253-1-101	A-12
3-A	COMPARISON TABLE OF MAGNETIC COMPONENTS INSTALLED IN UPS253-1-106 & UPS253-1-101	A-14
4-A	TABLE OF COMPONENTS USED IN UPS253-1-106 & UPS253-1-101	A-15 TO A-22
5-A	TABLE OF NON-SAFETY RELATED COMPONENTS USED IN UPS253-1-106 & UPS253-1-101	A-23 & A-24



Table No. 1-A

Comparison Table of Assemblies

Installed in UPS 253-1-106 and UPS 253-1-101

UPS 253-1-106		UPS 253-1-101	
Assembly	Number	Assembly	Number
Filter Panel	5321074-01	Filter Panel	643-389-40
DC Ground Detect	5340400-01	Not Required	
Fuse Sense	5430002-20	Not Required	
Current Transducer	5430008-01	Not Required	
I/O Panel	5431003-01	I/O Panel	643-362-40
1% Ripple Filter	5431081-01	Filter Panel	643-389-40
Charger-SS-Diode	5431086-02	Charger-SS Panel	643-356-40
Circuit Breaker	5431112-01	CB/Switch Plate	643-382-40
Driver Logic	5490001-01	1-Phase 3-Bridge Driver	643-100-40
SS Logic	5490002-01	SS Logic	643-158-40
Alarm Logic	5490006-01	Alarm Logic	643-154-40
DC-DC Converter	5490008-01	DC-DC Converter	628-135-40
Charger Drive	5490009-01	Charger Drive	643-152-40
SS Drive	5490009-02	SS Drive	642-106-40
Inverter Drive	5490009-03	SS Drive	642-106-40
1-Phase 3-Bridge PWM Logic	5490014-01	1-Phase 3-Bridge PWM Logic	643-101-40
Backplane PCB	5490015-04	Charger/Inverter Backplane	643-353/354-40
Transducer	5490016-01	Transducer	643-148-40
Charger Logic A	5490018-01	Charger Logic A	643-156-40
Charger Logic D	5490019-01	Charger Logic D	643-155-40
Analog Logic	5490030-01	PWM Analog Logic	643-102-40
Fuse Sense	628-137-41	Not Required	
Relay Drive	633-270-40	Not Required	
Regulator/SS Drive	642-106-40	SS Drive	642-106-40
Oscillator	643-119-40	Oscillator	643-119-40
Fan Cover	643-377-40	Fan Cover	643-377-40
Heatsink Panel	643-383-40	Heatsink Panel	643-383-40
Fan Mount Panel	643-518-40	Fan Mount Panel	643-412-40
Inverter Panel 12kVA	643-523-40	Inverter Panel (A2)	643-291-40
Inverter Panel 7kVA	643-524-40	Inverter Panel (A3, A4)	643-415-40
Right Door Plate	643-530-41	Right Door Plate	643-408-40
Right Side Plate	643-563-40	Right Side Plate	643-381-40
Distribution Chassis	643-607-40	Distribution Chassis	643-380-40
UPS Cabinet	643-623-40	UPS Cabinet	643-386-40
UPS Chassis	643-624-40	Chassis	643-292-41
Distribution Cabinet	643-630-40	Distribution Cabinet	643-385-40
Control Panel	643-628-40	Left Door	643-395-40
Lamp PCB	643-628-40	Annunciator	643-308-40
Line Reg. Control	648-100-40	Line Reg. Control	648-100-40
Line Reg. Drive	648-101-40	Line Reg. Driver	648-101-40



Table No. 2-A

Matrix of Comparable Engineering Drawings
For UPS 253-1-106 and UPS 253-1-101

Drawing Title	Drawing No. UPS 253-1-106	Drawing No. UPS 253-1-101
Overall Schematic	543-625-60	543-288-60
Installation Drawing	543-514-70	543-288-71
Filter Panel	5321074-01	643-389-40
Fuse Sense	5/6430002-20	Not Required
Current Transducer	5/6430008-01	Not Required
Alarm Logic	5/6490006-01	643-1540-40/60
1% Ripple Filter	5431081-01	Not Required
Charger-SS-Diode Panel	5431086-02	643-356-40
Fan Mount Panel	643-518-40	643-412-40
I/O Panel	5431003-01	643-362-40
DC Ground Detect	5/6340400-01	Not Required
UPS Cabinet	643-623-40	643-386-40
Distribution Cabinet	643-630-40	643-385-40
Control Panel (Control Door)	643-626-40	643-395-40
Lamp PCB (Annunciator Assy)	643-628-40/60	643-308-40/
Driver Logic (1-Phase 3-Bridge Driver)	5/6490001-01	643-100-40/60
SS Logic	5/6490002-02	643-158-40/60
DC-DC Converter	5/6490008-01	628-135-40/60
Charger Drive	5/6490009-01	643-152-40/60
SS Drive	5/6490009-02	642-106-40/60
Inverter Drive	5/6490009-03	643-124/125-40/60
1-Phase 3-Bridge PWM Logic	5/6490014-01	643-101-40/60
Backplane	5/6490015-04	643-353/354-40/60
Transducer	5/6490016-01	643-148-40/60
Charger Logic A	5/6490018-01	643-156-40/60
Charger Logic D	5/6490019-01	643-155-40/60
Analog Logic	5/6490030-01	643-102-40/60
Fuse Sense	628-137-41/61	Not Required
Relay Drive	633-270-40/60	Not Required
Regulator/SS Drive	643-106-40/60	643-106-40/60
UPS Chassis	642-624-40	642-292-41
Fan Cover	643-377-40	643-377-40
Distribution Chassis	643-607-40	643-380-40
Heatsink Panel	643-383-40	643-383-40
Inverter Panel 12kVA	643-523-40/60	643-291-40/643-204-60
Inverter Panel 7kVA	643-524-40	643-415-40
Right Door Plate	643-530-41	643-408-40
Right Side Plate	643-563-40	643-381-40
Oscillator	643-119-40/60	643-119-40/60
Line Regulator Control	648-100-40/60	648-100-40/60
Line Regulator Drive	648-101-40/60	648-101-40/60



Table No. 3-A

Comparison Table of Magnetic Components
Installed in UPS 253-1-106 and UPS 253-1-101

UPS 253-1-106		UPS 253-1-101	
Magnetic Component	Number	Magnetic Component	Number
Input Power	9900048-01	Input Power	991-139-90
Isolation Transformer	9900049-01	Isolation Transformer	991-172-90
DC-DC Converter Choke	9900051-02	DC-DC Converter Choke	990-956-90
DC-DC Converter Power Transformer	9900053-01	DC-DC Converter Power Transformer	990-955-90
Current Transformer	990-361-91	Current Transformer	990-361-91
Input Filter Choke	990-769-90	Input Filter Choke	990-769-90
Commutating Choke	990-846-90	Commutating Choke	990-846-90
Drive Transformer	990-892-90	Drive Transformer	990-892-90
Series Reactor	990-899-90	Series Reactor	990-899-90
Control Transformer	990-941-90	Control Transformer	990-941-90
DC-DC Converter	990-954-90	DC-DC Converter	990-954-90
Drive Transformer		Drive Transformer	
12kVA Summer Transformer	990-990-90	12kVA Summer Transformer	990-990-90
7kVA Summer Transformer	990-991-90	7kVA Summer Transformer	990-991-90
12th Harmonic Choke	991-009-91	12th Harmonic Choke	991-009-91
Current Transformer	991-014-90	Current Transformer	991-014-90
Transformer		Transformer	
Interphase Transformer	991-140-90	Interphase Transformer	991-140-90
Charger Filter Choke	991-141-90	Charger Filter Choke	991-141-90
Line Regulator Transformer	991-173-90	Line Regulator Transformer	991-173-90
Line Regulator Transformer	991-174-90	Line Regulator Transformer	991-174-90
Sense Transformer	991-182-90	Sense Transformer	991-182-90
Power Supply Transformer	991-191-90	Power Supply Transformer	991-191-90



Table No. 4-A

Table of Components
Used in UPS 253-1-106 and UPS 253-1-101

Component and Type	UPS 253-1-106	UPS 253-1-101
Ceramic Capacitors		
CK05	X	X
DD	X	X
DDM	X	X
HY	X	X
Y5U	X	X
811	X	X
Film Capacitors		
BA	X	X
ZA	X	X
6PS	X	X
715P	X	X
DA	X	P
Film/Paper Cap.		
KTNP	P	X
SCRN	X	X
26F	X	X
Paper Capacitors		
.97F	X	X
28F	P	X
Mica Capacitors		
DM15	X	X
DM19	X	X
Tantalum Capacitors		
196D	X	X
Aluminum Electrolytic Capacitors		
39D	X	X
86F	X	X
500D	X	P

P = Parameter Difference



Table No. 4-A (Continued)

Table of Components
Used in UPS 253-1-106 and UPS 253-1-101

Component and Type	UPS 253-1-106	UPS 253-1-101
Signal Diodes		
1N914	X	X
Rectifier Diodes		
1N4004	X	X
1N4006	P	X
1N4936	X	X
1N5624	X	X
1N5625	X	P
3SF4/MR854	X	X
A397E	X	X
A430M	X	X
Rectifier Diode Bridge		
MDA 990	X	X
VM48	X	X
Voltage Reference Diodes		
1N821	X	X
Voltage Regulator Diodes		
1N753	X	X
1N4742	X	X
1N4757	P	X
1N4936	X	X
1N5245	X	P
1N5352	X	X
Thyristors		
C6A	X	X
C350M	X	X
C355E	X	X
C380M	X	X
C384E	X	X
C385E	X	X
C430M	X	X
S2800M	X	X

P = Parameter Difference



Table No. 4-A (Continued)

Table of Components
Used in UPS 253-1-106 and UPS 253-1-101

Component and Type	UPS 253-1-106	UPS 253-1-101
Unilateral Switch		
2N4984	X	X
Fuses		
A25	X	P
A50	X	X
KAB	X	P
KLM	X	P
AGC	X	X
313002	X	X
3AG	P	X
Fuse Holders		
P243	X	X
P266	X	X
3530	X	X
3823	P	X
4561	X	X
342004	X	X
4287	X	P
Connectors		
156	X	P
08-56	X	P
09-50	P	X
09-65	P	X
09-72	X	X
H4	X	X
Relays		
ARD	X	X
R10	X	X
CSJ	P	X

P = Parameter Difference



Table No. 4-A (Continued)

Table of Components
Used in UPS 253-1-106 and UPS 253-1-101

Component and Type	UPS 253-1-106	UPS 253-1-101
Transistors		
2N2222A	X	P
2N3440	X	X
2N3567	X	X
2N3585	X	P
2N3767	P	X
2N3772	X	X
2N3585	X	P
2N4236	X	X
2N5682	P	X
GE6060	X	X
Circuit Breaker		
CD2	P	X
TED	P	X
THED	X	P
TFJ	P	X
TJJ	X	X
C. C. Resistors		
RC07	X	X
RC20	X	X
RC32	X	X
RC42	X	X
M. F. Resistors		
RN60	X	X
V53	X	P
316	P	X
W. W. Resistors		
CW5	X	X
CW10	X	X
RH50	X	X
RH250	X	P
RS5	P	X

P = Parameter Difference



Table No. 4-A (Continued)

Table of Components
Used in UPS 253-1-106 and UPS 253-1-101

Component and Type	UPS 253-1-106	UPS 253-1-101
Potentiometers		
3059	X	X
3250	X	X
3255	X	X
Current Shunt		
PR0400	X	X
I.C. Op Amplifiers		
741	X	X
LF356	X	P
LM301	X	X
LM308	X	P
LM348	X	X
TL084	X	X
I.C. Comparators		
LM2311	X	X
LM311	X	X
LM339	X	X
I.C. Switch		
CD4016	X	X
DG302	X	X
DG303	X	X
I.C. Transistor Array		
ULN2004	X	X
I.C. Dual Drivers		
DS3632	X	X
I.C. Timers		
LM555	X	X

P = Parameter Difference



Table No. 4-A (Continued)

Table of Components
Used in UPS 253-1-106 and UPS 253-1-101

Component and Type	UPS 253-1-106	UPS 253-1-101
I.C. Decoder		
CD4028	X	X
I.C. PWM Regulator		
SG3524	X	X
I.C. Opto-Isolator		
MCA 230	X	X
MCS 2400	X	P
I.C. Voltage Regulators		
LM342P15	X	X
7815	X	X
7824	X	X
7915	X	X
I.C. Hex Inverter/Buffer		
CD4069	X	X
74C04	P	X
CD4049	P	X
I.C. Gates		
CD4001	X	X
CD4011	X	X
CD4023	P	P
CD4025	X	X
CD4070	X	X
CD4073	X	X
CD4081	X	X
I.C. Schmitt Trigger		
CD4093	X	X
CD40106	X	X

P = Parameter Difference



Table No. 4-A (Continued)

Table of Components
Used in UPS 253-1-106 and UPS 253-1-101

Component and Type	UPS 253-1-106	UPS 253-1-101
I.C. Flip-Flops		
CD4013	X	X
CD4027	X	X
I.C. Quad Latches		
CD4043	X	X
CD4044	P	X
I.C. Mono M.V.		
CD4098	X	X
I.C. Phase-Lock Loop		
CD4046	X	X
I.C. Counters		
CD4017	X	X
CD4028	X	X
CD4040	X	P
CD40192	X	X
Varistors		
V130	X	X
V150	X	X
V320	X	P
Quartz Crystals		
815A	X	X
Switches		
REK	X	X
107/407	X	X
10250	P	X
7101	X	P
P = Parameter Difference		



Table No. 4-A (Continued)

Table of Components
Used in UPS 253-1-106 and UPS 253-1-101

Component and Type	UPS 253-1-106	UPS 253-1-101
Thermo Switch		
2450	X	X
Terminal Blocks		
140	X	X
170	X	X
172	X	P
601	X	X
642	X	X
EB25	P	X
OP10	X	X
Current Sensor		
ID-5001M	X	NR

P = Parameter Difference
NR = Not Required



Table No. 5-A

Table of Non-Safety Related Components
Used in UPS 253-1-106 and UPS 253-1-101

Component and Type	UPS 253-1-106	UPS 253-1-101
LED Indicators		
91	P	X
5082	X	P
DC Voltmeters		
50-112	P	X
237-01	X	P
DC Amperemeters		
50-112	P	X
237-01	X	P
AC Voltmeters		
50-105	P	X
237-01	X	P
AC Amperemeters		
50-105	P	X
237-02	X	P
Frequency Meters		
50-112	P	X
237-41	X	P
Instrument Switches		
C7B	P	X
8373	X	P
AC Amperemeter Transformers		
605	P	X
802	X	P

P = Parameter Difference



Table No. 5-A (Continued)

Table of Non-Safety Related Components
Used in UPS 253-1-106 and UPS 253-1-101

Component and Type	UPS 253-1-106	UPS 253-1-101
Elapsed Time Meter		
235-156	X	NR
Fans		
CL2	X	X
Air Switches		
FS3101	X	NR
Space Heater		
FS1022	NR	X

P = Parameter Difference
NR = Not Required



ATTACHMENT "B"RRS FOR CONTROL BUILDING EL. 261 FT.PAGE NO.DESCRIPTION

49

HORIZONTAL RRS - 3% SSE

50

VERTICAL RRS - 3% SSE

97

HORIZONTAL RRS - 2% OBE

98

VERTICAL RRS - 2% OBE



PSPECTRA VER 01 LEV 09

55E

6 JUL 1965

NIADARRA MOHAWK-NINE MILE POINT 2 L. CALC 12177-NM(C)-M6-1828 REV 1

RRS OF ACC.-CONTROL & DIESEL GENERATOR BLDGS. ELEVATION 261.0

JOB 2018


PEAK SPREAD 152

DISK CURVE SET NO. 4

HOK DIRECTION

DAMPING VALUE = 0.050

ACCELERATION: 0
0.20
0.40
0.60
0.80
1.00
1.20
1.40



FREQUENCY IN HZ



PSPECTRA VER 01 LEV 09

SSE

6 JUL 1983

NIAGARA MOHAWK NINE MILE POINT 2 - (ALC12177-NH(C)-M5-1828 REV14)

RRS OF ACC.-CONTROL & DIESEL GENERATOR BLOOD ELEVATION 281.0


JOB 2018

PEAK SPREAD +/-15%

DISK CURVE SET NO. 1

VER DIRECTION

DAMPING VALUE = 0.030



SPECTRA VER ON LEV ON

OBE

8 JUL 1985

NIADANA MOHAWK-NINE MILE POINT 2 - CALC12177-NM1C1-MS-1980 REV101

RMS OF ACC.-CONTROL & DIESEL GENERATOR BLOOS ELEVATION 261.0

JOB 2090

PEAK SPREAD 152

DISK CURVE SET NO.4

HOR DIRECTION

DAMPING VALUE 0.020

ACCELERATION 0.00 0.20 0.40 0.60 0.80 1.00 1.20 1.40



FREQUENCY IN HZ



PSPECTRA VER 01 LEV 09

OBE

8 JUL 1985

NIAOARA MONAWK-NINE MILE POINT 2 - CALC12177-HMIC1-M5-1928 REV143

RRS OF ACC-CONTROL & DIESEL GENERATOR BLOOD ELEVATION 261.0


JOB 2080

PEAK SPREAD: 9-15Z

DISK CURVE SET NO.4

VER DIRECTION

DAMPING VALUE = 0.020





ATTACHMENT "C"TR5 FROD TEST REPORTPAGE NO.DESCRIPTION

2-89

FRONT-TO-BACK 3% SSE (X-Y)

2-90

VERTICAL 3% SSE (X-Y)

2-151

SIDE-TO-SIDE 3% SSE (Z-Y)

- 2-152

VERTICAL 3% SSE (Z-Y)

2-61

FRONT-TO-BACK 2% OBE (X-Y)

2-62

VERTICAL 2% OBE (X-Y)

2-125

SIDE-TO-SIDE 2% OBE (Z-Y)


2-126

VERTICAL 2% OBE (Z-Y)



CUSTOMER Elgar Job No. 58733 Date 2-17-82
Specimen U. P. S. Axis of Test X-Y
Accel. No. 1 Axis X Control (☒) Response () OBE () SSE (☒) DBE ()
Full Scale 10 g Damping 3.5% Run No. 10
Operator Q E Engineer MLP


RESPONSE SPECTRUM





CUSTOMER Elgar Job No. 58733 Date 2-17-82
Specimen U.P.S Axis of Test X-Y
Accel. No. 2 Axis Y Control (☒) Response () OBE () SSE (☒) DBE ()
Full Scale 10 g Damping 3.5 Run No. 10
Operator JE Engineer MCP


RESPONSE SPECTRUM





CUSTOMER Elgar Job No. 58733 Date 2-17-82
Specimen U.P.S. Axis of Test Z-Y
Accel. No. 1 Axis Z Control ☒ Response () ORE () SSE ☒ DBZ ()
Full Scale 10 g Damping 3.5 Run No. 17
Operator J.E. Engineer M.P.

RESPONSE SPECTRUM



XC Form Approval



CHIER

E1822

Job No. 58733

Date 2-17-82

Specimen

U.P.S.

Axis of Test Z-Y

Accel. No. 2

Axis Y

Control (V)

Response ()

ONE ()

SSE (✓)

DBE ()

Full Scale 10

g


Damping 3.5

Run No. 17

Operator J.E.

Engineer M.P.

RESPONSE SPECTRUM



FREQUENCY Hz

100

200

1000

2

10



WYLE LABORATORIES

ATTACHMENT C

Report No. 58733

Page No. 2-61

CUSTOMER Elgar Job No. 58733 Date 2-17-82


Specimen U.P.S. Axis of Test XY

Accel. No. 1 Axis X Control ☒ Response ☐ OBE ☒ SSE ☐ DBE ☐

Full Scale 10 g Damping 2.5 Run No. 6

Operator JE Engineer ml

RESPONSE SPECTRUM



ACCELERATION PEAK
X-Form Approval



Report No. 58711Page No. 2-52

CUSTOMER

Elgar

Job No.

58733

Date

2-17-82

Specimen

U.P.S.

Axis of Test

XY

Accel. No.

2

Axis

Y

Control

☒

Response

☐

OBE

☒

SSE

☐

DBE

☐

Full Scale

11

g

Damping

2.5

Run No.

6


Operator

JS

Engineer

MLP

RESPONSE SPECTRUM






Operator LE Engineer ML



Report No. 58733Page No. 2-126

DATE Elgar Job No. 58733 Date 2-17-82
Specimen U.P.S. Axis of Test Z-Y
Accel. No. 2 Axis Y Control (☒) Response () ORZ (☒) SSE () -DBE ()
Full Scale 10 g Damping 2.5 Run No. 14
Operator JE Engineer MIP

RESPONSE SPECTRUM



SPEC. NO. NMP2-E092B

SQRT # 14

NINE MILE POINT NUCLEAR STATION UNIT 2

EQUIPMENT DYNAMIC QUALIFICATION

COMPONENT NAME: HEAT TRACING PANEL

MARK NUMBERS: 2HTS*PNL003



STONE & WEBSTER

Seismic and Dynamic Qualification Summary of Equipment

I. Plant Name: Nine Mile Point Nuclear Station - Unit 2

1. Utility: Niagara Mohawk Power Corporation

2. WSSS: General Electric Co. BWR: 5 MK 2

3. A/E: Stone & Webster Engineering Corp. Other

II. Component Name: HEAT TRACING CONTROL PANEL

MARK NO. 2 HTS XPNL003

1. Scope: ☐ NSSS ☒ BOP ☐ Other

2. Model Number: N/A Quantity: 1

3. Size or Range: 15 VOLTS DC, 60 WATTS

4. Vendor: THERMON MANUFACTURING CO.

5. If the component is a cabinet or panel, name and model number of the devices included:

ATTACHMENT 1

6. Physical Description:

a. Appearance: VERTICAL BOX

b. Dimensions: 72" X 24" X 90" HIGH

c. Weight: 5000 LBS.

7. Location: Building: AUX. BAY SOUTH

Elevation: 240'

8. Field Mounting Conditions ☒ Bolt (No. 18 - Size 1/2") HILT 1 BOLTS
☐ Weld (Length)
☐

9. Mounting Orientation (e.g., on floor, cantilevered, suspended, etc.)

ON FLOOR

10. a. System in which located: HTS SYSTEM
120VAC POWER CONTROL PANEL FOR
HEAT TRACING SYSTEM

b. Functional Description: 120VAC POWER SUPPLY

c. Is the equipment required for ☐ Hot Standby ☐ Cold Shutdown ☒ Both ☐ Neither ☐ Other



11. Pertinent Reference Design Specifications for Qualification Requirements: _____

SPEC. NO. NMP2-E092B, REV 1, MAY 14, 1984

- a. ☒ Seismic Input d. Service Conditions
b. Hydrodynamic Load Input e. Qualified Life
c. Fatigue Considerations

III. Is Equipment Available for Inspection in the Plant:

☒ Yes () No () Partial or limited availability

IV. Equipment Qualification Method:

☒ Test () Analysis () Combination of Test and Analysis

Qualification Report*: SWEC SDDF # IEEE 1.620-5000 B

(No., Title and Date): QUALIFICATION TEST REPORT NMP-2/EQR-1, MAY 14, 1984

Company that Prepared Report: THERMON MANUFACTURING CO.

Company that Reviewed Report: SWEC

Where Report is filed or available: NMP2 SITE

Applicable Codes and/or Standards: IEEE 344-1975. RG1.100

V. Vibration Input:

1. Loads considered: a. ☒ Seismic only
b. () Hydrodynamic only
c. () Vibration from normal operation
d. () Combination of (a), (b), and (c)

2. Method of Combining RRS:

() Absolute Sum

() SRSS

☒ N/A
(other, specify)

3. Required Response Spectra** (attach the graphs): ATTACHMENT 2

NOTE:

*If more than one report complete items IV thru VII for each report.

**If other than RRS is used, describe method.



4. Damping Corresponding to RRS: OBE 2% SSE 3%

5. Required Acceleration in Each Direct:

(☒) ZPA () Other _____
(specify)

OBE S/S = 0.20g F/B = 0.20g V = 0.15g

SSE S/S = 0.30g F/B = 0.30g V = 0.20g

6. Were fatigue effects considered?

() Yes (☒) No

If yes, describe how they were treated in overall qualification program: _____

N/A

VI. If Qualification by Test, then Complete:

1. () Single Frequency (☒) Multi-Frequency (☒) Random
() Sine Beat
() _____

2. () Single Axis (☒) Multi-Axis
(☒) Independent ~~Axis~~ (☐) In-phase Motions
MOTIONS

3. Number of Qualifications Tests:

OBE 5 SSE 1 Other _____
(specify)

4. Frequency Range: 1 - 50 Hz

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = 8.75 Hz F/B = 7.5 Hz V = 14.5 Hz

6. Method of Determining Natural Frequencies

(☒) Lab Test () In-Situ Test () Analysis

7. TRS Enveloping RRS Using Multi-Frequency Test

(☒) Yes (Attach TRS & RRS graphs) ATTACHMENT 3
() No

8. Maximum Input g Level Test:

OBE S/S = 0.537 F/B = 0.493 V = 0.425

SSE S/S = 0.816 F/B = 0.591 V = 0.562

9. Laboratory Mounting:

A. ☒ Bolt (No. 16 Size 1/2-13) X-Z AXIS TEST; (NO. 14 SIZE 1/2-13) Y-Z AXIS TEST
() Weld (Length) ()

B. Orientation and Fixturing: MOUNTED RIGIDLY ON SHAKE TABLE

10. Functional Operability Verified:

☒ Yes () No () Not Applicable

11. Test Results Including Modifications Made: FUNCTIONED

SATISFACTORILY. NO MODIFICATIONS

12. Other Tests Performed (such as aging or fragility test, including results):

ALL TESTS PERTINENT TO IEEE 323-1974

13. Failure Modes (If appropriate STRUCTURAL & ELECTRICAL)

14. Margins Available: ☒ Input Spectrum () Fragility

VII. If Qualification by Analysis, Then Complete: N/A

1. Method of Analysis:

() Static Analysis () Equivalent Static Analysis
() Dynamic Analysis: () Time-History () Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = F/B = V =

3. Model Type: () 3D () 2D () 1D
() Finite Element () Beam
() Closed Form Solution () Other



4. () Computer Codes: _____

Frequency Range and No. of Modes

() Hand Calculations

5. Method of Combining Dynamic Responses from Seismic and Other Dynamic Loads:

() Absolute Sum () SRSS () Other: _____
(specify)

6. Damping:

OBE _____ SSE _____ Basis for the Damping Used: _____

7. Support Considerations in the Model: _____

8. Critical Structural Elements:

	Governing Load or Response Combination	Seismic Stress	Total Stress	Stress Allowable
A. <u>Identification Location</u>				

B. <u>Maximum Critical Deflection</u>	<u>Location</u>	<u>Maximum Allowable Deflection to Assure Functional Operability</u>

9. Failure Modes: _____

10. Margins Available: () Input Spectrum () Stress or Deflection



3.0 DEFINITIONS

Term definitions are as given in Section 3.0 of Reference 2.2 and Section 2.0 of Reference 2.1.

4.0 TEST ITEM IDENTIFICATION

The following is Thermon equipment which was seismically qualified.

- 4.1 Control Panel, 2HTS-PNL107, 90" x 72" x 24", NEMA 12 Hoffman Enclosure with installed subcomponents.

The following is a list of unaged subcomponents in the panel for which components of the same type were aged in a previous project, Reference 2.9. The number in parentheses is the identification number found in the final report, Reference 2.9.

- 4.2 Control Card, Solid State, Thermon Cat. #CC-10 (3.4)
- 4.3 Relay, Solid State, 15 Amp, Opto 22 Cat. #240025 (3.5)
- 4.4 Fuse Block, Bussman Cat. #4407 w/5 Amp Fuse, Bussman Cat. #ABC-05 (3.6)
- 4.5 Main Circuit Breaker, Square D Cat. #KAL-36225 (3.11)
- 4.6 Breaker Frame, Square D Cat. #NQOB-330-SP (3.13)
- 4.7 Branch Circuit Breaker, Square D Cat. #QOB-120 (3.15)
- 4.8 Wire SIS, #14 AWG, G.E. Vulkene, with Burndy Type YAV Lugs (3.18)
- 4.9 Wire, #22 AWG, Tefzel Insulated, with Burndy Type YAV Lugs (3.20)
- 4.10 Power Distribution Block, Taylor Cat. #66013 (3.22)
- 4.11 D.C. Power Supply, Thermon Cat. #PS-10 (3.24)
- 4.12 Auxiliary Electronics Module, Thermon Cat. #EP-10, Part of Control Card Rack, Thermon Cat. #RA356 (3.25)
- 4.13 Terminal Block, Marathon Cat. #1500 (3.26)
- 4.14 Terminal Block, Marathon Cat. #200 (3.27)
- 4.15 Fan, Condor Model 12, 575 CFM with Finger Guard (3.7)
- 4.16 Operator, Pushbutton Station with Two Pushbuttons, Square D Cat. #BF-214 (3.21)

The following item is prequalified nuclear grade wire:

- 4.17 Main Frame Wiring, Firewall EP, 2/0, Rockbestos (prequalified by Rockbestos)



The following items in the panel have not been previously aged either because they are non-ageable or not considered critical to the IE function of the panel:

- 4.18 Heat Sink for Solid State Relays, Thermon Cat. #HS-10 (non-ageable, metal)
- 4.19 Relay, Alarm, Square D Cat. #8501, L0-20 (non-critical)
- 4.20 Wire Duct, White, Chlorine-free, Panduit (non-critical)
- 4.21 Mounting Track, Pre-Punched Aluminum, Buchanan (non-ageable, metal)
- 4.22 Thermostat, SPDT, Seymour Cat. #ETD-5S (non-critical)
- 4.23 Light Base w/Globe and Guard, Hubbell #VB-152 (non-critical)
- 4.24 Light Switch, SPST, Seymour Cat. #501-I (non-critical)
- 4.25 Receptacle, 15 Amp, Hubbell Cat. #5262 (non-critical)
- 4.26 Receptacle Cover, Appleton Cat. #2510 (non-ageable, metal)
- 4.27 Handy Box, Appleton Cat. #4CS-1/2 (non-ageable, metal)
- 4.28 Filter, 24" x 24" x 1", Farr Cat. #30/30 (non-critical)
- 4.29 Filter Frame, Air San Cat. #AH2-45 (non-ageable, metal)
- 4.30 Ground Bar, Copper (non-ageable)
- 4.31 Brace, Heat Sink, Thermon Cat. #19520 (non-ageable, metal)
- 4.32 Brace, Top Rack Assy, Thermon Cat. #19522 (non-ageable, metal)
- 4.33 Brace, Bottom Rack Assy, Thermon Cat. #19523 (non-ageable, metal)

Differences between those items previously aged in Ref. 2.9 and those provided in this panel, 2HTS-PNL107:

1. Item 4.2, Control Card #CC-10 is identical to the CC-20, Item 3.4 of Ref. 2.9 with the exception that the CC-20 has an additional switch.
2. Item 4.4, Fuse, 5A, Bussman, is identical to the 3A Fuse, Item 3.6 of Ref. 2.9 with the exception of the current rating.
3. Item 4.6, Breaker Frame, Square D #NQOB-330-SP is constructed of the same ageable materials as the NQOB-424, Item 3.13 of Ref. 2.9. The NQOB-330-SP is a single phase, 3 pole, 30 space frame with silver plated copper busses. The NQOB-424 is a 3 phase, single pole, 42 space frame with copper busses.



4. Item 4.10, Power Distribution Block, Taylor Cat. #66013 is constructed of the same materials as the Taylor Cat. #66011, Item 3.22 of Ref. 2.9. The 66013 has 3 poles and the 66011 is a single pole block. Both are used in 2HTS-PNL107.
5. Item 4.13, Terminal Block, Marathon Cat. #1500 series are all constructed of the same materials. The Cat. #1504DJ, #1506DJ and #1512DJ are used in 2HTS-PNL107. The 04, 06 and 12 denote number of terminals.
6. Item 4.14, Terminal Block, Marathon Cat. #200 series are all constructed of the same materials. The Cat. #214 is used in 2HTS-PNL107. The 14 denotes number of terminals.

5.0 SEISMIC QUALIFICATION TEST PROCEDURE

The test items in Section 4.0 will be tested in accordance with paragraph 6.3, "Type Test" of IEEE 323-1974. All test items will be qualified as Class 1E equipment. The test procedure conforms to the requirements for the Random Motion Tests of paragraph 6.6.3.3 of IEEE 344-1975.

Components of the same type listed in Section 4.0 were thermally aged, exposed to radiation, and seismically tested in a previous Thermon project. Results of these tests are found in the final report, Reference 2.9. Also the thermal and radiation aging is summarized in Table 5.1. A qualified life for these components has been calculated using the Arrhenius Equation, the average service temperature of 87°F from the SWEC letter No. 942-15,431, Reference 2.8, and the aging temperatures and activation energy constants found in the SwRI final report, Reference 2.9. This qualified life is given in Table 5.1. The equipment operation after the radiation total integrated dose of 3.08×10^4 plus 10% margin, as taken from the SWEC letter, Reference 2.8, has been demonstrated in the previous project, as shown in Table 5.1. The components were not seismically tested, however, per the requirements of the SWEC specification, Reference 2.7, in the previous project.

At the request of Thermon, unaged components will be tested in this program similar to those listed in Reference 2.9. It will be demonstrated that the Class 1E function of the usage equipment is not impaired during and after seismic excitation per the SWEC specification, Reference 2.7.

5.1 Mounting

Item 4.1 will be mounted to our biaxial hydraulically actuated seismic facility. A description of this facility is given in Appendix C. Subcomponents 4.2 through 4.14 will be mounted in 4.1. Mounting will be in a manner that simulates the intended in-service mounting; i.e., the same orientation of the component to the vertical, the same bolt location, bolt size, etc. This is in accordance with paragraph 6.1.1 of IEEE 344-1975. Detail on the current in-service mounting will be provided by Thermon.



PSPECTRA VER 01 LEV 08

UPSET

CONDITION

NIAGARA MOHAWK-NINE MILES POINT UNIT -2 J.O. 17 MS-1746-0
RMS OF ACCELERATION SECONDARY CONT.(ELEV. 240.0 FT)

24 JAN 1985

MS 1746


MICHAEL K DO

DAMPING VALUES = 0.010
0.020
0.040

DISK CURVE SET NO.29

NOR DIRECTION

NOTE: MULTIPLY BY RMS CURVES WITH DAMPING 1X 2X & 4X
THESE CURVES REPRESENT A SPREAD OF +15% AND -15%.



ATTACHMENT 2

PAGE 1 OF 4

PAGE # 79



PSPECTRA VER 01 LEV 08 UPSET CONDITION

24 JAN 1989

NIRAKA MOWANK-NINE MILES POINT UNIT -2 J.O. 177 MS-1746-0
RRS OF ACCELERATION SECONDARY CONT.(ELEV. 240.0 FT)


MS 1746
MICHAEL R 00

DISK CURVE SET NO.29.

VER DIRECTION

DAMPING VALUES : 0.010
0.020
0.040

NOTE: MULTIPLY BY RRS CURVES WITH DAMPING 1X 2X & 4X
THESE CURVES REPRESENT A SPREAD OF +15% AND -15%



ATTACHMENT 2

PAGE 2 OF 4

PAGE # 80



SPECTRA VER 01 LEV 00

FAULTED

CONDITION:

25 JAN 1989

WADSWORTH HARBOR-NINE MILES POINT UNIT -2 0.1 7 MS-747-0
RMS OF ACCELERATION SECONDARY CONT (ELEV: 240.0 FT)

MS 1743

MICHAEL R. DO

DISK CURVE SET NO. 28


HOR DIRECTION

DAMPING VALUES: 0.020
0.080
0.040

NOTE: MULTIPLY BY DISK CURVE WITH DAMPING 22.52 & 42
THESE CURVES REPRESENT A SPREAD OF +10% AND -10%

ACCELERATION - G
2.80
2.40
2.00
1.60
1.20
0.80
0.40
0.00

10⁰



FREQUENCY IN HZ

ATTACHMENT 2

PAGE 3 OF 4



PSPECTRA VER 01 LEV 05 FAULTED CONDITION

25 JAN 1989

NIAGARA MOHAWK-NINE MILES POINT UNIT -2 J.O.12177 MS-1747-0
RRS OF ACCELERATION SECONDARY CONT.(ELEV. 240.0 FT)


MS 1747
MICHAEL K 00

DISK CURVE SET NO.29

VER DIRECTION

DAMPING VALUES = 0.020
0.030
0.040



NOTE: MULTIPLY OF RRS CURVES WITH DAMPING 22 32 & 42
THESE CURVES REPRESENT A SPREAD OF +15% AND -15%





ATTACHMENT 2

PAGE 4 OF 4















Figure 11.7

Run OBEXZ3

AH





Figure 11.8

Run OBEXZ3

AV





ATTACHMENT 3

PAGE 5 OF 14

Figure 11.9

Run OBEXZ4

AH




Figure 11.10

Run OBEXZ4

AV






Figure 11.11

Run OBEXZ5

AH





Figure 11.12

Run OBEXZ5

AV





ATTACHMENT 3

PAGE 7 OF 14

Figure 11.13

Run SSEXZ1

AH





Figure 11.14



Run SSEXZ1

AV



Rev. 1







ATTACHMENT 3

PAGE 9 OF 14

Figure 11.17

Run OBEYZ2

AH







Figure 11.18

Run OBEYZ2

AV















Figure 11.23

Run OBEYZ5

AH




Figure 11.24

Run OBEYZ5

AV






Figure 11.25

Run SSEYZ1

AH




Figure 11.26

Run SSEYZ1

AV






Figure 11.27

Run SSEYZ1A

AH





Figure 11.28

Run SSEYZ1A

AV





NINE MILE POINT NUCLEAR STATION UNIT 2

EQUIPMENT DYNAMIC QUALIFICATION

MOTOR OPERATED
COMPONENT NAME: ROTARY GATE
MARK NUMBERS: 2SWP * MOV 30A



STONE & WEBSTER



Seismic and Dynamic Qualification Summary of Equipment

I. Plant Name: Nine Mile Point Nuclear Station - Unit 2

1. Utility: Niagara Mohawk Power Corporation
2. WSSS: General Electric Co. BWR: 5 MK 2
3. A/E: Stone & Webster Engineering Corp. Other

II. Component Name: MOTOR OPERATED ROTARY GATE

1. Scope: () WSSS ☒ BOP () Other
2. Model Number: RECT. B.V. Quantity: 1
3. Size or Range: 48" W x 72" H.
4. Vendor: HENRY PRATT Co.
5. If the component is a cabinet or panel, name and model number of the devices included: N/A

6. Physical Description:

- a. Appearance: RECT. GATE WITH EXTENDED MOTOR-OPERATOR
- b. Dimensions: 48" W x 72" H. GATE; 4 1/2" DIA STEM DRIVE
- c. Weight: 6915 lbs.

7. Location: Building: SCREENWELL

Elevation: 285' (FLOORSTAND & OPERATOR)

8. Field Mounting Conditions ☒ Bolt (No. 4 - Size 1" ϕ)
() Weld (Length _____)
☒ TORQUE TUBE IS SUPPORTED FROM THE WALL AT INTERMEDIATE LEVELS

9. Mounting Orientation (e.g., on floor, cantilevered, suspended, etc.)
DISC GATE (EMBEDDED IN CONCRETE), EXTENDED OPERATOR ON FLOORSTAND

10. a. System in which located: SERVICE WATER

- b. Functional Description: ISOLATE NORTH INTAKE SHAFT

- c. Is the equipment required for () Hot Standby () Cold Shutdown () Both () Neither ☒ Other ALL CONDITIONS EXCEPT COLD SHUTDOWN



-2-

11. Pertinent Reference Design Specifications for Qualification Requirements: SPEC. NO P121A, "MOTOR-OPERATED ROTARY GATES", REV. 1 AND ADDENDA 2 & 3.

- ☒ a. Seismic Input d. Service Conditions
b. Hydrodynamic Load Input e. Qualified Life
c. Fatigue Considerations

III. Is Equipment Available for Inspection in the Plant:

☒ Yes () No () Partial or limited availability

IV. Equipment Qualification Method:

() Test () Analysis ☒ Combination of Test and Analysis

Qualification Report*: } SECTIONS IV THRU VII FOR
(No., Title and Date): } EACH REPORT FOLLOW :

Company that Prepared Report: _____

Company that Reviewed Report: _____

Where Report is filed or available: _____

Applicable Codes and/or Standards: _____

V. Vibration Input:

1. Loads considered: a. () Seismic only
b. () Hydrodynamic only
c. () Vibration from normal operation
d. () Combination of (a), (b), and (c)

2. Method of Combining RRS:

() Absolute Sum () SRSS () _____
(other, specify)

3. Required Response Spectra** (attach the graphs): _____

NOTE:

*If more than one report complete items IV thru VII for each report.

**If other than RRS is used, describe method.

SEISMIC ANALYSIS2SWP * MOV 30A

-2-

11. Pertinent Reference Design Specifications for Qualification Requirements: _____

- a. Seismic Input d. Service Conditions
 b. Hydrodynamic Load Input e. Qualified Life
 c. Fatigue Considerations

III. Is Equipment Available for Inspection in the Plant:

() Yes () No () Partial or limited availability

IV. Equipment Qualification Method:

() Test (X) Analysis () Combination of Test and Analysis

Qualification Report*: "RECTANGULAR BUTTERFLY VALVE - SEISMIC ANALYSIS" 8/20/80; "RESPONSE TO SEISMIC ANALYSIS REVIEW" 11/19/80
 (No., Title and Date): _____

Company that Prepared Report: HENRY PRATT COCompany that Reviewed Report: SWECWhere Report is filed or available: NINE MILE SITEApplicable Codes and/or Standards: ANSI B31.1, 1977; AWWA C504, 1974IEEE 323, 1974; IEEE 344, 1975V. Vibration Input:AWS D1.1 Rev 2-1977; NEMA MG-1

1. Loads considered: a. (X) Seismic only
 b. () Hydrodynamic only
 c. () Vibration from normal operation
 d. () Combination of (a), (b), and (c)

2. Method of Combining RRS: _____

() Absolute Sum

() SRSS

N/A

(other, specify)

3. Required Response Spectra** (attach the graphs): N/ANOTE: (STATIC ANALYSIS, RIGID RANGE)

*If more than one report complete items IV thru VII for each report.

**If other than RRS is used, describe method.

4. Damping Corresponding to RRS: ~~1%~~ OBE 2% SSE 3%

5. Required Acceleration in Each Direct:

☒ ZPA ☒ Other
(specify)

OBE S/S = 0.26g F/B = 0.26g V = 0.13g
SSE S/S = 0.41g F/B = 0.41g V = 0.24g

6. Were fatigue effects considered?

() Yes ☒ No

If yes, describe how they were treated in overall qualification program: N/A

VI. If Qualification by Test, then Complete: N/A

1. () Single Frequency () Multi-Frequency () Random
() Sine Beat
()

2. () Single Axis () Multi-Axis
() Independent Axis () In-phase Motions

3. Number of Qualifications Tests:

OBE SSE Other
(specify)

4. Frequency Range:

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = F/B = V =

6. Method of Determining Natural Frequencies
() Lab Test () In-Situ Test () Analysis

7. TRS Enveloping RRS Using Multi-Frequency Test

() Yes (Attach TRS & RRS graphs)
() No



8. Maximum Input g Level Test:

OBE S/S = _____ F/B = _____ V = _____

SSE S/S = _____ F/B = _____ V = _____

9. Laboratory Mounting:

A. ☐ Bolt (No. _____ Size _____)
☐ Weld (Length _____) ☐ _____

B. Orientation and Fixturing: _____

10. Functional Operability Verified:

☐ Yes ☐ No ☐ Not Applicable

11. Test Results Including Modifications Made: _____

12. Other Tests Performed (such as aging or fragility test, including results): _____

13. Failure Modes (If appropriate _____)

14. Margins Available: ☐ Input Spectrum ☐ Fragility

VII. If Qualification by Analysis, Then Complete: ☒

1. Method of Analysis:

☒ Static Analysis ☐ Equivalent Static Analysis
☐ Dynamic Analysis: ☐ Time-History ☐ Response Spectrum

* 2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

BODY) S/S = 88 Hz. F/B = >88 Hz V = >88 Hz

3. Model Type: ☐ 3D ☐ 2D ☐ 1D
☐ Finite Element ☐ Beam
☒ Closed Form Solution ☐ Other

* 2. (CONT)

DISC) S/S = 262 Hz F/B = — V = 53 Hz.

FLOORSTAND) S/S = 73 Hz TORS = 37 Hz.

TORQUE TUBE) S/S = 39 Hz



4. () Computer Codes: N/A

Frequency Range and No. of Modes N/A

◆ Hand Calculations

5. Method of Combining Dynamic Responses from Seismic and Other Dynamic Loads: N/A

() Absolute Sum () SRSS () Other: _____
(specify)

6. Damping: N/A

OBE _____ SSE _____ Basis for the Damping Used: _____

7. Support Considerations in the Model: SIMPLY SUPPORTED

8. Critical Structural Elements:

A. Identification Location	Governing Load or Response Combination	Seismic Stress	Total Stress	Stress Allowable
DISC	DESIGN PRESSURE + SEISMIC	—	10.24 ksi	12.6 ksi

B. Maximum Critical Deflection	Location	Maximum Allowable Deflection to Assure Functional Operability
i) 4.8°	FLOORSTAND & TORQUE TUBE	5°
ii) 0.032 inch	BODY SIDE CHANNEL	0.040 inch

9. Failure Modes: STRUCTURAL, DEFLECTION,

10. Margins Available: () Input Spectrum ◆ Stress or Deflection



DYNAMIC TESTINGSMB-0-15/HABC OPERATOR

-2-

11. Pertinent Reference Design Specifications for Qualification Requirements: _____

- a. Seismic Input d. Service Conditions
b. Hydrodynamic Load Input e. Qualified Life
c. Fatigue Considerations

III. Is Equipment Available for Inspection in the Plant:

☐ Yes ☐ No ☐ Partial or limited availability

IV. Equipment Qualification Method:

☒ Test ☐ Analysis ☐ Combination of Test and Analysis

Qualification Report*: LIMITORQUE VALVE ACTUATOR
"QUALIFICATION" REPORT BOO58,
APPENDIX D OF APPENDIX 'F'
(No., Title and Date): 1/11/80 (UNIT TESTED WAS SMB-1-25/HABC)

Company that Prepared Report: LIMITORQUE CORP.

Company that Reviewed Report: SWEC

Where Report is filed or available: NINE MILE SITE

Applicable Codes and/or Standards: IEEE 344-75

V. Vibration Input:

1. Loads considered: a. ☒ Seismic only
b. ☐ Hydrodynamic only
c. ☐ Vibration from normal operation
d. ☐ Combination of (a), (b), and (c)

2. Method of Combining RRS:

☐ Absolute Sum ☐ SRSS ☐ N/A
(other, specify)

3. Required Response Spectra** (attach the graphs): N/ANOTE:METHOD - SINGLE FREQUENCY TESTING

*If more than one report complete items IV thru VII for each report.

**If other than RRS is used, describe method.

4. Damping Corresponding to RRS: OBE 2% SSE 3%

5. Required Acceleration in Each Direct:

☒ ZPA ☐ Other _____
(specify)

OBE S/S = 0.26G. F/B = 0.26G V = 0.13G.

SSE S/S = 0.41G. F/B = 0.41G V = 0.24G.

6. Were fatigue effects considered?

☐ Yes ☒ No

If yes, describe how they were treated in overall qualification program: N/A

VI. If Qualification by Test, then Complete:

1. ☒ Single Frequency ☐ Multi-Frequency ☐ Random
☐ Sine Beat
☒ FRAGILITY

2. ☒ Single Axis ☐ Multi-Axis
☐ Independent Axis ☐ In-phase Motions

3. Number of Qualifications Tests:

OBE _____ SSE _____ Other FIVE 30 SEC. SINE
DWELLS, EACH AXIS
(specify)

4. Frequency Range: 1-33 HZ (NO LOWER NATURAL FREQUENCIES)

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = > 33 HZ F/B = > 33 HZ V = > 33 HZ

6. Method of Determining Natural Frequencies

☒ Lab Test ☐ In-Situ Test ☐ Analysis

7. TRS Enveloping RRS Using Multi-Frequency Test N/A

☐ Yes (Attach TRS & RRS graphs)
☐ No



8. Maximum Input g Level Test:

SINE DWELL ~~DBE~~ S/S = 8.0G. F/B = 7.9G. V = 8.4G.

N/A SSE S/S = _____ F/B = _____ V = _____

9. Laboratory Mounting:

A. ☒ Bolt (No. _____ Size _____)
() Weld (Length _____) () _____

B. Orientation and Fixturing: H4BC GEARBOX STEM NUT - VERTICAL

10. Functional Operability Verified:

☒ Yes () No () Not Applicable

11. Test Results Including Modifications Made: UNIT FUNCTIONED
PROPERLY DURING & AFTER ALL TESTS. NO INDICATION
OF CONTACT CHATTER OR PHYSICAL DAMAGE.

12. Other Tests Performed (such as aging or fragility test,
including results):

ALL TESTS PERTINENT TO
IEEE-323-1974

13. Failure Modes (If appropriate STRUCTURAL, ELECTRICAL)

14. Margins Available: () Input Spectrum ☒ Fragility

VII. If Qualification by Analysis, Then Complete: N/A

1. Method of Analysis:

() Static Analysis () Equivalent Static Analysis
() Dynamic Analysis: () Time-History () Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back,
Vertical):

S/S = _____ F/B = _____ V = _____

3. Model Type: () 3D () 2D () 1D
() Finite Element () Beam
() Closed Form Solution () Other



SPEC. NO. NMP2-P222X
SQRT #16

NINE MILE POINT NUCLEAR STATION UNIT 2

EQUIPMENT DYNAMIC QUALIFICATION

COMPONENT NAME: SERVICE WATER PUMP

MARK NUMBERS: 2SWP*PIA



STONE & WEBSTER

SQRT #16

Seismic and Dynamic Qualification Summary of Equipment

I. Plant Name: Nine Mile Point Nuclear Station - Unit 2

1. Utility: Niagara Mohawk Power Corporation
2. NSSS: General Electric Co. BWR: 5 MK 2
3. A/E: Stone & Webster Engineering Corp. Other

II. Component Name: SERVICE WATER PUMP, 2SWP #PIA

1. Scope: () NSSS (✓) BOP () Other
2. Model Number: 3415M Quantity: 6
3. Size or Range: 14" DISCHARGE, 16" SUCTION, 600 HP
4. Vendor: GOULD PUMPS INC.
5. If the component is a cabinet or panel, name and model number of the devices included:

N/A

6. Physical Description:

- a. Appearance: HORIZONTAL CENTRIFUGAL PUMP
- b. Dimensions: 11'-4" LG. x 6' WIDE x 5'-2 1/4" HIGH
- c. Weight: 13,810 LBS WET, 13,060 LBS DRY

7. Location: Building: SCREENWELL
Elevation: 224'-0"

8. Field Mounting Conditions (X) Bolt (No. 10 - Size 1 3/4")
() Weld (Length)
()

9. Mounting Orientation (e.g., on floor, cantilevered, suspended, etc.)

PUMP ASSEMBLY MOUNTED ON FLOOR

10. a. System in which located: SERVICE WATER

- b. Functional Description: PROVIDE COOLING WATER TO SAFETY-RELATED EQUIPMENT

- c. Is the equipment required for () Hot Standby () Cold Shutdown (X) Both () Neither () Other



11. Pertinent Reference Design Specifications for Qualification Requirements: SAFETY RELATED HORIZONTAL

CENTRIFUGAL PUMPS; SPEC. No NMP2-P222X THRU ADDENDA II
(FORMERLY SPEC. No. 50 TO ADDENDA No. 3)

- (a) Seismic Input d. Service Conditions
b. Hydrodynamic Load Input e. Qualified Life
c. Fatigue Considerations

III. Is Equipment Available for Inspection in the Plant:

(✓) Yes () No () Partial or limited availability

IV. Equipment Qualification Method: (PUMP)

() Test (✓) Analysis () Combination of Test and Analysis

Qualification Report*: SWEC No. STRS 2.170-5002C, SEISMIC STRESS ANALYSIS

(No., Title and Date): OF SERVICE WATER PUMPS, (VENDOR REPORT # WE-1158) 6/19/85

Company that Prepared Report: MCDONALD ENGINEERING ANALYSIS Co.

Company that Reviewed Report: SWEC

Where Report is filed or available: NINE MILE SITE

Applicable Codes and/or Standards: ASME III '71 THRU SUMMER 73 ADDENDA.

V. Vibration Input:

CODE CASE 1677, IEEE-344-1975,
REGULATORY GUIDE 1.100

1. Loads considered: a. (X) Seismic only
b. () Hydrodynamic only
c. () Vibration from normal operation
d. () Combination of (a), (b), and (c)

2. Method of Combining RRS:

() Absolute Sum

() SRSS

(X) N/A
(other, specify)

3. Required Response Spectra** (attach the graphs): SEE ATTACHMENT "A"

NOTE:

*If more than one report complete items IV thru VII for each report.

**If other than RRS is used, describe method.



-3-

4. Damping Corresponding to RRS: OBE 2.8 SSE 2.6

5. Required Acceleration in Each Direct:

() ZPA (X) Other RIGID RANGE RESPONSE
(specify)

OBE S/S = 0.13g F/B = 0.13g V = 0.10g

SSE S/S = 0.23g F/B = 0.23g V = 0.19g

6. Were fatigue effects considered?

() Yes (✓) No

If yes, describe how they were treated in overall qualification program: _____

N/A

VI. If Qualification by Test, then Complete: N/A

1. () Single Frequency () Multi-Frequency () Random
() Sine Beat
() _____

2. () Single Axis () Multi-Axis
() Independent Axis () In-phase Motions

3. Number of Qualifications Tests:

OBE _____ SSE _____ Other _____
(specify)

4. Frequency Range: _____

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S= _____ F/B= _____ V= _____

6. Method of Determining Natural Frequencies
() Lab Test () In-Situ Test () Analysis

7. TRS Enveloping RRS Using Multi-Frequency Test

() Yes (Attach TRS & RRS graphs)
() No



8. Maximum Input g Level Test:

OBE S/S = _____ F/B = _____ V = _____

SSE S/S = _____ F/B = _____ V = _____

9. Laboratory Mounting:

A. () Bolt (No. _____ Size _____)
() Weld (Length _____) () _____

B. Orientation and Fixturing: _____

10. Functional Operability Verified:

() Yes () No () Not Applicable

11. Test Results Including Modifications Made: _____

12. Other Tests Performed (such as aging or fragility test, including results):

13. Failure Modes (If appropriate _____)

14. Margins Available: () Input Spectrum () Fragility

VII. If Qualification by Analysis, Then Complete:

1. Method of Analysis:

(X) Static Analysis () Equivalent Static Analysis
() Dynamic Analysis () Time-History () Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = ≥ 34.1 Hz F/B = ≥ 34.1 Hz V = ≥ 34.1 Hz

3. Model Type: (X) 3D () 2D () 1D
(X) Finite Element (X) Beam
() Closed Form Solution () Other



4. (X) Computer Codes: ICES-STRUDL

Frequency Range and No. of Modes N/A

() Hand Calculations

5. Method of Combining Dynamic Responses from Seismic and Other Dynamic Loads:

(X) Absolute Sum () SRSS () Other: _____
(specify)

6. Damping:

OBE 28 SSE 28 Basis for the Damping Used: FSAR

7. Support Considerations in the Model: BEDPLATE RIGIDLY SUPPORTED
AT FOUNDATION BOLTS

8. Critical Structural Elements:

A. Identification Location		Governing Load or Response Combination	Seismic Stress	Total Stress	Stress Allowable (2)	
PUMP HOLD-DOWN BOLTS	PUMP/ BEDPLATE INTERFACE	SSE + OPERATING	2951 PSI	29,192 PSI	29,956 PSI	TENSION
			2950 PSI	12,527 PSI	14,784 PSI	SHEAR

B. Maximum Critical Deflection	Location	Maximum Allowable Deflection to Assure Functional Operability
0.005 INCHES	IMPELLER/IMPELLER HOUSING	0.007 INCHES

9. Failure Modes: STRESS, DEFLECTION

10. Margins Available: (1) (X) Input Spectrum (X) Stress or Deflection

(1) STATIC ANALYSIS CALCULATION OF STRESSES WAS BASED ON HORIZONTAL/VERTICAL SSE ACCELERATIONS OF 1.0g/1.2g RESPECTIVELY. CALCULATION OF DEFLECTIONS WAS BASED ON HORIZONTAL/VERTICAL ACCELERATIONS OF 0.5g/0.5g RESPECTIVELY. (REQUIRED SSE ACCELERATIONS ARE 0.23/0.19g)

(2) COMBINED TENSION AND SHEAR SATISFY REQUIREMENTS OF XVII-2461.



11. Pertinent Reference Design Specifications for Qualification Requirements: _____

- a. Seismic Input
- b. Hydrodynamic Load Input
- c. Fatigue Considerations
- d. Service Conditions
- e. Qualified Life

III. Is Equipment Available for Inspection in the Plant:

() Yes () No () Partial or limited availability

IV. Equipment Qualification Method: (MOTOR)

() Test () Analysis (X) Combination of Test and Analysis

Qualification Report*: SWEC No. STRS 02.170-503A, SEISMIC ANALYSIS

(No., Title and Date): OF SERVICE WATER PUMP MOTOR, 5/4/79
(VENDOR REPORT No. 77F14708)

Company that Prepared Report: WESTINGHOUSE ELECTRIC CORP.

Company that Reviewed Report: SWEC

Where Report is filed or available: NINE MILE SITE

Applicable Codes and/or Standards: IEEE 334-1974, IEEE 344-1975,
IEEE-323-1974; REGULATORY
GUIDE 1.100

V. Vibration Input:

1. Loads considered:
- a. (X) Seismic only
 - b. () Hydrodynamic only
 - c. () Vibration from normal operation
 - d. () Combination of (a), (b), and (c)

2. Method of Combining RRS:

() Absolute Sum () SRSS (X) N/A
(other, specify)

3. Required Response Spectra** (attach the graphs): SEE ATTACHMENT "A"

NOTE:

*If more than one report complete items IV thru VII for each report.

**If other than RRS is used, describe method.



4. Damping Corresponding to RRS: OBE 28 SSE 28

5. Required Acceleration in Each Direct:

() ZPA (X) Other RIGID RANGE RESPONSE
(specify)

OBE S/S = 0.13g F/B = 0.13g V = 0.10g

SSE S/S = 0.23g F/B = 0.23g V = 0.19g

6. Were fatigue effects considered?

() Yes (X) No

If yes, describe how they were treated in overall qualification program: _____

N/A

VI. If Qualification by Test, then Complete: (CONDUIT BOX ONLY)

1. () Single Frequency () Multi-Frequency () Random
() Sine Beat
(X) IMPACT *
("BUMP TEST")

2. (X) Single Axis () Multi-Axis
() Independent Axis () In-phase Motions

3. Number of Qualifications Tests:

OBE _____ SSE _____ Other N/A
(specify)

4. Frequency Range: N/A

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = ≥ 53 Hz F/B = ≥ 53 Hz V = ≥ 53 Hz

6. Method of Determining Natural Frequencies
(X) Lab Test () In-Situ Test () Analysis

7. TRS Enveloping RRS Using Multi-Frequency Test

() Yes (Attach TRS & RRS graphs)
() No

N/A

* TEST PERFORMED TO IDENTIFY NATURAL FREQUENCY ONLY



8. Maximum Input g Level Test:

OBE S/S = N/A F/B = N/A V = N/A
SSE S/S = N/A F/B = N/A V = N/A

9. Laboratory Mounting:

A. () Bolt (No. _____ Size _____)
() Weld (Length _____) () _____

B. Orientation and Fixturing: _____

10. Functional Operability Verified:

() Yes () No (X) Not Applicable

11. Test Results Including Modifications Made: _____

N/A

12. Other Tests Performed (such as aging or fragility test, including results):

N/A

13. Failure Modes (If appropriate N/A)

14. Margins Available: () Input Spectrum () Fragility N/A

VII. If Qualification by Analysis, Then Complete:

1. Method of Analysis:

(X) Static Analysis () Equivalent Static Analysis
() Dynamic Analysis: () Time-History () Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = ≥ 53 Hz F/B = ≥ 53 Hz V = ≥ 53 Hz

3. Model Type: () 3D () 2D (X) 1D
() Finite Element (X) Beam
() Closed Form Solution () Other



-5-

4. (X) Computer Codes: WESTINGHOUSE INTERNAL PROGRAM ME-9032

Frequency Range and No. of Modes

(X) Hand Calculations

5. Method of Combining Dynamic Responses from Seismic and Other Dynamic Loads:

() Absolute Sum () SRSS (X) Other: ALGEBRAIC SUM
(specify)

6. Damping:

OBE 2% SSE 2% Basis for the Damping Used: FSAR

7. Support Considerations in the Model: SUPPORTED AT MOTOR
HOLD DOWN BOLTS (1)

8. Critical Structural Elements:

A. Identification Location	Governing Load or Response Combination	Seismic Stress	Total Stress	Stress Allowable
----------------------------	--	----------------	--------------	------------------

SHAFT SHEAR STRESS	SHAFT SSE + OPERATING LOADS	1 PSI	7,936 PSI	15,000 PSI
--------------------	-----------------------------	-------	-----------	------------

B. Maximum Critical Deflection	Location	Maximum Allowable Deflection to Assure Functional Operability
--------------------------------	----------	---

0.001 INCH	MOTOR SHAFT AT COUPLING	0.104 INCH *
------------	-------------------------	--------------


9. Failure Modes: STRESS, DEFLECTION

10. Margins Available: (X) Input Spectrum (X) Stress or Deflection

* ALLOWABLE DEFLECTION TAKEN FROM PUMP ASSEMBLY SEISMIC ANALYSIS (STRS 2.170-5002C), PG. 27.

(1) HOLD DOWN BOLTS ADDRESSED IN PUMP ASSEMBLY REPORT.






ATTACHMENT "A"

MS 1373 REV 0 PG 045

12177






MS-1373 REV 0 PG 054
 12177


ATTACHMENT A
 Pg 2 of 4





12177
 MYS-1373 REV 0 PG 09C





12177
 MS-1373 REV 0 PG 081

ATTACHMENT A
 PG 4 OF 4

SPEC. NO. NMP2-P222X
SQRT #17

NINE MILE POINT NUCLEAR STATION UNIT 2

EQUIPMENT DYNAMIC QUALIFICATION

COMPONENT NAME: REACTOR (RCIC) SYSTEM PRESSURE PUMPS
MARK NUMBERS: 2ICS*P2



STONE & WEBSTER

Seismic and Dynamic Qualification Summary of Equipment**I. Plant Name:** Nine Mile Point Nuclear Station - Unit 21. Utility: Niagara Mohawk Power Corporation2. WSSS: General Electric Co. BWR: 5 MK 23. A/E: Stone & Webster Engineering Corp. Other**II. Component Name:** RCIC SYSTEM PRESSURE PUMP, 2ICS #P21. Scope: () WSSS ☒ BOP () Other2. Model Number: 3196 ST Quantity: 53. Size or Range: 1 INCH DISCHARGE, 1 1/2 INCH SUCTION, 10 HP.4. Vendor: GOULDS PUMPS, INC

5. If the component is a cabinet or panel, name and model number of the devices included: _____

N/A

6. Physical Description:

a. Appearance: HORIZONTAL CENTRIFUGAL PUMPb. Dimensions: 42" LG x 18" WIDE x 16 3/8" HIGHc. Weight: 417 LBS. WET, 415 LBS. DRY7. Location: Building: REACTOR BUILDING SECONDARY CONTAINMENTElevation: 175'-0"8. Field Mounting Conditions ☒ Bolt (No. 4 - Size 5/8")☐ Weld (Length _____)☐ _____

9. Mounting Orientation (e.g., on floor, cantilevered, suspended, etc.)

PUMP ASSEMBLY MOUNTED ON FLOOR SILL10. a. System in which located: REACTOR CORE ISOLATION COOLING (RCIC)b. Functional Description: MAINTAIN RCIC DISCHARGE LINE
- PRESSURIZEDc. Is the equipment required for ☒ Hot Standby ☐ Cold Shutdown ☐ Both ☐ Neither ☐ Other _____



11. Pertinent Reference Design Specifications for Qualification Requirements: SAFETY RELATED HORIZONTAL CENTRIFUGAL

PUMPS, SPEC. No. NMP2-P222X THRU ADDENDA II (FORMERLY SPEC No. 50 TO ADDENDA No. 3)

- a. ☒ Seismic Input
- b. Hydrodynamic Load Input
- c. Fatigue Considerations
- d. Service Conditions
- e. Qualified Life

III. Is Equipment Available for Inspection in the Plant:

☒ Yes () No () Partial or limited availability

IV. Equipment Qualification Method: (PUMP)

() Test ☒ Analysis () Combination of Test and Analysis

Qualification Report*: ME-563 REV. 0 (WITH ADDENDA I), SEISMIC

(No., Title and Date): ANALYSIS OF PRESSURE PUMPS, 4/23/84

Company that Prepared Report: MCDONALD ENGINEERING ANALYSIS CO., INC.

Company that Reviewed Report: SNEC

Where Report is filed or available: NINE MILE SITE

Applicable Codes and/or Standards: ASME III '74 THRU WINTER 1976
ADDENDA, IEEE-344-1975; REGULATORY
GUIDE 1.100

V. Vibration Input:

- 1. Loads considered:
 - a. ☒ Seismic only
 - b. () Hydrodynamic only
 - c. () Vibration from normal operation
 - d. () Combination of (a), (b), and (c)

2. Method of Combining RRS:

() Absolute Sum () SRSS (X) N/A
(other, specify)

3. Required Response Spectra** (attach the graphs): SEE ATTACHMENT "A"

NOTE:

*If more than one report complete items IV thru VII for each report.

**If other than RRS is used, describe method.



-3-

4. Damping Corresponding to RRS: OBE 2% SSE 2%

5. Required Acceleration in Each Direct:

() ZPA (X) Other DIGID RANGE VALUES
(specify)

OBE S/S = 0.64g F/B = 0.64g V = 1.11g

SSE S/S = 0.74g F/B = 0.74g V = 1.19g

6. Were fatigue effects considered?

() Yes (X) No

If yes, describe how they were treated in overall qualification program: _____

N/A

VI. If Qualification by Test, then Complete: N/A

1. () Single Frequency () Multi-Frequency () Random
() Sine Beat
() _____

2. () Single Axis () Multi-Axis
() Independent Axis () In-phase Motions

3. Number of Qualifications Tests:

OBE _____ SSE _____ Other _____
(specify)

4. Frequency Range: _____

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S= _____ F/B= _____ V= _____

6. Method of Determining Natural Frequencies
() Lab Test () In-Situ Test () Analysis

7. TRS Enveloping RRS Using Multi-Frequency Test

() Yes (Attach TRS & RRS graphs)
() No



8. Maximum Input g Level Test:

OBE S/S = _____ F/B = _____ V = _____

SSE S/S = _____ F/B = _____ V = _____

9. Laboratory Mounting:

A. () Bolt (No. _____ Size _____)
() Weld (Length _____) () _____

B. Orientation and Fixturing: _____

10. Functional Operability Verified:

() Yes () No () Not Applicable

11. Test Results Including Modifications Made: _____

12. Other Tests Performed (such as aging or fragility test, including results):

13. Failure Modes (If appropriate _____)

14. Margins Available: () Input Spectrum () Fragility

VII. If Qualification by Analysis, Then Complete:

1. Method of Analysis:

(X) Static Analysis () Equivalent Static Analysis
() Dynamic Analysis () Time-History () Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = $\geq 49 \text{ Hz}$ F/B = $\geq 49 \text{ Hz}$ V = $\geq 49 \text{ Hz}$

3. Model Type: (X) 3D () 2D () 1D
(X) Finite Element (X) Beam
() Closed Form Solution () Other



-5-

4. (X) Computer Codes: ICES - STBU DL

Frequency Range and No. of Modes N/A

() Hand Calculations

5. Method of Combining Dynamic Responses from Seismic and Other Dynamic Loads:

(X) Absolute Sum () SRSS () Other: _____
 (specify)

6. Damping:

OBE 2% SSE 2% Basis for the Damping Used: FSAR

7. Support Considerations in the Model: BEDPLATE RIGIDLY SUPPORTED

8. Critical Structural Elements: AT FOUNDATION BOLTS

A. Identification Location	Governing Load or Response Combination		Seismic Stress	Total Stress	Stress Allowable
FLANGE STRESS	FRAME ADAPTOR FLANGE	SSE + OPERATING LOAD	570 PSI	19,278 PSI	26,250 PSI

B. Maximum Critical Deflection	Location	Maximum Allowable Deflection to Assure Functional Operability
0.003 INCH	IMPELLER/IMPELLER HOUSING	0.025 INCH

9. Failure Modes: STRESS, DEFLECTION

10. Margins Available: (X) Input Spectrum ⁽¹⁾ (X) Stress or Deflection

1) STATIC ANALYSIS WAS BASED ON SSE HORIZONTAL/VERTICAL ACCELERATION. VALUES OF 1.0g/1.5g. THE SPECIFICATION REQ'D SSE HORIZONTAL/VERTICAL ACCELERATIONS ARE 0.74g/1.19g.



11. Pertinent Reference Design Specifications for Qualification Requirements: _____

- | | |
|----------------------------|-----------------------|
| a. Seismic Input | d. Service Conditions |
| b. Hydrodynamic Load Input | e. Qualified Life |
| c. Fatigue Considerations | |

III. Is Equipment Available for Inspection in the Plant:

() Yes () No () Partial or limited availability

IV. Equipment Qualification Method: (MOTOR)

() Test (X) Analysis () Combination of Test and Analysis

Qualification Report*: SNEC No. STRS 02.260-5007A, SEISMIC ANALYSIS

(No., Title and Date): OF PRESSURE PUMP MOTORS 6/12/79
(VENDOR No. SY5591)

Company that Prepared Report: WESTING HOUSE

Company that Reviewed Report: SNEC

Where Report is filed or available: NINE MILE SITE

Applicable Codes and/or Standards: IEEE-334-1974, IEEE 344-1975
IEEE-323-1974; REGULATORY
GUIDE 1.100

V. Vibration Input:

1. Loads considered:
- | | |
|----|--------------------------------------|
| a. | (X) Seismic only |
| b. | () Hydrodynamic only |
| c. | () Vibration from normal operation |
| d. | () Combination of (a), (b), and (c) |

2. Method of Combining RRS:

() Absolute Sum () SRSS (X) N/A
(other, specify)

3. Required Response Spectra** (attach the graphs): SEE ATTACHMENT "A"

NOTE:

*If more than one report complete items IV thru VII for each report.

**If other than RRS is used, describe method.



-3-

4. Damping Corresponding to RRS: OBE 2 $\frac{1}{2}$ SSE 2 $\frac{1}{2}$

5. Required Acceleration in Each Direct:

() ZPA (X) Other RIGID RAUGE
(specify)

OBE S/S = 0.64g F/B = 0.64g V = 1.1g

SSE S/S = 0.74g F/B = 0.74g V = 1.19g

6. Were fatigue effects considered?

() Yes (X) No

If yes, describe how they were treated in overall qualification program: _____

N/A

VI. If Qualification by Test, then Complete: N/A

1. () Single Frequency () Multi-Frequency () Random
() Sine Beat
() _____

2. () Single Axis () Multi-Axis
() Independent Axis () In-phase Motions

3. Number of Qualifications Tests:

OBE _____ SSE _____ Other _____
(specify)

4. Frequency Range: _____

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S= _____ F/B= _____ V= _____

6. Method of Determining Natural Frequencies
() Lab Test () In-Situ Test () Analysis

7. TRS Enveloping RRS Using Multi-Frequency Test

() Yes (Attach TRS & RRS graphs)
() No



8. Maximum Input g Level Test:

OBE S/S = _____ F/B = _____ V = _____

SSE S/S = _____ F/B = _____ V = _____

9. Laboratory Mounting:

A. () Bolt (No. _____ Size _____)
() Weld (Length _____) () _____

B. Orientation and Fixturing: _____

10. Functional Operability Verified:

() Yes () No () Not Applicable

11. Test Results Including Modifications Made: _____

12. Other Tests Performed (such as aging or fragility test, including results):

13. Failure Modes (If appropriate _____)

14. Margins Available: () Input Spectrum () Fragility

VII. If Qualification by Analysis, Then Complete:

1. Method of Analysis:

(☒) Static Analysis () Equivalent Static Analysis
() Dynamic Analysis: () Time-History () Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = ≥ 151.7 Hz F/B = ≥ 151.7 Hz V = ≥ 151.7 Hz

3. Model Type: () 3D () 2D (☒) 1D
() Finite Element (☒) Beam
() Closed Form Solution () Other



-5-

4. (X) Computer Codes: WESTINGHOUSE INTERNAL PROGRAMS
 (2g. ME-7701)

Frequency Range and No. of Modes

() Hand Calculations

5. Method of Combining Dynamic Responses from Seismic and Other Dynamic Loads:

() Absolute Sum (X) SRSS () Other: _____
 (specify)

6. Damping:

OBE 2% SSE 2% Basis for the Damping Used: FSAR

7. Support Considerations in the Model: SUPPORTED AT MOTOR

8. Critical Structural Elements: HOLD DOWN BOLTS (2)

A. Identification Location	Governing Load or Response Combination	Seismic Stress	Total Stress	Stress Allowable
SHAFT STRESS	MOTOR SHAFT SSE + OPERATING LOAD	306 PSI (BENDING) 10 PSI (TENSION)	1049 PSI (COMBINED)	36,000 PSI

B. Maximum Critical Deflection	Location	Maximum Allowable Deflection to Assure Functional Operability
0.00638 INCH	ROTOR DEFLECTION	0.0202 INCH

9. Failure Modes: STRESS, DEFLECTION

10. Margins Available: () Input Spectrum (X) Stress or Deflection

(1) SEISMIC LOADS ARE COMBINED BY SRSS METHODOLOGY. THESE LOADS ARE THEN ADDED DIRECTLY TO THE NORMAL OPERATING LOADS.

(2) HOLD DOWN BOLTS ADDRESSED IN PUMP ASSEMBLY REPORT ME-563



PSPECTRA VER 01 LEV 08

CONDITION

24 JAN 1985

NIAGARA MOHAWK-NINE MILES POINT UNIT -2 J.O. 17 MS-1746-0
RRS OF ACCELERATION SECONDARY CONT.(ELEV. 175.0 FT)

MS 1746


MICHAEL K 00

DISK CURVE SET NO.92

HOR DIRECTION

DAMPING VALUES = 0.010
0.020
0.040

NOTE: MULTIPLY OF RRS CURVES WITH DAMPING 12 2X & 4X
THESE CURVES REPRESENT A SPREAD OF +15% AND -15%



ATTACHMENT "A"

REF 6 4

Pg. 10F 4



PSPECTRA VER 01 LEV 08

CONDITION

24 JAN 1985

NIAGARA MOHAWK-NINE MILES POINT UNIT -2 J.O. 177 MS-1746-0
RRS OF ACCELERATION SECONDARY CONT.(ELEV. 175.0 FT)

MS 1746


MICHAEL K DO

DISK CURVE SET NO.92

VER DIRECTION

DAMPING VALUES = 0.010
0.020
0.040

NOTE: MULTIPLY OF RRS CURVES WITH DAMPING 1X 2X & 4X
THESE CURVES REPRESENT A SPREAD OF +15% AND -15%



ATTACHED
18 JAN 85
REF 64



PGPECTRA VER 01 LEV 08

ED CONDITION

25 JAN 1985

NINORAKA MOHAWK-NINE MILES POINT UNIT -2 J.O.12177 MS-1747-0
RRS OF ACCELERATION SECONDARY CONT.(ELEV. 175.0 FT)

MS 1747


MICHAEL K OD

DAMPING VALUES = 0.020
0.030
0.040

DISK CURVE SET NO.32

VER DIRECTION

NOTE: MULTIPLY OF RRS CURVES WITH DAMPING 2X 5X & 4X
THESE CURVES REPRESENT A SPREAD OF +15% AND -15%



REF 64



PSPECTRA VER 01 LEV 00

TESTED CONDITION

25 JAN 1989

NIAGARA MOHAWK-NINE MILES POINT UNIT -2 J. 177 MS-1747-0
RRS OF ACCELERATION SECONDARY CONT.(ELEV. 175.0 FT)


MS 1747
MICHAEL K 00

DISK CURVE SET NO.92

HOR DIRECTION

DAMPING VALUES = 0.020
0.030
0.040

NOTE: MULTIPLOT OF RRS CURVES WITH DAMPING 2% 3% & 4%
THESE CURVES REPRESENT A SPREAD OF +15% AND -15%



PG 4004
REF 64



SPEC. NO. NMPZ-P303D

SQRT # 18

NINE MILE POINT NUCLEAR STATION UNIT 2

EQUIPMENT DYNAMIC QUALIFICATION

COMPONENT NAME: LOGIC CABINET

MARK NUMBERS: ZMSSX1PDL90A



STONE & WEBSTER

Seismic and Dynamic Qualification Summary of Equipment

I. Plant Name: Nine Mile Point Nuclear Station - Unit 2

1. Utility: Niagara Mohawk Power Corporation
2. WSSS: General Electric Co. BWR: 5 MK 2
3. A/E: Stone & Webster Engineering Corp. Other

II. Component Name: LOGIC CABINET, MARK NO. 2MSS*IPNL90A

1. Scope: () WSSS (☒) BOP () Other
2. Model Number: N/A Quantity: 1
3. Size or Range: 30 1/16" X 18 1/16" X 72 1/16" HIGH
4. Vendor: CROSBY
5. If the component is a cabinet or panel, name and model number of the devices included: ATTACHMENT-1

6. Physical Description:

- a. Appearance: VERTICAL BOARD
- b. Dimensions: 30 1/16" X 18 1/16" X 72 1/16" HIGH
- c. Weight: 400 LBS.

7. Location: Building: AUX. BAY SOUTH
Elevation: 240'.

8. Field Mounting Conditions (☒) Bolt (No. 9 - Size 3/8)
() Weld (Length)
()

9. Mounting Orientation (e.g., on floor, cantilevered, suspended, etc.)

ON FLOOR

10. a. System in which located: MAIN STEAM

- b. Functional Description: CONTROL OF CONTAINMENT ISOLATION OF VALVE 2MSS*HYV6A

- c. Is the equipment required for () Hot Standby () Cold Shutdown () Both () Neither (☒) Other ALL CONDITIONS.

OTHER THAN COLD SHUT DOWN



11. Pertinent Reference Design Specifications for Qualification Requirements: _____

SPEC NO. NMP2-P303D REV 1, E&DCRS P12582, P12632, P12333

- (a) Seismic Input d. Service Conditions
b. Hydrodynamic Load Input e. Qualified Life
c. Fatigue Considerations

III. Is Equipment Available for Inspection in the Plant:

(☒) Yes () No () Partial or limited availability

IV. Equipment Qualification Method:

(☒) Test () Analysis () Combination of Test and Analysis

Qualification Report*: SWEC JDDF#
STRS 05.360-5022A
(No., Title and Date): SEISMIC SIMULATION TEST REPORT
REPORT NO. 46912-1 SEPT. 29, 1983

Company that Prepared Report: WYLE LABORATORIES

Company that Reviewed Report: SWEC

Where Report is filed or available: NMP2 SITE

Applicable Codes and/or Standards: IEEE-344-1975, RG 1.00

V. Vibration Input:

1. Loads considered: a. (☒) Seismic only
b. () Hydrodynamic only
c. () Vibration from normal operation
d. () Combination of (a), (b), and (c)

2. Method of Combining RRS:

() Absolute Sum () SRSS (☒) N/A
(other, specify)

3. Required Response Spectra** (attach the graphs): ATTACHMENT 2

NOTE:

*If more than one report complete items IV thru VII for each report.

**If other than RRS is used, describe method.



4. Damping Corresponding to RRS: OBE 2% SSE 2%

5. Required Acceleration in Each Direct:

☒ ZPA () Other _____
(specify)

OBE S/S = 0.200 F/B = 0.200 V = 0.150
SSE S/S = 0.360 F/B = 0.360 V = 0.200

6. Were fatigue effects considered?

() Yes ☒ No

If yes, describe how they were treated in overall qualification program: N/A

VI. If Qualification by Test, then Complete:

1. () Single Frequency ☒ Multi-Frequency ☒ Random
() Sine Beat
() _____

2. () Single Axis ☒ Multi-Axis
☒ Independent Axis ☐ In-phase Motions
MOTIONS

3. Number of Qualifications Tests:

OBE 5 SSE 1 Other _____
(specify)

4. Frequency Range: 1 - 100 Hz

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical): NOT DETERMINED - RANDOM MULTIFREQUENCY TEST

S/S = _____ F/B = _____ V = _____

6. Method of Determining Natural Frequencies N/A
() Lab Test () In-Situ Test () Analysis

7. TRS Enveloping RRS Using Multi-Frequency Test

☒ Yes (Attach TRS & RRS graphs) ATTACHMENT 3
() No



8. Maximum Input g Level Test:

OBE S/S = 0.41 F/B = 0.40 V = 0.36
SSE S/S = 0.88 F/B = 0.70 V = 1.00

9. Laboratory Mounting:

A. ☒ Bolt (No. 4 Size 3/4-10)
() Weld (Length) ()

B. Orientation and Fixturing: BOLTED TO RIGID FIXTURE WHICH IS IN
TURN WELED TO THE SHAKE TABLE

10. Functional Operability Verified:

☒ Yes () No () Not Applicable

11. Test Results Including Modifications Made: FUNCTIONED

SATISFACTORILY. NO MODIFICATIONS WERE MADE

12. Other Tests Performed (such as aging or fragility test, including results):

ALL TESTS PERTINENT TO IEEE 323-1974

13. Failure Modes (If appropriate STRUCTURAL & ELECTRICAL)

14. Margins Available: ☒ Input Spectrum () Fragility

VII. If Qualification by Analysis, Then Complete: N/A

1. Method of Analysis:

() Static Analysis () Equivalent Static Analysis
() Dynamic Analysis: () Time-History () Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = F/B = V =

3. Model Type: () 3D () 2D () 1D
() Finite Element () Beam
() Closed Form Solution () Other



4. () Computer Codes: _____

Frequency Range and No. of Modes

() Hand Calculations

5. Method of Combining Dynamic Responses from Seismic and Other Dynamic Loads:

() Absolute Sum () SRSS () Other: _____
(specify)

6. Damping:

OBE _____ SSE _____ Basis for the Damping Used: _____

7. Support Considerations in the Model: _____

8. Critical Structural Elements:

	Governing Load or Response Combination	Seismic Stress	Total Stress	Stress Allowable
A. <u>Identification Location</u>				

B. <u>Maximum Critical Deflection</u>	<u>Location</u>	<u>Maximum Allowable Deflection to Assure Functional Operability</u>
---	-----------------	--

9. Failure Modes: _____

10. Margins Available: () Input Spectrum () Stress or Deflection



MAIN STEAM ISOLATION VALVE DATA BY DELBERT L. LUTHER
ELECTRICAL COMPONENT LIST FOR MSIV EPCO/600 MOTOR AND LOGIC CONTROL CABINET

Client: Niagara Mohawk Power Corporation
Project: Nine Mile Point Nuclear Station - Unit 2

S&W Mark No. 2MSS*HYV6A,B,C,E
2MSS*HYV7A,B,C,E

Page 4-24 1.11
Spec. No. NMP2-P303D 1.12
J.O. No. 12177 1.13
By: *H. J. Bell* 1.14
Date: *11/5/82* 1.15
1.16

Equipment	Component Number	Location	Supplier	Description	IEEE 323-74	IEEE 344-75	ASTM D635	Additional Consideration	Class 1E	
Trip Sol.	SFA	Actuator	Valcor	80 lb, 120 V ac,	Yes	Yes*	Not	Wire Loads	Yes	1.21
	1SPB			60 Hz			Combustible	meet IEEE 323-1974		1.22
										1.23
Limit Switches	CIS 3, 4, 5, 6, 10, 11, 12	Actuator	Waco	EA180-14303	Yes	Yes*	Not		Yes	1.25
	OIS 1, 2, 5, 7						Combustible			1.26
	ECIS 13, 14, 15									1.27
										1.28
1 1/2 Sol. Valves	GVS A	Actuator	Target Rock	Model No. 81AL-001	Yes	Yes*	Not	Class II	Yes	1.40
	GVS B						Combustible	Coil		1.41
1/2 Sol. Valve	GVC	Actuator	Target Rock	Model No. 81AL-002	No	Yes*	Not	Class II	No	1.43
							Combustible	Coil		1.44
Motor	M	Actuator	Westinghouse	M10, 3 hp, 575 V ac, 60 Hz, 1750 rpm	No	Yes*	Not	Class II	No	1.46
							Combustible	Coil, Rad		1.47
								Resistant		1.48
Pressure Trans.	N/A	Actuator	Computer	Model 5000	No	Yes*	Minimal		No	1.50
			Instr.	D501545			Internal			1.51
							Plastics			1.52
Level Switch	N/A	Actuator	Delaval	CEHC-LS 2050-30300	No	Yes*	Minimal		No	1.54
							Internal			1.55
							Plastics			1.56
Wire	N/A	Logic Cab. & Actuator	Rockbestos (Cerro)	#14 AWG, NEC, SIS	Yes	Yes*	N/A	IEEE 383-74	Yes	1.58
										2.1
Conduit	N/A	Actuator	Anasconda	MHC Jacket	Yes	Yes*	N/A	IEEE 282-74	Yes	2.3
										2.4
Terminal Block	N/A	Logic Cab. & Actuator	Buchanan	NQB106, NQB108, and NQB112	Yes	Yes*	UL-94 94V-1		Yes	2.6
										2.7
Wire Lugs	N/A	Logic Cab. & Actuator	Thomas Betts	Sta-Kon Ring Tefzel	Yes	Yes*	UL-94 94V-0		Yes	2.9
										2.10

ch-12177-2704d

11/04/82

102

ATTACHMENT 1 PAGE 1 OF 2



ELECTRICAL COMPONENT LIST FOR MSIV EPCO/600 ACTUATOR AND LOGIC CONTROL CABINET(1) (CONT)

Page 4-25

<u>Equipment</u>	<u>Component Number</u>	<u>Location</u>	<u>Supplier</u>	<u>Description</u>	<u>IEEE 323-74</u>	<u>IEEE 344-75</u>	<u>ASTM D635</u>	<u>Additional Consideration</u>	<u>Class 1E</u>	
Relays	CR	Logic Cab.	Gould**	J10, J13	Yes	Yes*	UL-94 94V-0	ANSI C19.3-73, C19.6-73 NEMA ICS142, 1978	Yes	2.12 2.13 2.14 2.15
Wire Trays	N/A	Logic Cab.	Panduit	Noryl	No	Yes*	UL-94 94V-1		No	2.18 2.19
Cable Ties	N/A	Logic Cab. & Actuator	Panduit	Sta-Strap	N/A	Yes*	N/A		No	2.23 2.24
Wire Marker	N/A	Logic Cab. & Actuator	Electromark Co.	Style No. WA-1000	N/A	Yes*	Yes - Self- Extinguishing		No	2.28 2.29
Conduit	N/A	Logic Cab.	American Boe, Inc.	NB Series Unbraided	N/A	Yes*	N/A		No	2.33 2.34
Control	CS1-142	Shop Test			N/A	N/A			No	2.38
Switch (2)		Panel								2.39
Push	BBTA	Shop Test			N/A	N/A			No	2.43
Buttons (2)	BBTB	Panel								2.44
and Lights	BBB									2.45
	BBB1									2.46
	BBB2									2.47
	BT1-BT12									2.48
(1) Data taken from Seller's procedure "G+W (FSD) - MSIV Actuator - Environmental Qualification Plan for Class 1E" - PS-1185.										2.51
(2) Identical components being supplied by SWEC in the control room with the exception of being Class 1E and meeting IEEE 323-74 and IEEE 344-75.										2.52
(3) Provided that for accident closure this solenoid valve is not required to be open for the MSIV to close and remain closed.										2.53
*Seismically tested in actuator or logic cabinet assembly.										2.54
**These suppliers previously "Approved" by Engineers.										2.55
										2.56
										2.57

ATTACHMENT 1 PAGE 2 OF 2



PSPECTRA VER 01 LEV 08 UPSET UP TATION
 NIADARA MOWANK-NINE MILES POINT UNIT -2 J.O. .17 MS-1746-0
 RRS OF ACCELERATION SECONDARY CONT.(ELEV. 240.0 FT)

24 JAN 1989

MS 1746


MICHAEL K DO

DAMPING VALUES : 0.010
 0.020
 0.040

DISK CURVE SET NO.29

NOR DIRECTION

NOTE: MULTIPLY BY RRS CURVES WITH DAMPING 1X 2X & 4X
 THESE CURVES REPRESENT A SPREAD OF +15% AND -15%.



ATTACHMENT 2

PAGE 1 OF 4

PAGE # 79



 **CONDITION**

24 JAN 1988

NIRARA MOHAWK-NINE MILES POINT UNIT -2 J.O. 177 MS-1746-0
RRE OF ACCELERATION SECONDARY CONT.(ELEV. 240.0 FT)

MS J 746
MICHAEL R DO


MICHAEL R BO

DAMPING VALUES : 0.010
 : 0.020
 : 0.040

DISK CURVE SET NO.29

VER DIRECTION

NOTE: MULTIPLY OF RES CURVES WITH DRAWING 1X 2X & 4X
THESE CURVES REPRESENT A SPREAD OF +15% AND -15%




ATTACHMENT 2

PAGE 2 OF 4

PAGE # 80



10:080
10:040



PAGE 3 OF 4



PSPECTRA VER 01 LEV 08 FAULTED

DITION

25 JAN 1989

NIAGARA MOHAWK-NINE MILES POINT UNIT -2 J.O.12177 MS-1747-0
RRS OF ACCELERATION SECONDARY CONT.(ELEV. 240.0 FT)

MS 1747


MICHAEL K 00

DISK CURVE SET NO.29

VER DIRECTION

DAMPING VALUES = 0.020
0.030
0.040

NOTE: MULTIPLY OF RRS CURVES WITH DAMPING 22 32 & 42
THESE CURVES REPRESENT A SPREAD OF +15% AND -15%



ATTACHMENT 2

PAGE 4 OF 4


22



Page No. 25

Report No. 46912-1

FULL SCALE SHOCK SPECTRUM (g Peak)

1.0 ☐ 10 ☒ 100 ☐ 10000DAMPING ☐ 1% ☒ 2% ☐ 5%

SPECIMEN _____


LOCATION NO. SS HCAAXIS TriaxTEST RUN NO. 2



Page No. 24

Report No. 46912-1


FULL SCALE SHOCK SPECTRUM (g Peak)

1.0 ☐ 10 ☒ 100 ☐ 1000 ☐DAMPING ☐ 2% ☒SPECIMEN LOCATION NO. FB HCAAXIS TriaxTEST RUN NO. 2

Page No. 26

Report No. 46912-1

FULL SCALE SHOCK SPECTRUM (g Peak)


1.0 ☐ 10 ☒ 100 ☐ 1000 ☐DAMPING ☒ 2%SPECIMEN LOCATION NO. VCAAXIS TriaxTEST RUN NO. 2



FULL SCALE SHOCK SPECTRUM (g Peak)

1.0 □ 10 □ 100 □ 1000 □


DAMPING 2 %



SPECIMEN _____


LOCATION NO. SS HCAAXIS Tria xTEST RUN NO. 7

FULL SCALE SHOCK SPECTRUM (g Peak)

1.0 ☐ 10 ☐ 100 ☒ 1000 ☐DAMPING ☐ 1% ☒ 2% ☐ 5% ☐ 10%SPECIMEN LOCATION NO. FB HCAAXIS TriaxTEST RUN NO. 7



FULL SCALE SHOCK SPECTRUM (g Peak)

1.0 ☐ 10 ☐ 100 ☒ 1000 ☐DAMPING ☐ 2% ☒SPECIMEN LOCATION NO. VCAAXIS TriaxTEST RUN NO. 7



SPEC. NO. P304D

SQRT # 19

NINE MILE POINT NUCLEAR STATION UNIT 2

EQUIPMENT DYNAMIC QUALIFICATION

COMPONENT NAME: 18"-300[#] BUTTERFLY VALVE WITH
SMB-DD-10/H3BC ACTUATOR

MARK NUMBERS: 2 RHY * MOV 9A



STONE & WEBSTER

Seismic and Dynamic Qualification Summary of Equipment**I. Plant Name:** Nine Mile Point Nuclear Station - Unit 21. Utility: Niagara Mohawk Power Corporation2. NSSS: General Electric Co.BWR: 5 MK 23. A/E: Stone & Webster Engineering Corp. OtherII. Component Name: 18"-300" BUTTERFLY VALVE
W/ SMB-00-10/H3BC ACTUATOR

1. Scope: () NSSS (X) BOP () Other

2. Model Number: N/A Quantity: 13. Size or Range: 18"-300"4. Vendor: POSI SEAL INC

5. If the component is a cabinet or panel, name and model number of the devices included: _____

(NOT APPLICABLE)

6. Physical Description:

a. Appearance: MOTOR OPERATED VALVE (MOV)b. Dimensions: 18" MOVc. Weight: 1414# TOTAL 886# VALVE
528# ACTUATOR/BACKET7. Location: Building: ABN (AUXILIARY BAY NORTH)Elevation: 201' COL. 46.00 LINE W8. Field Mounting Conditions () Bolt (No. _____ - Size _____)
() Weld (Length _____)
() NOT INSTALLED

9. Mounting Orientation (e.g., on floor, cantilevered, suspended, etc.)

PIPE MOUNTED10. a. System in which located: RESIDUAL HEAT REMOVAL (RHS/RHR)

VALVE IS NORMALLY OPEN. IT PROVIDES A FLOWPATH TO

b. Functional Description: HEAT EXCHANGER 2 RHR/EIA. FOR SHUTDOWN. SUPPRESSION POOL
AND CONTAINMENT SPRAY

c. Is the equipment required for () Hot Standby () Cold Shutdown (X) Both () Neither () Other _____



11. Pertinent Reference Design Specifications for Qualification Requirements: SPEC. P304D, REV. 1 "SPECIFICATION FOR

OPERATED, AIR OPERATED, & MANUAL BUTTERFLY VALVES EIDCRS:
P13057, P13248, C91957, P13078A, P13090

- a. Seismic Input d. Service Conditions
b. Hydrodynamic Load Input e. Qualified Life
c. Fatigue Considerations

III. Is Equipment Available for Inspection in the Plant:

☐ Yes ☒ No ☐ Partial or limited availability

IV. Equipment Qualification Method:

() Test () Analysis (X) Combination of Test and Analysis

Qualification Report*: SECTIONS IV THRU VII FOR

(No., Title and Date): EACH REPORT FOLLOWS:

Company that Prepared Report:

Company that Reviewed Report:

Where Report is filed or available:

Applicable Codes and/or Standards:

V. Vibration Input:

1. Loads considered: a. () Seismic only
b. () Hydrodynamic only
c. () Vibration from normal operation
d. () Combination of (a), (b), and (c)

2. Method of Combining RRS:

() Absolute Sum () SRSS ()
 (other, specify)

3. Required Response Spectra (attach the graphs):**

NOTE:

*If more than one report complete items IV thru VII for each report.

**If other than RRS is used, describe method.



STATIC ANALYSIS - VALVE ASSEMBLY

3

11. Pertinent Reference Design Specifications for Qualification Requirements: _____

- a. Seismic Input
- b. Hydrodynamic Load Input
- c. Fatigue Considerations
- d. Service Conditions
- e. Qualified Life

III. Is Equipment Available for Inspection in the Plant:

() Yes () No () Partial or limited availability

IV. Equipment Qualification Method:

() Test (X) Analysis () Combination of Test and Analysis

Qualification Report*: STRS 5.332-5000A

(No., Title and Date): 34077-01, "NUCLEAR SEISMIC ANALYSIS", 9-27-84

Company that Prepared Report: POSI SEAL INC.

Company that Reviewed Report: POSI SEAL / SWEC

Where Report is filed or available: NINE MILE POINT 2 JOB SITE

Applicable Codes and/or Standards: ASTM SECT. III, SUBSRT. NC, 1977 edition & Addenda up to & including 7-30-77, Code Case N-142-1 (1774-1)

V. Vibration Input:

1. Loads considered:
- a. (X) Seismic only
 - b. () Hydrodynamic only
 - c. () Vibration from normal operation
 - d. () Combination of (a), (b), and (c)

2. Method of Combining RRS: (NOT APPLICABLE)

() Absolute Sum () SRSS () _____
(other, specify)

3. Required Response Spectra** (attach the graphs): (NOT APPLICABLE)

VALVE ACCELERATIONS FROM PILING ANALYSIS

NOTE:

*If more than one report complete items IV thru VII for each report.

**If other than RRS is used, describe method.



4. Damping Corresponding to RRS: * OBE 2% SSE 3%

5. Required Acceleration in Each Direct:

() ZPA (X) Other PIPING ANALYSIS
(specify)

OBE S/S = 2.0g F/B = 2.0g V = 2.0g

SSE S/S = 3.0g F/B = 3.0g V = 3.0g

6. Were fatigue effects considered?

() Yes (X) No

If yes, describe how they were treated in overall qualification program: (NOT APPLICABLE)

VI. If Qualification by Test, then Complete: Not Applicable

1. () Single Frequency () Multi-Frequency () Random
() Sine Beat
() _____

2. () Single Axis () Multi-Axis
() Independent MOTION () In-phase Motions

3. Number of Qualifications Tests:

OBE _____ SSE _____ Other _____
(specify)

4. Frequency Range: _____

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S= _____ F/B= _____ V= _____

6. Method of Determining Natural Frequencies
() Lab Test () In-Situ Test () Analysis

7. TRS Enveloping RRS Using Multi-Frequency Test

() Yes (Attach TRS & RRS graphs)
() No

NOTE: DAMPING VALUES CORRESPOND TO THE DAMPING USED IN GENERATING THE RRS WHICH INTURN WAS USED IN THE RESPONSE SPECTRUM MODAL ANALYSIS FOR THE PIPING ANALYSIS. THE PIPING ANALYSIS PROVIDES THE ACCELERATION LEVELS FOR THE VALVE.



8. Maximum Input g Level Test:

OBE S/S = _____ F/B = _____ V = _____

SSE S/S = _____ F/B = _____ V = _____

9. Laboratory Mounting:

A. () Bolt (No. _____ Size _____)
() Weld (Length _____) () _____

B. Orientation and Fixturing: _____

10. Functional Operability Verified:

() Yes () No () Not Applicable

11. Test Results Including Modifications Made: _____

12. Other Tests Performed (such as aging or fragility test, including results):

13. Failure Modes (If appropriate _____)

14. Margins Available: () Input Spectrum () Fragility

VII. If Qualification by Analysis, Then Complete:

1. Method of Analysis:

☒ Static Analysis () Equivalent Static Analysis

() Dynamic Analysis: () Time-History () Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

LONG. = 58 hz TRANS. = 89 hz V = 453 hz

3. Model Type: () 3D () 2D () 1D
() Finite Element () Beam
☒ Closed Form Solution () Other



4. () Computer Codes: (NOT APPLICABLE)

Frequency Range and No. of Modes

(X) Hand Calculations

5. Method of Combining Dynamic Responses from Seismic and Other Dynamic Loads: (NOT APPLICABLE)

() Absolute Sum () SRSS () Other: _____
(specify)

6. Damping: (NOT APPLICABLE)

OBE — SSE — Basis for the Damping Used: —

7. Support Considerations in the Model: FIXED AT RING ENDS

8. Critical Structural Elements:

A. Identification Location	Governing Load or Response Combination	Seismic Stress	Total ** Stress	Stress Allowable
1. BRACKET BOLT	OPERATING + SEISMIC + DWT	21023 PSI (SEISMIC) 6479 PSI (DWT)	27131 PSI	37500 PSI
2. STEM	OPERATING + SEISMIC + DWT	3711 PSI (SEISMIC) 21023 PSI (DWT)	32603 PSI	52800 PSI

B. Maximum Critical Deflection	Location	Maximum Allowable Deflection to Assure Functional Operability
N / A		

9. Failure Modes: STRUCTURAL

10. Margins Available: () Input Spectrum (X) Stress or Deflection



DYNAMIC TESTING ~ LIMITORQUE ACTUATOR
(SMB-00-10/H3BC)
7

11. Pertinent Reference Design Specifications for Qualification Requirements: _____

- a. Seismic Input
- b. Hydrodynamic Load Input
- c. Fatigue Considerations
- d. Service Conditions
- e. Qualified Life

III. Is Equipment Available for Inspection in the Plant:

() Yes () No () Partial or limited availability

IV. Equipment Qualification Method:

(X) Test () Analysis () Combination of Test and Analysis

Qualification Report*: IEEE 05.312-5000 B & C

(No., Title and Date): B0058, "VALVE ACTUATOR QUALIFICATION REPORT," 1-11-80

Company that Prepared Report: LIMITORQUE

Company that Reviewed Report: POST SEAL INC. / SWEC

Where Report is filed or available: NINE MILE POINT 2 Job Site

Applicable Codes and/or Standards: IEEE 323-1974, 344-1975, 382-1972

V. Vibration Input:

1. Loads considered:
- a. (X) Seismic only
 - b. () Hydrodynamic only
 - c. (X) Vibration from normal operation
 - d. () Combination of (a), (b), and (c)

2. Method of Combining RRS: (NOT APPLICABLE)

() Absolute Sum () SRSS () _____
(other, specify)

3. Required Response Spectra** (attach the graphs): (NOT APPLICABLE)
VALVE ACCELERATIONS FROM PIPING ANALYSIS.

NOTE:

*If more than one report complete items IV thru VII for each report.

**If other than RRS is used, describe method.

1) ... Appendix F (B0037), Appendix 11 - LIMITORQUE REPORT B0047 (SMB-3-150/H5BC) &
Report B0048 (SMB-1-60/H3BC)



4. Damping Corresponding to RRS: * OBE 2% SSE 3%

5. Required Acceleration in Each Direct:

() ZPA (X) Other PIPING ANALYSIS
(specify)

OBE S/S = 2.0 g F/B = 2.0 g V = 2.0 g

SSE S/S = 3.0 g F/B = 3.0 g V = 3.0 g

6. Were fatigue effects considered?

() Yes (X) No

If yes, describe how they were treated in overall qualification program: (NOT APPLICABLE)

VI. If Qualification by Test, then Complete: FOR ACTUATOR ONLY

1. (X) Single Frequency () Multi-Frequency () Random
() Sine Beat
(X) SINE DWELLS

2. (X) Single Axis () Multi-Axis
() Independent Motion () In-phase Motions

3. Number of Qualifications Tests:

OBE 5~2.2g INPUT SSE 1~4.4g INPUT Other ~
30 SEC. DWELL 30 SEC. DWELL (specify)
@ 35 Hz @ 35 Hz

4. Frequency Range: 1 TO 35 HERTZ

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical): Rpt. B0048

PARALLEL TO MOTOR = 34 Hz ⊥ TO MOTOR 4 Hz V = > 60 Hz

6. Method of Determining Natural Frequencies
(X) Lab Test () In-Situ Test () Analysis

7. TRS Enveloping RRS Using Multi-Frequency Test (NOT APPLICABLE)

() Yes (Attach TRS & RRS graphs)
() No

* NOTE: DAMPING VALUES CORRESPOND TO THE DAMPING USED IN GENERATING THE RRS WHICH IN TURN WAS USED IN THE RESPONSE SPECTRUM MODAL ANALYSIS FOR THE PIPING ANALYSIS. THE PIPING ANALYSIS PROVIDES THE ACCELERATION LEVELS FOR THE VALVE.



8. Maximum Input g Level Test: SINGLE FREQUENCY TESTS AT 35 Hz.

OBE S/S = 2.2g F/B = 2.2g V = 2.2g

SSE S/S = 4.4g F/B = 4.4g V = 4.4g

9. Laboratory Mounting:

A. ☒ Bolt (No. Size)
☐ Weld (Length) ()

B. Orientation and Fixturing: ACTUATOR COUPLER TO TEST FIXTURE

10. Functional Operability Verified:

☒ Yes ☐ No ☐ Not Applicable

11. Test Results Including Modifications Made: SUCCESSFULLY

PASSED TEST

12. Other Tests Performed (such as aging or fragility test, including results): PLANT VIBRATION

SINE SWEEP, TESTING AT .75g INPUT BETWEEN 10 TO 100 Hz AT A
RATE OF 2 OCTAVES/MIN. FOR 90 MIN. IN EACH AXIS.

13. Failure Modes (If appropriate STRUCTURAL, FUNCTIONAL)

14. Margins Available: ☒ Input Accelerations ☐ Fragility

VII. If Qualification by Analysis, Then Complete: (NOT APPLICABLE)

1. Method of Analysis:

☐ Static Analysis ☐ Equivalent Static Analysis
☐ Dynamic Analysis: ☐ Time-History ☐ Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = F/B = V =

3. Model Type: ☐ 3D ☐ 2D ☐ 1D
☐ Finite Element ☐ Beam
☐ Closed Form Solution ☐ Other



STATIC OPERABILITY TEST ~ VALVE ASSEMBLY

10

11. Pertinent Reference Design Specifications for Qualification Requirements: _____

- | | |
|----------------------------|-----------------------|
| a. Seismic Input | d. Service Conditions |
| b. Hydrodynamic Load Input | e. Qualified Life |
| c. Fatigue Considerations | |

III. Is Equipment Available for Inspection in the Plant:

() Yes () No () Partial or limited availability

IV. Equipment Qualification Method:

(X) Test () Analysis () Combination of Test and Analysis

Qualification Report*: STRS 05.312.5008 B & A

(No., Title and Date): 34077 OT-01, "STATIC SEISMIC OPERABILITY TEST PROC. & RESULTS"

Company that Prepared Report: POSI SEAL INC.

Company that Reviewed Report: SWEC

Where Report is filed or available: NINE MILE POINT 2 JOB SITE

Applicable Codes and/or Standards: NRC REG GUIDE 1.4B, 1.14B,

V. Vibration Input:

1. Loads considered:
- | | |
|----|--------------------------------------|
| a. | (X) Seismic only |
| b. | () Hydrodynamic only |
| c. | () Vibration from normal operation |
| d. | () Combination of (a), (b), and (c) |

2. Method of Combining RRS: (NOT APPLICABLE)

() Absolute Sum () SRSS () _____
(other, specify)

3. Required Response Spectra** (attach the graphs): (NOT APPLICABLE)

** VALVE ACCELERATIONS FROM PIPING ANALYSIS

NOTE:

*If more than one report complete items IV thru VII for each report.

**If other than RRS is used, describe method.



4. Damping Corresponding to RRS: * OBE 2% SSE 3%

5. Required Acceleration in Each Direct: *

() ZPA (X) Other SPEC. REQUIREMENTS
(specify)

OBE S/S = 2.0 g F/B = 2.0 g V = 2.0 g

SSE S/S = 3.0 g F/B = 3.0 g V = 3.0 g

6. Were fatigue effects considered?

() Yes (X) No

If yes, describe how they were treated in overall

qualification program: (NOT APPLICABLE)

VI. If Qualification by Test, then Complete:

1. () Single Frequency () Multi-Frequency () Random
() Sine Beat
(X) STATIC OPERABILITY

2. (X) Single Axis () Multi-Axis
() Independent MOTION () In-phase Motions

3. Number of Qualifications Tests:

OBE ~ SSE ~ Other VALVE/ACTUATOR CYCLED 3 TIMES
AT 460V WITH EQUIVALENT
STATIC LOAD (3636 lb) + PRESSURE
(specify)

4. Frequency Range: (NOT APPLICABLE)

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical): (NOT APPLICABLE)

S/S = ~ F/B = ~ V = ~

6. Method of Determining Natural Frequencies (NOT APPLICABLE)
() Lab Test () In-Situ Test () Analysis

7. TRS Enveloping RRS Using Multi-Frequency Test (NOT APPLICABLE)

() Yes (Attach TRS & RRS graphs)
() No

NOTE: Damping Values Correspond To The Damping Used In Generating The RRS WHICH IN TURN WAS USED IN THE RESPONSE SPECTRUM MODAL ANALYSIS FOR THE PIPING ANALYSIS. THE PIPING ANALYSIS PROVIDES THE ACCELERATION LEVELS FOR THE VALVE.
1) THE EQUIVALENT ACCELERATION LEVEL OF 7.5 g's WAS APPLIED (3636 LBS)

8. Maximum Input g Level Test:¹⁾OBE S/S = F/B = V = SSE S/S = 7.5 g's F/B = V =

APPLIED ALONG WEAKEST AXIS

9. Laboratory Mounting:

- A. () Bolt (No. Size)
 () Weld (Length) ()

B. Orientation and Fixturing: CLAMPED IN FUTURE - VALVE WAS HORIZONTAL

10. Functional Operability Verified:

(X) Yes () No () Not Applicable

11. Test Results Including Modifications Made: VALVE CYCLED WITH
STATIC LOAD APPLIED - NO MODIFICATIONS12. Other Tests Performed (such as aging or fragility test,
including results):HYDROSTATIC SEAT TEST13. Failure Modes (If appropriate STRUCTURAL, FUNCTIONAL)14. Margins Available: (X) Input (Spectrum) () Fragility
AccelerationVII. If Qualification by Analysis, Then Complete: (NOT APPLICABLE)

1. Method of Analysis:

- () Static Analysis () Equivalent Static Analysis
 () Dynamic Analysis: () Time-History () Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back,
Vertical):S/S = F/B = V = 3. Model Type: () 3D () 2D () 1D
 () Finite Element () Beam
 () Closed Form Solution () Other

¹⁾ THE EQUIVALENT ACCELERATION LEVEL OF 7.5 g's WAS APPLIED TO VALVE ASSEMBLY
 FORCE APPLIED - 3636 #



NINE MILE POINT NUCLEAR STATION UNIT 2

EQUIPMENT DYNAMIC QUALIFICATION

COMPONENT NAME: 24" - 900# GATE VALVE
WITH SMB-4-200 ACTUATOR

MARK NUMBERS: 2 FWS * MOV 21A



STONE & WEBSTER

Seismic and Dynamic Qualification Summary of Equipment

I. Plant Name: Nine Mile Point Nuclear Station - Unit 2

1. Utility: Niagara Mohawk Power Corporation

2. WSSS: General Electric Co.

BWR: 5 MK 2

3. A/E: Stone & Webster Engineering Corp. Other _____

II. Component Name: RPV LONG TERM ISOLATION VALVE - 24" - 900# GATE VALVE WITH
SMB-4-200 ACTUATOR

1. Scope: () WSSS (X) BOP () Other

2. Model Number: (NOT APPLICABLE) Quantity: 1

3. Size or Range: 24" - 900#

4. Vendor: VELAN ENGINEERING

5. If the component is a cabinet or panel, name and model number of the devices included:

(NOT APPLICABLE)

6. Physical Description:

a. Appearance: MOTOR OPERATED VALVE (MOV)

b. Dimensions: 24" MOV

c. Weight: 10850 LBS (APPROX) INCL. OPERATOR

7. Location: Building: RB - REACTOR BLDG COL. 01.30 LINE B

Elevation: 257'

8. Field Mounting Conditions () Bolt (No. _____ - Size _____)

(X) Weld (Length 75") APPROX.

() _____

9. Mounting Orientation (e.g., on floor, cantilevered, suspended, etc.)

PIPE MOUNTED

10. a. System in which located: FEEDWATER SYSTEM

b. Functional Description: LONG-TERM FEED FLOW ISOLATION

c. Is the equipment required for () Hot Standby () Cold Shutdown () Both () Neither (X) Other ALL CONDITIONS

EXCEPT COLD SHUTDOWN



11. Pertinent Reference Design Specifications for Qualification Requirements: SPEC. P304 R, REV. 2, ADDENDA 1 TO 6

"SPECIFICATION FOR MOTOR-OPERATED CARBON STEEL VALVES"

- | | |
|------------------------------|-----------------------|
| (a.) Seismic Input | d. Service Conditions |
| (b.) Hydrodynamic Load Input | e. Qualified Life |
| (c.) Fatigue Considerations | |

III. Is Equipment Available for Inspection in the Plant:

(X) Yes () No () Partial or limited availability

IV. Equipment Qualification Method:

() Test () Analysis (X) Combination of Test and Analysis

Qualification Report*: SECTIONS IV THRU VII FOR

(No., Title and Date): EACH REPORT FOLLOWS :

Company that Prepared Report: _____

Company that Reviewed Report: _____

Where Report is filed or available: _____

Applicable Codes and/or Standards: _____

V. Vibration Input:

1. Loads considered:
- | | |
|----|--------------------------------------|
| a. | () Seismic only |
| b. | () Hydrodynamic only |
| c. | () Vibration from normal operation |
| d. | () Combination of (a), (b), and (c) |

2. Method of Combining RRS:

() Absolute Sum () SRSS () _____
(other, specify)

3. Required Response Spectra** (attach the graphs): _____

NOTE:

*If more than one report complete items IV thru VII for each report.

**If other than RRS is used, describe method.



STATIC ANALYSIS - VALVE ASSEMBLY

3

11. Pertinent Reference Design Specifications for Qualification Requirements:

- a. Seismic Input
- b. Hydrodynamic Load Input
- c. Fatigue Considerations
- d. Service Conditions
- e. Qualified Life

III. Is Equipment Available for Inspection in the Plant:

() Yes () No () Partial or limited availability

IV. Equipment Qualification Method:

() Test (X) Analysis () Combination of Test and Analysis

Qualification Report*:

(No., Title and Date):

Company that Prepared Report:

Company that Reviewed Reports:

Where Report is filed or available:

Applicable Codes and/or Standards:

V. Vibration Input:

1. Loads considered:
 - a. (X) Seismic only
 - b. (X) Hydrodynamic only
 - c. () Vibration from normal operation
 - d. () Combination of (a), (b), and (c)

2. Method of Combining RRS:

() Absolute Sum

(X) SRSS

()

(other, specify)

3. Required Response Spectra** (attach the graphs): (NOT APPLICABLE)

** VALVE ACCELERATIONS FROM PIPING ANALYSIS

NOTE:

*If more than one report complete items IV thru VII for each report.

**If other than RRS is used, describe method.



4. Damping Corresponding to RRS: * $\frac{UPSET}{OBE}$ 2% $\frac{FAULTED}{SSE}$ 2%

5. Required Acceleration in Each Direct:

() ZPA (X) Other PIPING ANALYSIS
(specify)

$\frac{UPSET}{OBE}$ S/S = 4.0g F/B = 4.0g V = 4.0g
 $\frac{FAULTED}{SSE}$ S/S = 6.5g F/B = 6.5g V = 6.5g

6. Were fatigue effects considered?

(X) Yes () No

If yes, describe how they were treated in overall qualification program: PEAK STRESSES ARE CALCULATED AT THE CRITICAL SECTIONS, USING S/N CURVES FROM ASME SECT. III APPENDICES + MINER'S RULE, CUMULATIVE USAGE FACTORS ARE DETERMINED TO BE LESS THAN UNITY.

VI. If Qualification by Test, then Complete:

1. () Single Frequency () Multi-Frequency () Random
() Sine Beat
() _____

2. () Single Axis () Multi-Axis
() Independent MOTION () In-phase Motions

3. Number of Qualifications Tests:

OBE _____ SSE _____ Other _____
(specify)

4. Frequency Range: _____

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S= _____ F/B= _____ V= _____

6. Method of Determining Natural Frequencies
() Lab Test () In-Situ Test () Analysis

7. TRS Enveloping RRS Using Multi-Frequency Test

() Yes (Attach TRS & RRS graphs)
() No

* NOTE: DAMPING VALUES CORRESPOND TO THE DAMPING USED IN GENERATING THE RRS WHICH IN TURN WAS USED IN THE RESPONSE SPECTRUM MODAL ANALYSIS FOR THE PIPING ANALYSIS. THE PIPING ANALYSIS PROVIDES THE ACCELERATION LEVELS FOR THE VALVE.



8. Maximum Input g Level Test:

OBE S/S = _____ F/B = _____ V = _____

SSE S/S = _____ F/B = _____ V = _____

9. Laboratory Mounting:

A. () Bolt (No. _____ Size _____)
() Weld (Length _____) () _____

B. Orientation and Fixturing: _____

10. Functional Operability Verified:

() Yes () No () Not Applicable

11. Test Results Including Modifications Made: _____

12. Other Tests Performed (such as aging or fragility test, including results):

13. Failure Modes (If appropriate _____)

14. Margins Available: () Input Spectrum () Fragility

VII. If Qualification by Analysis, Then Complete:

1. Method of Analysis:

(X) Static Analysis () Equivalent Static Analysis

() Dynamic Analysis: () Time-History () Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back,

* FUNDAMENTAL FREQUENCY IN HORIZONTAL DIRECTION Vertical):
└─ TO RUN OF PIPE* S/S = 59 HZ F/B = >59 HZ V = >59 HZ3. Model Type: () 3D () 2D () 1D
() Finite Element () Beam
(X) Closed Form Solution () Other



4. () Computer Codes: (NOT APPLICABLE)

Frequency Range and No. of Modes

(X) Hand Calculations

5. Method of Combining Dynamic Responses from Seismic and Other Dynamic Loads:

() Absolute Sum (X) SRSS () Other: _____
(specify)

6. Damping: (NOT APPLICABLE)

OBE _____ SSE _____ Basis for the Damping Used: _____

7. Support Considerations in the Model: FIXED AT PIPING ENDS

8. Critical Structural Elements:

A. Identification Location	Governing Load or Response Combination	Seismic ^{**} Stress	Total Stress	Stress Allowable
<u>BOTTOM OF YOKE ARMS</u>	<u>SEISMIC + HYDRAULIC + OPERATING</u>	<u>16107</u>	<u>21620</u>	<u>29100 PSI</u>

B. Maximum Critical ^{***} Deflection	Location	Maximum Allowable Deflection to Assure Functional Operability
<u>0.0244IN</u>	<u>STEM</u>	<u>.05 INCH</u>

9. Failure Modes: STRUCTURAL

10. Margins Available: () Input Spectrum (X) Stress or Deflection

** SEISMIC STRESS IS CALCULATED BASED ON AN ACCELERATION VALUE OF 6.5 G's.
*** STEM DEFLECTION " " " " " " " " " " " "



DYNAMIC TESTING - LIMITORQUE ACTUATOR
(SMB-4-200)
7

11. Pertinent Reference Design Specifications for Qualification Requirements: _____

- | | |
|----------------------------|-----------------------|
| a. Seismic Input | d. Service Conditions |
| b. Hydrodynamic Load Input | e. Qualified Life |
| c. Fatigue Considerations | |

III. Is Equipment Available for Inspection in the Plant:

() Yes () No () Partial or limited availability

IV. Equipment Qualification Method: *(see Page 8 for General Comment)*

(X) Test () Analysis () Combination of Test and Analysis

Qualification Report*: TEST 05.321.5013A

(No., Title and Date): REPORT No B-0115, HYDRODYNAMIC VIBRATION TESTING (NEW LOADS) 6-24-82

Company that Prepared Report: LIMITORQUE

Company that Reviewed Report: SWEC

Where Report is filed or available: NINE MILE POINT 2 JOB SITE

Applicable Codes and/or Standards: IEEE 323-1974, 344-1975 382-1972

V. Vibration Input:

1. Loads considered:
- | | |
|----|--------------------------------------|
| a. | () Seismic only |
| b. | () Hydrodynamic only |
| c. | () Vibration from normal operation |
| d. | (X) Combination of (a), (b), and (c) |

2. Method of Combining ^{ACCELERATIONS} RRS:

() Absolute Sum (X) SRSS () _____
(other, specify)

3. Required Response Spectra** (attach the graphs): (NOT APPLICABLE)
ACTUATOR QUALIFIED BY EIM TESTING

NOTE:

*If more than one report complete items IV thru VII for each report.

**If other than RRS is used, describe method.



GENERAL COMMENT:

Qualification of the Limiting Actuators for hydrodynamic loading is accomplished by referring to the following documents:

1. SWEC Calc. 12/77-NM(C)-MS-1942, Rev.0, dated 5-31-85,
"Similarity Analysis for Dynamic Qualification of Limiting Motor Operators"
2. IEEE 05.321.5001C, 1D
Limiting Qualification Report, B0058, "Valve
Actuator Qualification Report," 1-11-80.
3. IEEE 05.321.5013A
Hydrodynamic Vibrations Testing (New Grade)
Limiting Report No. B-0115, 6-24-82
4. SWEC Transmittal Ltr # T-42,842 (1-19-82) &
T-42622 (6-10-82) for P-801H, "Dynamic Testing
of Limiting Operators & Modified Limit Switches
NTS Ltr # 548-9291, Rev.2. 3 Volumes (5-25-82)



4. Damping Corresponding to RRS: * UPSET OBE 2% FAULTED SSE 2%

5. Required Acceleration in Each Direction:

() ZPA (X) Other PIPING ANALYSIS
(specify)

UPSET OBE S/S = 4.0 g F/B = 4.0 g V = 4.0 g
FAULTED SSE S/S = 6.5 g F/B = 6.5 g V = 6.5 g

6. Were fatigue effects considered?

(X) Yes () No

If yes, describe how they were treated in overall qualification program: FATIGUE EFFECTS WERE INCORPORATED IN THE
NUMBER OF SINE BEATS, AND NUMBER & DURATIONS OF THE TESTS.

VI. If Qualification by Test, then Complete: FOR ACTUATOR ONLY

1. (X) Single Frequency () Multi-Frequency () Random
(X) Sine Beat ^D
() _____

2. (X) Single Axis () Multi-Axis
() Independent Motion () In-phase Motions

3. Number of Qualifications Tests: (EQUIVALENT) ^D

UPSET OBE 5 FAULTED SSE 1 Other ADDITIONAL TESTING TO
ACCOUNT FOR SRV + LOCA LOADS
(specify)

4. Frequency Range: 1 TO 100 hertz -

5. ** Natural Frequencies in Each Direction (Side/Side, Front/Back, ^{1/4MB-4250}
Vertical): LOWEST MOTOR FREQUENCY = 70 HZ (HORIZONTAL) ⊥ TO MOTOR } OPEN
HANDWHEEL (UNDEFINED) = 29 HZ (HORIZONTAL) PARALLEL TO MOTOR } ACTUATOR
S/S = NONE BETWEEN 20 AND 40 HZ - CLOSED ACTUATOR F/B = 58 HZ (VERT.) V = 58 HZ (VERT.)

6. Method of Determining Natural Frequencies
(X) Lab Test () In-Situ Test () Analysis

7. TRS Enveloping RRS Using Multi-Frequency Test (NOT APPLICABLE)

() Yes (Attach TRS & RRS graphs)
() No

*NOTE: DAMPING VALUES CORRESPOND TO THE DAMPING USED IN GENERATING THE RRS WHICH IN TURN WAS USED IN THE RESPONSE SPECTRUM MODEL ANALYSIS FOR THE PIPING ANALYSIS.
THE PIPING ANALYSIS PROVIDES THE ACCELERATION LEVELS FOR THE VALVE.

8. Maximum Input g Level Test:

UPSET / FAULTED EQUIPMENT

OBE S/S = 7g's F/B = 7g's V = 7g's

SSE S/S = _____ F/B = _____ V = _____

9. Laboratory Mounting:

- A. ☒ Bolt (No. ~ Size ~)
☐ Weld (Length) ☐ _____

B. Orientation and Fixturing: BOLTED TO TEST FIXTURE
ACTUATOR STEM - VERTICAL

10. Functional Operability Verified:

☒ Yes ☐ No ☐ Not Applicable

11. Test Results Including Modifications Made: PERFORMED ALL REQUIRED FUNCTIONS
WITH NO INDICATION OF MALFUNCTION

12. Other Tests Performed (such as aging or fragility test,
including results):

NONE

13. Failure Modes (If appropriate STRUCTURAL, FUNCTIONAL)

14. Margins Available: ☐ Input ^{ACCELERATION} Spectrum ☐ Fragility

VII. If Qualification by Analysis, Then Complete:

1. Method of Analysis:

- ☐ Static Analysis ☐ Equivalent Static Analysis
☐ Dynamic Analysis: ☐ Time-History ☐ Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back,
Vertical):

S/S = _____ F/B = _____ V = _____

3. Model Type: ☐ 3D ☐ 2D ☐ 1D
☐ Finite Element ☐ Beam
☐ Closed Form Solution ☐ Other



DYNAMIC TESTING - LIMITORQUE ACTUATOR

//

11. Pertinent Reference Design Specifications for Qualification Requirements: _____

- a. Seismic Input
- b. Hydrodynamic Load Input
- c. Fatigue Considerations
- d. Service Conditions
- e. Qualified Life

III. Is Equipment Available for Inspection in the Plant:

() Yes () No () Partial or limited availability

IV. Equipment Qualification Method: (see Page 8 for General Comments)

(X) Test () Analysis () Combination of Test and Analysis

Qualification Report*: ^{SPEC. P801H₂} SWEC TRANS. GTR. T47622 (6/10/82)

(No., Title and Date): ^{NTS Report 548-9291, RE2. 3 VOLUMES (5.25.82)} DYNAMIC TESTING OF LIMITORQUE OPERATORS & MODIFIED UNIT SWITCHES

Company that Prepared Report: NTS/SWEC

Company that Reviewed Report: NTS/SWEC

Where Report is filed or available: NINE MILE POINT 2 JOB SITE

Applicable Codes and/or Standards: IEEE 382-1980, IEEE 344-1975

V. Vibration Input:

1. Loads considered:
- a. () Seismic only
 - b. () Hydrodynamic only
 - c. () Vibration from normal operation
 - d. (X) Combination of (a), (b), and (c)

2. Method of Combining RRS:

() Absolute Sum (X) SRSS () _____
(other, specify)

3. Required Response Spectra** (attach the graphs): Not Applicable ACTUATOR QUALIFIED BY RIM TESTING†

NOTE:

*If more than one report complete items IV thru VII for each report.

**If other than RRS is used, describe method.

† A GENERIC TYPE TESTING PROGRAM WAS CONDUCTED WHEREIN RMF TESTING WAS INCLUDED, CONCRETE RRS WERE USED, HOWEVER THE ACTUATOR IS QUALIFIED BY RIM TESTING. THEREFORE, RRS ARE NOT INCLUDED IN THIS PACKAGE



4. Damping Corresponding to RRS: * LIPSET OBE 2% FAULTED SSE 2%

5. Required Acceleration in Each Direct:

() ZPA (X) Other PIPING ANALYSIS
(specify)

LIPSET
OBE S/S = 4.0 g F/B = 4.0 g V = 4.0 g
FAULTED
SSE S/S = 6.5 g F/B = 6.5 g V = 6.5 g

6. Were fatigue effects considered?

(X) Yes () No

If yes, describe how they were treated in overall qualification program: FATIGUE EFFECTS WERE INCORPORATED IN

THE NUMBER OF SINE BEATS, & NUMBER & DURATION OF THE TESTS

VI. If Qualification by Test, then Complete:

1. (X) Single Frequency (X) Multi-Frequency (X) Random
(X) Sine Beat
(X) FRAGILITY TESTS

2. (X) Single Axis (X) Multi-Axis
() Independent Axis () In-phase Motions

3. Number of Qualifications Tests: (equivalent)

UPSET OBE 5 FAULTED SSE 1 Other ADDITIONAL TESTING TO
ACCOUNT FOR SERV + LOAD LOADS
(specify)

4. Frequency Range: 1 TO 100 HERTZ

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, (SMB-0-25 Model)
Vertical): LOWEST MOTOR FREQUENCY = 64 HZ
GROSS STRUCTURE = 130 HZ
LIMIT SWITCH = 150 HZ
S/S = ~ F/B = ~ V = ~

6. Method of Determining Natural Frequencies
(X) Lab Test () In-Situ Test () Analysis

7. TRS Enveloping RRS Using Multi-Frequency Test (NOT Applicable)

() Yes (Attach TRS & RRS graphs)
() No

* THE DAMPING VALUES CORRESPOND TO THE RRS USED IN PIPING ANALYSIS.



8. Maximum Input g Level Test:

OBE S/S = 14.0g F/B = 14.0g V = 14.0g
 SSE S/S = ~ F/B = ~ V = ~

9. Laboratory Mounting:

A. ☒ Bolt (No. 4 Size 1/5" DIA)
☐ Weld (Length) ☐

B. Orientation and Fixturing: NO FIXTURE, BOLTED TO TEST TABLE,
ACTUATOR STEM IN VERTICAL POSITION

10. Functional Operability Verified:

☒ Yes ☐ No ☐ Not Applicable

11. Test Results Including Modifications Made: PERFORMED ALL REQUIRED FUNCTIONS
WITH NO INDICATION OF MALFUNCTION. LIMIT SWITCH SCREW TORQUES WERE ADJUSTED
AND FINGER ASSEMBLY GAPS WERE ADJUSTED.

12. Other Tests Performed (such as aging or fragility test, including results):

VIBRATION Aging & RANDOM MULTIFREQUENCY TESTS.

13. Failure Modes (If appropriate STRUCTURAL, FUNCTIONAL)

14. Margins Available: ☒ Input ^{Acceleration} ~~Spectrum~~ ☐ Fragility

VII. If Qualification by Analysis, Then Complete:

1. Method of Analysis:

☐ Static Analysis ☐ Equivalent Static Analysis
☐ Dynamic Analysis: ☐ Time-History ☐ Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = F/B = V =

3. Model Type: ☐ 3D ☐ 2D ☐ 1D
☐ Finite Element ☐ Beam
☐ Closed Form Solution ☐ Other



STATIC OPERABILITY TEST - VALVE ASSEMBLY
14

11. Pertinent Reference Design Specifications for Qualification Requirements: _____

- | | |
|----------------------------|-----------------------|
| a. Seismic Input | d. Service Conditions |
| b. Hydrodynamic Load Input | e. Qualified Life |
| c. Fatigue Considerations | |

III. Is Equipment Available for Inspection in the Plant:

() Yes () No () Partial or limited availability

IV. Equipment Qualification Method:

(X) Test () Analysis () Combination of Test and Analysis

Qualification Report*: STR 05.321.5053 A

(No., Title and Date): P3-7026-N (ITEM 50) "OPERABILITY TEST RESULTS" 12/12/83

Company that Prepared Report: VELAN

Company that Reviewed Report: SWEC

Where Report is filed or available: NINE MILE POINT 2 JOB SITE

Applicable Codes and/or Standards: —

V. Vibration Input:

1. Loads considered:
- a. (X) Seismic only
 - b. (X) Hydrodynamic only
 - c. () Vibration from normal operation
 - d. () Combination of (a), (b), and (c)

2. Method of Combining RRS: ACCELERATIONS

() Absolute Sum (X) SRSS () _____
(other, specify)

3. Required Response Spectra** (attach the graphs): (NOT APPLICABLE)
— VALVE ACCELERATION FROM PIPING ANALYSIS

NOTE:

*If more than one report complete items IV thru VII for each report.

**If other than RRS is used, describe method.



4. Damping Corresponding to RRS: * UPSET OBE 2% FAULTED SSE 2%

5. Required Acceleration in Each Direct: *

() ZPA (X) Other PIPING ANALYSIS
(specify)

... UPSET OBE S/S = N/A F/B = N/A V = N/A
FAULTED SSE S/S = 6.5g F/B = 6.5g V = 6.5g

6. Were fatigue effects considered?

() Yes (X) No

If yes, describe how they were treated in overall qualification program: (NOT APPLICABLE)

VI. If Qualification by Test, then Complete:

1. () Single Frequency () Multi-Frequency () Random
() Sine Beat
(X) STATIC OPERABILITY

2. (X) Single Axis () Multi-Axis
() Independent Motion () In-phase Motions

3. Number of Qualifications Tests:

OBE ~ SSE ~ Other VALVE/ACTUATOR CYCLED 3 TIMES EACH
AT 632V + 460V WITH
EQUIVALENT STATIC LOAD (27840 lb)
+ PRESSURE APPLIED
(specify)

4. Frequency Range: (NOT APPLICABLE)

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical): (NOT APPLICABLE)

S/S = ~ F/B = ~ V = ~

6. Method of Determining Natural Frequencies (NOT APPLICABLE)
() Lab Test () In-Situ Test () Analysis

7. TRS Enveloping RRS Using Multi-Frequency Test (NOT APPLICABLE)

() Yes (Attach TRS & RRS graphs)
() No

* NOTE: DAMPING VALUES CORRESPOND TO THE DAMPING USED IN GENERATING THE RRS WHICH IN TURN WAS USED IN THE RESPONSE SPECTRUM MODAL ANALYSIS FOR THE PIPING ANALYSIS. THE PIPING ANALYSIS PROVIDED THE ACCELERATION LEVELS FOR THE VALVE.

1) THE EQUIVALENT ACCELERATION LEVELS FOR THE VALVE



8. Maximum Input g Level Test: *

UNSET OBE S/S = ~ F/B = ~ V = ~
 FAULTED SSE S/S = 11.6 g's F/B = ~ V = ~
 APPLIED ALONG WEAKEST AXIS

9. Laboratory Mounting:

A. (X) Bolt (No. ~ Size ~)
 () Weld (Length ~) () ~

B. Orientation and Fixturing: CLAMPED AT BODY ENDS - VALVE
 VERTICAL STEM AXIS WAS

10. Functional Operability Verified:

(X) Yes () No () Not Applicable

11. Test Results Including Modifications Made: VALVE CYCLED WITH
 STATIC LOAD APPLIED - NO MODIFICATIONS

12. Other Tests Performed (such as aging or fragility test,
 including results):

SEAT LEAKAGE TEST
 CYCLE TEST

13. Failure Modes (If appropriate) STRUCTURAL, FUNCTIONAL

14. Margins Available: (X) Input Accelerations Spectrum () Fragility

VII. If Qualification by Analysis, Then Complete:

1. Method of Analysis:

() Static Analysis () Equivalent Static Analysis
 () Dynamic Analysis: () Time-History () Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = ~ F/B = ~ V = ~

3. Model Type: () 3D () 2D () 1D
 () Finite Element () Beam
 () Closed Form Solution () Other

* THE EQUIVALENT ACCELERATION LEVEL OF 11.6 g's WAS APPLIED TO VALVE ASSEMBLY
 FORCE APPLIED - 27840 LBS.



SPEC. NO. P413 E/V

SQRT # 21

NINE MILE POINT NUCLEAR STATION UNIT 2

EQUIPMENT DYNAMIC QUALIFICATION

COMPONENT NAME: CENTRAL STATION
AIR CONDITIONING
UNIT FOR CONTROL ROOM

MARK NUMBERS: 2 HVC * ACU 1 A



STONE & WEBSTER



Seismic and Dynamic Qualification Summary of Equipment

I. Plant Name: Nine Mile Point Nuclear Station - Unit 2

1. Utility: Niagara Mohawk Power Corporation
2. NSSS: General Electric Co. BWR: 5 MK 2
3. A/E: Stone & Webster Engineering Corp. Other

II. Component Name: Central Station Air Conditioning Unit For Control Room. (2 HVC * ACU 1A)

1. Scope: ☐ NSSS ☒ BOP ☐ Other
2. Model Number: 39 ED 57 Quantity: 1
3. Size or Range: 23280 CFM
4. Vendor: Carrier Corporation
5. If the component is a cabinet or panel, name and model number of the devices included: N.A.

6. Physical Description:

- a. Appearance: Rectangular box
- b. Dimensions: 141" W X 723.5" D X 81.68" H
- c. Weight: 8039 lb.

7. Location: Building: Control Building
Elevation: 288' 6"

8. Field Mounting Conditions ☒ Bolt (No. 10 Size 5"
☐ Weld (Length)
☐

9. Mounting Orientation (e.g., on floor, cantilevered, suspended, etc.)
Floor

10. a. System in which located: Control Building - Air Conditioning (HVC)
b. Functional Description: Provides air-conditioned air to Control Room & EL. 306'
c. Is the equipment required for ☒ Hot Standby ☒ Cold Shutdown ☒ Both ☐ Neither ☒ Other All normal and accident conditions



11. Pertinent Reference Design Specifications for Qualification

Requirements: 1. Spec # P 413 E, Central Station Air Conditioning Units
For Control & Relay Rooms, Rev. 1. 2. Spec. # P 413 V, Safety Related
Air Cooling Coils For Control & Relay Room Air Conditioning Units, Rev. 1.

- a. Seismic Input
- b. Hydrodynamic Load Input
- c. Fatigue Considerations
- d. Service Conditions
- e. Qualified Life

III. Is Equipment Available for Inspection in the Plant:

(☒) Yes () No () Partial or limited availability

IV. Equipment Qualification Method: Housing, coil & fan

☐ Test ☒ Analysis ☐ Combination of Test and Analysis

Qualification Report*: 1. M'S.-1846, Supplemental Calculation, 1-6-84.
2. A-266-79, Seismic Qualification Report of
 (No., Title and Date): Control & Relay Rooms Central Station Air
Conditioning Units, 12-10-79, and Addenda
(cont'd below)***

Company that Prepared Report: 1. SWEC for report 1
2. CCDC/ carrier for report 2
 Company that Reviewed Report: SWEC

Where Report is filed or available: .. Nine mile site

Applicable Codes and/or Standards: IEEE 344-1975
AFSC Code E

V. Vibration Input:

ASME Code, Sec. III, Appendices E & NF
(1974 - winter '76)

1. Loads considered: a. (X) Seismic only
b. () Hydrodynamic only
c. () Vibration from normal operation
d. () Combination of (a), (b), and (c)

2. Method of Combining RRS:

() Absolute Sum () SRSS (✓) N. A.
(other, specify)

3. Required Response Spectra** (attach the graphs): Attachment A

NOTE:

*If more than one report complete items IV thru VII for each report.

****If other than RRS is used, describe method.**

*** Add. 1, 10-2-80,
Add. 2, 11-26-80
- & Add. 3, 1-9-81

-3-

4. Damping Corresponding to RRS: OBE 2 % SSE 3 %

5. Required Acceleration in Each Direction:

() ZPA (✓) Other Rigid Range
(specify)OBE S/S = 0.34 F/B = 0.34 V = 0.33SSE S/S = 0.48 F/B = 0.48 V = 0.49

6. Were fatigue effects considered?

() Yes (✓) No

If yes, describe how they were treated in overall qualification program: _____

VI. If Qualification by Test, then Complete: N. A.1. () Single Frequency () Multi-Frequency () Random
() Sine Beat
() _____2. () Single Axis () Multi-Axis
() Independent Axis () In-phase Motions

3. Number of Qualifications Tests:

OBE _____ SSE _____ Other _____
(specify)

4. Frequency Range: _____

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S= _____ F/B= _____ V= _____

6. Method of Determining Natural Frequencies

() Lab Test () In-Situ Test () Analysis

7. TRS Enveloping RRS Using Multi-Frequency Test

() Yes (Attach TRS & RRS graphs)
() No



-4-

8. Maximum Input g Level Test:
- OBE S/S = _____ F/B = _____ V = _____
- SSE S/S = _____ F/B = _____ V = _____
9. Laboratory Mounting:
- A. ☐ Bolt (No. _____ Size _____)
- ☐ Weld (Length _____) ☐ _____
- B. Orientation and Fixturing: _____
10. Functional Operability Verified:
- ☐ Yes ☐ No ☐ Not Applicable
11. Test Results Including Modifications Made: _____
- _____
12. Other Tests Performed (such as aging or fragility test, including results):
- _____
- _____
13. Failure Modes (If appropriate _____)
14. Margins Available: ☐ Input Spectrum ☐ Fragility
- VII. If Qualification by Analysis, Then Complete:
1. Method of Analysis:
- ☒ Static Analysis ☐ Equivalent Static Analysis
- ☒ Dynamic Analysis: ☐ Time-History ☒ Response Spectrum
2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):
- S/S = $\begin{matrix} > 43.29 \text{ Hz} \\ 29.35 \text{ Hz} \end{matrix}$ F/B = $\begin{matrix} 43.29 \text{ Hz} \\ 16.72 \text{ Hz} \end{matrix}$ V = $\begin{matrix} > 43.29 \text{ Hz} \\ 18.56 \text{ Hz} \end{matrix}$ Coil Assembly
3. Model Type: ☒ 3D ☒ 2D ☐ 1D
- ☒ Finite Element ☒ Beam
- ☐ Closed Form Solution ☐ Other



-5-

iCAP, CCL Proprietary Coil Analysis Program

4. (✓) Computer Codes: 2 STARDYNE

Frequency Range and No. of Modes

0 - 33.4 Hz / 4 modes for STARDYNE

(✓) Hand Calculations

5. Method of Combining Dynamic Responses from Seismic and Other Dynamic Loads:

() Absolute Sum () SRSS (✓) Other: N.A.
(specify)

6. Damping:

OBE 2 % SSE 3 % Basis for the Damping Used: FSAR7. Support Considerations in the Model: The air conditioning unit is free standing with 10 nodes at the base, fixed in translation & rotation.

8. Critical Structural Elements:

A. Identification Location	Governing Load or Response Combination	Seismic Stress	Total Stress	Stress Allowable
1. Beam, fan section top panel	SSE + DW +		27209	43200
2. Plate, fan section end panel	operating		15784	28350
3. plate, fan side plate	load.		15958	28350
4. Anchor bolt, underneath coil section			13014	13300
5. Attachment bolt, coil X-brace center bracket			10125	13300
6. Attachment weld, coil X-brace corner bracket			6510	7500

B. Maximum Critical
Deflection

Location

Maximum Allowable Deflection
to Assure Functional Operability1. 0.08855" Fan inlet cone
relative to fan
wheel0.235"9. Failure Modes: Structural

10. Margins Available: () Input Spectrum (✓) Stress or Deflection



-2-

11. Pertinent Reference Design Specifications for Qualification Requirements: _____

- | | |
|----------------------------|-----------------------|
| a. Seismic Input | d. Service Conditions |
| b. Hydrodynamic Load Input | e. Qualified Life |
| c. Fatigue Considerations | |

III. Is Equipment Available for Inspection in the Plant:

() Yes () No () Partial or limited availability

IV. Equipment Qualification Method: *Motor*

() Test (✓) Analysis () Combination of Test and Analysis

Qualification Report*: *1. MS-1846, Supplemental Calculation, 1-6-84.*
2. Carrier No. 7110P2009, Seismic Qualification
 (No., Title and Date): *Report of Westinghouse Motor for the Carrier*
Air Handling Units, Rev. 2, 4-1-80.
*3. (cont'd below) ****

Company that Prepared Report: *1. SWEC for report 1*

Company that Reviewed Report: *2. Westinghouse for reports 2 & 3.*
SWEC

Where Report is filed or available: *Nine Mile site*

Applicable Codes and/or Standards: *R.G. 1.100*
IEEE 344-1975, 117-1974 &
334-1974

V. Vibration Input:

1. Loads considered: a. (✓) Seismic only
 b. () Hydrodynamic only
 c. () Vibration from normal operation
 d. () Combination of (a), (b), and (c)

2. Method of Combining RRS:

() Absolute Sum () SRSS (✓) *N.A.*
 (other, specify)

3. Required Response Spectra** (attach the graphs): *Attachment A*

NOTE:

*If more than one report complete items IV thru VII for each report.

**If other than RRS is used, describe method.

*** *3. NM-9112, Qualification Document Class I E Medium*
AC Motors, 1-18-80.



-3-

4. Damping Corresponding to RRS: OBE 2% SSE 3%

5. Required Acceleration in Each Direct:

() ZPA (✓) Other Rigid range
(specify)OBE S/S = 0.34 F/B = 0.34 V = 0.33SSE S/S = 0.48 F/B = 0.48 V = 0.49

6. Were fatigue effects considered?

() Yes (✓) No

If yes, describe how they were treated in overall qualification program: _____
_____VI. If Qualification by Test, then Complete: N. A.1. () Single Frequency () Multi-Frequency () Random
() Sine Beat
() _____2. () Single Axis () Multi-Axis
() Independent Axis () In-phase Motions

3. Number of Qualifications Tests:

OBE _____ SSE _____ Other _____
(specify)

4. Frequency Range: _____

5. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S= _____ F/B= _____ V= _____

6. Method of Determining Natural Frequencies

() Lab Test () In-Situ Test () Analysis

7. TRS Enveloping RRS Using Multi-Frequency Test

() Yes (Attach TRS & RRS graphs)
() No



-4-

8. Maximum Input g Level Test:

OBE S/S = _____ F/B = _____ V = _____

SSE S/S = _____ F/B = _____ V = _____

9. Laboratory Mounting:

- A. ☐ Bolt (No. _____ Size _____)
☐ Weld (Length _____) ☐ _____

B. Orientation and Fixturing: _____

10. Functional Operability Verified:

☐ Yes ☐ No ☐ Not Applicable

11. Test Results Including Modifications Made: _____

12. Other Tests Performed (such as aging or fragility test, including results):

13. Failure Modes (If appropriate _____)

14. Margins Available: ☐ Input Spectrum ☐ Fragility

VII. If Qualification by Analysis, Then Complete:

1. Method of Analysis:

- ☒ Static Analysis ☐ Equivalent Static Analysis
☐ Dynamic Analysis: ☐ Time-History ☐ Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = 112.5 Hz F/B = > 112.5 Hz V = > 112.5 Hz

3. Model Type: ☐ 3D ☐ 2D ☒ 1D
☐ Finite Element ☒ Beam
☐ Closed Form Solution ☐ Other



(

-5-

4. (✓) Computer Codes: ME-7701, Proprietary Program of
Westinghouse Motor & Gearing Div.
 Frequency Range and No. of Modes

() Hand Calculations

5. Method of Combining Dynamic Responses from Seismic and Other
 Dynamic Loads: N.A.

() Absolute Sum () SRSS () Other: _____
 (specify)

6. Damping:

OBE 2% SSE 3% Basis for the Damping Used: FSAR

7. Support Considerations in the Model: Motor feet hinged at
the base restraining bolt
 8. Critical Structural Elements: displacement


A. Identification Location	Governing Load or Response Combination	Seismic Stress	Total Stress	Stress Allowable
<u>shaft</u>	<u>SSE + DW +</u> <u>Operating load</u>		<u>16021</u>	<u>36000</u>

B. Maximum Critical Deflection	Location	Maximum Allowable Deflection to Assure Functional Operability
<u>0.004026"</u>	<u>Air gap between</u> <u>the motor stator</u> <u>& the motor rotor</u>	<u>0.0238"</u>

9. Failure Modes: Structural

10. Margins Available: () Input Spectrum (✓) Stress or Deflection





Attachment A

REF 18

P. 01 of 04



PSPECTRA VER 01 LEV 00

DBE.

8 JUL 1988

NIAHARA MOHAWK-NINE MILE POINT 2 - CALC12177-KHIC7-MS-1928 REV(4)

Jobb 2000

RRS OF ACC.-CONTROL & DIESEL GENERATOR BLDGS ELEVATION 308.0.


PEAK SPREAD +-15Z...

DISK CURVE SET NO.2

VER DIRECTION

DAMPING VALUE L 0.020

ACCELERATION G 0.00 0.20 0.40 0.60 0.80 1.00 1.20 1.40



FREQUENCY IN HZ

Ref 1B

PSPECTRA VER 01. LEV. 09

85E.

6 JUL 1985

NIAODARA MOHAWK-NINE MILE POINT 2 - CALC 12177-KN(C)-NS-1326 REV 13

NRS OF ACC.-CONTROL: DIESEL GENERATOR BLOOD ELEVATION: 508.0

JOB 2016

PEAK SPREAD +-15%

DISK CURVE SET NO. 2

HOR DIRECTION

DAMPING VALUE = 0.050

ACCELERATION G
0.00 0.50 1.00 1.50 2.00 2.50 3.00 3.50




FREQUENCY IN HZ

REF-18

P. 83 of 114





REF 18

p. 14 of 14



SPEC. NO. P413L

SQRT # 22

NINE MILE POINT NUCLEAR STATION UNIT 2

EQUIPMENT DYNAMIC QUALIFICATION

COMPONENT NAME: ELECTRIC DUCT HEATER
CONTROL PANEL

MARK NUMBERS: ZHVC * PNLCH11A



STONE & WEBSTER

57



Seismic and Dynamic Qualification Summary of Equipment

I. Plant Name: Nine Mile Point Nuclear Station - Unit 2

1. Utility: Niagara Mohawk Power Corporation
2. NSSS: General Electric Co. BWR: 5 MK 2
3. A/E: Stone & Webster Engineering Corp. Other

II. Component Name: Electric Duct Heater Control Panel

Mark NO. ZHVC*PNLCH11A

1. Scope: () NSSS (☒) BOP () Other
2. Model Number: N.A. Quantity: 1
3. Size or Range: N.A.
4. Vendor: Schneider Inc. / Nutherm International
5. If the component is a cabinet or panel, name and model number of the devices included:

See Attachment A

6. Physical Description:

- a. Appearance: Rectangular box
- b. Dimensions: 9.25" (D) x 48" (H) x 48" (W)
- c. Weight: 215 lb

7. Location: Building: Control Building

Elevation: 306'

8. Field Mounting Conditions (☒) Bolt (No. 6 Size 3/8")
() Weld (Length)
()

9. Mounting Orientation (e.g., on floor, cantilevered, suspended, etc.)

Wall mounted

10. a. System in which located: Control Building (HVC)

b. Functional Description: To operate duct heater ZHVC*CH11A

- c. Is the equipment required for (☒) Hot Standby (☒) Cold Shutdown (☒) Both () Neither (☒) Other All normal & accident conditions



-2-

11. Pertinent Reference Design Specifications for Qualification Requirements: Spec No. P413 L, Ventilation & Air-Conditioning System Ductwork, Rev. 5

- | | |
|--|-----------------------|
| <input checked="" type="checkbox"/> a. Seismic Input | d. Service Conditions |
| b. Hydrodynamic Load Input | e. Qualified Life |
| c. Fatigue Considerations | |

III. Is Equipment Available for Inspection in the Plant:

☒ Yes ☐ No ☐ Partial or limited availability

IV. Equipment Qualification Method:

☐ Test ☐ Analysis ☒ Combination of Test and Analysis

Qualification Report*: NO. 51123, Rev. 1, Qualification Report Electric Air Duct Heaters/Remote Control Panels, 10-19-84, SDDF NO. IEEE 10.460-5001B
(No., Title and Date): _____

Company that Prepared Report: Nutherm Int'l

Company that Reviewed Report: SWEC

Where Report is filed or available: Nine mile site

Applicable Codes and/or Standards: IEEE 344-1975
R.G. 1.89 & R.G. 1.100

V. Vibration Input:

AISC code
ASME code, sec. III, NA & NF

1. Loads considered: a. ☒ Seismic only
b. ☐ Hydrodynamic only
c. ☐ Vibration from normal operation
d. ☐ Combination of (a), (b), and (c)

2. Method of Combining RRS:

☐ Absolute Sum ☒ SRSS ☐ _____
(other, specify)

3. Required Response Spectra** (attach the graphs): See Attachment B

NOTE:

*If more than one report complete items IV thru VII for each report.

**If other than RRS is used, describe method.

- If yes, describe how they were treated in overall qualification program:

(✓) Yes (Attach TRS & RRS graphs) Attachment C - TRS by F&H
() No " D - " " Bailey
" E - " " EDI
" F - " " Wyle

-4-

8. Maximum Input g Level Test:

1. F&H Test		3.28		3.82		3.45
2. Bailey Test	OBE S/S =	4-5	F/B =	4-5	V =	4-5
3. EDI Test		3		3		3.6
4. Wyle Test		3.87		3.87		3.87
1. F&H "	SSE S/S =	7.54	F/B =	6.56	V =	6.93
2. Bailey "		7-B		7-B		7-B
3. EDI "		5.4		5.4		6.9
4. Wyle "		5.8		5.8		5.8

9. Laboratory Mounting:

*Simulating the actual in-service configurations*A. (✓) Bolt (No. N.A. Size N.A.)(✓) Weld (Length N.A.) (✓) ClampedB. Orientation and Fixturing: The specimen is attached to the vertical mounting fixture. The fixture is welded or clamped to the test table

10. Functional Operability Verified:

(✓) Yes () No () Not Applicable

11. Test Results Including Modifications Made: N.A.

12. Other Tests Performed (such as aging or fragility test, including results):

N.A.13. Failure Modes (If appropriate Electrical & Structural)

14. Margins Available: (✓) Input Spectrum () Fragility

VII. If Qualification by Analysis, Then Complete: For Panel Only

1. Method of Analysis:

(✓) Static Analysis () Equivalent Static Analysis

() Dynamic Analysis: () Time-History () Response Spectrum

2. Natural Frequencies in Each Direction (Side/Side, Front/Back, Vertical):

S/S = > 39 Hz F/B = 39 Hz V = > 39 Hz3. Model Type: (✓) 3D () 2D () 1D
(✓) Finite Element () Beam
() Closed Form Solution () Other

-5-

4. (✓) Computer Codes: STARDYNEFrequency Range and No. of Modes N.A.

(✓) Hand Calculations

5. Method of Combining Dynamic Responses from Seismic and Other Dynamic Loads: N.A.() Absolute Sum () SRSS () Other: _____
(specify)

6. Damping:

OBE 2 % SSE 3 % Basis for the Damping Used: FSAR7. Support Considerations in the Model: The back panel is supported at 3 points along each of the upper and lower edges of the panel

8. Critical Structural Elements:

A. Identification Location	Governing Load or Response Combination		Seismic Stress	Total Stress, psi	Stress Allowable, psi
1. Plate	Center, subpanel	Faulted		1200	13700
2. Anchor bolt direct stress	Corner, back panel	"		1688	20000
3. Anchor bolt shear stress	Corner, back panel	"		3645	10000

B. Maximum Critical

DeflectionLocationMaximum Allowable Deflectionto Assure Functional Operability0.42"
0.19"Center, back panel
Center, subpanelWithin operational limit
" " "9. Failure Modes: Structural

10. Margins Available: () Input Spectrum (✓) Stress or Deflection

Attachment A

<u>NO.</u>	<u>Devices</u>	<u>Model Number</u>	
1	Disconnect Switch	American Solenoid	K50-A292-120VE
2	Fuse	Bussmann	ABC-15
3	Fuse	Bussmann	FRS-R40
4	Airflow Switch	Cumco	RH15-05-D1
5*	External Reset Operator	Cutler-Hammer	10935H6
6	Contactor, 24V Coil	Elmwood	30-F0-30-24
7	Transformer, 575/24 Volt	Hevi-Duty	W075 Design 2B19253T00
8	Fuse Holder	Hevi-Duty	FB-1
9	SCR Controller	Loyola	DPAC-3S-600-31-RHS
10	Door Switch	McGill	100
11	Terminal Block	Marathon	1606
12	Terminal Block	Marathon	1608
13	Fuse Holder	Marathon	R6F60A3S
14	Power Block	Marathon	1423123
15	Automatic Thermal Cutout	Ranco	L6-476
16	Manual Thermal Cutout	Ranco	IM5-2507-60
17	Wire, 90°C, 8 AWG SISF133 Strand	Rockbestos	ABJ-0006-05S
18	Wire, 90°C, 10 AWG SISF10 Strand	Rockbestos	ABJ-0116-05S
19	Wire, 90°C, 14 AWG SISF7 Strand	Rockbestos	AB2-0146 05S
20	Indicator	Westinghouse	PB11HB074

* Not a safety related device



p. B1 of B9

Attachment B

RRS

PSPECTRA VER 01 LEV 09

OBE

6 JUL 1989

MIRAMAR MOHAWK-NINE MILE POINT 2 - CALC12177-MMIC1-M5-1528 REV143

ARS OF ACC.-CONTROL & DIESEL GENERATOR BLDGS ELEVATION 506.0.


UOB 2080

PEAK SPREAD +-15%

DISK CURVE SET NO.2

NOR DIRECTION

DAMPING VALUE = 0.020



P. BZ of B9 PAGE 93

PSPECTRA VER 01 LEV 09

DBE

6 JUL 1983

NIADARA MOHAWK-NINE MILE POINT 2.- CALC12177-NM1C1-MB-1928 REV(4)

NRS OF ACC.-CONTROL & DIESEL GENERATOR BLOOS ELEVATION 287.5810

JOB 2080

PEAK SPREAD +-15%

DISK CURVE SET NO.3

HOR DIRECTION


DAMPING VALUE = 0.020

ACCELERATION G

0.00 0.40 0.80 1.20 1.60 2.00 2.40 2.80

10⁰ 2 3 4 5 6 7 8 9 10¹ 2 3 4 5 6 7 8 9 10² 2 3 4 5 6 7 8 9 10³

FREQUENCY IN HZ



P. B34589

PAGE 95

SPECTRA VER 01 LEV 09

OBE

5 JUL 1989

NIAGARA MOHAWK-NINE MILE POINT 2 - CALC12177-AMCJ-MS-1928 REV(4)

RMS OF ACC.-CONTROL & DIESEL GENERATOR BLOOD ELEVATION 306.0

000 2080


PEAK SPREAD +/-15%

DISK CURVE SET NO.2

VER DIRECTION

DAMPING VALUE 0.020


ACCELERATION 0 0.20 0.40 0.60 0.80 1.00 1.20 1.40



FREQUENCY IN HZ

P. 84 of 89
PAGE 94







PSPECTRA VER 01. LEV. 00

SEE

8 JUL 1989

NIRAKA MOHAWK-NINE MILE POINT 2 - CALC12177-KMIC)-MS-1928 REV(4)

RMS OF ACC.-CONTROL: DIESEL GENERATOR SLOOS ELEVATION: 305.0

JOB 2010

PEAK SPREAD +-15%

DISK CURVE SET NO. 2

HOR DIRECTION

DAMPING VALUE = 0.030


ACCELERATION G



FREQUENCY IN HZ

P. B. G. of B. 9. PAGE 45







PSPECTRA VER 01 LEV 08

66E

8 JUL 1988

MINORRA MOHAWK-NINE MILE POINT 2 - CRLC12177-RHIC1-MB-1928 REV 43

RRS OF ACC.-CONTROL & DIESEL GENERATOR BLOOS ELEVATION 308.0

UDB 2018

PEAK SPREAD = 15Z

DISK CURVE SET NO.2

VER DIRECTION

DAMPING VALUE = 0.030

ACCELERATION

10⁰

2

3

4

5

6

7

8

9

10¹

2

3

4

5

6

7


8

9

10²

FREQUENCY IN HZ





P. B9 of B9

PAGE 44



Attachment C

TRS^{*} by FEH for Devices No.


3, 7, 10, 13, 14 & 20

of Attachment A

* From document NO. FEH 10200-C



p. C2 of C7



12-MAR-84
03:05:00
?

SHOCK RESPONSE
10200 OBE 5 CONTROL (X) Y Z


5.8 % Damp Abs Acc
1/3 Octave Maxi-Max

Free	Appl	Free	Appl	Free	Appl
1.00	0.97	5.01	6.43	25.12	5.83
1.26	1.25	6.31	5.58	31.62	5.53
1.58	1.75	7.94	6.13	39.81	4.92
2.00	2.92	10.00	5.65	50.12	4.32
2.51	3.77	12.59	5.13	63.10	4.31
3.16	4.29	15.85	5.42	79.43	4.06
3.98	5.42	19.95	5.81		

FIGURE 6.2



- p. C3 of C7



12-MAR-84
03:07:18
?

SHOCK RESPONSE
10200 OBE 5 CONTROL X(Y) Z


5.8 % Damp Abs Acc
1/3 Octave Maxi-Max

Free	Appl	Free	Appl	Free	Appl
1.00	0.99	5.01	6.90	25.12	6.02
1.26	1.63	6.31	6.97	31.62	4.36
1.58	2.58	7.94	6.25	39.81	4.59
2.00	3.83	10.00	6.31	50.12	4.23
2.51	4.68	12.59	5.79	63.18	4.38
3.16	5.89	15.85	6.00	79.43	3.59
3.98	7.04	19.95	7.14		

FIGURE 6.3



-p. C4 of C7.



12-MAR-84
03:09:28
?

SHOCK RESPONSE
10200 OBE 5 CONTROL X Y (2)


5.0 % Damp Abs Acc
1/3 Octave Maxi-Max

Free	Aapl	Free	Aapl	Free	Aapl
1.00	1.03	5.01	6.51	25.12	7.91
1.26	1.49	6.31	6.61	31.62	7.38
1.58	1.94	7.94	7.86	39.81	7.22
2.00	4.02	10.00	6.16	50.12	4.76
2.51	3.82	12.59	6.35	63.10	7.22
3.16	4.63	15.85	6.01	79.43	6.88
3.98	6.20	19.95	0.50		

FIGURE 6.4



p. 6.5 of C7



12-MAR-84
02:55:38
?


SHOCK RESPONSE
10200 SSE1 CONTROL (X) Y Z

5.8 % Damp Abs. Acc
1/3 Octave Maxi-Max

Free	Ampl	Free	Ampl	Free	Ampl
1.00	2.59	5.01	10.88	25.12	10.97
1.26	2.87	6.31	10.94	31.62	9.43
1.58	3.46	7.94	11.30	39.81	8.62
2.00	5.42	10.00	9.86	50.12	7.56
2.51	6.93	12.59	10.06	63.10	8.11
3.16	9.01	15.85	10.79	79.43	6.88
3.98	9.88	19.95	10.00		

FIGURE 6.5

p. C. 6 of 57



12-MAR-84
02:57:38
?

SHOCK RESPONSE
10200 SSE1 CONTROL X(Y) Z


5.0 % Damp Abs Acc
1/3 Octave Maxi-Max

Free	Ampl	Free	Ampl	Free	Ampl
1.00	2.29	5.01	9.08	25.12	11.61
1.26	2.63	6.31	10.77	31.62	8.72
1.58	3.34	7.94	9.41	39.81	7.61
2.00	5.51	10.00	9.24	50.12	6.29
2.51	7.15	12.59	9.43	63.10	6.35
3.16	8.00	15.85	9.06	79.43	5.62
3.98	9.80	19.95	11.19		

FIGURE 6.6



P. C7 of C7



12-MAR-84
03:00:20
?

SHOCK RESPONSE
10200 SSE1 CONTROL X Y (2)

5.0 % Damp Abs Acc
1/3 Octave Maxi-Max

Free	Ampl	Free	Ampl	Free	Ampl
1.00	1.75	5.01	10.83	25.12	13.77
1.26	2.44	6.31	10.38	31.62	9.38
1.58	3.08	7.94	12.31	39.81	7.42
2.00	6.61	10.00	10.54	50.12	7.37
2.51	6.58	12.59	11.35	63.10	9.78
3.16	8.21	15.85	11.43	79.43	11.31
3.98	10.42	19.95	13.32		

FIGURE 6.7

Attachment D

TRS* by Bailey Controls for

Devices No. 1, 4, 6, 9, 15 & 16

of Attachment A

* From document NO. QR-4405-N-

194 P-1



Plotted by:

S. Mandville

Checked by:

J. H. Hays

Date:

8-29-84

Time:

Babcock & Wilcox

Bailey Controls Company


QUALIFICATION TEST LAB.

Test Item:

NUTHERN ITEM # 1A

Item P/N:

Item S/N:



Ref. Spec.: _____

Unit: Operational ☒ Non-operational ☐

Temp. & Humidity: 71°F @ 52% RH

Test Type: ORE

Duration: _____

Sweep Speed: _____ oct/minute

Damping: 2%

Pickup Sensing Axis: Z

Pickup Sensitivity: 100 $\frac{mv \text{ peak}}{g \text{ peak}}$

Vibration Axis: -XZ

☒ Live ☐ Tape

Graph Number: 1

Tolerance: _____



Plotted by:

S. Macdonell

Checked by:

S. Macdonell

Date: 8-27-84 Time: _____

Babcock & Wilcox

Bailey Controls Company


QUALIFICATION TEST LAB.

Test Item:

WUTHERM ITEM #1A

Item P/N: _____

Item S/N: _____



Ref. Spec.: _____

Unit: Operational ☒ Non-operational ☐

Temp. & Humidity: 71°F @ 52% RH

Test Type: ORE

Duration: _____

Sweep Speed: _____ oct/minute

Damping: 2%

Pickup Sensing Axis: Z

Pickup Sensitivity: 100 $\frac{mv \text{ peak}}{g \text{ peak}}$

Vibration Axis: -YZ

☒ Live ☐ Tape

Graph Number: 4

Tolerance: _____

-P.03 of 025.



Plotted by: B. J. J. J. J.

Checked by: J. J. J.

Date: 8-29-84 Time: _____


Babcock & Wilcox
Bailey Controls Company

QUALIFICATION TEST LAB.

Test Item: NUTHERN ITEM #1A

Item P/N: _____

Item S/N: _____



Ref. Spec.: _____

Unit: Operational ☒ Non-operational ☐

Temp. & Humidity: 71°F @ 52% RH

Test Type: OBE

Duration: _____

Sweep Speed: _____ oct/minute

Damping: 2%

Pickup Sensing Axis: Z

Pickup Sensitivity: 100 mv peak / g peak

Vibration Axis: TXZ

☒ Live ☐ Tape

Graph Number: 10

Tolerance: _____

P-04 of 025



Plotted by: B. Mandeville

Checked by: Gattys

Date: 8-29-84 Time: _____


Babcock & Wilcox
Bailey Controls Company

QUALIFICATION TEST LAB.

Test Item: NUTHERN ITEM # 1A

Item P/N: _____

Item S/N: _____



Ref. Spec.: _____

Unit: Operational ☒ Non-operational ☐

Temp. & Humidity: 71°F 52%RH

Test Type: ORF

Duration: _____

Sweep Speed: _____ oct/minute

Damping: 2%

Pickup Sensing Axis: Z

Pickup Sensitivity: 100 $\frac{mv\ peak}{g\ peak}$

Vibration Axis: +YZ

☒ Live ☐ Tape

Graph Number: 16

Tolerance: _____

P.D.S. of 025



Plotted by: R.L. Summers Jr

Checked by: Gattop

Date: 9-10-84 Time: _____

Babcock & Wilcox


Valley Controls Company

QUALIFICATION TEST LAB.

Test Item: Nutherm Item # 1A

Item P/N: _____

Item S/N: _____



Ref. Spec.: _____

Unit: Operational ☒ Non-operational ☐

Temp. & Humidity: 71 F @ 52% Rh.

Test Type: SSE

Duration: _____

Sweep Speed: _____ oct/minute

Damping: 2, 3, 5 %

Pickup Sensing Axis: Z

Pickup Sensitivity: 100 mv peak
g peak

Vibration Axis: -XZ

☒ Live ☐ Tape

Graph Number: 3 RE

Tolerance: _____

-P.06 of 025



Plotted by: R. L. Summer Jr.

Checked by: J. L. Lipp

Date: 9-10-84 Time: _____


Babcock & Wilcox
Bailey Controls Company

QUALIFICATION TEST LAB.

Test Item: Nutherm Item # 1A

Item P/N: _____

Item S/N: _____



Ref. Spec.: _____

Unit: Operational ☒ Non-operational ☐

Temp. & Humidity: 71 F @ 52% Rh.

Test Type: SSE

Duration: _____

Sweep Speed: _____ oct/minute

Damping: 2, 3, 5%

Pickup Sensing Axis: Z

Pickup Sensitivity: 100 mv peak
g peak

Vibration Axis: -YZ

☒ Live

☐ Tape

Graph Number: 9 RE

Tolerance: _____

P. D. 7.0 f. 0.25



Plotted by: B.L. Summer Jr.

Checked by: Galtz

Date: 9-10-84 Time: _____


Babcock & Wilcox
Bailey Controls Company

QUALIFICATION TEST LAB.

Test Item: Nutherm Item # 1A

Item P/N: _____

Item S/N: _____



Ref. Spec.: _____

Unit: Operational ☒ Non-operational ☐

Temp. & Humidity: 71 F @ 52% Rh.

Test Type: SSE

Duration: _____

Sweep Speed: _____ oct/minute

Damping: 2, 3, 5

Pickup Sensing Axis: Z

Pickup Sensitivity: 100 $\frac{\text{mv peak}}{\text{g peak}}$

Vibration Axis: + X Z

☒ Live ☐ Tape

Graph Number: 15 RE

Tolerance: _____

P. 28 of 225



Plotted by: R. L. Simmer Jr.

Checked by: Gatty

Date: 9-10-84 Time: _____


Babcock & Wilcox
Bailey Controls Company

QUALIFICATION TEST LAB.

Test Item: Nutherm Item # 1A

Item P/N: _____

Item S/N: _____



Ref. Spec.: _____

Unit: Operational ☒ Non-operational ☐

Temp. & Humidity: 71 F @ 52% Rh.

Test Type: SSE

Duration: _____

Sweep Speed: _____ oct/minute

Damping: 2, 3, 5 %

Pickup Sensing Axis: Z

Pickup Sensitivity: 100 mv peak
g peak

Vibration Axis: + Y2

☒ Live ☐ Tape

Graph Number: 21 RE

Tolerance: _____

P. 29 of 225



Plotted by: B. Martindale

Checked by: Sutcliffe

Date: 8-30-84 Time: _____


Babcock & Wilcox
Bailey Controls Company

QUALIFICATION TEST LAB.

Test Item: Nuclear Item #1C

Item P/N: _____

Item S/N: _____



Ref. Spec.: _____

Unit: Operational ☒ Non-operational ☐

Temp. & Humidity: 71°F @ 51% RH

Test Type: ORF

Duration: _____

Sweep Speed: _____ oct/minute

Damping: 2%

Pickup Sensing Axis: Z

Pickup Sensitivity: 100 $\frac{\text{mv peak}}{\text{g peak}}$

Vibration Axis: XZ

☒ Live ☐ Tape

Graph Number: 1

Tolerance: _____

-P. 210 of 025



Plotted by:

S. Nardone

Checked by:

Guttagi

Date:

8-30-84

Time:

Babcock & Wilcox

Bailey Controls Company


QUALIFICATION TEST LAB.

Test Item:

WUTHERM ITEM #1C

Item P/N:

Item S/N:



Ref. Spec.:

Unit:

☒ Operational

☐ Non-operational

Temp. & Humidity:

71°F 51% RH

Test Type:

ORF

Duration:

Sweep Speed:

_____ oct/minute

Damping:

2%

Pickup Sensing Axis:

Z

Pickup Sensitivity:

100 $\frac{mv \text{ peak}}{g \text{ peak}}$

Vibration Axis:

-42

☒ Live

☐ Tape

Graph Number:

7

Tolerance:

-P. 11. of 25.



Plotted by:

L. Nierwinski

Checked by:

Guthrie

Date:

9-30-84

Time:

Babcock & Wilcox
Bailey Controls Company

QUALIFICATION TEST LAB.

Test Item:

NUTHERN ITEM # 1C

Item P/N:

Item S/N:

Ref. Spec.:

Unit: Operational ☒ Non-operational ☐

Temp. & Humidity: 71°F @ 51% RH

Test Type: QAE

Duration:

Sweep Speed: _____ oct/minute

Damping: 2%

Pickup Sensing Axis: Z

Pickup Sensitivity: 100 $\frac{mv \text{ peak}}{g \text{ peak}}$


Vibration Axis: XYZ

☒ Live

☐ Tape

Graph Number: 14

Tolerance:



P. 012 of 025



Plotted by:

L. J. Powell

Checked by:

Gatty

Date:

8-30-84 Time: _____

Babcock & Wilcox

Balley Controls Company

QUALIFICATION TEST LAB.

Test Item:

NUTHERN ITEM #1C

Item P/N: _____

Item S/N: _____

Ref. Spec.: _____

Unit: Operational ☒ Non-operational ☐

Temp. & Humidity: 71°F @ 52% RH

Test Type: ORF

Duration: _____

Sweep Speed: _____ oct/minute

Damping: 2%

Pickup Sensing Axis: Z

Pickup Sensitivity: 100 $\frac{\text{mv peak}}{\text{g peak}}$


Vibration Axis: X/Y

☒ Live

☐ Tape

Graph Number: 19

Tolerance: _____



P. 013 of 025



Plotted by: RL Smalley, Jr.

Checked by: J. Attozzi

Date: 9-10-84 Time: _____


Babcock & Wilcox
Bailey Controls Company

QUALIFICATION TEST LAB.

Test Item: Nutherm Item # 1C

Item P/N: _____

Item S/N: _____



Ref. Spec.: _____

Unit: Operational ☒ Non-operational ☐

Temp. & Humidity: 71 F @ 52% Rh.

Test Type: SSE

Duration: _____

Sweep Speed: _____ oct/min

Damping: 2, 3, 5 %

Pickup Sensing Axis: 2

Pickup Sensitivity: 100 $\frac{mv\ peak}{g\ peak}$

Vibration Axis: RL
XZ - XZ

☒ Live ☐ Tape

Graph Number: GRE

Tolerance: _____

P. 014 of 025

C-94

Page No. 1-2



Plotted by: B. L. Summer Jr

Checked by: Guttuzi

Date: 9-10-84 Time: _____


Babcock & Wilcox
Bailey Controls Company

QUALIFICATION TEST LAB.

Test Item: Nutherm Item 1: 1C

Item P/N: _____

Item S/N: _____



Ref. Spec.: _____

Unit: Operational ☒ Non-operational ☐

Temp. & Humidity: 71 F @ 52% Rh.

Test Type: SSE

Duration: _____

Sweep Speed: _____ oct/minu

Damping: 2, 3, 5%

Pickup Sensing Axis: Z

Pickup Sensitivity: 100 $\frac{mv\ peak}{g\ peak}$

Vibration Axis: -Y Z

☒ Live ☐ Tape

Graph Number: 12 RE

Tolerance: _____

P. 015 of 025

C-96



Plotted by: R.L. Summers Jr

Checked by: Gutierrez

Date: 9-10-84 Time: _____


Babcock & Wilcox
Bailey Controls Company

QUALIFICATION TEST LAB.

Test Item: Nutherm Item # 1 C

Item P/N: _____

Item S/N: _____



Ref. Spec.: _____

Unit: Operational ☒ Non-operational

Temp. & Humidity: 71 F@52%RH.

Test Type: SS E

Duration: _____

Sweep Speed: _____ oct/min

Damping: 2, 3, 5

Pickup Sensing Axis: Z

Pickup Sensitivity: 100 $\frac{mv}{g}$

Vibration Axis: +Y Z

☒ Live ☐ Tape

Graph Number: 18 R0

Tolerance: _____

P. 016 of 025

C-98



Plotted by: R.L. Summer Jr.

Checked by: Sutton

Date: 9-10-84 Time: _____


Babcock & Wilcox
Bailey Controls Company

QUALIFICATION TEST LAB.

Test Item: Nutherm Item # 1C

Item P/N: _____

Item S/N: _____



Ref. Spec.: _____

Unit: Operational ☒ Non-operational

Temp. & Humidity: 71 F @ 52% Rh.

Test Type: SSE

Duration: _____

Sweep Speed: _____ oct/mi

Damping: 2, 3, 5

Pickup Sensing Axis: Z

Pickup Sensitivity: 100 $\frac{mv}{g}$

Vibration Axis: +Y2

☒ Live ☐ Tape

Graph Number: 24RE

Tolerance: _____

P. 017 of 025

C-100

PAGE NO. 5-101



Plotted by:

S. Nardella
Gattzy

Checked by:

Date: 8-31-84 Time: _____

Babcock & Wilcox
Bailey Controls Company

QUALIFICATION TEST LAB.

Test Item:

NUTHERN ITEM # 1E

Item P/N:

Item S/N:

Ref. Spec.: _____

Unit: Operational ☒ Non-operational ☐

Temp. & Humidity: 71°F @ 52% RH

Test Type: CPE

Duration: _____

Sweep Speed: _____ oct/minute

Damping: 2%, 3%, 5%

Pickup Sensing Axis: Z

Pickup Sensitivity: 100 $\frac{\text{mv peak}}{\text{g peak}}$


Vibration Axis: -XZ

☒ Live

☐ Tape

Graph Number: 1

Tolerance: _____





Plotted by:

S. Marshall

Checked by:

Sattari

Date:

8-31-84

Time:

Babcock & Wilcox

Bailey Controls Company

QUALIFICATION TEST LAB.

Test Item:

NUTTER ITEM # 1E

Item P/N:

Item S/N:

Ref. Spec.:

Unit: Operational ☒ Non-operational ☐

Temp. & Humidity: 71°F 52% RH

Test Type: ORF

Duration:

Sweep Speed: oct/minute

Damping: 22%, 3%, 5%

Pickup Sensing Axis: Z


Pickup Sensitivity: 100 $\frac{mv \text{ peak}}{g \text{ peak}}$

Vibration Axis: -YZ

☒ Live ☐ Tape

Graph Number: 6

Tolerance:





Plotted by:

B. Mandel

Checked by:

Sett

Date:

8-31-84

Time:

Babcock & Wilcox Bailey Controls Company

QUALIFICATION TEST LAB.

Test Item:

NUTHERN ITEM #1E

Item P/N:

Item S/N:

Ref. Spec.:

Unit: Operational

☒ Non-operational ☐

Temp. & Humidity:

71°F 52% RH

Test Type:

OBE

Duration:

Sweep Speed:

_____ oct/minute

Damping:

2%, 3%, 5%

Pickup Sensing Axis:

Z

Pickup Sensitivity:

100 $\frac{mv \text{ peak}}{g \text{ peak}}$

Vibration Axis:

+XZ


☒ Live

☐ Tape

Graph Number:

11

Tolerance:



P. 020 of 025

Plotted by:

H. Mairville

Checked by:

Satoggi

Date:

8-31-84

Time:

Babcock & Wilcox
Bailey Controls Company

QUALIFICATION TEST LAB.

Test Item:

NUTHERN ITEM # 1E

Item P/N:

Item S/N:

Ref. Spec.:

Unit: Operational ☒ Non-operational ☐

Temp. & Humidity: 71°F 52% RH

Test Type: ORF

Duration: _____

Sweep Speed: _____ oct/min

Damping: 2%, 3%, 5%

Pickup Sensing Axis: Z

Pickup Sensitivity: 100 $\frac{mv}{g}$ $\frac{pa}{g}$


Vibration Axis: X Y Z

☒ Live

☐ Tape

Graph Number: 16

Tolerance: _____



H. D21 of 025

C-153

Plotted by: S. M. M. M.

Checked by: G. H. H.

Date: 8-31-84 Time: _____


Babcock & Wilcox
Bailey Controls Company

QUALIFICATION TEST LAB.

Test Item: NUTHERN ITEM # 1E

Item P/N: _____

Item S/N: _____



Ref. Spec.: _____

Unit: Operational ☒ Non-operational ☐

Temp. & Humidity: 71°F @ 52% RH

Test Type: SSC

Duration: _____

Sweep Speed: _____ oct/min

Damping: 25.3%, 58.9%

Pickup Sensing Axis: Z

Pickup Sensitivity: 100 $\frac{mv}{g}$ per $\frac{g}{g}$

Vibration Axis: -XZ

☒ Live ☐ Tape

Graph Number: 21

Tolerance: _____

P. 022 of 025

C-158

LABORATORY

Plotted by:

S. J. J. J. J.

Checked by:

S. J. J. J. J.

Date:

8-31-84 Time: _____

Babcock & Wilcox

Bailey Controls Company

QUALIFICATION TEST LAB.

Test Item:

NUTHERN ITEM #1E

Item P/N:

Item S/N:

Ref. Spec.:

Unit: Operational ☒ Non-operational ☐

Temp. & Humidity: 71°F @ 52% RH

Test Type: SSE

Duration: _____

Sweep Speed: _____ oct/min

Damping: 2%, 3%, 5%

Pickup Sensing Axis: Z


Pickup Sensitivity: 100 $\frac{mv\ peak}{g\ peak}$

Vibration Axis: -YZ

☒ Live ☐ Tape

Graph Number: 22

Tolerance: _____



P.023 of 025

C-159

Page No. C-1.



Plotted by: B. Manderville

Checked by: Gatto 74

Date: 8-31-84 Time: _____


Babcock & Wilcox
Bailey Controls Company

QUALIFICATION TEST LAB.

Test Item: NUTHERN ITEM #1E

Item P/N: _____

Item S/N: _____



Ref. Spec.: _____

Unit: Operational ☒ Non-operational ☐

Temp. & Humidity: 71°F @ 52% RH

Test Type: SSC

Duration: _____

Sweep Speed: _____ oct/min

Damping: 2%, 0%, 5%

Pickup Sensing Axis: Z

Pickup Sensitivity: 100 $\frac{mv\ peak}{g\ peak}$

Vibration Axis: X/Y

☒ Live ☐ Tape

Graph Number: 23

Tolerance: _____

P. 024 of 025



Plotted by:

R. Mandville

Checked by:

Saltozzi

Date:

8-31-84

Time:

Babcock & Wilcox

Bailey Controls Company


QUALIFICATION TEST LAB.

Test Item:

NUTHERN ITEM #1E

Item P/N:

Item S/N:



Ref. Spec.: _____

Unit: Operational ☒ Non-operational ☐

Temp. & Humidity: 71°F @ 52%

Test Type: SSE

Duration: _____

Sweep Speed: _____ oct/min

Damping: 2%, 3%, 5%

Pickup Sensing Axis: Z

Pickup Sensitivity: 100 mv peak
g peak

Vibration Axis: +Y2

☒ Live

☐ Tape

Graph Number: 24

Tolerances: _____

11025 of 025



Attachment E


TRS^{*} by EDI for Devices No.

8 & 11

of Attachment A

* See EDI test document






HORIZONTAL OBE RESPONSE SPECTRA
FRONT-BACK EXCITATION

Damping - 0.02

FIGURE 7-1





HORIZONTAL SSE RESPONSE SPECTRUM
FRONT-BACK EXCITATION

Damping - 0.03





FIGURE 7-3






VERTICAL SSE RESPONSE SPECTRUM
VERTICAL EXCITATION

Damping - 0.03

FIGURE 7-4






HORIZONTAL OBE RESPONSE SPECTRA.
SIDE-SIDE EXCITATION .

Damping - 0.02





Frequency. (Hz)

HORIZONTAL SSE RESPONSE SPECTRUM
SIDE-SIDE EXCITATION

Damping - 0.03

FIGURE 7-6

Attachment F

TRS* by Wyle Lab for Devices

No. 17, 18 & 19 of


Attachment A

* See Wyle Lab test document

FULL SCALE SHOCK SPECTRUM (g Peak)

1.0 ☐ 10 ☐ 100 ☒ 1000 ☐

DAMPING ☒ 2%



SPECIMEN

LOCATION NO. FB 4cA

AXIS TR-1

TEST RUN NO. 2 (OBE)




Page No. 26
Report No. 47577-1
FULL SCALE SHOCK SPECTRUM (g Peak)

p.F3 of F7

1.0 ☐ 10 ☐ 100 ☒ 1000 ☐

DAMPING ☒ 2%



SPECIMEN _____
AXIS TRI


LOCATION NO. 35 HcA
TEST RUN NO. 2 (OBE)



FULL SCALE SHOCK SPECTRUM (g Peak)

1.0 ☐ 10 ☐ 100 ☒ 1000 ☐

DAMPING ☒ 2%



SPECIMEN

LOCATION NO. VCA

AXIS TR1


TEST RUN NO. 2 (QBE)



FULL SCALE SHOCK SPECTRUM (g Peak)

1.0 ☐ 10 ☐ 100 ☒ 1000 ☐

DAMPING ☒ 3%



SPECIMEN
AXIS TR1

LOCATION NO. FB HCA
TEST RUN NO. 8 (SSE)



Page No. 90


Report No. 47577-1

P. F6 of F7

FULL SCALE SHOCK SPECTRUM (g Peak)

1.0 ☐ 10 ☐ 100 ☒ 1000 ☐

DAMPING ☒ 3 %



SPECIMEN _____

LOCATION NO. SS HCA

AXIS Y21


TEST RUN NO. 8 (SS E)



FULL SCALE SHOCK SPECTRUM (g Peak)

1.0 ☐ 10 ☐ 100 ☒ 1000 ☐

DAMPING ☒ 3%



SPECIMEN

LOCATION NO. VCA

AXIS TR1

TEST RUN NO. 8 (SS E)



SPEC. NO. NMP2-P222X
PVORT #5

NINE MILE POINT NUCLEAR STATION UNIT 2

EQUIPMENT DYNAMIC QUALIFICATION

COMPONENT NAME: SERVICE WATER PUMP

MARK NUMBERS: 2SWP* PIA



STONE & WEBSTER

SPEC. NO. UMP2-P222X
Revision 0

PORT #5

PUMP AND VALVE

OPERABILITY ASSURANCE REVIEW

I. PLANT INFORMATION

1. Name: Nine Mile Point Unit No. 2 2. Docket No.: 50-410
3. Utility: Niagara Mohawk Power Corporation
4. NSSS: General Electric Co. () PWR (X) BWR
5. A/E: Stone & Webster Engineering Corporation
6. C.P. and/or O. L. SER date 6/24/74

II. GENERAL COMPONENT* INFORMATION

1. Supplier: () NSSS (X) BOP
2. Location:
 - a. Building/Room SCREENWELL
 - b. Elevation 224'
 - c. System SERVICE WATER
3. Component I.D. No. on P&ID dwg. 2SWP x PIA
4. If component is a (X) Pump complete II.5.
If component is a () Valve complete II.6.

5. General Pump Data

<u>a. Pump</u>	<u>b. Prime-mover</u>
Name <u>SERVICE WATER PUMP</u>	Name <u>SERVICE WATER PUMP ELECTRIC MOTOR</u>
Mfg. <u>GOULDS PUMPS, INC.</u>	Mfg. <u>WESTINGHOUSE</u>
Model <u>3A15 M</u>	Model <u>FRAME 5809L</u>
S/N <u>N 239B505-1</u>	S/N <u>77F14707-1S-78</u>
Type <u>HORIZONTAL CENTRIFUGAL</u>	Type <u>HORIZONTAL SQUIRREL CAGE INDUCTION MOTOR</u>

* The component, whether pump or valve, is considered to be an assembly composed of the body, internals, prime-mover (or actuator) and functional accessories.



a. Pump (Continued)

Overall Dimensions 62.25" - HEIGHT
55" - WIDTH
60" - LENGTH

Weight 4810 LBS (WET)Mounting Method BOLTEDRequired B.H.P. 556.2 AT 10,000 GPM

Parameter	Component Design	System Normal/Accident
-----------	------------------	------------------------

Press (PSIG) 150 92 / 90Temp (°F) 100 32-78 / 32-78Flow (GPM) 10,085 10,000 / 10,000Head (Ft) 188.1 185 / 185Media LAKE WATER LAKE WATER / LAKE WATER

Required NPSH at maximum

flow 27 FT. AT 10,000 GPMAvailable NPSH 38 FT.Operating Speed 1188 RPMCritical Speed 2046 RPMList functional accessories: * N/A

b. Prime-mover (Continued)

Overall Dimensions 29" - HEIGHT
48.9" - WIDTH
59.5" - LENGTH

Weight 4650 LB.Mounting Method BOLTEDH.P. 600

Prime Mover Requirements: (include normal, maximum and minimum)

Motor (Voltage) _____

4000 / 3Ø / 60 HZ NORMAL OPERATING
3000 / 3Ø / 60 HZ REDUCED VOLTAGE
 ACCELERATION REQ'D (75%)

Turbine (pressure) N/A

If MOTOR list:

Duty cycle CONTINUOUSStall current 447 Amps (LOCKED ROTOR)Class of insulation CLASS BWITH THERMOPLASTIC EPOXY

* Functional accessories are those sub-components not supplied by the manufacturer that are required to make the pump assembly operational, (e.g., coupling, lubricating oil system, speed control sys., feedback, etc.)



SPEC. No. NMP2-PZZX
REVISION 0
PVORT *5

6. General Valve Data N/A

a. Valve

Name _____

Mfg. _____

Model _____

S/N _____

Type _____

Size _____

Weight _____

Mounting
Method _____

Max. Required
Torque _____

b. Actuator (if not an integral unit)

Name _____

Mfg. _____

Model _____

S/N _____

Type _____

Size _____

Weight _____

Mounting
Method _____

Max. Delivered
Torque _____

Parameter	Component Design	System Normal/Accident
-----------	---------------------	---------------------------

Press	_____	_____/_____
-------	-------	-------------

Temp	_____	_____/_____
------	-------	-------------

Flow	_____	_____/_____
------	-------	-------------

Media	_____	_____/_____
-------	-------	-------------

Max P across valve _____

Closing time @ max P _____

Opening time @ max P _____

Power Requirements: (include normal, maximum and minimum).

Electrical _____

Other: ()Pneumatic ()Hydraulic

List functional accessories:* _____

* Functional accessories are those sub-components not supplied by the manufacturer that are required to make the valve assembly operational, (e.g., limit switches, solenoid valves, accumulators, etc.)



III. FUNCTION

1. Briefly describe components' normal and safety functions (include accident initiating signals.)

Normal: PROVIDE COOLING AND MAKEUP WATER TO
VARIOUS CAT. I, II AND III COMPONENTS

Safety: PROVIDE COOLING AND MAKEUP WATER TO
PLANT SAFETY RELATED SYSTEMS

2. The components normal state is: (X) Operating () Standby

3. Safety function:

- | | | |
|--|---|----------|
| a. (X) Emergency reactor shutdown | b. (X) Containment heat removal | |
| c. () Containment isolation | d. (X) Reactor heat removal | |
| e. (X) Reactor core cooling | f. () Prevent significant release of radioactive material to environment | |
| g. () Does the component function to mitigate the consequences of one or more of the following events? (X) Yes () No | | |
| (X) LOCA | (X) HELB | (X) MSLB |
| () Other _____ | | |

4. Safety requirements:

- | | |
|----------------------------|--------------------------------|
| () Intermittent Operation | (X) During postulated event |
| (X) Continuous Operation | (X) Following postulated event |

If component operation is required following an event, give approximate length of time component must remain operational.

100 DAYS (e.g., hours, days, etc.)

5. For VALVES:

does the component () Fail open () Fail closed () Fail as is

Is this the fail safe position? () Yes () No

Is the valve used for throttling purposes? () Yes () No

What is the maximum acceptable internal and external leakrate?



IV. QUALIFICATION

1. Reference by specific number those applicable sections of the design codes and standards applicable to the component: ASME III, DIVISION I, 1971 CODE
THRU SUMMER 1973 ADDENDA - SUBSECTION ND.
2. Reference those qualification standards, used as a guide to qualify the component: IEEE-334-1974, IEEE-117-1974,
IEEE-344-1975, IEEE-323-1974
REGULATORY GUIDES 1.48, 1.84, 1.85, 1.89, 1.61 & 1.100
3. Have acceptance criteria been established and documented in the test plan(s) for the component?
☒ Yes⁽¹⁾ () No
4. Are the margins* identified in the qualification documentation? ☒ Yes () No
5. Was the component that was qualified a model or an actual assembly? ASSEMBLY. If a model, what was its scale? N/A. If an actual assembly, was it qualified as an assembly or by sub-assemblies (i.e., valve, actuator, pump, driver) BY SUB-ASSEMBLIES
(i.e., PUMP, MOTOR)
6. List all component tests performed or to be performed that demonstrate qualification:
PUMP HYDROSTATIC TEST
PUMP PERFORMANCE TEST
MOTOR ROUTINE TESTS
COLD HYDRO TEST
VIBRATION & BEARING TEMPERATURE TEST
MOTORETTE ENVIRONMENTAL QUALIFICATION

* Margin is the difference between design basis parameters and the test parameters used for equipment qualification.

(1) MAINTAINED AT VENDOR'S SHOP



7. List all component analyses performed that demonstrate qualification:

1) PUMP ASSEMBLY SEISMIC STRESS
ANALYSIS

2) MOTOR SEISMIC STRESS ANALYSIS

8. As a result of any of the tests (or analysis), were any deviations from design requirements identified?
() Yes (X) No If "Yes", briefly describe any changes made in tests (or analyses) or to the component to correct the deviation.

9. Was the tested component precisely identical (as to model, size, etc.) to the in-plant component? () Yes (X) No* If "No", is installed component () oversized or () undersized?

* MOTORETTE USED IN ENVIRONMENTAL TESTS ARE IDENTICAL

10. Is component orientation sensitive? (X) Yes () No () Unknown If "Yes", does installed orientation coincide with test/analysis orientation? (X) Yes () No

List all loads and numerical values used during tests or analysis and indicate whether applied individually or in combination:

SEE ATTACHMENT "A"



11. Does the component have a unique design or utilize unique materials in its construction? (Examples are special gaskets or packings, one of a kind components, limitations on nonferrous materials, special coatings or surfaces, etc.)

() Yes ☒ No If "Yes" identify: _____

12. What is the design (qualified) life of the component, exclusive of normal maintenance items such as packings, bearings, seals, diaphragms, gaskets, and other elastomers?

40 YEARS

13. Which of the components normal maintenance items requires the most frequent replacement? LUBE OIL

What is the normal time interval between replacements of this item?

6 MONTHS

14. What is the harshest (accident/post-accident) external environment that the component could be exposed to during its qualified life? (e.g., temp., press., humidity, submergence, radiation type and dose, etc.)

MILD ENVIRONMENT

TEMPERATURE — 104°F

PRESSURE — ATMOSPHERIC

HUMIDITY — 90% RELATIVE HUMIDITY

RADIATION — 277 RADS (T.I.D.)

NO. SUBMERGENCE



ATTACHMENT "A"

LOADS USED IN ANALYSES

1) NOZZLE LOADS

	SUCTION	DISCHARGE
F _{AXIAL} (LBS)	5,959	7,216
F _{SHEAR} (LBS)	1,066	3,472
M _{BENDING} (IN-LBS)	74,304	196,344
M _{TORSION} (IN-LBS)	3,744	92,220

2) SEISMIC LOADS (PUMP ASSEMBLY)

	SSE	OBE
HORIZONTAL (X&Z)	1.0g	0.6g
VERTICAL (Y)	1.2g	1.1g

3) INTERNAL PRESSURE

THE INTERNAL PRESSURE DESIGN CONDITIONS ARE; 150 psig AT 100°F

4) SHAFT TORSIONAL LOADING

FOR 600 HP. MOTOR AT 1186 RPM, SHAFT TORQUE = $(63,000 \times \text{HP}) / \text{RPM}$

5) IMPELLER LOADS

$$\text{S.T.} = (63,000 \times 600) / 1186$$

$$\text{S.T.} = 31,872 \text{ IN-LBS}$$

IMPELLER LOADS ARE 500 LBS RADIAL AND 2000 LBS AXIAL



LOAD COMBINATIONS

THE ANALYSIS WAS MADE FOR THE FOLLOWING LOAD CASES
(BASED ON ALL THE LOADS PROVIDED ABOVE)

1. NOZZLE LOADS + IMPELLER LOADS IN "X" DIRECTION
2. 1.0g LATERAL "X" LOAD
3. 1.0g LATERAL "Z" LOAD
4. 1.0g VERTICAL "Y" LOAD
5. NOZZLE LOADS + IMPELLER LOADS IN "Y" DIRECTION

LOADS FOR THE "X", "Y" AND "Z" ARE ADDED DIRECTLY

ENVIRONMENTAL

MILD ENVIRONMENT



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
<u>SPECIFICATIONS</u>				
SPEC. PZZZX THRU ADD. II	SAFETY RELATED HORIZONTAL CENTRIFUGAL PUMPS	8-8-73 TO 5-5-83	SWEC	SWEC
E4DCR PO1964	REVISE INSULATION CLASS REQUIREMENTS	12-21-83	SWEC	SWEC
E4DCR PO2451	REVISED SEISMIC ACCELERATIONS	11-21-84	SWEC	SWEC
E4DCR PO2455A	REVISED NOZZLE ALLOWABLES	1-3-85	SWEC	SWEC



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
<u>DRAWINGS</u>				
2.170-050-003E	SWP CROSS-SECTIONAL DRAWING	12-4-78	GOULDS PUMPS	SWEC
2.170-050-12E	SWP PUMP-MOTOR OUTLINE DRAWING	8-21-79	GOULDS PUMPS	SWEC
2.170-050-023B	SWP BEDPLATE DRAWING	10-3-78	GOULDS PUMPS	SWEC
2.170-050-026E	SWP PUMP OUTLINE DWG	4-26-85	GOULDS PUMPS	SWEC
12177-EM-8C REV. 11	MACHINE LOCATION DRAWING	4-19-84	SWEC	SWEC
12177-EM-8E REV. 10	MACHINE LOCATION DRAWING	4-19-84	SWEC	SWEC
12177-EC-14A REV. 10	SCREENWELL FOUNDATION PLAN	2-11-83	SWEC	SWEC
12177-EC-14Z REV. C	FOUNDATION DETAILS	3-30-84	SWEC	SWEC
12177-EC-14AC REV. 2	FOUNDATION DETAILS	4-8-83	SWEC	SWEC



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
FSAR FIG. 9.2-1b	PIPING AND INSTRUMENTATION DRAWING	—	SWEC	SWEC
12177-FSK 9-10A	FLOW DIAGRAM	2/14/85	SWEC	SWEC



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
<u>QUALIFICATION DOCUMENTS</u>				
STRS 02. 170-5002C	SEISMIC STRESS ANALYSIS OF SERVICE WATER PUMPS	6-14-86	GOULD'S PUMPS	SWEC
STRS 02. 260-5003A	SEISMIC ANALYSIS OF SERVICE WATER PUMP MOTOR	5-4-79	WESTINGHOUSE / GOULD PUMPS	SWEC
STRS 02. 260-5005A	GOULD LETTER NO. 80-BCA-5 (SUPPLEMENT TO MOTOR SEISMIC ANALYSIS)	1-25-80	WESTINGHOUSE / GOULD PUMPS	SWEC
STRS 02. 170-5002	SEISMIC CERTIFICATE OF COMPLIANCE	—	GOULD'S PUMPS	SWEC
QCP-120	HYDROSTATIC TEST PROCEDURE	—	GOULD'S PUMPS	GOULD'S PUMPS
QCP-133	HYDRAULIC PERFORMANCE TEST PROCEDURE	—	GOULD'S PUMPS	GOULD'S PUMPS
QCP-130A	VIBRATION AND BEARING TEMP. TEST PROCEDURE	—	GOULD'S PUMPS	GOULD'S PUMPS
MP.GENE. 001	GENERIC ASME III PRESSURE TEST PROCEDURE, REV. 3	11-12-84	SWEC / NMPC	SWEC / NMPC



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
2.170-050-013C	SWP MOTOR SPEED VS. TORQUE CURRENT	1-29-79	GOULD'S PUMPS	SWEC
2.170-050-015D	SWP MOTOR TEMP. VS. HP CURVE	7-31-79	GOULD'S PUMPS	SWEC
2.170-050-016D	SWP TIME VS. CURRENT CURVE	7-24-79	GOULD'S PUMPS	SWEC
2.170-050-044A	SWP BEARING T/C CURVE	3-20-79	GOULD'S PUMPS	SWEC
—	HYDROSTATIC TEST RESULTS	10-19-78	GOULD'S PUMPS	SWEC
QA-110	VIBRATION AND BEARING TEMP. TEST LOG	11-19-80	GOULD'S PUMPS	SWEC
A25939 REV. A	SERVICE WATER CERTIFIED PUMP PERFORMANCE CURVE REV. 1	8-20-79	GOULD'S PUMPS	SWEC
—	REPORT OF MOTOR COMMERCIAL TESTS (ROUTINE)	3-4-80	GOULD'S PUMPS	SWEC
WCAP 8754	WESTINGHOUSE ENVIRONMENTAL QUALIFICATION OF CLASS 1E MOTORS	1-25-84	GOULD'S PUMPS	SWEC
—	SERVICE WATER PUMP DOCUMENTATION PACKAGE	11-1-79	GOULD'S PUMPS	SWEC



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
..	DOCUMENTATION CHECKLIST - SERVICE WATER REV. 1	12-29-78	GOULD'S PUMPS	SNEC
INST. 2-170 5002A	INSTRUCTION BOOK For NMPC/NMP2 P.O.# NMP2-P222X	8-11-82	GOULD'S PUMPS	SNEC
EQEDC-1	EQUIPMENT QUALIFICATION ENVIRONMENTAL DESIGN CRITERIA	5-2-84	SNEC	SNEC
MEQ-P222X, REV.1	ENVIRONMENTAL QUALIFICATION OF MECHANICAL EQUIPMENT	3-27-85	SNEC	SNEC



SPEC. NO. NMP2-P222X
PVORT #6

NINE MILE POINT NUCLEAR STATION UNIT 2

EQUIPMENT DYNAMIC QUALIFICATION

COMPONENT NAME: HIGH PRESSURE CORE SPRAY (CSH) SYSTEM PRESSURE PUMP
MARK NUMBERS: 2CSH * P2



STONE & WEBSTER



PUMP AND VALVEOPERABILITY ASSURANCE REVIEWI. PLANT INFORMATION

1. Name: Nine Mile Point Unit No. 2 2. Docket No.: 50-410
3. Utility: Niagara Mohawk Power Corporation
4. NSSS: General Electric Co. () PWR (X) BWR
5. A/E: Stone & Webster Engineering Corporation
6. C.P. and/or O. L. SER date 6/24/74

II. GENERAL COMPONENT* INFORMATION

1. Supplier: () NSSS (X) BOP
2. Location:
 - a. Building/Room REACTOR BUILDING SECONDARY CONTAINMENT
 - b. Elevation 175'
 - c. System HIGH PRESSURE CORE SPRAY (CSH)
3. Component I.D. No. on P&ID, dwg. 2 CSH *P2
4. If component is a (X) Pump complete II.5.
If component is a () Valve complete II.6.
5. General Pump Data
 - a. Pump
Name SYSTEM PRESSURE PUMP
Mfg. GOULDS PUMPS INC.
Model 3196ST
S/N N-7738980-3
Type HORIZONTAL CENTRIFUGAL
 - b. Prime-mover
Name CSH PUMP ELECTRIC MOTOR
Mfg. WESTINGHOUSE
Model TBDP, FRAME 21ST
S/N 78D36029-7808-01-003
Type SQUIREL CAGE INDUCTION MOTOR

* The component, whether pump or valve, is considered to be an assembly composed of the body, internals, prime-mover (or actuator) and functional accessories.

SPEC No NMP2-P22ZX
REVISION 0
PVORT # 6

a. Pump (Continued)

Overall LENGTH 17.5"
Dimensions WIDTH 18"
HEIGHT 12"

Weight 102 LBS (WET)

Mounting Method BOLTED

Required B.H.P. 5.5 AT 50 GPM

Parameter	Component Design	System Normal/Accident
Press (PSIG)	<u>185</u>	<u>100 / 100</u>
Temp (°F)	<u>212</u>	<u>70 / 212</u>
Flow (GPM)	<u>50</u>	<u>50 / 50</u>
Head (FT)	<u>175</u>	<u>140 / 140</u>
Media	<u>DEMIN. WATER</u>	<u>DEMIN. WATER / DEMIN. WATER</u>

Required NPSH at maximum

flow 2.4 FT AT 50 GPM

Available NPSH 14.78 FT

Operating Speed 3500 RPM

Critical Speed 2960 RPM

List functional accessories:*

b. Prime-mover (Continued)

Overall LENGTH 17.31"
Dimensions WIDTH 14"
HEIGHT 12.64"

Weight 140 LBS

Mounting Method BOLTED

H.P. 10

Prime Mover Requirements: (include normal, maximum and minimum)

Motor (Voltage) _____

575/3Ø/60 Hz NORMAL OPERATING
431.25/3Ø/60 Hz REDUCED VOLTAGE
ACCELERATION REQUIREMENT
(75%)

Turbine (pressure) N/A

If MOTOR list:

Duty cycle CONTINUOUS

Stall current 51 AMPS LOCKED ROTOR

Class of insulation H

U/A

* Functional accessories are those sub-components not supplied by the manufacturer that are required to make the pump assembly operational, (e.g., coupling, lubricating oil system, speed control sys., feedback, etc.)



6. General Valve Data N/A

a. Valve

Name _____
 Mfg. _____
 Model _____
 S/N _____
 Type _____
 Size _____
 Weight _____
 Mounting
 Method _____
 Max. Required
 Torque _____

b. Actuator (if not an integral unit)

Name _____
 Mfg. _____
 Model _____
 S/N _____
 Type _____
 Size _____
 Weight _____
 Mounting
 Method _____
 Max. Delivered
 Torque _____

Parameter	Component Design	System Normal/Accident
Press	_____	_____/_____
Temp	_____	_____/_____
Flow	_____	_____/_____
Media	_____	_____/_____
Max P across valve	_____	
Closing time @ max P	_____	
Opening time @ max P	_____	

Power Requirements: (include normal, maximum and minimum).

Electrical _____

Other: ()Pneumatic ()Hydraulic

List functional accessories:*

* Functional accessories are those sub-components not supplied by the manufacturer that are required to make the valve assembly operational, (e.g., limit switches, solenoid valves, accumulators, etc.)



III. FUNCTION

1. Briefly describe components' normal and safety functions
(include accident initiating signals.)

Normal: MAINTAIN PRESSURE IN CSH PUMP DISCHARGE
PIPING TO PREVENT WATERHAMMER DURING CSH PUMP START-UP.

Safety: SAME AS ABOVE

2. The components normal state is: ☒ Operating ☐ Standby

3. Safety function:

- a. ☐ Emergency reactor shutdown b. ☐ Containment heat removal
c. ☐ Containment isolation d. ☐ Reactor heat removal
e. ☒ Reactor core cooling f. ☐ Prevent significant release of radioactive material to environment
g. ☐ Does the component function to mitigate the consequences of one or more of the following events? ☒ Yes ☐ No
☒ LOCA ☒ HELB ☒ MSLB
☐ Other _____

4. Safety requirements:

- ☐ Intermittent Operation ☐ During postulated event
☒ Continuous Operation ☐ Following postulated event

If component operation is required following an event, give approximate length of time component must remain operational.

100 DAYS (e.g., hours, days, etc.)

5. For VALVES:

N/A

does the component ☐ Fail open ☐ Fail closed ☐ Fail as is

Is this the fail safe position? ☐ Yes ☐ No

Is the valve used for throttling purposes? ☐ Yes ☐ No

What is the maximum acceptable internal and external leakrate?



IV. QUALIFICATION

1. Reference by specific number those applicable sections of the design codes and standards applicable to the component: ASME III, DIVISION I, 1974 EDITION
THROUGH WINTER 1976 ADDENDA - SUBSECTION NC
2. Reference those qualification standards, used as a guide to qualify the component: IEEE-334-1974, IEEE-117-1974,
IEEE-344-1975, IEEE-323-1974
REGULATORY GUIDES 1.48, 1.84, 1.85, 1.89, 1.61 & 1.100
3. Have acceptance criteria been established and documented in the test plan(s) for the component?
(X) Yes⁽¹⁾ () No
4. Are the margins* identified in the qualification documentation? (X) Yes () No
5. Was the component that was qualified a model or an actual assembly? ASSEMBLY. If a model, what was its scale? N/A. If an actual assembly, was it qualified as an assembly or by sub-assemblies? (i.e., valve, actuator, pump, driver) BY SUBASSEMBLIES
(i.e., PUMP, MOTOR)
6. List all component tests performed or to be performed that demonstrate qualification:
PUMP HYDROSTATIC TEST
PUMP PERFORMANCE TEST
MOTOR ROUTINE TESTS
COLD HYDRO TEST
VIBRATION AND BEARING TEMPERATURE TEST
MOTORETTE ENVIRONMENTAL QUALIFICATION

* Margin is the difference between design basis parameters and the test parameters used for equipment qualification.

(1) MAINTAINED AT VENDOR'S SHOP



7. List all component analyses performed that demonstrate qualification:

1) PUMP ASSEMBLY SEISMIC STRESS

ANALYSIS

2) MOTOR SEISMIC STRESS ANALYSIS

8. As a result of any of the tests (or analysis), were any deviations from design requirements identified?
() Yes (X) No If "Yes", briefly describe any changes made in tests (or analyses) or to the component to correct the deviation.

9. Was the tested component precisely identical (as to model, size, etc.) to the in-plant component? () Yes (X) No. If "No", is installed component () oversized or () undersized?

- *MOTORETTE USED IN ENVIRONMENTAL TESTS ARE IDENTICAL
10. Is component orientation sensitive? (X) Yes () No
() Unknown If "Yes", does installed orientation coincide with test/analysis orientation? (X) Yes
() No

List all loads and numerical values used during tests or analysis and indicate whether applied individually or in combination:

SEE ATTACHMENT "A"



11. Does the component have a unique design or utilize unique materials in its construction? (Examples are special gaskets or packings, one of a kind components, limitations on nonferrous materials, special coatings or surfaces, etc.)

(X) Yes () No If "Yes" identify: _____

INBOARD/OUTBOARD "BUNA N" OIL SEALS
AND BEARING HOUSING SEALS

12. What is the design (qualified) life of the component, exclusive of normal maintenance items such as packings, bearings, seals, diaphragms, gaskets, and other elastomers?

40 YEARS

13. Which of the components normal maintenance items requires the most frequent replacement? MOTOR - CHEVRON

SRI-2 GREASE PUMP - LUBE OIL What is the normal time interval between replacements of this item?

MOTOR - 2 YEARS; PUMP - SURVEILLANCE/PERIODIC
SAMPLING OR LUB OIL
MANUFACTURER RECOMMENDATION

14. What is the harshest (accident/post-accident) external environment that the component could be exposed to during its qualified life? (e.g., temp., press., humidity, submergence, radiation type and dose, etc.)

	<u>NORMAL</u>	<u>ACCIDENT</u>
<u>TEMPERATURE °F</u>	<u>85 -</u>	<u>175</u>
<u>PRESSURE (PSIG)</u>	<u>-.25 IN WATER</u>	<u>2.8 PSIG</u>
<u>HUMIDITY (% RH)</u>	<u>50</u>	<u>100</u>
<u>RADIATION (RADS) GAMMA</u>	<u>1.8×10^3</u>	<u>4.6×10^7</u>
<u>BETA</u>	<u>N/A</u>	<u>1.3×10^7</u>



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
<u>SPECIFICATIONS</u>				
SPEC. P222X THRU ADD. II	SAFETY RELATED HORIZONTAL CENTRIFUGAL PUMPS	8-8-73 TO 5-5-83	SWEC	SWEC
E&DCR PO2,465A	REVISED NOZZLE ALLOWABLES	1-3-85	SWEC	SWEC



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
<u>DRAWINGS</u>				
2.170 - 050-009A	PRESSURE MAINTENANCE PUMPS CROSS-SECTION DRAWING	2-28-78	GOULDS PUMPS	SWEC
2.170 - 050-035A	SYS. PRESSURE PUMPS BEDPLATE DRAWING	6-8-78	GOULDS PUMPS	SWEC
16.300 - 050.002E	PRESSURE PUMPS OUTLINE DRAWING	7-22-80	GOULDS PUMPS	SWEC
2.170 - 050-027H	SYS. PRESSURE PUMPS MOTOR OUTLINE DRAWING	4-6-78	GOULDS PUMPS	SWEC
16.300 050-001B	MECHANICAL SEAL SYS. PRESSURE PUMPS	11-17-78	GOULDS PUMPS	SWEC
12177 EM-2A REV. 18	REACTOR BLDG MACHINE LOCATION	11-5-84	SWEC	SWEC
12177 EC-30HB REV. 7	PAD LOCATIONS REACTOR BLDG. & Aux. BAY	5-3 -84	SWEC	SWEC
12177 EC-30AC REV. 6	REACTOR BLDG. & PAD DETAILS	7-9-82	SWEC	SWEC
12177 EM-2N REV. 12	MACHINE LOCATION REACTOR BLDG. & Aux. BAY	10-8-84	SWEC	SWEC



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
FSK 27-4B	FLOW DIAGRAM	10-31-84	SWEC	SWEC
FSAR FIGURE 6.3-6	PIPING & INSTRUMENTATION DRAWING	-	GE	SWEC



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
<u>QUALIFICATION DOCUMENTS</u>				
ME-563 REV. 6 WITH ADD.#1	SEISMIC ANALYSIS OF PRESSURE PUMPS	4-23-84	GOULD'S PUMPS	SNEC
STRS 02.260- 5007A	SEISMIC ANALYSIS OF PRESSURE PUMP MOTOR	6-12-79	WESTINGHOUSE / GOULD	SNEC
STRS 02.260- 5005A	GOULD LETTER No. 80-BCA-5 (SUPPLEMENT TO MOTOR SEISMIC ANALYSIS	1-25-80	GOULD'S PUMPS	SNEC
ME-563 REV. 0 & ADD.#1	SEISMIC CERTIFICATE OF COMPLIANCE	4-23-84	GOULD'S PUMPS	SNEC
QCP-122	HYDROSTATIC TEST PROCEDURE	—	GOULD'S PUMPS	GOULD'S PUMPS
QCP-132	HYDRAULIC TEST PROCEDURE	—	GOULD'S PUMPS	GOULD'S PUMPS
QCP-130A	VIBRATION AND BEARING TEMP. TEST PROCEDURE	—	GOULD'S PUMPS	GOULD'S PUMPS



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
MP. GENE. 001	GENERIC ASME III PRESSURE TEST PROCEDURE, REV. 3	11-12-84	SWEC / NNIPC	SWEC / NNIPC
16.300 050-003B	SYS. PRESSURE PUMPS MOTOR SPEED VS. TORQUE CURVE	2-12-79	GOULD'S PUMPS	SWEC
16.300 050-004B	SYS. PRESS. PUMPS SPEED VS. TORQUE CURRENT - 75%	7-26-79	GOULD'S PUMPS	SWEC
16.300 050-005B	SYS PRESS. PUMPS SPEED VS. TORQUE CURRENT - 80%	7-26-79	GOULD'S PUMPS	SWEC
16.300 050-006B	SYS. PRESS. PUMPS SPEED VS. TORQUE CURRENT - 100%	7-31-79	GOULD'S PUMPS	SWEC
16.300 050-007B	SYS. PRESS. PUMPS TYP. NOISE DATA	2-12-79	GOULD'S PUMPS	SWEC
—	HYDROSTATIC TEST RESULTS	8-14-79	GOULD'S PUMPS	SWEC
QA-110	VIBRATION AND BEARING TEMP. TEST LOG	—	GOULD'S PUMPS	SWEC
2.170- 050-028A	SYS. PRESS. PUMPS MOTOR SPEED VS. TORQUE DATA	4-6-78	GOULD'S PUMPS	SWEC



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
AZC438-REV. A	PUMP PERFORMANCE TEST LOGS AND CURVES	11-2-79	GOULD'S PUMPS	SNIEC
MAC-A-2-REV. 2	REPORT OF COMPLETE TEST FOR INDUCTION MOTORS - JOCKEY PUMP MOTORS	8-24-78	GOULD'S PUMPS	SNIEC
MAC-A-1-REV. 1	ROUTINE TESTS ON INDUCTION MOTORS - JOCKEY PUMP MOTORS	8-24-78	GOULD'S PUMPS	SNIEC
MM-9112	WESTINGHOUSE ENVIRONMENTAL QUALIFICATION OF CLASS 1E MOTORS	9-1-81	WESTINGHOUSE / GOULD	SNIEC
—	PRESSURE PUMP DOCUMENTATION PACKAGE	6-22-82	GOULD'S PUMPS	SNIEC
—	DOCUMENT CHECKLIST-REV. 1 - SYS. PRESSURE PUMPS	12-29-78	GOULD'S PUMPS	SNIEC
INST. 2.170-5002 H	INSTRUCTION BOOK FOR NMP1/NMP2 P.O. # NMP2-P222X	8-11-82	GOULD'S PUMPS	SNIEC



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
EQEDC-1	EQUIPMENT QUALIFICATION ENVIRONMENTAL DESIGN CRITERIA	5/2/84	SWEC	SWEC
MEQ-P222X, REV.1	ENVIRONMENTAL QUALIFICATION OF MECHANICAL EQUIPMENT	3-27-85	SWEC	SWEC



ATTACHMENT "A"

LOADS USED IN ANALYSES

1) NOZZLE LOADS

	SUCTION	DISCHARGE
F _{AXIAL} (LBS)	300	245
F _{SHEAR} (LBS)	180	147
M _{BENDING} (IN-LBS)	1619	914
M _{TORSION} (IN-LBS)	1943	1097

2) SEISMIC LOADS (PUMP ASSEMBLY)

	SSE	OBE
HORIZONTAL (X & Z)	1.0g	0.75g
VERTICAL (Y)	1.5g	1.25g

3) INTERNAL PRESSURE

THE INTERNAL PRESSURE DESIGN CONDITIONS ARE; 185 PSIG AT 212°F

4) SHAFT TORSIONAL LOADING

FOR 10 HP.. MOTOR AT 3500 RPM, SHAFT TORQUE = $(63,000 \times \text{HP}) / \text{RPM}$

5) IMPELLER LOADS

$$\text{S.T.} = 63,000 \times 10 / 3500$$

$$\text{S.T.} = 180 \text{ IN-LBS}$$

IMPELLER LOADS ARE 60 LBS RADIAL AND 500 LBS
AXIAL



LOAD COMBINATIONS

THE ANALYSIS WAS MADE FOR THE FOLLOWING LOAD CASES
(BASED ON ALL THE LOADS PROVIDED ABOVE)

- 1) 1.0g LATERAL "X" LOAD
- 2) 1.0g LATERAL "Z" LOAD
- 3) 1.0g VERTICAL "Y" LOAD
- 4) NOZZLE LOADS + IMPELLER LOADS IN "Z" DIRECTION
- 5) NOZZLE LOADS + IMPELLER LOADS IN "X" DIRECTION

LOADS FOR THE "X", "Y" AND "Z" ARE ADDED DIRECTLY

ENVIRONMENTAL

APPLIED IN COMBINATION	{	TEMPERATURE (°F)	<u>NORMAL</u>	<u>ACCIDENT</u>
			85	175
		PRESSURE	ATMOSPHERIC	2.8 PSIG
		RELATIVE HUMIDITY (%)	50	100
		RADIATION	2.0 x 10 ⁸ RADS	



SPEC. NO. NMP2-P222X

PVORT #7

NINE MILE POINT NUCLEAR STATION UNIT 2

EQUIPMENT DYNAMIC QUALIFICATION

RESIDUAL HEAT REMOVAL
COMPONENT NAME: (RHS) SYSTEM PRESSURE PUMP
MARK NUMBERS: 2RHS*P2



STONE & WEBSTER

12



SPEC. NO. NIMP2-P222X
Revision 0
PVORT # 7

PUMP AND VALVE

OPERABILITY ASSURANCE REVIEW

1. PLANT INFORMATION

1. Name: Nine Mile Point Unit No. 2 2. Docket No.: 50-410
3. Utility: Niagara Mohawk Power Corporation
4. NSSS: General Electric Co. () PWR (X) BWR
5. A/E: Stone & Webster Engineering Corporation
6. C.P. and/or O. L. SER date 6/24/74

II. GENERAL COMPONENT* INFORMATION

1. Supplier: () NSSS (X) BOP
2. Location:
 - a. Building/Room AUXILIARY BAY SOUTH
 - b. Elevation 175'
 - c. System RESIDUAL HEAT REMOVAL (RHS)
3. Component I.D. No. on P&ID dwg. 2RHS * P2
4. If component is a (X) Pump complete II.5.
If component is a () Valve complete II.6.
5. General Pump Data
 - a. Pump
RESIDUAL HEAT REMOVAL (RHS)
Name SYSTEM PRESSURE PUMP
Mfg. GOULDS PUMPS
Model 3196 ST
S/N N-773B980-1
Type HORIZONTAL CENTRIFUGAL
 - b. Prime-mover
Name RHS PRESSURE PUMP MOTOR
Mfg. WESTINGHOUSE
Model TBDP, FRAME 215T
S/N 78036029-7808-01-001
SQUIREL CAGE
Type INDUCTION MOTOR

* The component, whether pump or valve, is considered to be an assembly composed of the body, internals, prime-mover (or actuator) and functional accessories.



SPEC. No. NMP2-P2ZZX
REVISION 0
PVORT #7

a. Pump (Continued)
LENGTH — 17.5"
Overall WIDTH — 18"
Dimensions HEIGHT — 12"

Weight 102 LBS (WET)

Mounting
Method BOLTED

Required B.H.P. 5.5 AT 50 GPM

b. Prime-mover (Continued)
LENGTH — 17.31"
Overall WIDTH — 14"
Dimensions HEIGHT — 12.64"

Weight 140 LBS

Mounting
Method BOLTED

H.P. 10

Parameter	Component	System	
	Design	Normal	Accident
Press (PSIG)	<u>185</u>	<u>87</u>	<u>121</u>
Temp (°F)	<u>212</u>	<u>70</u>	<u>212</u>
Flow (GPM)	<u>50</u>	<u>50</u>	<u>50</u>
Head (FT)	<u>175</u>	<u>110</u>	<u>110</u>
Media	<u>DEMIN. WATER</u>	<u>DEMIN. WATER</u>	<u>DEMIN. WATER</u>

Prime Mover Requirements: (include normal, maximum and minimum)

Motor (Voltage) _____

575/3Ø/60 HZ NORMAL OPERATING
431:25/3Ø/60 HZ REDUCED VOLTAGE
ACCELERATION REQ'D MNT (75%)

Turbine (pressure) N/A

Required NPSH at maximum

flow 2.4 FT. AT 50 GPM.

Available NPSH 20.3 FT

Operating Speed 3500 RPM

Critical Speed 2960 RPM

List functional accessories:*

If MOTOR list:

Duty cycle CONTINUOUS

Stall current 51 AMPS LOCKED ROTOR

Class of insulation H

N/A

* Functional accessories are those sub-components not supplied by the manufacturer that are required to make the pump assembly operational, (e.g., coupling, lubricating oil system, speed control sys., feedback, etc.)



SPEC No NMPZ-P222X
REVISION 0
PORT # 7

N/A

6. General Valve Data

a. Valve

Name _____

Mfg. _____

Model _____

S/N _____

Type _____

Size _____

Weight _____

Mounting
Method _____

Max. Required
Torque _____

b. Actuator (if not an integral unit)

Name _____

Mfg. _____

Model _____

S/N _____

Type _____

Size _____

Weight _____

Mounting
Method _____

Max. Delivered
Torque _____

Parameter	Component Design	System Normal/Accident
-----------	---------------------	---------------------------

Press	_____	_____/_____
-------	-------	-------------

Temp	_____	_____/_____
------	-------	-------------

Flow	_____	_____/_____
------	-------	-------------

Media	_____	_____/_____
-------	-------	-------------

Max P across valve _____

Closing time @ max P _____

Opening time @ max P _____

Power Requirements: (include normal, maximum and minimum).

Electrical _____

Other: ()Pneumatic ()Hydraulic

List functional accessories:*

* Functional accessories are those sub-components not supplied by the manufacturer that are required to make the valve assembly operational, (e.g., limit switches, solenoid valves, accumulators, etc.)



III. FUNCTION

1. Briefly describe components' normal and safety functions (include accident initiating signals.)

Normal: MAINTAIN RHR MAIN PUMP DISCHARGE LINE FILLED
TO MITIGATE EFFECTS OF FLUID TRANSIENTS

Safety: SAME AS ABOVE

2. The components normal state is: ☒ Operating ☐ Standby

3. Safety function:

- a. ☒ Emergency reactor shutdown b. ☒ Containment heat removal
c. ☐ Containment isolation d. ☒ Reactor heat removal
e. ☐ Reactor core cooling f. ☐ Prevent significant release of radioactive material to environment
g. ☐ Does the component function to mitigate the consequences of one or more of the following events? ☒ Yes ☐ No
☒ LOCA ☒ HELB ☒ MSLB
☐ Other _____

4. Safety requirements:

- ☐ Intermittent Operation ☒ During postulated event
☒ Continuous Operation ☒ Following postulated event

If component operation is required following an event, give approximate length of time component must remain operational.

100 DAYS (e.g., hours, days, etc.)

5. For VALVES:

J/A

does the component ☐ Fail open ☐ Fail closed ☐ Fail as is

Is this the fail safe position? ☐ Yes ☐ No

Is the valve used for throttling purposes? ☐ Yes ☐ No

What is the maximum acceptable internal and external leakrate?



IV. QUALIFICATION

1. Reference by specific number those applicable sections of the design codes and standards applicable to the component: ASME III, DIVISION 1, 1974 EDITION
THROUGH WINTER 1976 ADDENDA - SUBSECTION NC
2. Reference those qualification standards, used as a guide to qualify the component: IEEE-334-1974, IEEE-117-1974,
IEEE-344-1975, IEEE-323-1974
REGULATORY GUIDES 1.48, 1.84, 1.85, 1.89, 1.61 & 1.100
3. Have acceptance criteria been established and documented in the test plan(s) for the component?
☒ Yes⁽¹⁾ () No
4. Are the margins* identified in the qualification documentation? ☒ Yes () No
5. Was the component that was qualified a model or an actual assembly? ASSEMBLY. If a model, what was its scale? U/A. If an actual assembly, was it qualified as an assembly or by sub-assemblies? (i.e., valve, actuator, pump, driver) BY SUB-ASSEMBLIES
(i.e., PUMP, MOTOR)
6. List all component tests performed or to be performed that demonstrate qualification:
PUMP HYDROSTATIC TEST
PUMP PERFORMANCE TEST
MOTOR ROUTINE TESTS
COLD HYDRO TEST
VIBRATION & BEARING TEMPERATURE TEST
MOTORETTE ENVIRONMENTAL QUALIFICATION

* Margin is the difference between design basis parameters and the test parameters used for equipment qualification.

(1) MAINTAINED AT VENDOR'S SHOP



7. List all component analyses performed that demonstrate qualification:

1) PUMP ASSEMBLY SEISMIC STRESS

ANALYSIS

2) MOTOR SEISMIC STRESS ANALYSIS

8. As a result of any of the tests (or analysis), were any deviations from design requirements identified?
() Yes (X) No If "Yes", briefly describe any changes made in tests (or analyses) or to the component to correct the deviation.

9. Was the tested component precisely identical (as to model, size, etc.) to the in-plant component? () Yes (X) No. If "No", is installed component () oversized or () undersized?

- * MOTORETTE USED IN ENVIRONMENTAL TESTS ARE IDENTICAL
10. Is component orientation sensitive? (X) Yes () No
() Unknown If "Yes", does installed orientation coincide with test/analysis orientation? (X) Yes
() No

List all loads and numerical values used during tests or analysis and indicate whether applied individually or in combination:

SEE ATTACHMENT "A"



11. Does the component have a unique design or utilize unique materials in its construction? (Examples are special gaskets or packings, one of a kind components, limitations on nonferrous materials, special coatings or surfaces, etc.)

(X) Yes () No If "Yes" identify: _____

INBOARD/OUTBOARD "BUNA N" OIL SEALS
AND BEARING HOUSING SEALS

12. What is the design (qualified) life of the component, exclusive of normal maintenance items such as packings, bearings, seals, diaphragms, gaskets, and other elastomers?

40 YEARS

13. Which of the components normal maintenance items requires the most frequent replacement? MOTOR - CHEVRON

SRI-2 GEASE; PUMP - LUBE OIL What is the normal time interval between replacements of this item?

MOTOR - 2 YEARS; PUMP - SURVEILLANCE / PERIODIC
SAMPLING OR PER LUB. OIL
MANUFACTURER RECOMMENDATION

14. What is the harshest (accident/post-accident) external environment that the component could be exposed to during its qualified life? (e.g., temp., press., humidity, submergence, radiation type and dose, etc.)

	<u>NORMAL</u>	<u>ACCIDENT</u>
<u>TEMPERATURE °F</u>	<u>85</u>	<u>175</u>
<u>PRESSURE (PSIG)</u>	<u>-.25 IN. WATER</u>	<u>2.8 PSIG</u>
<u>HUMIDITY (% R.H.)</u>	<u>50</u>	<u>100</u>
<u>RADIATION (RADS)</u>	<u>GAMMA — 3.3x10⁵</u>	<u>4.1x10⁷</u>
	<u>BETA — N/A</u>	<u>1.3x10⁷</u>



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
<u>SPECIFICATIONS</u>				
SPEC. P222X THRU ADD. II	SAFETY RELATED HORIZONTAL CENTRIFUGAL PUMPS	8-8-73 TO 5-5-83	SWEC	SWEC
E&DR P02,4SA	REVISED NOZZLE ALLOWABLES	1-3-85	SWEC	SWEC



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
<u>DRAWINGS</u>				
2.170-050-009A	PRESSURE MAINTENANCE PUMPS CROSS-SECTION DRAWING	2-28-78	GOULD'S PUMPS	SWEC
2.170-050-035A	SYS. PRESSURE PUMPS BEDPLATE DRAWING	6-8-78	GOULD'S PUMPS	SWEC
16.300-050.002E	PRESSURE PUMPS OUTLINE DRAWING	7-22-80	GOULD'S PUMPS	SWEC
2.170-050-027A	SYS. PRESSURE PUMPS MOTOR OUTLINE DRAWING	4-6-78	GOULD'S PUMPS	SWEC
16.300-050-001B	MECHANICAL SEAL SYS. PRESSURE PUMPS	11-17-78	GOULD'S PUMPS	SWEC
12177 EM-2A REV. 18	REACTOR BLDG MACHINE LOCATION	11-5-84	SWEC	SWEC
12177 EC-30AB REV. 7	PAD LOCATIONS REACTOR BLDG. & AUX. BAY	5-3 -84	SWEC	SWEC
12177 EC-30AC REV. 6	REACTOR BLDG. PAD DETAILS	7-9-82	SWEC	SWEC
12177 EM-2N REV. 12	MACHINE LOCATION REACTOR BLDG & AUX. BAY	10-8-84	SWEC	SWEC



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
FSK 27-7G	FLOW DIAGRAM	10-31-84	SWEC	SWEC
FSAR FIGURE 5.4-13 SHEET 1 OF 2	PIPING & INSTRUMENTATION DRAWING	—	GE	SWEC



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
<u>QUALIFICATION DOCUMENTS</u>				
ME-563 REV. 0 WITH ADD. #1	SEISMIC ANALYSIS OF PRESSURE PUMPS	4-23-84	GOULD'S PUMPS	SWEC
STRS 02.260- 5007A	SEISMIC ANALYSIS OF PRESSURE PUMP MOTOR	6-12-79	WESTINGHOUSE / GOULD	SWEC
STRS 02.260- 5005A	GOULD LETTER NO. 80-BCA-5 (SUPPLEMENT TO MOTOR SEISMIC ANALYSIS	1-25-80	GOULD'S PUMPS	SWEC
ME-563 REV. 0 & ADD. #1	SEISMIC CERTIFICATE OF COMPLIANCE	4-23-84	GOULD'S PUMPS	SWEC
QCP-122	HYDROSTATIC TEST PROCEDURE	—	GOULD'S PUMPS	GOULD'S PUMPS
QCP-132	HYDRAULIC TEST PROCEDURE	—	GOULD'S PUMPS	GOULD'S PUMPS
QCP-130A	VIBRATION AND BEARING TEMP. TEST PROCEDURE	—	GOULD'S PUMPS	GOULD'S PUMPS



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
MP. GENE 001	GENERIC ASME III PRESSURE TEST PROCEDURE, REV. 3	11-12-84	SWEC / NMPC	SWEC / NMPC
16.300 050-003B	SYS. PRESSURE PUMPS MOTOR SPEED VS. TORQUE CURVE	2-12-79	GOULD'S PUMPS	SWEC
16.300 050-004B	SYS. PRESS. PUMPS SPEED VS. TORQUE CURRENT - 75%	7-26-79	GOULD'S PUMPS	SWEC
16.300 050-005B	SYS. PRESS. PUMPS SPEED VS. TORQUE CURRENT - 80%	7-26-79	GOULD'S PUMPS	SWEC
16.300 050-006B	SYS. PRESS. PUMPS SPEED VS. TORQUE CURRENT - 100%	7-31-79	GOULD'S PUMPS	SWEC
16.300 050-007A	SYS. PRESS. PUMPS TYP. NOISE DATA	2-12-79	GOULD'S PUMPS	SWEC
—	HYDROSTATIC TEST RESULTS	8-14-79	GOULD'S PUMPS	SWEC
QA-110	VIBRATION AND BEARING TEMP. TEST LOG	—	GOULD'S PUMPS	SWEC
2.170- 050-028A	SYS. PRESS. PUMPS MOTOR SPEED VS. TORQUE DATA	4-6-78	GOULD'S PUMPS	SWEC



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
AZC43G REV. A	PUMP PERFORMANCE TEST LOGS AND CURVES	11-2-79	GOULD'S PUMPS	SWEC
MAC-A-2 REV. 2	REPORT OF COMPLETE TEST FOR INDUCTION MOTORS - JOCKEY PUMP MOTORS	8-24-78	GOULD'S PUMPS	SWEC
MAC-A-1 REV. 1	ROUTINE TESTS ON INDUCTION MOTORS - JOCKEY PUMP MOTORS	8-24-78	GOULD'S PUMPS	SWEC
MM - 9112	WESTINGHOUSE ENVIRONMENTAL QUALIFICATION OF CLASS 1E MOTORS	9-1-81	WESTINGHOUSE / GOULD	SWEC
—	PRESSURE PUMP DOCUMENTATION PACKAGE	6-22-82	GOULD'S PUMPS	SWEC
—	DOCUMENT CHECKLIST - REV. 1 - SYS. PRESSURE PUMPS	12-29-78	GOULD'S PUMPS	SWEC
INST. 2.170- 5002H	INSTRUCTION BOOK FOR NMPC / NMP2 P.O. # NMP2-P222X	8-11-82	GOULD'S PUMPS	SWEC



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
EQ EDC-1	EQUIPMENT QUALIFICATION ENVIRONMENTAL DESIGN CRITERIA	5/2/89	SWEC	SWEC
MEQ-P222X, REV. 1	ENVIRONMENTAL QUALIFICATION OF MECHANICAL EQUIPMENT	3-27-85	SWEC	SWEC



ATTACHMENT "A"

LOADS USED IN ANALYSES

1) NOZZLE LOADS

	SUCTION	DISCHARGE
F _{AXIAL} (LBS)	300	245
F _{SHEAR} (LBS)	180	147
M _{BENDING} (IN-LBS)	1619	914
M _{TORSION} (IN-LBS)	1943	1097

2) SEISMIC LOADS (PUMP ASSEMBLY)

	SSE	OBE
HORIZONTAL (X & Z)	1.0g	0.75g
VERTICAL (Y)	1.5g	1.25g

3) INTERNAL PRESSURE

THE INTERNAL PRESSURE DESIGN CONDITIONS ARE; 185 psig AT 212°F

4) SHAFT TORSIONAL LOADING

FOR 10 HP. MOTOR AT 3500 RPM, SHAFT TORQUE = $(63,000 \times \text{HP}) / \text{RPM}$

5) IMPELLER LOADS

$$\text{S.T.} = 63,000 \times 10 / 3500$$

$$\text{S.T.} = 180 \text{ IN-LBS}$$

IMPELLER LOADS ARE 60 LBS RADIAL AND 500 LBS AXIAL



LOAD COMBINATIONS

THE ANALYSIS WAS MADE FOR THE FOLLOWING LOAD CASES
(BASED ON ALL THE LOADS PROVIDED ABOVE)

- 1) 1.0g LATERAL "X" LOAD
- 2) 1.0g LATERAL "Z" LOAD
- 3) 1.0g VERTICAL "Y" LOAD
- 4) NOZZLE LOADS + IMPELLER LOADS IN "Z" DIRECTION
- 5) NOZZLE LOADS + IMPELLER LOADS IN "X" DIRECTION

LOADS FOR THE "X", "Y" AND "Z" ARE ADDED DIRECTLY

ENVIRONMENTAL

	APPLIED IN COMBINATION	<u>NORMAL</u>	<u>ACCIDENT</u>
TEMPERATURE (°F)		85	175
PRESSURE		ATMOSPHERIC	2.8 PSIG
RELATIVE HUMIDITY (%)		50	100
RADIATION			2.0×10^8 RADS



BP

SPEC. NO. P121A

PORT # 8

NINE MILE POINT NUCLEAR STATION UNIT 2

EQUIPMENT DYNAMIC QUALIFICATION

MOTOR OPERATED

COMPONENT NAME: ROTARY GATE VALVE

MARK NUMBERS: 2SWP * MOV 30A



STONE & WEBSTER



PUMP AND VALVE
OPERABILITY ASSURANCE REVIEW

1. PLANT INFORMATION

1. Name: Nine Mile Point Unit No. 2 2. Docket No.: 50-410
3. Utility: Niagara Mohawk Power Corporation
4. NSSS: General Electric Co. () PWR (X) BWR
5. A/E: Stone & Webster Engineering Corporation
6. C.P. and/or O. L. SER date 6/24/74

II. GENERAL COMPONENT* INFORMATION

1. Supplier: () NSSS ☒ BOP
2. Location: a. Building/Room TURBINE BLDG (SCREENWELL)
b. Elevation 285' (FLOORSTAND & OPERATOR)
c. System SERVICE WATER
3. Component I.D. No. on P&ID dwg. 2SWP * MOV 30A

4. If component is a () Pump complete II.5.

If component is a ☒ Valve complete II.6.

5. General Pump Data N/A

a. Pump

b. Prime-mover

Name _____

Name _____

Mfg. _____

Mfg. _____

Model _____

Model _____

S/N _____

S/N _____

Type _____

Type _____

* The component, whether pump or valve, is considered to be an assembly composed of the body, internals, prime-mover (or actuator) and functional accessories.



a. Pump (Continued)

Overall Dimensions _____

Weight _____

Mounting Method _____

Required B.H.P. _____

Parameter	Component Design	System Normal/Accident
-----------	------------------	------------------------

Press	_____	_____/_____
-------	-------	-------------

Temp	_____	_____/_____
------	-------	-------------

Flow	_____	_____/_____
------	-------	-------------

Head	_____	_____/_____
------	-------	-------------

Media	_____	_____/_____
-------	-------	-------------

Required NPSH at maximum

flow _____

Available NPSH _____

Operating Speed _____

Critical Speed _____

List functional accessories:*

b. Prime-mover (Continued)

Overall Dimensions _____

Weight _____

Mounting Method _____

H.P. _____

Prime Mover Requirements: (include normal, maximum and minimum)

Motor(Voltage) _____

Turbine (pressure) _____

If MOTOR list:

Duty cycle _____

Stall current _____

Class of insulation _____

* Functional accessories are those sub-components not supplied by the manufacturer that are required to make the pump assembly operational, (e.g., coupling, lubricating oil system, speed control sys., feedback, etc.)



6. General Valve Data

a. Valve

Name RECTANGULAR VALVE
 Mfg. HENRY PRATT CO
 Model RECTANGULAR BV
 S/N D-022467-1-1

Type MOTOR-OPERATED ROTARY GATE
 Size 48" W x 72" H.
 Weight 3470 (EXCLUDING WT. OF OPERATOR)

Mounting FRAMES EMBEDDED IN
 Method CONCRETE, SECURED WITH JACK BOLTS

Max. Required
 Torque 153,600 in.-lb

Parameter	Component Design	System Normal/Accident
-----------	------------------	------------------------

Press, psig	<u>20</u>	<u>9 / 9</u>
-------------	-----------	--------------

Temp, °F	<u>33-90</u>	<u>52-78 / 32-78</u>
----------	--------------	----------------------

Flow, gpm	<u>50,000</u>	<u>28,300 / 26,000</u>
-----------	---------------	------------------------

Media	<u>WATER</u>	<u>WATER / WATER</u>
-------	--------------	----------------------

Max P across valve 46 A. WATER

Closing time @ max P 60 sec / 55 sec, test

Opening time @ max P 60 sec / 55 sec, test

List functional accessories:*

b. Actuator (if not an integral unit)

Name MOTOR OPERATOR WITH ROTARY GEAR

Mfg. LIMITORQUE

Model SMB-0-15/H4BC

S/N 341652

Type ELECTRIC

Size SMB-0-15

Weight 765 lbs

Mounting BOLTED ON TORQUE
 Method TUBE EXTENSION

Max. Delivered (STALL)
 Torque 201,660 in.-lb

Power Requirements: (include normal, maximum and minimum).

Electrical AC

VOLTAGE: 575 V, -20%, +10% RANGE

3-PHASE, 60 HZ.

TEMP, °F: 60 - 104 (AMBIENT)

Other: () Pneumatic () Hydraulic

* Functional accessories are those sub-components not supplied by the manufacturer that are required to make the valve assembly operational, (e.g., limit switches, solenoid valves, accumulators, etc.)



III.

FUNCTION

1. Briefly describe components' normal and safety functions (include accident initiating signals.)

Normal: OPEN

Safety: ISOLATES NORTH INTAKE SHAFT UPON
FAILURE OF DISCHARGE TUNNEL

2. The components normal state is: () Operating ☒ Standby

3. Safety function:

- | | |
|--|---|
| a. () Emergency reactor shutdown | b. <input checked="" type="checkbox"/> Containment heat removal |
| c. () Containment isolation | d. <input checked="" type="checkbox"/> Reactor heat removal |
| e. () Reactor core cooling | f. <input checked="" type="checkbox"/> Prevent significant release of radioactive material to environment |
| g. () Does the component function to mitigate the consequences of one or more of the following events? <input checked="" type="checkbox"/> Yes () No | |
| <input checked="" type="checkbox"/> LOCA | <input checked="" type="checkbox"/> HELB |
| () Other | <input checked="" type="checkbox"/> MSLB |

4. Safety requirements:

- | | |
|--|--|
| <input checked="" type="checkbox"/> Intermittent Operation | <input checked="" type="checkbox"/> During postulated event |
| () Continuous Operation | <input checked="" type="checkbox"/> Following postulated event |

If component operation is required following an event, give approximate length of time component must remain operational.

100 DAYS (e.g., hours, days, etc.)

5. For VALVES:

does the component () Fail open () Fail closed ☒ Fail as is

Is this the fail safe position? ☒ Yes () No (VALVE 2SWP#110V308 IS BACK UP)

Is the valve used for throttling purposes? () Yes ☒ No

What is the maximum acceptable internal and external leakrate?

20 GPM (INTERNAL) - NO EXTERNAL REQUIREMENT



7. List all component analyses performed that demonstrate qualification:

1) ASME CLASS 1 STRESS REPORT ON VALVE BODY

2) COMBINATION DYNAMIC (RESPONSE SPECTRUM) AND STATIC ANALYSIS FOR MAIN ROLLER BEARING LOAD ON MSIV ACTUATOR

3) VALVE BODY - DEPRESSURIZATION STRESS ANALYSIS
CONT'D ATTACHED SHEET:

8. As a result of any of the tests (or analysis), were any deviations from design requirements identified?
(☒) Yes () No If "Yes", briefly describe any changes made in tests (or analyses) or to the component to correct the deviation.

ACTUATOR DYNAMIC TESTING: THE ORIGINAL

ROLLER BEARING FAILED DURING SEISMIC

TESTING. FURTHER INVESTIGATION REVEALED A DESIGN DEFICIENCY. RESOLUTION OF ROLLER BEARING ADEQUACY IS IN PROGRESS.

9. Was the tested component precisely identical (as to model, size, etc.) to the in-plant component? (☒) Yes () No. If "No", is installed component () oversized or () undersized?

10. Is component orientation sensitive? (☒) Yes () No () Unknown If "Yes", does installed orientation coincide with test/analysis orientation? (☒) Yes () No

List all loads and numerical values used during tests or analysis and indicate whether applied individually or in combination:

1) HYDROSTATIC SHELL TEST: PRESSURE = 2900 PSIG

2) HYDROSTATIC CLOSURE: PRESSURE = 1403 PSIG

3) SEAT LEAKAGE (WATER): PRESSURE = 1403 PSIG

4) SEAT LEAKAGE (AIR): PRESSURE = 45 PSIG

5) STEM LEAKAGE: PRESSURE = 1403 PSIG

6) VALVE TORQUE TEST: FULL OPEN TO 10% CLOSED, 1403 PSIG

7) LOCA TEST: TEST TO LOCA ENV'T. (SUBASSEMBLIES HAVE VARYING LEVELS) - IN PROGRESS

8) SEISMIC TEST OF ACTUATOR (RANDOM MULTIFREQUENCY):

SRV RRS PEAK 0.95 → 2.65g, ZPA 0.13 → 33g:

LEVEL B RRS (UPSET) PEAK 2.7 → 5.2g, ZPA 0.32 → 0.56g

LEVEL C/D (EMERGENCY/FAULTED) PEAK 4.6 → 9.0g,

ZPA 0.7 → 1.2g; LOCA PEAK 1.2 → 5.0g

CONT'D ATTACHED SHT:



IV. QUALIFICATION

1. Reference by specific number those applicable sections of the design codes and standards applicable to the component: ASME CLASS 1 7/1/74 AND
ADDENDA THROUGH 12/31/76; NB-3500;
NA-3250
2. Reference those qualification standards, used as a guide to qualify the component: IEEE 382-1972, IEEE 344-1975
IEEE 323-1974; REG. GUIDE 1.48, 1.61,
1.75, 1.92, AND 1.100
3. Have acceptance criteria been established and documented in the test plan(s) for the component?
(☒) Yes () No
4. Are the margins* identified in the qualification documentation? (☒) Yes () No
5. Was the component that was qualified a model or an actual assembly? ASSEMBLY. If a model, what was its scale? _____. If an actual assembly, was it qualified as an assembly or by sub-assemblies? (i.e., valve, actuator, pump, driver) PERFORMANCE TESTS FOR SUBASSEMBLIES QUALIFIED IEEE: LIMIT SWITCH, SOLENOID VALVE, ETC./DYNAMIC TEST FOR SUBASSEMBLY
6. List all component tests performed or to be performed that demonstrate qualification: (ACTUATOR)
VALVE: HYDROSTATIC SHELL TEST
HYDROSTATIC CLOSURE
SEAT LEAKAGE (AIR) & (WATER)
STEM LEAKAGE
VALVE TORQUE TEST
ACTUATOR: SEISMIC/DYNAMIC TESTS - OPERABILITY TESTS
ENVIRONMENTAL LOCA TEST (IN-PROGRESS)
LIFE CYCLE TEST (TO BE PERFORMED)
ROLLER BEARING STATIC LOAD TEST
(TO BE PERFORMED)

* Margin is the difference between design basis parameters and the test parameters used for equipment qualification.



III. FUNCTION

1. Briefly describe components' normal and safety functions (include accident initiating signals.)

Normal: STANDBY: VALVE OPEN TO PERMIT PASSAGE
OF STEAM TURBINE FROM REACTOR

Safety: REACTOR CONTAINMENT ISOLATION DURING ACCIDENT
TRIP SIGNALS (1) MANUAL (2) HIGH STEAM FLOW

(3) LOW LEVEL-VESSEL (4) LOW VACUUM-CONDENSER (5) HIGH RADIATION
IN STEAM TUNNEL (6) LOW STEAM PRESSURE - RUN MODE (7) HIGH
TEMP STEAM TUNNEL (8) HIGH DIFFERENTIAL TEMP - STEAM TUNNEL

2. The components normal state is: ☒ Operating ☐ Standby

3. Safety function:

- | | |
|--|---|
| a. <input type="checkbox"/> Emergency reactor shutdown | b. <input type="checkbox"/> Containment heat removal |
| c. <input checked="" type="checkbox"/> Containment isolation | d. <input type="checkbox"/> Reactor heat removal |
| e. <input type="checkbox"/> Reactor core cooling | f. <input checked="" type="checkbox"/> Prevent significant release of radioactive material to environment |
| g. <input type="checkbox"/> Does the component function to mitigate the consequences of one or more of the following events? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | |
| <input checked="" type="checkbox"/> LOCA <input checked="" type="checkbox"/> HELB <input checked="" type="checkbox"/> MSLB | |
| <input type="checkbox"/> Other _____ | |

4. Safety requirements:

- | | |
|--|--|
| <input type="checkbox"/> Intermittent Operation | <input checked="" type="checkbox"/> During postulated event |
| <input checked="" type="checkbox"/> Continuous Operation
(AVAILABLE FOR OPERATION AT ALL TIMES) | <input checked="" type="checkbox"/> Following postulated event |

If component operation is required following an event, give approximate length of time component must remain operational.
6 HRS (e.g., hours, days, etc.)

5. For VALVES:

does the component ☐ Fail open ☒ Fail closed ☐ Fail as is

Is this the fail safe position? ☒ Yes ☐ No

Is the valve used for throttling purposes? ☐ Yes ☒ No

What is the maximum acceptable internal and external leakrate?

INTERNAL 4.42 SCFH NO EXTERNAL
(PER MSS SP61)



6. General Valve Data

a. Valve

Name MAIN STEAM ISOLATION VALVE

Mfg. CROSBY VALVE AND GAGE CO.

Model BALL VALVE

S/N 6427

Type DOUBLE TRUNION BALL VALVE

Size 24"

Weight 12,900 LBS

Mounting

Method WELDED IN LINE

Max. Required

Torque 150,000 IN-LBS.

Parameter	Component Design	System Normal/Accident
-----------	------------------	------------------------

Press(PSIG)	<u>1375</u>	<u>964 / 1015</u>
-------------	-------------	-------------------

Temp (°F)	<u>586</u>	<u>540 / 550</u>
-----------	------------	------------------

Flow (LBS/Hr)	<u>4.25x10⁶</u>	<u>3.57x10⁶ / 7.08x10⁶</u>
---------------	----------------------------	--

Media	<u>STEAM</u>	<u>STEAM / STEAM</u>
-------	--------------	----------------------

Max P across valve 1250

Closing time @ max P 3-5 SEC.

Opening time @ max P 5-7 MIN.

List functional accessories:*

b. Actuator (if not an integral unit)

Name MAIN STEAM ISOLATION VALVE

Mfg. CROSBY VALVE AND GAGE CO.

Model SERIES 600

S/N 5

Type STORED ENERGY (SPRING)

Size L=1007/8", HT=73", ~W=50"

Weight 12,500 lbs

Mounting

Method BOLTED TO VALVE (ON TOP)

Max. Delivered

Torque 1,054,560 IN-LBS

Power Requirements: (include normal, maximum and minimum).

Electrical 575/3/60

Other: () Pneumatic () Hydraulic

HYDRAULIC TO OPEN / SPRING TO CLOSE

* Functional accessories are those sub-components not supplied by the manufacturer that are required to make the valve assembly operational, (e.g., limit switches, solenoid valves, accumulators, etc.)



a. Pump (Continued) N/A

b. Prime-mover (Continued)

Overall Dimensions _____

Overall Dimensions _____

Weight _____

Weight _____

Mounting Method _____

Mounting Method _____

Required B.H.P. _____

H.P. _____

Parameter	Component Design	System Normal/Accident
-----------	------------------	------------------------

Prime Mover Requirements: (include normal, maximum and minimum)

Press	_____	_____/_____
-------	-------	-------------

Motor(Voltage) _____

Temp	_____	_____/_____
------	-------	-------------

Flow	_____	_____/_____
------	-------	-------------

Head	_____	_____/_____
------	-------	-------------

Turbine (pressure) _____

Media	_____	_____/_____
-------	-------	-------------

Required NPSH at maximum

If MOTOR list:

flow _____

Duty cycle _____

Available NPSH _____

Stall current _____

Operating Speed _____

Class of insulation _____

Critical Speed _____

List functional accessories: * _____

* Functional accessories are those sub-components not supplied by the manufacturer that are required to make the pump assembly operational, (e.g., coupling, lubricating oil system, speed control sys., feedback, etc.)



PUMP AND VALVE
OPERABILITY ASSURANCE REVIEW

1. PLANT INFORMATION

1. Name: Nine Mile Point Unit No. 2 2. Docket No.: 50-410
3. Utility: Niagara Mohawk Power Corporation
4. NSSS: General Electric Co. () PWR (X) BWR
5. A/E: Stone & Webster Engineering Corporation
6. C.P. and/or O. L. SER date 6/24/74

II. GENERAL COMPONENT* INFORMATION

1. Supplier: () NSSS (X) BOP
2. Location: a. Building/Room PRIMARY CONTAINMENT
b. Elevation 251'
c. System MAIN STEAM
3. Component I.D. No. on P&ID dwg. 2MSS*HYV6A
4. If component is a () Pump complete II.5.
If component is a (X) Valve complete II.6.
5. General Pump Data N/A
a. Pump b. Prime-mover
Name _____ Name _____
Mfg. _____ Mfg. _____
Model _____ Model _____
S/N _____ S/N _____
Type _____ Type _____

* The component, whether pump or valve, is considered to be an assembly composed of the body, internals, prime-mover (or actuator) and functional accessories.



BOP #9 PVORT

SPEC. NO. P303D

PVORT #9

NINE MILE POINT NUCLEAR STATION UNIT 2

EQUIPMENT DYNAMIC QUALIFICATION

COMPONENT NAME: MAIN STEAM ISOLATION VALVE

MARK NUMBERS: 2MSS*HYV6A



STONE & WEBSTER



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
ED. GENEVA	ELECTRICAL TEST PROCEDURE	—	SWEC	SWEC
—	IOM. J. VENTRE TO M. FACHADA LIMITORQUE BOLT TORQUES AND GAP ADJUSTMENT	5/30/85	SWEC	SWEC



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
FSK-9 -10AC	SWP FLOW DIA. Rev 7	11/19/84	SWEC	SWEC
PID -11H	SWP P & ID Rev 1	7/31/84	SWEC	SWEC
C03370	E&DCR: Access To LIMITORQUE	4/18/85	SWEC	SWEC
P01,321	E&DCR: DELETE MANUFACTURING PLAN	8/3/82	SWEC	SWEC
P02,261	E&DCR: ENVIRON- MENTAL CONDITIONS	7/5/84	SWEC	SWEC
P50,286	E&DCR: SHIPPING RELEASE	11/3/81	SWEC	SWEC
P50,292	E&DCR: HANDWHEEL RETAINING NUT	4/6/82	SWEC	SWEC
P50,621	E&DCR: PROTOTYPE TEST DATA	1/11/84	SWEC	SWEC
P50,829	E&DCR: EXCLUDED EQUIPMENT LIST	11/2/84	SWEC	SWEC
L02G	N&D: SANDBLAST & PAINT	7/1/82	SWEC	SWEC
C02826	E&DCR: ELECTRICAL GROUND	8/15/84	SWEC	SWEC
C52,652	E&DCR: USE OF STUDBOLTS	4/30/84	SWEC	SWEC
P01,828	E&DCR: PQA DOCUMENTATION	9/2/83	SWEC	SWEC
G-046	N&D: PQA INSPECTION	3/22/82	SWEC	SWEC



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
P121A	SPECIFICATION FOR ROTARY GATE VALVES, REV. 1 ADDENDA 1-3	3/2/79	SWEC	SWEC
—	RECTANGULAR BUTTERFLY VALVE-SEISMIC ANALYSIS	8/20/80	HENRY PRATT CO.	SWEC
—	RESPONSE TO SEISMIC ANALYSIS REVIEW	11/19/80	HENRY. PRATT CO.	SWEC
IEEE 05.360-5015A	LIMITORQUE VALVE ACTUATOR QUALIFICATION REPT. B0058	6/18/85	LIMITORQUE CORP	SWEC
5.360-171-155 RVC	GEN. ARRGMT. C-6491-3 M.O. ROTARY GATES	10/1/81	HENRY PRATT CR	SWEC
INST 5.360-5026	INSTALLATION & SERVICE MANUAL: HPCO 3.0 D-22467	5/20/82	HENRY PRATT CO.	SWEC
A&T 8 Rev 1 Add 2	ASSEMBLY, TEST AND ACCEPTANCE PROC.	8/23/79	HENRY PRATT CO.	SWEC
—	MOTOR OPERATOR TORQUE TEST PLAN	—	HENRY PRATT CO.	SWEC
	LIMITORQUE TEST DATA, D-22467	6/29/82	LIMITORQUE CORP	SWEC
EM-8E Rev 10	MACHINERY LOCATION DWG.	11/19/84	SWEC	SWEC



11. Does the component have a unique design or utilize unique materials in its construction? (Examples are special gaskets or packings, one of a kind components, limitations on nonferrous materials, special coatings or surfaces, etc.)

() Yes () No If "Yes" identify: _____

N/A

12. What is the design (qualified) life of the component, exclusive of normal maintenance items such as packings, bearings, seals, diaphragms, gaskets, and other elastomers?

40 YRS

13. Which of the components normal maintenance items requires the most frequent replacement? N/A

What is the normal time interval between replacements of this item?

N/A

14. What is the harshest (accident/post-accident) external environment that the component could be exposed to during its qualified life? (e.g., temp., press., humidity, submergence, radiation type and dose, etc.)

MILD ENVIRONMENT

TEMP: 104 °F

PRESS: ATMOS.

1 RH: 20-70%

RADIATION: $<1 \times 10^4$ RADS GAMMA



(CONT'D)

10.

SEAT & STEM LEAKAGE : 20 PSI, 5 MINS

3 CYCLES OPEN & CLOSE, 56 SECS; (60 SECS. SPECIFIED)

OPERATOR LOCKED ROTOR : 12.5 A (1.8 A NO LOAD)

(CLOSE) STALL TORQUE AT 110% VOLTAGE : 23,800 ft. lbs (25,600 LIMIT)

(OPEN) " " " " " : 17,600 ft. lbs (")



7. List all component analyses performed that demonstrate qualification:

"RECTANGULAR BUTTERFLY VALVE - SEISMIC ANALYSIS", 8/20/80, HENRY PRATT; "RESPONSE TO SEISMIC ANALYSIS REVIEW", 11/19/80, HENRY PRATT;

8. As a result of any of the tests (or analysis), were any deviations from design requirements identified?
☒ Yes () No If "Yes", briefly describe any changes made in tests (or analyses) or to the component to correct the deviation.

DUE TO LIMITORQUE ACTUATOR TESTING, LIMIT SWITCH SCREWS & BOLT TORQUES TO BE ADJUSTED & LIMIT SWITCH FINGER ASSEMBLY GAPS TO BE ADJUSTED

9. Was the tested component precisely identical (as to model, size, etc.) to the in-plant component? ☒ Yes - with one exception - see footnote *
() No. If "No", is installed component () oversized or exception -
() undersized?

10. Is component orientation sensitive? ☒ Yes () No
() Unknown If "Yes", does installed orientation coincide with test/analysis orientation? ☒ Yes
() No

List all loads and numerical values used during tests or analysis and indicate whether applied individually or in combination:

VALVE ANALYSIS: SEISMIC ACCEL. LEVELS OF 0.41g
IN BOTH HOR. AXES, 0.24g VERT + 1g GRAVITY, IN
COMBINATION WITH DESIGN PRESSURE - 20 psi
AND MAX. OPERATING TORQUE - 201,660 in. lbs.
OPERATOR TEST: 7.9-8.4g. SINE DWELL INPUT AT
33 HZ FOR 30 SEC. EACH AXIS.
(CONT)

* Seismic fragility test of valve operator was for Model SMB-1-25/H4BC. Referenced Limitorque report justifies similarity of parent unit to plant equipment operator (SMB-0-15/H4BC)



IV. QUALIFICATION

1. Reference by specific number those applicable sections of the design codes and standards applicable to the component: ANSI B31.1-77 (sect. 12.3); AWWA C504, 1974 (sect. 9, 12)
AWS D1.1 Rev. 2 - 1977 (VISUAL INSPECTION SECT.)

2. Reference those qualification standards, used as a guide to qualify the component: IEEE 323-1974; IEEE
344-1975; IEEE 382-1972.
RG's 1.48/1.61/1.89/1.100

3. Have acceptance criteria been established and documented in the test plan(s) for the component?
☒ Yes () No
4. Are the margins* identified in the qualification documentation? ☒ Yes () No
5. Was the component that was qualified a model or an actual assembly? ASSEMBLY. If a model, what was its scale? N/A. If an actual assembly, was it qualified as an assembly or by sub-assemblies? (i.e., valve, actuator, pump, driver) ASSEMBLY FOR SHOP TESTS; SUB-ASSEMBLY FOR OPERATOR
6. List all component tests performed or to be performed that demonstrate qualification:
OPERATOR - RESONANCE SEARCH/FRAGILITY TEST
ASSEMBLY - LEAKAGE, OPEN/CLOSE TESTS
MOTOR - LOCKED ROTOR, DIELECTRIC TESTS
OPERATOR - TORQUE AT MAX/MIN VOLTAGE, STALLED
TORQUE TEST.

* Margin is the difference between design basis parameters and the test parameters used for equipment qualification.



IV. QUALIFICATION

7. ANALYSES (CONT'D):

6A
9p

5) ACTUATOR ANALYSES:

- a) ACTUATOR BLOCKING LEVER STRESS ANALYSIS
- b) ACTUATOR FATIGUE ANALYSIS (DYNAMIC)
- c) ACTUATOR DYNAMIC ANALYSIS (FREQUENCY/MODES)
- d) TRIP SOLENOID SUPPORT: FREQUENCY (DYNAMIC) ; STRESS ANALYSIS (STATIC LOAD)
- e) TOP PINOT ACTUATOR DESIGN REPORT (EQUIVALENT STATIC ANALYSIS)
- f) THRUST TRACK BUCKLING ANALYSIS (STATIC LOAD)
- g) STATIC ANALYSIS - PIPING (HYDRAULIC SYSTEM)



IV. QUALIFICATION

10. CONTINUED

9) CLASS 1 STRESS REPORT: DESIGN

PRESSURE 1375 PSI, OPERATING PRESSURE

1050 PSI, MAX. DIFFERENTIAL PRESSURE 1220 PSI,

DESIGN TEMP. 586°F

TEMP. RANGE 65°F TO 568°F, SEISMIC

LOAD 4.5g + 1.0g DWT

10) STRESS ANALYSIS DEPRESSURIZATION

VALVE BODY, PHASE I: PRESS. 50 PSIA,

TEMP. 500°F / PHASE II: PRESS. (OUTSIDE)

14.7 PSIA, PRESS. (INSIDE) 13.8 PSIA

11) ACTUATOR ANALYSES:

a) BLOCKING LEVER STRESS ANALYSIS

FORCE = 1328.5 lb

b) TRIP SOLENOID VALVE STRESS ANALYSIS

SEISMIC/HYDRO. LD. = 4.5g + DWT

c) TOP PINOT ACTUATOR ANALYSIS

SUPPORTED LD. 100,050 lbs

DYNAMIC LD. FACTOR = 1.15, EQUIVALENT

STATIC LD. = 116,000 lbs

d) ROLLER BEARING DYNAMIC PORTION

OF ANALYSIS RRS ZPA = 1.1g



11. Does the component have a unique design or utilize unique materials in its construction? (Examples are special gaskets or packings, one of a kind components, limitations on nonferrous materials, special coatings or surfaces, etc.)

(☒) Yes () No If "Yes" identify: ACTUATOR IS
A ONE OF A KIND COMPONENT

12. What is the design (qualified) life of the component, exclusive of normal maintenance items such as packings, bearings, seals, diaphragms, gaskets, and other elastomers?

40 YEARS (IN PROGRESS)

13. Which of the components normal maintenance items requires the most frequent replacement?

"O" RINGS What is the normal
time interval between replacements of this item?

5 YEARS

14. What is the harshest (accident/post-accident) external environment that the component could be exposed to during its qualified life? (e.g., temp., press., humidity, submergence, radiation type and dose, etc.).

TEMP. 340°F

PRESSURE 45 PSIG

REL. HUMIDITY ALL STEAM

RADIATION 5.0 E7 RADS GAMMA (40 YRS.+ACCIDENT)

6.3 E8 RADS BETA (40 YRS.+ACCIDENT)



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
CALC. 83-01	MSIV SPECIAL CONDITIONS - DEPRESSURIZATION	2-7-83	G+W FLUID SYSTEMS	SWEC (STRS 05.360-5003A)
ER-81-28 REV. 0	MSIV ACTUATOR DYN. ANAL. MODE / FREQ.	10-29-81	G+W FLUID SYSTEMS	SWEC
ER-81-33 REV. 1 REV. 3	FREQ. STRESS ANAL. TRIP SOLENOID	12-29-81 7-26-82	G+W FLUID SYSTEMS	SWEC (STRS 05.360-5001A)
EC-1068	DESIGN REPORT TOP PIVOT ACTUATOR	5-29-84	G+W FLUID SYSTEMS	SWEC (STRS 05.360-5016A)
EH-3166N	THRUST TRACK CALC.	3-1-84	G+W FLUID SYSTEMS	SWEC (STRS 05.360-5007A)
CALC. 83-06	CALC. OF SOLENOID VALVE VS. PIPE	3-1-84	G+W FLUID SYSTEMS	SWEC (MISC 05.360-5006A)
22A2887 4L	NUCLEAR BOILER SYSTEM	6-18-84	GE - NEG	GE-NEG



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
DWG. A-1789 REV. A	IDENT. TAG STAMPING	3-25-79	G+W FLUID SYSTEMS	SWEC (DWG. 0005.360-180-123B)
DWG. E24.900- 14 REV. J	24" 900# MSIN EFCO 600 ACTUATOR	4-14-83 (APP. SWEC)	EPG FLUID SYSTEMS	SWEC (DWG. 0005.360-180-172J)
DWG. D-123435 REV. B	24" 900# MSIN BODY CROSS SECTION	12-4-80	EPG FLUID SYSTEMS	SWEC (DWG. 0005.360-180-024C)
12177- FSK-3-1A REV. 12	FLOW DIAGRAM MAIN STEAM	3-28-85	SWEC	SWEC
12177- EP-2A-11 REV. 10	MAIN STEAM PIPING REACTOR BLDG.	10-6-82	SWEC	SWEC
12177- EP-2B-9 REV. 8	MAIN STEAM PIPING REACTOR BLDG.	8-30-82	SWEC	SWEC
FIG. FSAR 10.1-3.0	P&ID MAIN STEAM SYSTEM	(NO DATE SHOWN)	SWEC	SWEC
SPEC NMP2- P303D REV. 1 FEIDCR PI2,333	MAIN STEAM ISOLATION VALVES	11-17-82 6-1-83	SWEC	SWEC



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
P.T.R. 2538-1	PERFORMANCE TEST REPORT	12-30-80	G+W FLUID SYSTEMS DIVISION	SWEC
46912-2	WYLE SEISMIC SIMULATION TEST REPORT	11-14-83	WYLE LABORATORIES FOR G+W FLUID SYSTEMS	G+W FLUID SYSTEMS / SWEC (TRS 05.360-5013A)
ER-81-3 REV. 1	ASME CLASS 1 STRESS REPORT (INCLUDING AMENDMENT)	2-23-81	G+W - FLUID SYSTEMS	SWEC STRESS RPT. #12177-N -SR-823-0
MEQ-P303D REV. 1	MEQ QUAL. REPORT	3-27-85	SWEC	SWEC
12177-NM(C)-MS-1956 REV. 0	ESTIMATION OF ROLLER BEARING LOAD FOR MSIV ACTUATOR	IN-PROCESS	SWEC	SWEC
CALC 81-27 REV. 1	BLOCKING LEVER STRESS ANALYSIS	3-30-82	G+W FLUID SYSTEMS	SWEC
CALC. 81-21 REV. 2	ACTUATOR FATIGUE ANALYSIS	4-16-82	G+W FLUID SYSTEMS	SWEC
G+W FSD 11798N	DYNAMIC EVALUATION TESTS OF AN EFCO 600 ACTUATOR	SEPT. '79	G+W FLUID SYSTEMS	SWEC



10P

SPEC. NO. P303W

PORT #10

NINE MILE POINT NUCLEAR STATION UNIT 2

EQUIPMENT DYNAMIC QUALIFICATION

COMPONENT NAME: SWING CHECK VALVE

MARK NUMBERS: 2RHS * AOV 16A



STONE & WEBSTER



PUMP AND VALVE

OPERABILITY ASSURANCE REVIEW

1. PLANT INFORMATION

1. Name: Nine Mile Point Unit No. 2 2. Docket No.: 50-410
3. Utility: Niagara Mohawk Power Corporation
4. NSSS: General Electric Co. () PWR (X) BWR
5. A/E: Stone & Webster Engineering Corporation
6. C.P. and/or O. L. SER date 6/24/74

II. GENERAL COMPONENT* INFORMATION

1. Supplier: () NSSS ☒ BOP
2. Location:
 - a. Building/Room PRIMARY CONTAINMENT
 - b. Elevation 316'
 - c. System RESIDUAL HEAT REMOVAL - RHS
3. Component I.D. No. on P&ID dwg. 2RHS * AOV 16A

4. If component is a () Pump complete II.5.

If component is a ☒ Valve complete II.6.

5. General Pump Data N/A

a. Pump	b. Prime-mover
Name _____	Name _____
Mfg. _____	Mfg. _____
Model _____	Model _____
S/N _____	S/N _____
Type _____	Type _____

* The component, whether pump or valve, is considered to be an assembly composed of the body, internals, prime-mover (or actuator) and functional accessories.

a. Pump (Continued)

Overall Dimensions _____

Weight _____

Mounting Method _____

Required B.H.P. _____

Parameter	Component Design	System Normal/Accident
-----------	------------------	------------------------

Press	_____	_____/_____/_____
-------	-------	-------------------

Temp	_____	_____/_____/_____
------	-------	-------------------

Flow	_____	_____/_____/_____
------	-------	-------------------

Head	_____	_____/_____/_____
------	-------	-------------------

Media	_____	_____/_____/_____
-------	-------	-------------------

Required NPSH at maximum

flow _____

Available NPSH _____

Operating Speed _____

Critical Speed _____

List functional accessories: * _____

b. Prime-mover (Continued)

Overall Dimensions _____

Weight _____

Mounting Method _____

H.P. _____

Prime Mover Requirements: (include normal, maximum and minimum)

Motor(Voltage) _____

Turbine (pressure) _____

If MOTOR list:

Duty cycle _____

Stall current _____

Class of insulation _____

* Functional accessories are those sub-components not supplied by the manufacturer that are required to make the pump assembly operational, (e.g., coupling, lubricating oil system, speed control sys., feedback, etc.)



6. General Valve Data

a. Valve

Name 2RHS * AOV 16A
Mfg. ANCHOR DARLING
Model 4412-3
S/N G308-13
Type TESTABLE SWING CHECK VALVE
Size 12 in.
Weight 1470 lb.
Mounting Method BUTT WELD ENDS
Max. Required Torque N/A

b. Actuator (if not an integral unit)

Name _____
Mfg. _____
Model _____
S/N _____
Type _____
Size _____
Weight _____
Mounting Method _____
Max. Delivered Torque _____

Parameter	Component Design	System Normal/Accident
Press, psig	<u>1250</u>	<u>1000 / 1350**</u>
Temp, °F	<u>575</u>	<u>552 / 575</u>
Flow, gpm	<u>8400</u>	<u>0 / 7450</u>
Media	<u>WATER</u>	<u>WATER / WATER</u>
Max P across valve	<u>1350 psig</u>	<u>**</u>
Closing time @ max P	<u>N/A</u>	
Opening time @ max P	<u>N/A</u>	

Power Requirements: (include normal, maximum and minimum).

Electrical 120 VAC ± 10%

Other: ☒ Pneumatic () Hydraulic

90-120 psig

List functional accessories:*

ASCO SOLENOID VALVE, MODEL HKX8220AB9V
NAMCO LIMIT SWITCH, MODEL EA180

* Functional accessories are those sub-components not supplied by the manufacturer that are required to make the valve assembly operational, (e.g., limit switches, solenoid valves, accumulators, etc.)

** Valve presently being revised to 1500 psi Accident and differential pressure



III. FUNCTION

1. Briefly describe components' normal and safety functions (include accident initiating signals.)

Normal: CONTAINMENT ISOLATION, PREVENTS BACKFLOW FROM RPV TO RHR SYSTEM

Safety: CONTAINMENT ISOLATION & INJECTION FLOWPATH

2. The components normal state is: () Operating ☒ Standby

3. Safety function:

- a. () Emergency reactor shutdown b. () Containment heat removal
c. ☒ Containment isolation d. () Reactor heat removal
e. () Reactor core cooling f. () Prevent significant release of radioactive material to environment
g. () Does the component function to mitigate the consequences of one or more of the following events? ☒ Yes () No
☒ LOCA ☒ HELB ☒ MSLB
() Other _____

4. Safety requirements:

- () Intermittent Operation ☒ During postulated event
☒ Continuous Operation ☒ Following postulated event

If component operation is required following an event, give approximate length of time component must remain operational.
100 DAYS (e.g., hours, days, etc.)

5. For VALVES:

does the component () Fail open () Fail closed () Fail as is N/A

Is this the fail safe position? () Yes () No N/A (CHECK VALVE)

Is the valve used for throttling purposes? () Yes ☒ No

What is the maximum acceptable internal and external leakrate?

1.2 SCFH AIR AT 45 PSIG ΔP (INTERNAL)

NONE (EXTERNAL)



IV.

QUALIFICATION

1. Reference by specific number those applicable sections of the design codes and standards applicable to the component: ASME B&PV CODE, SECTION III, DIV. 1, 1977;

SECT. NB; CODE CASE N-181.

MSS. SP-61, 1961

2. Reference those qualification standards, used as a guide to qualify the component: IEEE 323-1974

IEEE 382-1972; IEEE 344-1975

REQ. GUIDE 1.4E/1.61/1.83/1.100/1.82/1.35

3. Have acceptance criteria been established and documented in the test plan(s) for the component?

☒ Yes () No

4. Are the margins* identified in the qualification documentation? ☒ Yes () No

5. Was the component that was qualified a model or an actual assembly? ASSEMBLY. If a model, what was its scale? N/A. If an actual assembly, was it qualified as an assembly or by sub-assemblies? (i.e., valve, actuator, pump, driver) ASSEMBLY (S-OP TESTS). SUB-ASSEMBLY FOR ASCO SOLENOID VALVE AND NAMCO LIMIT SWITCH

6. List all component tests performed or to be performed that demonstrate qualification:

HYDROSTATIC SHELL & SEAT TESTS

PNEUMATIC SEAT LEAKAGE TESTS

PERFORMANCE TESTS - ASSEMBLY

RADIATION AND THERMAL AGING, LOCK TESTS

* Margin is the difference between design basis parameters and the test parameters used for equipment qualification.



7. List all component analyses performed that demonstrate qualification:
- ASCO SOV. - QUALIFIED LIFE AND ACCIDENT LEVELS
 - NAMCO LIMIT SWITCH - CALC. OF TOTAL INTEGRATED DOSE
 - NAMCO " " - EXTENSION OF POST-ACCIDENT OPERABILITY PERIOD • ASME CODE - STRESS/SEISMIC REPORT & SUPPLEMENTARY CALC. FOR HYDRODYNAMIC LOADS
 - NAMCO LIMIT SWITCH - SUPPLEMENTARY CALC. FOR DYNAMIC QUAL. OF NAMCO LIMIT SWITCH, MODEL EA100 & ER740
 - ASCO SOV. - SUPPLEMENTARY CALC. FOR DYNAMIC QUAL. OF ASCO SOLENOID VALVES
8. As a result of any of the tests (or analysis), were any deviations from design requirements identified?
 () Yes ☒ No If "Yes", briefly describe any changes made in tests (or analyses) or to the component to correct the deviation.

9. Was the tested component precisely identical (as to model, size, etc.) to the in-plant component? ☒ Yes
 () No. If "No", is installed component () oversized or () undersized?

10. Is component orientation sensitive? ☒ Yes () No
 () Unknown If "Yes", does installed orientation coincide with test/analysis orientation? ☒ Yes
 () No

List all loads and numerical values used during tests or analysis and indicate whether applied individually or in combination:

SHOP
TEST

HYDRO SHELL TEST - 3375 PSIG

DISC & SEAT LEAKAGE TEST - 2250 PSIG

PNEUMATIC SEAT LEAKAGE TEST - 45 PSIG

EMPIRICAL
METAL
TESTS

TEMP: 150°F - NORMAL ; 448°F - ACCIDENT

PRESS: ATMOS. NORMAL ; 68 PSIG - ACCIDENT

R.H.: 100% NORMAL ; STEAM - ACCIDENT

RADIATION: 2.05×10^8 RADS GR/MIN

APPLIED IN
COMBINATION

APPLIED
INDIVIDUALLY

DYNAMIC LOAD
ANALYSIS
DYNAMIC TEST
(LIMIT SW. & SOV.)

SSE - 3g IN THREE DIRECTIONS, COMBINED WITH NORMAL OPERATING LOADS

OBE + SRV + NORMAL OPERATING LOADS - 6g, 6000 cycles.



11. Does the component have a unique design or utilize unique materials in its construction? (Examples are special gaskets or packings, one of a kind components, limitations on nonferrous materials, special coatings or surfaces, etc.)

() Yes ~~No~~ If "Yes" identify: _____

12. What is the design (qualified) life of the component, exclusive of normal maintenance items such as packings, bearings, seals, diaphragms, gaskets, and other elastomers?

9.1 YRS ASCO SOLENOID VALVE

QUAL. IN PROGRESS FOR SELF-LUBE BEARINGS ON VALVE INDICATOR SHAFT

13. Which of the components normal maintenance items requires the most frequent replacement? EPDM

GASKET - ASCO VALVE What is the normal time interval between replacements of this item?

UPON DISASSEMBLY OR AS REQUIRED

14. What is the harshest (accident/post-accident) external environment that the component could be exposed to during its qualified life? (e.g., temp., press., humidity, submergence, radiation type and dose, etc.)

TEMP: 135°F (AVERAGE) NORMAL; 340°F ACCIDENT

PRESS: 0.5-1.0 PSIG-NORMAL; 45 PSIG ACC.

RH: 90% NORMAL; 100% ACCIDENT

RADIATION. 1.24 X 10⁸ RADS - COMBINED RADIATION

FOR GAMMA, BETA AND NEUTRON FOR 40 YRS

PLUS ACCIDENT (INCLUDES BETA REDUCTION AND NEUTRON CONVERSION)



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
P303W	SPECIFICATION FOR SPECIAL CHECK VALVES ASME III, Classes 1 and 2. Rev 1, and Addenda 1,2,3	4/22/80 thru 6/15/83	SWEC	SWEC
P02387	E&DCR -EXCLUDED EQMT.	9/27/84	SWEC	SWEC
P02447A	E&DCR - ENVIRON. QUAL. REQMTS	3/28/85	SWEC	SWEC
P02552	E&DCR - PRESS. RETAINING PARTS	2/13/85	SWEC	SWEC
P12,794	E&DCR - ADDITION OF NEW VALVE	3/30/85	SWEC	SWEC
P13,267	E&DCR - INCORRECT VALVE MK. NO	2/12/85	SWEC	SWEC
Z099	N&D: NONCOM- PLIANCE WITH ASME	8/7/84	SWEC	SWEC
Z100	N&D: NONCOM- PLIANCE WITH ASME	8/13/84	SWEC	SWEC
Z066	N&D: DESSICANT APPROVAL	7/8/81	SWEC	SWEC
1G-5891	N&D: ARC STRIKE	1/14/85	SWEC	SWEC
10,351	N&D: INCORRECT MK. No. DOCUMENTATION	11/19/84	SWEC	SWEC
IEEE 5.320 -5001A	QUALIFICATION REPT. QTR-105 Pvd. (NAMCO LIMIT SW.)	1/9/84	NAMCO	SWEC



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
-	QA PACKAGE -SHOP TESTS	-	VARIOUS	SWEC
P02,618A	EDCR-HYDRODYNAMIC LOADS	6/18/85	SWEC	SWEC
MS-1904	SUPP. CALC - DYNAMIC QUAL. OF ASCO SOV'S	6/17/85	SWEC	SWEC
MS-1903	SUPP. CALC - DYNAMIC QUAL. OF NAMCO LIMIT SWITCHES	6/17/85	SWEC	SWEC
IEEE 05.320 -5000B	ENVIRONMENTAL QUAL. OF ASCO SOV'S	6/20/85	ASCO/SWEC	SWEC
12177 EQS-016	ASCO SOV-QUAL. LIFE & ACCIDENT LEVELS	5/1/85	SWEC	SWEC
12177 EQS-021	CALC. OF T.I.D. FOR NAMCO LIMIT SWITCH	6/26/85	SWEC	SWEC
12177 EQS-022	EXTENSION OF POST-ACCIDENT OPERABILITY PERIOD FROM 30 TO 100 DAYS + MARGIN - NAMCO LIMIT SW.	6/26/85	SWEC	SWEC
V-5970	ASCO INSTALLATION AND MAINTENANCE INSTRUCTION FORM	-	ASCO	SWEC
MEQ-P303W	MECH. EQUIPMENT ENVIRON. QUAL. Rev1	3/27/85	SWEC	SWEC



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
INST. S.320 -5009A	INSTRUCTION AND MAINTENANCE MAN. REPT. 2242.1	12/20/79	ANCHOR DARLING	SWEC
-	PERFORMANCE TEST PROCEDURE REPT. 2160.1 Rev C	8/14/79	ANCHOR DARLING	SWEC
5.360-170-232A	VALVE DWG. BILL OF MATL, 4412-3 SH.1	5/14/81	ANCHOR DARLING	SWEC
5.360-170-233A	VALVE DWG.	5/14/81	ANCHOR DARLING	SWEC
-	DESIGN & SEISMIC REPORT-LAB 79.195 12177-N-SR821-0	11/24/80	ANAMET LABS FOR ANCHOR DARLING	SWEC
EQEDC -1	EQUIPMENT QUAL. ENVIRONMENTAL DESIGN CRITERIA	5/2/84	SWEC	SWEC
EP-71K Rev II	RHS PIPING DWG -REACTOR BLDG	10/31/84	SWEC	SWEC
FSK 27-7A	RHS - FLOW DIA.	10/31/84	SWEC	SWEC
5.4-13	RHS - Pd ID SH. 2 OF 2	-	GE	SWEC
MS-1884 Rev. 2	SUPPLEMENTARY CALC - SEISMIC & HYDRO DYNAMIC SUMMARY - SPEC P303W	6/18/85	SWEC	SWEC
-	OWNERS CERTIFICATION STRESS REPT. 12177-N-SR-821-0	11/24/80	SWEC	SWEC



11P

SPEC. NO. P304A

PVORT #11

NINE MILE POINT NUCLEAR STATION UNIT 2

EQUIPMENT DYNAMIC QUALIFICATION

COMPONENT NAME: BALL VALVE

MARK NUMBERS: 2SWP*MOVIA



STONE & WEBSTER



PUMP AND VALVE

OPERABILITY ASSURANCE REVIEW

1. PLANT INFORMATION

1. Name: Nine Mile Point Unit No. 2 2. Docket No.: 50-410
3. Utility: Niagara Mohawk Power Corporation
4. NSSS: General Electric Co. () PWR (X) BWR
5. A/E: Stone & Webster Engineering Corporation
6. C.P. and/or O. L. SER date 6/24/74

II. GENERAL COMPONENT* INFORMATION

1. Supplier: () NSSS ☒ BOP
2. Location: a. Building/Room SCREENWELL
b. Elevation 257'
c. System SERVICE WATER
3. Component I.D. No. on P&ID dwg. 2SWP* MOVIA
4. If component is a () Pump complete II.5.
If component is a ☒ Valve complete II.6.
5. General Pump Data N/A
a. Pump b. Prime-mover
Name _____ Name _____
Mfg. _____ Mfg. _____
Model _____ Model _____
S/N _____ S/N _____
Type _____ Type _____

* The component, whether pump or valve, is considered to be an assembly composed of the body, internals, prime-mover (or actuator) and functional accessories.



a. Pump (Continued)

Overall
Dimensions _____

Weight _____

Mounting
Method _____

Required B.H.P. _____

Parameter	Component Design	System Normal/Accident
-----------	---------------------	---------------------------

Press	_____	_____/____
-------	-------	------------

Temp	_____	_____/____
------	-------	------------

Flow	_____	_____/____
------	-------	------------

Head	_____	_____/____
------	-------	------------

Media	_____	_____/____
-------	-------	------------

Required NPSH at maximum

flow _____

Available NPSH _____

Operating Speed _____

Critical Speed _____

List functional accessories:*

b. Prime-mover (Continued)

Overall
Dimensions _____

Weight _____

Mounting
Method _____

H.P. _____

Prime Mover Requirements: (include
normal, maximum and minimum)

Motor (Voltage) _____

Turbine (pressure) _____

If MOTOR list:

Duty cycle _____

Stall current _____

Class of insulation _____

* Functional accessories are those sub-components not supplied by the manufacturer that are required to make the pump assembly operational, (e.g., coupling, lubricating oil system, speed control sys., feedback, etc.)



6. General Valve Data

a. Valve

Name 4 in. TOP ENTRY BALL VALVE

Mfg. CONTROMATICS

Model U-2533-BC

S/N 86397-17-1

Type BALL VALVE - ^{ASME} U.3

Size 4"

Weight 150 lbs.

Mounting Method BUTT WELD

Max. Required Torque 276 FT. LBS

Parameter	Component Design	System Normal/Accident
-----------	------------------	------------------------

Press, psig	<u>150</u>	<u>65 / 90</u>
-------------	------------	----------------

Temp, °F	<u>130</u>	<u>32-77 / 32-77</u>
----------	------------	----------------------

Flow, gpm	<u>500</u>	<u>400 / 400</u>
-----------	------------	------------------

Media	<u>WATER</u>	<u>WATER / WATER</u>
-------	--------------	----------------------

Max P across valve 100 psig

Closing time @ max P **

Opening time @ max P **

List functional accessories:*

b. Actuator (if not an integral unit)

Name ACTUATOR

Mfg. LIMITORQUE

Model SMB-000-2/HIBC

S/N 340735-340741

Type ELECTRO-MECHANICAL

Size SMB-00

Weight 405 lb (INCLUDES MTG. BRACKET)

Mounting Method BOLTED TO VALVE

Max. Delivered Torque 2,288 FT. LBS

Power Requirements: (include normal, maximum and minimum).

Electrical 575V/3PH/60HZ.

Other: ()Pneumatic ()Hydraulic

* Functional accessories are those sub-components not supplied by the manufacturer that are required to make the valve assembly operational, (e.g., limit switches, solenoid valves, accumulators, etc.)

** CONTROMATICS TO RETROFIT ACTUATOR & VALVE STEM DUE TO SPEC. VIOLATION OF MAX. ACTUATOR TORQUE OUTPUT.



III. FUNCTION

1. Briefly describe components' normal and safety functions (include accident initiating signals.)

Normal: VALVE TO OPEN WHEN STRAINER
CLOGGED TO ALLOW SELF CLEANING BACKWASH

Safety: (SAME)

2. The components normal state is: ☒ Operating ☒ Standby
CYCLES ON BACKWASH

3. Safety function:

- | | |
|---|--|
| a. <input type="checkbox"/> Emergency reactor shutdown | b. <input checked="" type="checkbox"/> Containment heat removal |
| c. <input type="checkbox"/> Containment isolation | d. <input checked="" type="checkbox"/> Reactor heat removal |
| e. <input type="checkbox"/> Reactor core cooling | f. <input type="checkbox"/> Prevent significant release of radioactive material to environment |
| g. <input checked="" type="checkbox"/> Does the component function to mitigate the consequences of one or more of the following events? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | |
| <input checked="" type="checkbox"/> LOCA | <input checked="" type="checkbox"/> HELB |
| <input type="checkbox"/> Other | <input checked="" type="checkbox"/> MSLB |

4. Safety requirements:

- ☒ Intermittent Operation ☐ During postulated event
☐ Continuous Operation ☒ Following postulated event

If component operation is required following an event, give approximate length of time component must remain operational.
100 DAYS (e.g., hours, days, etc.)

5. For VALVES:

does the component ☐ Fail open ☐ Fail closed ☒ Fail as is

Is this the fail safe position? ☐ Yes ☒ No

Is the valve used for throttling purposes? ☐ Yes ☒ No

What is the maximum acceptable internal and external leakrate?

100/HR/INCH STEM DIA



IV.

QUALIFICATION

1. Reference by specific number those applicable sections of the design codes and standards applicable to the component: ASME B & PV CODE, SECT. III, DIV. 1,
1977 THRU. SUMMER '78 ADDENDA: MSS-SP-72, 1970.
F
2. Reference those qualification standards, used as a guide to qualify the component: IEEE Std. 344 - 75;
IEEE Std 382-72; IEEE Std. 323-1974
REG. GUIDES 1.48/1.61/1.89/1.100
3. Have acceptance criteria been established and documented in the test plan(s) for the component?
☒ Yes () No
4. Are the margins* identified in the qualification documentation? ☒ Yes () No
5. Was the component that was qualified a model or an actual assembly? ASSEMBLY. If a model, what was its scale? N/A. If an actual assembly, was it qualified as an assembly or by sub-assemblies? (i.e., valve, actuator, pump, driver) ASSEMBLY FOR SHOP TESTS ; SUB-ASSEMBLY FOR OPERATOR
6. List all component tests performed or to be performed that demonstrate qualification:
 - a) ASSEMBLY : OPERABILITY (STATIC LOAD TESTS)
 - b) SHOP TESTS : SHELL, SEAT & PACKING HYDROSTATIC LEAK TESTS
OPERATOR MOTOR - LOCKED ROTOR, DIELECTRIC TESTS
OPERATOR.: TORQUE AT MAX (+10%) & MIN (-20%) VOLTAGE
: STALL TORQUE (WITH TORQUE LIMIT DEVICES NEGATED)
ASSEMBLY : PERFORMANCE TESTS (3 CYCLES OPEN/CLOSE AGAINST
MAX ΔP AT MIN. VOLTAGE, WITH N SPEC. OPENING TIME)
 - c) OPERATOR : DYNAMIC LOAD - SNE DWELLS

* Margin is the difference between design basis parameters and the test parameters used for equipment qualification.



7. List all component analyses performed that demonstrate qualification:

STRS 05.340-5004D - SEISMIC ANALYSIS

RESPONSE TO SEISMIC ANALYSIS
STRS 05.340-5004E - REVIEW COMMENTS

MS-1949 Rev O - SUPP. CALC. FOR SEISMIC QUAL.

8. As a result of any of the tests (or analysis), were any deviations from design requirements identified?
☒ Yes () No If "Yes", briefly describe any changes made in tests (or analyses) or to the component to correct the deviation.

a) LIMITORQUE ACTUATOR TORQUE WAS FOUND TO
BE IN EXCESS OF SPECIFIED MAXIMUM. OPERATOR
GEARING BEING CHANGED TO REDUCE TORQUE: STEM
MATERIAL CHANGE TO HIGHER STRENGTH TO PREVENT TORQUE DAMAGE.
(SEE ATTACHED LETTERS).*

9. Was the tested component precisely identical (as to model, size, etc.) to the in-plant component? ☒ Yes, with one
(-) No. If "No", is installed component (u) oversized or exception**
() undersized?

10. Is component orientation sensitive? () Yes ☒ No
() Unknown If "Yes", does installed orientation coincide with test/analysis orientation? () Yes
() No

List all loads and numerical values used during tests or analysis and indicate whether applied individually or in combination:

STATIC OPERABILITY TEST: 4G. IN 3 ORTHOGONAL

DIRECTIONS SIMULTANEOUSLY WITH DESIGN PRESSURE,

AND STROKED WITH SPEC. TIME AT 80% RATED VOLTAGE.

HYDRO: SHELL-450 psig for 10 mins.; DISC-315 psig
for 1 min; SEAT-315 psig for 1/2 min.

ASSY. PERFORMANCE - CYCLE IN SPEC. TIME AGAINST MAX. ΔP

MOTOR ROUTINE: 0.3A NO LOAD; 2.3A LOCKED ROTOR

* 8) (CONT.) DUE TO LIMITORQUE ACTUATOR TESTING, LIMIT SWITCH
SCREWS & BOLT TORQUES TO BE ADJUSTED & LIMIT SWITCH
FINGER ASSY. GAPS TO BE ADJUSTED

** 9) DYNAMIC TEST OF LIMITORQUE WAS PERFORMED ON SMB-000-5/HIBC
COMPARED TO SMB-000-2/HIBC

11. Does the component have a unique design or utilize unique materials in its construction? (Examples are special gaskets or packings, one of a kind components, limitations on nonferrous materials, special coatings or surfaces, etc.)

() Yes ☒ No If "Yes" identify: _____

12. What is the design (qualified) life of the component, exclusive of normal maintenance items such as packings, bearings, seals, diaphragms, gaskets, and other elastomers?

40 YEARS

13. Which of the components normal maintenance items requires the most frequent replacement? GASKETS,

GREASE AND PACKING RINGS What is the normal time interval between replacements of this item?

UPON DISASSEMBLY OR AS REQUIRED PER ISI & MAINTENANCE PROGRAM WHICH WILL BE ESTABLISHED 6 MONTHS PRIOR TO COMMERCIAL OPERATION

14. What is the harshest (accident/post-accident) external environment that the component could be exposed to during its qualified life? (e.g., temp., press., humidity, submergence, radiation type and dose, etc.)

MILD ENVIRONMENT -

TEMP: 92°F

PRESS: ATMOS.

REL.HUM: 90%



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
P304A	SPEC: "BALL VALVES - ALL SIZES" ADDENDA 1 & 2	11-8-79 THRU 2/9/81	SWEC	SWEC
P00,994	E&DCR: SHOP PAINT EXCEPTION	1/7/82	SWEC	SWEC
P01,071	E&DCR: IDENTITY PLATE MARKING	1/28/82	SWEC	SWEC
P01,138	E&DCR: DOCUMENT SHIPPING RELEASE	11/3/81	SWEC	SWEC
P01,310	E&DCR: SHIPPING RELEASE	7/28/82	SWEC	SWEC
P21,373	E&DCR: MILD ENVIRON. REQMTS	6/27/84	SWEC	SWEC
P01,309	E&DCR: SUPPLY DOCS. AFTER SHIPPING	7/27/72	SWEC	SWEC
12177- ER66B-7	DWG: MISC. PIPING SCREENWELL BLDG.	—	SWEC	SWEC
12177 FSK-9-10A	FLOW DIAG. -SERVICE WATER	2/14/85	SWEC	SWEC
P&ID -11A	PIPING & INST. DWG. -SERVICE WATER SYST.	7/31/84	SWEC	SWEC
0005.340 -952-045B	DWG. -LIMITORQUE OPERATOR	1/22/82	LIMITORQUE	SWEC
0005.540 -952-033G	DWG - 4" MOTOR OPER. BALL VALVE	3/19/85	CONTRONATICS	SWEC
STRS. 5.340- 5000B	SEISMIC QUAL. REPORT 4" TOP ENTRY BUTTWELD VALVE MOUNTED TO AN ACTUATOR - 16985-82N (OPERABILITY TEST)	6/16/82	CONTRONATICS	SWEC



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
TEST. 5.340 -5000B	TEST PROCEDURE FOR CONTRONATICS FOR STATIC LOAD TESTING (OPERABILITY)	2/8/82	ACTON TEST CORP.	SWEC
STRS 05.340 -5004E	SEISMIC ANALYSIS RESPONSE TO COMMENTS	5/29/85	CONTRONATICS	SWEC
STRS 05.340 -5004D	SEISMIC ANALYSIS	6/25/85	ACTON TEST CORP	SWEC
IEEE 5.340 -5009A	LIMITORQUE REPT B0058, APP. 10 OF APP. F.	3/13/79	ACTON TEST CORP	SWEC
—	QA. PACKAGE: SPEC COMPLIANCE DOCS.	—	VARIOUS	SWEC
EQEDC -1	EQUIP. QUAL. ENVIRON. DESIGN CRITERIA	5/2/84	SWEC	SWEC
MS-1949 Rev 0	SUPP. CALC. FOR SEISMIC QUAL. OF CONTRONATICS- 4" VALVE	5/31/85	SWEC	SWEC
TEST 5.340 -5001A	MOTOR OPERATOR TEST PROCEDURE	4/6/85	CONTRONATICS	SWEC
TEST 5.340 -5002A	MOTOR OPERATOR TEST DATA	4/6/85	CONTRONATICS	SWEC
86397-1	VALVE TEST PROCEDURE	1/18/82	CONTRONATICS	SWEC
PT-86397	PERFORMANCE TEST	1/4/82	CONTRONATICS	SWEC
ED- GENE.014	ELECTRICAL TEST PROCEDURE	—	SWEC	SWEC



NOTED JAN 31 1985 R SWP

CONTROMATICS Division of Quamco, Inc.

Low Control Products

222 Roberts Street, East Hartford, Connecticut 06108

General 203 528-9935

Sales 203 528-9903

063288

55 JAN 31 P 11:47
January 28, 1985

Stone & Webster Engineering Corp
P.O. Box 5200
Cherry Hill, NJ 08034

Attn: T.B. Madden
Lead Power Engineer

Ref: P.O. No. NMP2-P304A
Ball Valves
Section III, Class 2 & 3
Nine Mile Point Unit 2
Niagara Mohawk Power Corp
Our S.O. NP 86397
Your letter of 11-10-84 (9M2-17-406)

J. Sullivan
T.B. Madden
DIVISION: 46

Gentlemen,

In order to correct the installed motor operated valves,
2 SWP *MOV 1A, 1B, 1C, 1D, 1E and 1F we are proceeding with the following;

1. New gears will be installed in the motor operators to reduce torque out put to 1200 inch lbs. This will change the operating time to approximately 5 seconds.
2. Contromatics will manufacture six new stems from 17-4 ph, which requires 1500 inch lbs before it starts to twist.

It will take approximately 10-12 weeks to manufacture the new stems.
We are contacting Limitorque to determine when they will be ready to install the new gears.

Would you identify a individual, either in New Jersey or New York with whom I can coordinate the timing of this repair.

If you have any questions please contact me.

Very truly yours,
CONTROMATICS
Division of Quamco, Inc.

L Bosh
Len Bosh
Manager, Sales Administration

RECEIVED
STONE & WEBSTER

JAN 31 1985

RECEIVED CONTROMATICS

LB/jmf
cc: W. Concannon
J. Sullivan
B. Bodnar (2)



STONE & WEBSTER ENGINEERING CORPORATION

Copy to:

JPThomas

RWHaddix

JTNiezabytowski

TBMadden

PDVisalli

CFOrdille

Doc. Control/CHOC

Doc. Control/Site

Job Book P304A

C3/12177/101/5YLWPC/41

JTSullivan

WConcannon

NOTED MAR 25 1985 I. MUM

Contromatics

Attention Mr. Len Bosh

222 Roberts Street

East Hartford, CT 06108

March 25, 1985

J.O.No. 12177

9M2-17,813

Responds to: NA

Response Required by: April 5, 1985

PURCHASE ORDER NO. NMP2-P304A

BALL VALVES ALL SIZES CATEGORY I

NINE MILE POINT NUCLEAR STATION - UNIT 2

NIAGARA MOHAWK POWER CORPORATION

In accordance with your letter dated January 28, 1985, the gear ratio and valve stems for 2SWP*MOV1A through F will be changed to comply with specification requirements.

Please complete the enclosed valve data sheet, Motor-Operated Ball Valve Data Sheet by Seller. In addition to the above-referenced change, please also complete items identified as Approx. or Later. Your prompt response in this matter is appreciated.



T. B. Madden

Lead Power Engineer

Enclosure

JTS:SG



SPEC. NO. P304D

PORT 12

NINE MILE POINT NUCLEAR STATION UNIT 2

EQUIPMENT DYNAMIC QUALIFICATION

COMPONENT NAME: 18" 300[#] BUTTERFLY VALVE
WITH SMB-00-10 JH3BC ACTUATOR

MARK NUMBERS: 2 RHS * MOV 9A



STONE & WEBSTER



PUMP AND VALVE
OPERABILITY ASSURANCE REVIEW

I. PLANT INFORMATION

1. Name: Nine Mile Point Unit No. 2 2. Docket No.: 50-410
3. Utility: Niagara Mohawk Power Corporation
4. NSSS: General Electric Co. () PWR (X) BWR
5. A/E: Stone & Webster Engineering Corporation
6. C.P. and/or O. L. SER date 6/24/74

II. GENERAL COMPONENT* INFORMATION

1. Supplier: () NSSS (X) BOP
2. Location:
 - a. Building/Room ABN - (Auxiliary Bay-North)
 - b. Elevation 201' COL. 46.00 LINE W
 - c. System RESIDUAL HEAT REMOVAL (RHS/RHR)
3. Component I.D. No. on P&ID dwg. E12 * F047A (2RHS + MOV9A)
4. If component is a () Pump complete II.5.
If component is a (X) Valve complete II.6.
5. General Pump Data (NOT APPLICABLE)
 - a. Pump
 - b. Prime-mover

Name _____	Name _____
Mfg. _____	Mfg. _____
Model _____	Model _____
S/N _____	S/N _____
Type _____	Type _____

* The component, whether pump or valve, is considered to be an assembly composed of the body, internals, prime-mover (or actuator) and functional accessories.



a. Pump (Continued)

Overall
Dimensions _____

Weight _____

Mounting
Method _____

Required B.H.P. _____

Parameter	Component	System
	Design	Normal/Accident
Press	_____	_____/_____
Temp	_____	_____/_____
Flow	_____	_____/_____
Head	_____	_____/_____
Media	_____	_____/_____

Required NPSH at maximum

flow _____

Available NPSH _____

Operating Speed _____

Critical Speed _____

List functional accessories:*

b. Prime-mover (Continued)

Overall
Dimensions _____

Weight _____

Mounting
Method _____

H.P. _____

Prime Mover Requirements: (include
normal, maximum and minimum)

Motor(Voltage) _____

Turbine (pressure) _____

If MOTOR list:

Duty cycle _____

Stall current _____

Class of insulation _____

* Functional accessories are those sub-components not supplied by the manufacturer that are required to make the pump assembly operational, (e.g., coupling, lubricating oil system, speed control sys., feedback, etc.)

6. General Valve Data

a. Valve

Name 18" 300[#] MOTOR OPERATED BUTTERFLY VALVE
 Mfg. POSI SEAL INC.
 Model (NOT APPLICABLE)
 S/N 34077-1A
 Type MOTOR OPERATED BUTTERFLY VALVE
 Size 18"
 Weight 1414[#] (TOTAL) 886[#] VALVE 528[#] ACT/BK
 Mounting Method FLG. BOLTED TO PIPE

b. Actuator (if not an integral unit)

Name MOTOR OPERATED ACTUATOR
 Mfg. LIMITORQUE
 Model SMB-00-10/H3BC
 S/N MOTOR - 87726926M-ZK-1
ACTUATOR - L 375489
H3BC - L 375485
 Type MOTOR OPERATED
 Size SMB-00-10
 Weight 528[#] ACT/BK
 Mounting Method BOLTED TO MTG. BRK.

* Max. Required Torque 33192 in.-lb. @ 500 PSI

*** Max. Delivered Torque 33840 IN.-LBS @ 460V (NOMINAL SETTINGS)
42720 IN.-LBS @ 460V (MAXIMUM SETTINGS)
126720 IN.-LBS @ 632V (STALL VOLTAGE)*

Parameter	*Component Design	System Normal/Accident
Press (PSIG)	500	425 / 350
Temp (°F)	358	40-358 / 212
Flow (GPM)	8400	7450 / 7450
Media	WATER	WATER / WATER
Max Δ P across valve	500 PSIG	

Power Requirements: (include normal, maximum and minimum).

Electrical
 NORMAL 575 V / 3Ø / 60Hz
 MAX. 633 V / 3Ø / 60Hz
 MIN. 460V / 3Ø / 60Hz

*** Closing time @ max P 47 SEC *15 SEC MIN *80 SEC MAX
 *** Opening time @ max P 47 SEC *15 SEC MIN *80 SEC MAX

Other: () Pneumatic () Hydraulic

List functional accessories: * (NOT APPLICABLE)

* Functional accessories are those sub-components not supplied by the manufacturer that are required to make the valve assembly operational, (e.g., limit switches, solenoid valves, accumulators, etc.)

* E-DCR P13248-

** LIMITORQUE TEST DATA - DOCUMENTATION PACKAGE - TORQUE SWITCH FOR OPEN POSITION

*** STR5 05.312.5008B

* (133680 IN.-LBS - 6056)



III. FUNCTION

1. Briefly describe components' normal and safety functions (include accident initiating signals.)

Normal: VALVE IS NORMALLY OPEN, IT PROVIDES A FLOWPATH TO HEAT EXCHANGER

2 RWS & EIA (E12-8001A) FOR SHUTDOWN & SUPPRESSION POOL COOLING

Safety: VALVE IS NORMALLY OPEN, IT PROVIDES A FLOWPATH TO HEAT EXCHANGER

2 RWS & EIA (E12-8001A) FOR SUPPRESSION POOL COOLING & CONTAINMENT SPRAY

2. The components normal state is: () Operating (X) Standby

3. Safety function:

- | | |
|--|---|
| a. () Emergency reactor shutdown | b. (X) Containment heat removal |
| c. () Containment isolation | d. (X) Reactor heat removal |
| e. () Reactor core cooling | f. () Prevent significant release of radioactive material to environment |
| g. () Does the component function to mitigate the consequences of one or more of the following events? (X) Yes () No | |
| (X) LOCA | () HELB |
| () Other | (X) MSLB |

4. Safety requirements:

- | | |
|----------------------------|--------------------------------|
| (X) Intermittent Operation | (X) During postulated event |
| () Continuous Operation | (X) Following postulated event |

If component operation is required following an event, give approximate length of time component must remain operational.

100 DAYS (e.g., hours, days, etc.)

5. For VALVES:

does the component () Fail open () Fail closed (X) Fail as is

Is this the fail safe position? (X) Yes () No

Is the valve used for throttling purposes? () Yes (X) No

What is the maximum acceptable internal and external leakrate?

2.5 GPH NON-PREFERRED DIRECT. 0 **
3.0 CC/MIN PREFERRED DIRECT.



IV.

QUALIFICATION

1. Reference by specific number those applicable sections of the design codes and standards applicable to the component: ASTM SECT III, SUBSECTION NC-1977 EDITION
& Addenda up to & including 7-30-77, CODE CASE N-142-1 (1774-1)

2. Reference those qualification standards, used as a guide to qualify the component: IEEE 323-1974, 344-1975, 382-1972,
NRC REG. GUIDE 1.48, 1.61, 1.73, 1.89, 1.100, 1.148

3. Have acceptance criteria been established and documented in the test plan(s) for the component?
(X) Yes () No
4. Are the margins* identified in the qualification documentation? () Yes (X) No
5. Was the component that was qualified a model or an actual assembly? Actual Assy ^{① FOR STATIC DEFLECTION TEST.} If a model, what was its scale? N/A. If an actual assembly, was it qualified as an assembly or by sub-assemblies? (i.e., valve, actuator, pump, driver)
SEISMIC ANALYSIS & STATIC DEFLECTION TEST - VALVE ASSEMBLY
LIMITORQUE TEST - TYPE TEST ACTUATOR ONLY
6. List all component tests performed or to be performed that demonstrate qualification:
 - 1) STATIC DEFLECTION TEST - VALVE ASSEMBLY
 - 2) ^{SEISMIC} TYPE TEST - LIMITORQUE ACTUATOR
 - 3) HYDROSTATIC SHELL TEST - VALVE ASSEMBLY..
 - 4) MAIN SEAT LEAKAGE TEST - VALVE ASSEMBLY
 - 5) HYDROSTATIC DISC TEST - VALVE ASSEMBLY
 - 6.) MOTOR TEST - LIMITORQUE MOTOR
 - a) LOCKED ROTOR TEST
 - b) DIELECTRIC TEST
 - 7) MOTOR OPERATOR/ACTUATOR PRODUCTION TEST - LIMITORQUE ACTUATOR
 - a) TORQUE TEST
 - b) STALLED TORQUE TEST
 - 8.) PERFORMANCE/ CYCLE TESTS - VALVE ASSEMBLY
 - 9.) ENVIRONMENTAL TESTS - LIMITORQUE ACTUATOR
 - a) RADIATION AGING
 - b) THERMAL AGING
 - c) LOCA TEST



7. List all component analyses performed that demonstrate qualification:

a) STATIC SEISMIC ANALYSIS - VALVE ASSEMBLY ①
 b) ARRHENIUS TECHNIQUES - TO CALCULATE QUALIFIED LIFE
+ EXTENDED PAOP

① SWEC C0LC. 12177-EQ5-025 (4-29-95)

8. As a result of any of the tests (or analysis), were any deviations from design requirements identified?
 (X) Yes () No If "Yes", briefly describe any changes made in tests (or analyses) or to the component to correct the deviation.

DUE TO LIMITORQUE ACTUATOR TESTING - LIMIT SWITCH SCREWS &
BOLT TORQUES WERE ADJUSTED & LIMIT SWITCH FINGER ASSEMBLY
GAPS WERE ADJUSTED

9. Was the tested component precisely identical (as to model, size, etc.) to the in-plant component? () Yes
 (X) No. If "No", is installed component (X) oversized or () undersized?

10. Is component orientation sensitive? (X) Yes () No
 () Unknown If "Yes", does installed orientation coincide with test/analysis orientation? (X) Yes
 () No

List all loads and numerical values used during tests or analysis and indicate whether applied individually or in combination:

1) STATIC SEISMIC ANALYSIS - SEISMIC LOAD, STATIC EQUIVALENT OF
3.0g IN 2 OF THE ORTHOGONAL AXES & 4.0g'S IN THE OTHER
TO ACCOUNT FOR DEADWEIGHT ADDED TO THE VALVE OPERATING
TORQUES - (PACKING 1134 in.-lbs, SEAL 9906 in.-lbs, HYDROSTATIC 18440 in.-lbs)
 2) SEISMIC TYPE TEST - LIMITORQUE ACTUATOR, SINGLE FREQUENCY SINE
DWELL TESTS 5-30 SEC. DWELLS WITH 2.2g INPUT @ 35 Hz & 1-30 SEC.
DWELL WITH 4.4g INPUT @ 35 Hz.



3. STATIC DEFLECTION TEST - EQUIVALENT STATIC FORCE OF 7.5 g's
(36.36 lbs) & LINE PRESSURE OF 500 PSI.

4. HYDROSTATIC SHELL TEST - DISC IN OPEN POSITION WITH
1125 PSIG APPLIED + HELD FOR 12 MINUTES

5. MAIN SEAT LEAKAGE TEST - IN PREFERRED
FLOW DIRECTION WITH 815 PSIG APPLIED + HELD
FOR 2 MINUTES, IN NON-PREFERRED FLOW DIRECTION
WITH 500 PSIG APPLIED + HELD FOR 2 MINUTES

6. HYDROSTATIC DISC TEST - IN PREFERRED FLOW
DIRECTION 815 PSIG APPLIED FOR 1 MINUTE

7. MOTOR OPERATOR / ACTUATOR PRODUCTION TEST

a) TORQUE TEST - 33840 IN LBS @ 460 VOLTS, NORMAL SETTING
TORQUE SWITCH IN OPEN POSITION

- 42720 IN LBS @ 460 VOLTS, MAXIMUM SETTING
TORQUE SWITCH IN OPEN POSITION

b) STALLED TORQUE TEST - 126720 IN LBS @ 63.2 VOLTS
IN OPEN POSITION

133680 IN LBS @ 63.2 VOLTS
IN CLOSED POSITION

8. MOTOR TEST

@ LOADED MOTOR - 8.2 AMPS

6 DIELECTRIC TEST - L.R. AMPS 10.0, 15 MINUTES

9. PERFORMANCE / CYCLE TEST - CYCLED, OPEN / CLOSED 2

TIMES WITH ACTUATOR AT 460 VOLTS, ONCE WITH
HAND WHEEL & ONCE WITH 500 PSIG

Response Times ~ Open 37 To 49 seconds

~ Close 46 to 49 seconds

10. ENVIRONMENTAL TESTS ~

- a. RADIATION Aging - 1.66×10^8 RADG G_{M100} - APPLIED INDIVIDUALLY
NORMAL 122°F
- * b. THERMAL Aging - ACCIDENT 250°F - 25 P516 - APPLIED TOGETHER
- * c) RH ~ NORMAL/ACCIDENT 100% - APPLIED WITH b

* IEEE 05.312.5000B, 5000C



11. Does the component have a unique design or utilize unique materials in its construction? (Examples are special gaskets or packings, one of a kind components, limitations on nonferrous materials, special coatings or surfaces, etc.)

() Yes (X) No If "Yes" identify: _____

12. What is the design (qualified) life of the component, exclusive of normal maintenance items such as packings, bearings, seals, diaphragms, gaskets, and other elastomers?

36 YEARS (Actuator) (A)

13. Which of the components normal maintenance items requires the most frequent replacement? LIMIT SWITCH GASKETS

4 LUBRICANTS What is the normal time interval between replacements of this item?

EVERY 18 MONTHS (B)

14. What is the harshest (accident/post-accident) external environment that the component could be exposed to during its qualified life? (e.g., temp., press., humidity, submergence, radiation type and dose, etc.) (C)

TEMP - 175 °F

PRESSURE - 2.8 PSIG

HUMIDITY - 100% R.H.

GAMMA (ACCIDENT) - 4.5×10^7

BETA (ACCIDENT) - 1.3×10^7

SPRAY/SUBMERGENCE - NOT APPLICABLE

(A) SWEC CALC 12177-EQS-025

(B) IEEE 03.312.5000B, ... Appendix A, LUBRICATION & MAINTENANCE DATA

(C) EQ-EDC-1 (5-2-84)



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
SPEC. P304D REV. 1	Specification for Motor Operated, Air Operated, & Manual Butterfly Valves	11-30-83	SWEC	SWEC
E+DCR's P13057 13078A 13090 13185 13248 C 91957 P13248A	ADDED MOV'S TO SPEC REVISED HANDWHEEL ORIENT UPDATED ENVT DATA ADDED CODE CASE 1774 (N-142) REVISED VALVE DATA SHEET REVISED VALVE INFO. REVISED VALVE DATA SHT (IN-PROGRESS)	10-9-84 1-29-85 10-30-85 1-11-85 2-6-85 3-24-85	SWEC	SWEC
DWG 5 05.332. 054.038F	18" Class 300 Single Flange Valve Assy. Dwg No 34077-01 Rev. E	4-22-85	Poor Seal	SWEC
05.312 054.020A	Limitorque Valve Control SMB/HBC Dwg No 02-441-0154-	2-14-85	Limitorque	SWEC
12177- F5K - 27-7F	Flow Diagram Residual Heat Removal Rev. 8	10-31-84	SWEC	SWEC
12177- EP-71B-10 -71D-10	Piping Drawings Residual Heat Removal	2-27-85 2-27-85	SWEC	SWEC
	P&ID Fig. 5.4-13 SHEET 2/2 GE Dwg 731E961AF		GE	GE & SWEC

01



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
061584	INSTALL., OPER., & MAINTENANCE MANUAL	6-15-84	POST-SEAL INTERNATIONAL INC.	SWEC (FILE NO. 05.332-5000A)
061584	INSTALL., OPER., & MAINTENANCE MANUAL	11-07-84	POST-SEAL INTERNATIONAL INC.	SWEC (FILE NO. 05.332-5000B)
34077-0T01/O	OP. TEST PROC.	1-16-85	POST-SEAL INTERNATIONAL INC.	SWEC (STRS 05.312-5008A)
14077-0T-01	OP. TEST RESULTS (IN CONJUNCTION WITH STRS. 05.312-5008A)	4-25-85	POST-SEAL INTERNATIONAL INC.	SWEC (STRS 05.312-5008B)
34077TP-02	CYCLE/PERFORMANCE TEST	1-27-84	POST-SEAL INTERNATIONAL INC.	SWEC (PROC. 05.312-5000A)
34077TP-01	HYDRO SEAT TEST PROCEDURE	10-01-84	POST-SEAL INTERNATIONAL INC.	SWEC (TEST. 05.312-5001B)
N/A	PERFORMANCE TEST REPORT	4-26-85	POST-SEAL INTERNATIONAL INC.	SWEC (TEST. 05.312-5003A)
CALC. 12177-EQS-025 REV. 0	QUAL. LIFE DETERMINATION OF LIMITORQUE ACTUATORS @ AC CLASS RH. INSULATED MOTORS OUTSIDE PRIMARY CNMT.	4-29-85	SWEC	SWEC



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
B0058	LIMITORQUE VALVE ACTUATOR QUALIFICATION	1-11-80	LIMITORQUE INC.	SWEC (IEEE 05.312-5000B 5000C)
	GE PHASE III PRETEST DOCUMENTS PRODUCT ANALYSIS REPORT (PAR)	6-6-84	GENERAL ELECTRIC	SWEC IEEE.016.820-5.007C
MEQ P304Y REV.1	MECHANICAL EQUIP ENV. QUAL.	1-30-85	SWEC	SWEC
EQEDC-1	EQUIP. QUAL. ENV. DESIGN CRITERIA	5-2-84	SWEC	SWEC
ED.GENE. 014	ELECTRICAL TEST PROCEDURE, MOTOR OPERATED VALVES	-	SWEC	SWEC



SPEC. NO. NMP2-P304K
PVORT #13

NINE MILE POINT NUCLEAR STATION UNIT 2

EQUIPMENT DYNAMIC QUALIFICATION

COMPONENT NAME: 2 INCH, 150 LB. AIR OPERATED
PLUG VALVE

MARK NUMBERS: 2CCP* AOV37B



STONE & WEBSTER

SPEC. NO. NMP2-P309KRevision 0

PVORT #13

PUMP AND VALVEOPERABILITY ASSURANCE REVIEWI. PLANT INFORMATION

1. Name: Nine Mile Point Unit No. 2 2. Docket No.: 50-410
3. Utility: Niagara Mohawk Power Corporation
4. NSSS: General Electric Co. () PWR (X) BWR
5. A/E: Stone & Webster Engineering Corporation
6. C.P. and/or O. L. SER date 6/24/74

II. GENERAL COMPONENT* INFORMATION

1. Supplier: () NSSS (X) BOP
2. Location:
 - a. Building/Room AUXILIARY BAY SOUTH
 - b. Elevation 176'-6"
 - c. System REACTOR BUILDING CLOSED-LOOP COOLING WATER (CCP)
3. Component I.D. No. on P&ID dwg. 2CCP * AOV37B
4. If component is a () Pump complete II.5.
If component is a (X) Valve complete II.6.
5. General Pump Data N/A
 - a. Pump
 - b. Prime-mover

Name _____	Name _____
Mfg. _____	Mfg. _____
Model _____	Model _____
S/N _____	S/N _____
Type _____	Type _____

* The component, whether pump or valve, is considered to be an assembly composed of the body, internals, prime-mover (or actuator) and functional accessories.

SPEC. No. NMP2-P304K
REVISION 0
PVORT #13

a. Pump (Continued)

Overall
Dimensions _____

Weight _____

Mounting
Method _____

Required B.H.P. _____

b. Prime-mover (Continued)

Overall
Dimensions _____

Weight _____

Mounting
Method _____

H.P. _____

Parameter	Component Design	System Normal/Accident
-----------	---------------------	---------------------------

Press	_____	_____/_____
-------	-------	-------------

Temp	_____	_____/_____
------	-------	-------------

Flow	_____	_____/_____
------	-------	-------------

Head	_____	_____/_____
------	-------	-------------

Media	_____	_____/_____
-------	-------	-------------

Prime Mover Requirements: (include
normal, maximum and minimum)

Motor(Voltage) _____

Turbine (pressure) _____

Required NPSH at maximum

flow _____

Available NPSH _____

Operating Speed _____

Critical Speed _____

If MOTOR list:

Duty cycle _____

Stall current _____

Class of insulation _____

List functional accessories: * _____

* Functional accessories are those sub-components not supplied by the manufacturer that are required to make the pump assembly operational, (e.g., coupling, lubricating oil system, speed control sys., feedback, etc.)



6. General Valve Data

a. Valve

Name 2 INCH, 150 # PLUG VALVEMfg. ATWOOD & MORRISModel 166 SWS/N 1-18038-27Type PLUG VALVESize 2 INCH, 150 #Weight 20 LBS ⁽¹⁾Mounting
Method LINE MOUNTED / SOCKET WELDMax. Required
Torque 2200 IN-LB

Parameter	Component Design	System Normal/Accident
-----------	------------------	------------------------

Press (PSIG)	<u>225</u>	<u>100 / 125</u>
--------------	------------	------------------

Temp (°F)	<u>150</u>	<u>95 / 150</u>
-----------	------------	-----------------

Flow (GPM)	<u>50</u>	<u>50 / 50</u>
------------	-----------	----------------

Media	<u>DEMIN WATER</u>	<u>DEMIN WATER / DEMIN WATER</u>
-------	--------------------	----------------------------------

Max P across valve 100 PSIClosing time @ max P 8 SECOpening time @ max P 16 SECList functional accessories: * N/A

b. Actuator (if not an integral unit)

Name ROBOTARM AIR ACTUATORMfg. BETTISModel NCB-725-SR80S/N 83-9054Type PISTON / SPRINGSize SERIES CB-725Weight 101 LBS ⁽¹⁾Mounting
Method BOLTEDMax. Delivered
Torque 3800 IN-LB

Power Requirements: (include normal, maximum and minimum).

Electrical 120 VOLTS AC, ±10%(SOLENOID VALVE)Other: ☒ Pneumatic ☐ Hydraulic70 PSIG - MINIMUM80 PSIG - NORMAL125 PSIG - MAXIMUM

* Functional accessories are those sub-components not supplied by the manufacturer that are required to make the valve assembly operational, (e.g., limit switches, solenoid valves, accumulators, etc.)

(1) NOTE: TOTAL VALVE ASSEMBLY WEIGHT IS 188 LBS (VALVE 20 LBS, ACTUATOR 101 LBS, BRACKET & ACCESSORIES 67 LBS)



III. FUNCTION

1. Briefly describe components' normal and safety functions (include accident initiating signals.)

Normal: THE VALVE IS NORMALLY OPEN TO ALLOW CCP

SYSTEM FLOW THROUGH THE RESIDUAL HEAT REMOVAL PUMP (ZRH5*PIB,C) SEAL COOLERS.

Safety: IF CCP SYSTEM FLOW IS NOT AVAILABLE AFTER AN

ACCIDENT, THE VALVE WILL ISOLATE THE CCP SYSTEM FROM SAFETY RELATED SERVICE WATER SYSTEM INTER-TIES.

2. The components normal state is: ☒ Operating ☐ Standby

3. Safety function:

a. ☐ Emergency reactor shutdown

b. ☒ Containment heat removal

c. ☐ Containment isolation

d. ☒ Reactor heat removal

e. ☐ Reactor core cooling

f. ☐ Prevent significant release of radioactive material to environment

g. ☐ Does the component function to mitigate the consequences of one or more of the following events? ☒ Yes ☐ No

☒ LOCA

☒ HELB

☒ MSLB

☐ Other _____

4. Safety requirements:

☐ Intermittent Operation

☐ During postulated event

☒ Continuous Operation

☒ Following postulated event

If component operation is required following an event, give approximate length of time component must remain operational.

100 DAYS (e.g., hours, days, etc.)

5. For VALVES:

does the component ☐ Fail open ☒ Fail closed ☐ Fail as is

Is this the fail safe position? ☒ Yes ☐ No

Is the valve used for throttling purposes? ☐ Yes ☒ No

What is the maximum acceptable internal and external leakrate?

INTERNAL: 4cc PER HOUR

EXTERNAL: NONE



IV. QUALIFICATION

1. Reference by specific number those applicable sections of the design codes and standards applicable to the component: ASME III, DIVISION 1, 1980 EDITION -

SUBSECTION ND

2. Reference those qualification standards, used as a guide to qualify the component: _____

IEEE 323-1974, IEEE-344-1975, IEEE-382-1972

REGULATORY GUIDES 1.4B, 1.84, 1.85, 1.100

3. Have acceptance criteria been established and documented in the test plan(s) for the component?

(X) Yes () No

4. Are the margins* identified in the qualification documentation? (X) Yes () No

5. Was the component that was qualified a model or an actual assembly? ASSEMBLY. If a model, what was its scale? N/A. If an actual assembly, was it qualified as an assembly or by sub-assemblies? (i.e., valve, actuator, pump, driver) SUB-ASSEMBLIES; (VALVE OPERATOR, LIMIT SWITCHES, SOLENOID VALVE, VALVE BODY)

6. List all component tests performed or to be performed that demonstrate qualification:

• HYDROSTATIC SHELL

• HYDROSTATIC SEAT

• VALVE ASSEMBLY STATIC DEFLECTION:

• AIR-OPERATOR SEISMIC TESTS

• ASCO SOLENOID VALVE QUALIFICATION TESTS⁽¹⁾

• NAMCO LIMIT SWITCH QUALIFICATION TESTS⁽¹⁾

* Margin is the difference between design basis parameters and the test parameters used for equipment qualification.

(1) NOTE: TEST PROGRAMS INCLUDE SEISMIC AND ENVIRONMENTAL TESTING



7. List all component analyses performed that demonstrate qualification:

1) VALVE ASSEMBLY SEISMIC ANALYSIS

2) ENVIRONMENTAL QUALIFIED LIFE CALCULATION

3) MECHANICAL QUALIFICATION CALCULATION

8. As a result of any of the tests (or analysis), were any deviations from design requirements identified?
() Yes (X) No If "Yes", briefly describe any changes made in tests (or analyses) or to the component to correct the deviation.

9. Was the tested component precisely identical (as to model, size, etc.) to the in-plant component? () Yes (X)*No. If "No", is installed component (X) oversized or () undersized?

- * OPERATOR (OVERSIZED), LIMIT SWITCH BOLT MOUNTING PATTERN DIFFERENT
10. Is component orientation sensitive? (X) Yes () No
() Unknown If "Yes", does installed orientation coincide with test/analysis orientation? (X) Yes () No

List all loads and numerical values used during tests or analysis and indicate whether applied individually or in combination:

SEE ATTACHMENT "A"

NOTE: LOADS PRESENTED ON ATTACHMENT "A"

WERE APPLIED SEPERATLY (EXCEPT

AS NOTED OTHERWISE)



11. Does the component have a unique design or utilize unique materials in its construction? (Examples are special gaskets or packings, one of a kind components, limitations on nonferrous materials, special coatings or surfaces, etc.)

☒ Yes () No If "Yes" identify: _____

POLYETHYLENE LINER AND SEALS IN VALVE
BODY

12. What is the design (qualified) life of the component, exclusive of normal maintenance items such as packings, bearings, seals, diaphragms, gaskets, and other elastomers?

40 YEARS - NAMCO LIMIT SWITCH
11.3 YEARS - ASCO SOLENOID VALVE
40 YEARS - POLYETHYLENE LINER AND SEALS

13. Which of the components normal maintenance items requires the most frequent replacement? SOLENOID VALVE

COIL & ELASTOMERIC COMPONENTS What is the normal time interval between replacements of this item?

RECOMMENDED REPLACEMENT SCHEDULE IS 4 YEARS

14. What is the harshest (accident/post-accident) external environment that the component could be exposed to during its qualified life? (e.g., temp., press., humidity, submergence, radiation type and dose, etc.)

	⁽¹⁾ NORMAL	⁽¹⁾ ACCIDENT
TEMPERATURE (°F)	85°F	175°F
PRESSURE	-0.25" H ₂ O (GAGE)	2.8 PSIG
RELATIVE HUMIDITY (%)	50	100
RADIATION - GAMMA (RADS)	8.4×10^5	4.6×10^7
BATA (RADS)	N/A	1.3×10^7

(1) NOTE. VALUES ARE EQUIPMENT SPECIFIC

ATTACHMENT A

VALVE BODY SHELL HYDROSTATIC- 450 psig
SEAT LEAKAGE- 315 psig

VALVE ASSEMBLY

- | | | | |
|--|-----|--------------------|------------------|
| 1) SEISMIC LOADS FOR <u>STATIC ANALYSIS</u>
AND <u>STATIC DEFLECTION TEST</u> | SSE | HORIZONTAL
3.0g | VERTICAL
3.0g |
|--|-----|--------------------|------------------|

(note: loads combined to
give a resultant of 5.83g)

- 2) LOW LEVEL IMPACT TESTING ("BUMP") TO
ESTABLISH NATURAL FREQUENCIES

VALVE OPERATOR (BETTIS AIR CYLINDER)

RANDOM MULTIFREQUENCY TESTS WITH ZERO PERIOD ACCELERATIONS (ZPA)
IN EXCESS OF 3.0g FOR OBE AND SSE TESTS

LIMIT SWITCHES

- 1) SINE DWELLS IN EACH ORTHOGONAL AXIS ("X", "Y", "Z") APPLIED AT
16 FREQUENCIES FOR THE FOLLOWING ACCELERATION LEVELS:

1 TO 4 Hz 0.6 to 10g's
4 TO 32 Hz 10g

- 2) ENVIRONMENTAL LOADS

		NORMAL	ACCIDENT
(1) {	TEMPERATURE (°F)	194	380
	PRESSURE (psig)	0	100
	REL. HUMIDITY (%)	100	STEAM
	RADIATION (GAMMA) - TOTAL DOSE		2.04×10^8 RADS

SOLENOID VALVE

- 1) OBE TEST: 2 SINUSOIDAL SWEEPS, FROM 1 TO 35 TO 1 Hz, AT A RATE
OF 1 OCTAVE/MIN AT 3.0g ABOVE 9Hz IN EACH AXIS. (TABLE
LIMITS BELOW 9Hz)

SSE TEST: SINE BEATS AT 17 FREQUENCIES, BETWEEN 1 AND 35 Hz IN
EACH AXIS, WITH PEAK ACCELERATIONS OF AT LEAST 3g ABOVE
6.0 Hz. (TABLE LIMITS BELOW 6Hz)

- 2) ENVIRONMENTAL LOADS

		NORMAL	ACCIDENT
	TEMPERATURE (°F)	140	346
	PRESSURE (psig)	0	110
	REL. HUMIDITY (%)	100	STEAM
	RADIATION (GAMMA) - TOTAL DOSE		2.0×10^8 RADS

(1) NOTE: APPLIED IN COMBINATION



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
<u>SPECIFIC ACTIONS</u>				
SPEC. No NHP2-P304K ADDENDUM THROUGH 5	MANUAL PLUG VALVES	8-6-81 TO 3-12-85	SNEC	SNEC/NMPC
E3DCR P13,336	REVISED DATA SHEETS	4-2-85	SNEC	SNEC



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
<u>DRAWINGS</u>				
5.340-144-374A	VALVE AND OPERATOR ASSEMBLY DRAWING	4/9/85	ATWOOD & MORRILL/SWEC	ATWOOD & MORRILL/SWEC
5.340-144-346D	LIMIT SWITCH BRACKET ASSEMBLY DRAWING	4/24/84	ATWOOD & MORRILL	SWEC
12177-DP372-13F-5	REACTOR BUILDING CLOSED LOOP COOLING PIPING ISOMETRIC	4/20/84	SWEC	SWEC
F-SAR FIGURE 9.2-3E	PIPING & INSTRUMENTATION DRAWING	—	SWEC	SWEC
12177-FSK-9-1C-8	FLOW DIAGRAM	5/22/85	SWEC	SWEC
12177-EP-72C-7	PIPING LOCATION DRAWING	6/29/84	SWEC	SWEC



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
<u>QUALIFICATION DOCUMENTS</u>				
STES- 5.340- 5028A	SEISMIC ANALYSIS, STATIC OPERABILITY TEST & LOW LEVEL IMPACT (NATURAL FREQUENCY) TEST REPORTS	5/16/84	ATWOOD & MORRILL	SWEC
IEEE - 5.340 - 5006	AIR- OPERATOR QUALIFICATION REPORT	—	SOUTHWEST RESEARCH INST., BETTS CORPORATION	SWEC
IEEE - 5.340 - 5002	AIR- OPERATOR CERTIFICATE OF COMPLIANCE	—	BETTS CORPORATION, ATWOOD & MORRILL	SWEC
IEEE - 5.340- 5004B	ASCO SOLENOID VALVE QUALIFICATION REPORT	1/23/85	AUTOMATIC SWITCH CO (ASCO).	SWEC
IEEE - 5.340- 5001	ASCO SOLENOID CERTIFICATE OF COMPLIANCE	—	AUTOMATIC SWITCH CO. (ASCO), ATWOOD & MORRILL	SWEC
IEEE - 5.312 - 5002B	NAMCO LIMIT SWITCH QUALIFICATION REPORT	2/11/85	NAMCO CONTROLS	SWEC



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
IEEE - 5.340-5000:	NAMCO LIMIT SWITCH CERTIFICATE OF COMPLIANCE	—	NAMCO CONTROLS, ATWOOD & MORRILL	SWEC
TEST - 5.500-5000 A	HYDROSTATIC SHELL AND SEAT LEAKAGE TEST PROCEDURE	7/22/82	ATWOOD & MORRILL	SWEC
—	HYDROSTATIC SHELL AND SEAT LEAKAGE TEST RESULTS	2/29/84	ATWOOD & MORRILL	SWEC
INST. 05.340-5008A	MAINTENANCE AND REPAIR INSTRUCTION MANUAL	12/20/84	ATWOOD & MORRILL	SWEC
MEQ-P304K REV.1	MECHANICAL EQUIPMENT ENVIRONMENTAL QUALIFICATION	3/27/85	SWEC	SWEC
12177-EQS-016	ENVIRONMENTAL QUALIFICATION CALCULATION	5/1/85	SWEC	SWEC
EQEDC-1	EQUIPMENT QUALIFICATION ENVIRONMENTAL DESIGN CRITERIA	5/2/84	SWEC	SWEC
—	DOCUMENTATION PACKAGE	5/30/84	ATWOOD & MORRILL	SWEC



NINE MILE POINT NUCLEAR STATION UNIT 2

EQUIPMENT DYNAMIC QUALIFICATION

COMPONENT NAME: SHUT-OFF VALVE

MARK NUMBERS: 2 MSS * MOV 112



STONE & WEBSTER

100

1



PUMP AND VALVE
OPERABILITY ASSURANCE REVIEW

I. PLANT INFORMATION

1. Name: Nine Mile Point Unit No. 2 2. Docket No.: 50-410
3. Utility: Niagara Mohawk Power Corporation
4. NSSS: General Electric Co. () PWR (X) BWR
5. A/E: Stone & Webster Engineering Corporation
6. C.P. and/or O. L. SER date 6/24/74

II. GENERAL COMPONENT* INFORMATION

1. Supplier: () NSSS (✓) BOP
2. Location:
 - a. Building/Room STEAM TUNNEL
 - b. Elevation 250'
 - c. System MAIN STEAM
3. Component I.D. No. on P&ID dwg. 2 MSS * MOV 112

4. If component is a () Pump complete II.5.

If component is a (✓) Valve complete II.6.

5. General Pump Data N/A

a. Pump

b. Prime-mover

Name _____

Name _____

Mfg. _____

Mfg. _____

Model _____

Model _____

S/N _____

S/N _____

Type _____

Type _____

* The component, whether pump or valve, is considered to be an assembly composed of the body, internals, prime-mover (or actuator) and functional accessories.



a. Pump (Continued)

Overall
Dimensions _____

Weight _____

Mounting
Method _____

Required B.H.P. _____

b. Prime-mover (Continued)

Overall
Dimensions _____

Weight _____

Mounting
Method _____

H.P. _____

Parameter	Component Design	System Normal/Accident
-----------	---------------------	---------------------------

Prime Mover Requirements: (include
normal, maximum and minimum)

Press	_____	_____/_____
-------	-------	-------------

Motor(Voltage) _____

Temp	_____	_____/_____
------	-------	-------------

Flow	_____	_____/_____
------	-------	-------------

Head	_____	_____/_____
------	-------	-------------

Turbine (pressure) _____

Media	_____	_____/_____
-------	-------	-------------

Required NPSH at maximum

If MOTOR list:

flow _____

Duty cycle _____

Available NPSH _____

Stall current _____

Operating Speed _____

Class of insulation _____

Critical Speed _____

List functional accessories:*

* Functional accessories are those sub-components not supplied by the manufacturer that are required to make the pump assembly operational, (e.g., coupling, lubricating oil system, speed control sys., feedback, etc.)



6. General Valve Data

a. Valve

Name SHUT - OFF VALVE
Mfg. VELAN ENGINEERING LTD.
Model VDWOGO - B-1MQE
S/N 1326

Type GLOBE, 600LBS, BOLTED BONNET

Size 6"

Weight 900 #

Mounting
Method WELDED TO PIPE

Max. Required
Torque 666 Ft-lb

b. Actuator (if not an integral unit)

Name MOTOR OPERATED ACTUATOR
Mfg. LIMITORQUE CORP.
Model SMB-2-25
S/N 336511

Type MOTOR OPERATED.

Size SMB-2-25

Weight 603 #

Mounting
Method BOLTED TO YOKE

Max. Delivered
Torque 1331 Ft-lb at 110% VOLTAGE

Parameter	Component Design	System Normal/Accident
-----------	------------------	------------------------

Press PSIG	<u>1250</u>	<u>964/1250</u>
------------	-------------	-----------------

Temp °F	<u>575</u>	<u>540/ 575</u>
---------	------------	-----------------

Flow #/HR.	<u>6355</u>	<u>6276/ 0</u>
------------	-------------	----------------

Media	<u>H₂O/STM</u>	<u>H₂O/ STM</u>
-------	---------------------------	----------------------------

Max P across valve	<u>1250</u>
--------------------	-------------

Closing time @ max P	<u>39.0 SEC.</u>
----------------------	------------------

Opening time @ max P	<u>38.6 SEC.</u>
----------------------	------------------

List functional accessories:* NONE

Power Requirements: (include normal, maximum and minimum).

Electrical AC,

NORMAL : 575 VOLTS

MAX. : 632 VOLTS

MIN. : 460 VOLTS

3 PHASE, 60 Hz

Other: ()Pneumatic ()Hydraulic

* Functional accessories are those sub-components not supplied by the manufacturer that are required to make the valve assembly operational, (e.g., limit switches, solenoid valves, accumulators, etc.)



III. FUNCTION

1. Briefly describe components' normal and safety functions (include accident initiating signals.)

Normal: DRAINS THE MAIN STEAM LINE DURING
START-UP AND SHUT-DOWN.

Safety: MAIN STEAM OUTSIDE CONTAINMENT ISOLATION
VALVE.

2. The components normal state is: () Operating () Standby N/A

3. Safety function:

- a. () Emergency reactor shutdown b. () Containment heat removal
c. (✓) Containment isolation d. () Reactor heat removal
e. () Reactor core cooling f. () Prevent significant release of radio-active material to environment
g. () Does the component function to mitigate the consequences of one or more of the following events? (✓) Yes () No
(✓) LOCA (✓) HELB (✓) MSLB
() Other _____

4. Safety requirements:

- () Intermittent Operation () During postulated event
() Continuous Operation () Following postulated event

If component operation is required following an event, give approximate length of time component must remain operational.
6 HRS (e.g., hours, days, etc.)

5. For VALVES:

does the component () Fail open () Fail closed (✓) Fail as is

Is this the fail safe position? () Yes () No N/A

Is the valve used for throttling purposes? () Yes (✓) No

What is the maximum acceptable internal and external leakrate?

0.6 FT.³/HR. OF AIR

0



IV.

QUALIFICATION

1. Reference by specific number those applicable sections of the design codes and standards applicable to the component: ASME B & PV CODE, SEC. III, '74 SUB-SECTIONS NA-3250 AND NC 3500 INCLUDING ADDENDA THRU 12/75.
2. Reference those qualification standards, used as a guide to qualify the component: IEEE 344-1975,
IEEE 323-74, IEEE 382-1972,
REG. GUIDES 1.48, 1.61, 1.92 & 1.100.
3. Have acceptance criteria been established and documented in the test plan(s) for the component?
☒ Yes ☐ No
4. Are the margins* identified in the qualification documentation? ☐ Yes ☒ No
5. Was the component that was qualified a model or an actual assembly? ACTUAL ASSEMBLY If a model, what was its scale? _____. If an actual assembly, was it qualified as an assembly or by sub-assemblies? (i.e., valve, actuator, pump, driver) THE VALVE IS QUALIFIED BY PERFORMANCE TEST AND OPERABILITY.
6. List all component tests performed or to be performed that demonstrate qualification:
HYDROSTATIC TEST, STATIC DEFLECTION (OPERABILITY) TEST, SEAT LEAKAGE TEST, ACTUATOR DYNAMIC TEST,
RADIATION THERMAL AGING AND LOCA TEST, :
DIELECTRIC TEST, LOCKED ROTOR TEST, PERFORMANCE TEST,
THRUST/TORQUE TEST, STALLED THRUST/TORQUE TEST.

* Margin is the difference between design basis parameters and the test parameters used for equipment qualification.



7. List all component analyses performed that demonstrate qualification:

a) SEISMIC ANALYSIS OF THE VALVE ASSEMBLY.

b) ANALYSIS USING ARHENIUS TECHNIQUE TO
CALCULATE QUALIFIED LIFE AND EXTEND
POST ACCIDENT OPERABILITY PERIOD (PROP).

8. As a result of any of the tests (or analysis), were any deviations from design requirements identified?
(☒) Yes () No If "Yes", briefly describe any changes made in tests (or analyses) or to the component to correct the deviation.

LIMIT SWITCH SCREWS & BOLTS TORQUED.

LIMIT SWITCH FINGER ASSEMBLY GAPS
ADJUSTED.

9. Was the tested component precisely identical (as to model, size, etc.) to the in-plant component? (☒) Yes * EXCEPTION
() No. If "No", is installed component () oversized or
() undersized?

* FOR ENVIRONMENTAL TEST, INSTALLED COMPONENT
IS OVERSIZED.

10. Is component orientation sensitive? (☒) Yes () No
() Unknown If "Yes", does installed orientation coincide with test/analysis orientation? (☒) Yes
() No

List all loads and numerical values used during tests or analysis and indicate whether applied individually or in combination:

a) ASSEMBLY STATIC ANALYSIS:

SEISMIC LOAD = 5.0 g's (SSE)
PRESSURE = 1500 PSIG } APPLIED IN COMBINATION
OPERATING THRUST = 39814 #.

b) OPERATOR DYNAMIC TEST: ACCELERATION = 10.0 g's

c) STATIC DEFLECTION TEST:
SEISMIC LOAD = 7.4 g's } APPLIED IN COMBINATION
DIFF. PRESS = 1220 PSI

d) ENVIRONMENTAL TESTS; LIMITORQUE OPERATOR:

TEMP = 122°F (NORMAL), 340°F (ACCIDENT)
PRESSURE = 0 PSIG (NORMAL), 30 PSIG (ACCIDENT)
RH = 100% (NORMAL), STEAM (ACCIDENT)
RADIATION = 1.66 x 10⁸ RADS GAMMA - ACCIDENT

e) HYDROSTATIC SHELL TEST: PRESSURE = 2250 PSI

f) SEAT LEAKAGE TEST: PRESSURE = 1220 PSI



11. Does the component have a unique design or utilize unique materials in its construction? (Examples are special gaskets or packings, one of a kind components, limitations on nonferrous materials, special coatings or surfaces, etc.)

(☒) Yes () No If "Yes" identify: CLASS RH
MOTOR, OUTSIDE CONTAINMENT SERVICE
MATERIAL.

12. What is the design (qualified) life of the component, exclusive of normal maintenance items such as packings, bearings, seals, diaphragms, gaskets, and other elastomers?

20 YEARS FOR THE LIMITORQUE ACTUATOR.

13. Which of the components normal maintenance items requires the most frequent replacement? LIMIT SWITCH

GASKET LUBRICANT What is the normal
time interval between replacements of this item?
AS PER MAINTENANCE INSTRUCTION, EVERY 18 MONTHS
WHEN LIMIT SWITCH COMPARTMENT IS OPENED
FOR INSPECTION.

14. What is the harshest (accident/post-accident) external environment that the component could be exposed to during its qualified life? (e.g., temp., press., humidity, submergence, radiation type and dose, etc.)

TEMPERATURE = 340°F
PRESSURE = 27.4 PSIG
REL. HUMIDITY = ALL STEAM
RADIATION = 2.4 E07 GAMMA, 40 YRS. + ACCIDENT
1.3 E07 BETA, 40 YRS. + ACCIDENT

Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
STRS 05. 321-5013A SR-6520 REV. 0	SEISMIC REPORT ITEM 5	5-2-85	VELAN ENGINEERING LTD.	SWEC
TEST 05. 321-5003B and 5005B P9-7026-N 53B and 82B	OPERABILITY TESTS ITEM 5	7-26-83	VELAN ENGINEERING LTD.	SWEC
WB50128	HYDROSTATIC TEST REPORT	1-24-85	VELAN ENGINEERING LTD.	SWEC
MS-1887 REV. 1	QUALIFICATION OF MOTOR OPERATED VALVES FOR SPEC. P304R	6-13-85	SWEC	SWEC
TEST 05. 321-5013A B-0115	HYDRODYNAMIC VIBRATION TESTING	5-31-85	LIMITORQUE CORP.	SWEC
MS-1942	SIMILARITY ANALYSIS FOR DYNAMIC QUAL. OF LIMITORQUE MOTOR OPERATORS	5-31-85	SWEC	SWEC
EQEDC-1	EQUIPMENT QUAL. ENVIRONMENTAL DESIGN CRITERIA	5-2-84	SWEC	SWEC
DWG. 1217T- EP-139A-5	MAIN STEAM DRAIN PIPING REACTOR	3-8-84	SWEC	SWEC



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
DWG. 12177 EP-13985	MAIN STEAM DRAIN PIPING REACTOR BLDG.	3-8-84	SWEC	SWEC
SWEC FILE # 0005.321- 122-320 E DWG. P3- 7026-N13	6" GOO [#] BB GLOBE VALVE M/O	3-7-84	LIMITORQUE VALVE CONTROL	SWEC
SWEC FILE # 0005.321- 122-191A DWG. 02- 408-0009-4	LIMITORQUE VALVE CONTROL	12-31-80	LIMITORQUE CORPORATION	SWEC
DWG. 12177 FSK-3-1A	FLOW DIAGRAM MAIN STEAM	3-28-85	SWEC	SWEC
VEL-FBBM	MAINTENANCE MANUAL FOR 2 1/2"-24" FORGED B-B GATE and GLOBE VALVES	—	VELAN	SWEC
—	FIGURE FSAR 10.1-3F MAIN STEAM-PAID	—	NMP2	NMP2
12177 P304R	SPEC. THRU REV. 2 APPENDIX MOTOR OPERATED CARBON STEEL VALVES	11-30-83	SWEC	SWEC
E & DCR PI3377A	HYDRODYNAMIC LOADS REVISED	6-13-85	SWEC	SWEC

Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
STRS 05. 321-5025 F DR-1195/5	DESIGN REPORT ITEM 5, SA	1-12-85	VELAN ENGINEERING LTD.	SWEC
STRS 05. 321-5025 G	MFRS. DESIGN C OF C ITEMS 5, SA	3-6-85	VELAN ENGINEERING LTD.	SWEC
MEQ- P304R	MECHANICAL EQUIPMENT ENVIRONMENTAL QUALIFICATIONS	3-27-85	SWEC	SWEC
CALC. 12177- A10.2-D	MAIN STEAM PIPING DRAIN LINES	1-9-79	SWEC	SWEC
SWEC FILE SDDF IEEE 05.321- 5061 C/D Report 80058	QUALIFICATION REPORT	1-11-80	LIMITORQUE CORP.	SWEC
SWEC FILE SDDF IEEE- 016-820- 5007C REPORT 126-57-84	PRODUCT ANALYSIS REPORT	9-17-84	GENERAL ELECTRIC	SWEC



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
SWEC FILE # TEST OS. 321-5012B	OPERABILITY TEST PROCEDURE	4-1-85	VELAN	SWEC
ED.GEN 014	ELECTRICAL TEST PROCEDURE, MOTOR OPERATED VALVES	—	SWEC	SWEC



2



SPEC. NO. P304X

PORT #15

NINE MILE POINT NUCLEAR STATION UNIT 2

EQUIPMENT DYNAMIC QUALIFICATION

COMPONENT NAME: Solenoid Valve

MARK NUMBERS: 2 HVK * SOV 36A



STONE & WEBSTER



SPEC. NO. P304X
Revision 0

PUMP AND VALVE

OPERABILITY ASSURANCE REVIEW

I. PLANT INFORMATION

1. Name: Nine Mile Point Unit No. 2 2. Docket No.: 50-410
3. Utility: Niagara Mohawk Power Corporation
4. NSSS: General Electric Co. () PWR (X) BWR
5. A/E: Stone & Webster Engineering Corporation
6. C.P. and/or O. L. SER date 6/24/74

II. GENERAL COMPONENT* INFORMATION

1. Supplier: () NSSS (X) BOP
2. Location:
 - a. Building/Room Control Bldg / HVAC Equip. Room
 - b. Elevation 290'-6"
 - c. System Control Bldg. Chilled Water (HVAC)
3. Component I.D. No. on P&ID dwg. 2HVAC *SDV 36A

4. If component is a () Pump complete II.5.

If component is a (X) Valve complete II.6.

5. General Pump Data N/A

a. Pump

b. Prime-mover

Name _____

Name _____

Mfg. _____

Mfg. _____

Model _____

Model _____

S/N _____

S/N _____

Type _____

Type _____

* The component, whether pump or valve, is considered to be an assembly composed of the body, internals, prime-mover (or actuator) and functional accessories.

a. Pump (Continued)

Overall
Dimensions _____

Weight _____

Mounting
Method _____

Required B.H.P. _____

Parameter	Component	System
	Design	Normal/Accident
Press	_____	_____/_____
Temp	_____	_____/_____
Flow	_____	_____/_____
Head	_____	_____/_____
Media	_____	_____/_____

Required NPSH at maximum

flow _____

Available NPSH _____

Operating Speed _____

Critical Speed _____

List functional accessories:*

b. Prime-mover (Continued)

Overall
Dimensions _____

Weight _____

Mounting
Method _____

H.P. _____

Prime Mover Requirements: (include
normal, maximum and minimum)

Motor(Voltage) _____

Turbine (pressure) _____

If MOTOR list:

Duty cycle _____

Stall current _____

Class of insulation _____

* Functional accessories are those sub-components not supplied by the manufacturer that are required to make the pump assembly operational, (e.g., coupling, lubricating oil system, speed control sys., feedback, etc.)



6. General Valve Data

a. Valve

Name 2HVK * SOV 36 A
Mfg. TARGET ROCK CORP.
Model 76 P-034
S/N 1
Type Solenoid operated Globe
Size 3"
Weight 505 lb
Mounting Method Butt welds ends
Max. Required Torque N/A

b. Actuator (if not an integral unit)

Name _____
Mfg. _____
Model _____
S/N _____
Type _____
Size _____
Weight _____
Mounting Method _____
Max. Delivered Torque _____

Parameter	Component Design	System Normal/Accident
-----------	------------------	------------------------

Press	** 50 PSIG	37 / 37
Temp	120°F	32-104°F 32-104°F
Flow	48 gpm	48 gpm 48 gpm
Media	Water	Water / Water
Max P across valve	50 PSIG	

Closing time @ max P N/A
Opening time @ max P N/A

List functional accessories: * N/A

Power Requirements: (include normal, maximum and minimum).

Electrical 120 VAC +10% -20%

0.8 AMPS

Other: () Pneumatic () Hydraulic

* Functional accessories are those sub-components not supplied by the manufacturer that are required to make the valve assembly operational, (e.g., limit switches, solenoid valves, accumulators, etc.)

** This data is being changed to 100 - Work in Progress.



III. FUNCTION

1. Briefly describe components' normal and safety functions (include accident initiating signals.)

Normal: 2 HVK #SOV 36A IS NORMALLY OPEN, SERVES AS AN ISOLATION BOUNDARY BETWEEN CAT I & CAT II PORTIONS OF THE CHILLED WATER SYSTEM.

Safety: IN THE EVENT CHILLED WATER EXPANSION TANK LEVEL BECOMES LOWER THAN NORMAL, 2HVK #SOV 36A CLOSES TO ISOLATE CAT II SYSTEM.

2. The components normal state is: ☒ Operating ☐ Standby

3. Safety function:

- a. ☐ Emergency reactor shutdown b. ☐ Containment heat removal
c. ☐ Containment isolation d. ☐ Reactor heat removal
e. ☐ Reactor core cooling f. ☐ Prevent significant release of radio-active material to environment
g. ☐ Does the component function to mitigate the consequences of one or more of the following events? ☒ Yes ☐ No
☐ LOCA ☐ HELB ☐ MSLB
☒ Other IN THE EVENT CHILLED WATER EXPANSION TANK LEVEL BECOMES LOWER THAN NORMAL, 2HVK #SOV 36A

4. Safety requirements: VALVE CLOSES TO ISOLATE CAT II SYSTEM

- ☐ Intermittent Operation ☐ During postulated event
☒ Continuous Operation ☐ Following postulated event

If component operation is required following an event, give approximate length of time component must remain operational.
(e.g., hours, days, etc.)

5. For VALVES:

does the component ☐ Fail open ☒ Fail closed ☐ Fail as is

Is this the fail safe position? ☒ Yes ☐ No

Is the valve used for throttling purposes? ☐ Yes ☒ No

What is the maximum acceptable internal and external leakrate?

30 CC PER HR. AT 3600 PSIG.



IV.

QUALIFICATION

1. Reference by specific number those applicable sections of the design codes and standards applicable to the component: ASME B&PV Code Sec III Subsection NC -1974, with addenda thru Winter 75. Class 2
2. Reference those qualification standards, used as a guide to qualify the component: IEEE 323-1974, 344-1975, IEEE 382-1972, NRC R.G. 1.48, 1.61, 1.92 and 1.100
3. Have acceptance criteria been established and documented in the test plan(s) for the component?
☒ Yes ☐ No
4. Are the margins* identified in the qualification documentation? ☐ Yes ☒ No
5. Was the component that was qualified a model or an actual assembly? ASSEMBLY. If a model, what was its scale? N/A. If an actual assembly, was it qualified as an assembly or by sub-assemblies? (i.e., valve, actuator, pump, driver) AS AN ASSEMBLY
6. List all component tests performed or to be performed that demonstrate qualification:
Hydrostatic Shell Test
Hydrostatic Seat Leakage test
Functional tests
Operability test (seismic)

* Margin is the difference between design basis parameters and the test parameters used for equipment qualification.



7. List all component analyses performed that demonstrate qualification:

Valve assembly seismic analysis.

8. As a result of any of the tests (or analysis), were any deviations from design requirements identified?
() Yes (X) No If "Yes", briefly describe any changes made in tests (or analyses) or to the component to correct the deviation.
-
-
-

9. Was the tested component precisely identical (as to model, size, etc.) to the in-plant component? () Yes (X) No. If "No", is installed component (X) oversized or () undersized?

10. Is component orientation sensitive? (X) Yes () No
() Unknown If "Yes", does installed orientation coincide with test/analysis orientation? (X) Yes () No

List all loads and numerical values used during tests or analysis and indicate whether applied individually or in combination:

- a) HYDROSTATIC SHELL TEST - 5400 PSIG.
- b) HYDROSTATIC SEAT LEAKAGE TEST - 3600 PSIG.
- c) ANALYSIS : STATIC SEISMIC OF 4.5 g AND
MAXM. OPERATING PRESSURE OF 50 PSIG.
APPLIED IN COMBINATION
- d) DYNAMIC TEST: ACCELERATION = 4.5 g; PRESSURE
= 2485 PSIG. PIPING END LOAD = 285 FT.LB MOMENT.
APPLIED IN COMBINATION
- e) MAX. TEMP. = 350°F. RH = 55% PR=2485 PSIG.
- f) TEMP-TRANSIENT OF 385°F/MIN, PR. TRANSIENT OF 66 PSIG/MIN.



11. Does the component have a unique design or utilize unique materials in its construction? (Examples are special gaskets or packings, one of a kind components, limitations on nonferrous materials, special coatings or surfaces, etc.)

(X) Yes () No If "Yes" identify: SILICONE
RUBBER GASKET, 'O' RING, PILOT DISC
ASSEMBLY AND MAIN DISC ASSEMBLY.

12. What is the design (qualified) life of the component, exclusive of normal maintenance items such as packings, bearings, seals, diaphragms, gaskets, and other elastomers?

40 YEARS

13. Which of the components normal maintenance items requires the most frequent replacement? _____

GASKET, 'O' RING / ELECTRICAL ASSY What is the normal
time interval between replacements of this item?

5/20 YEARS.

14. What is the harshest (accident/post-accident) external environment that the component could be exposed to during its qualified life? (e.g., temp., press., humidity, submergence, radiation type and dose, etc.).

MILD ENVIRONMENT

TEMPERATURE = 85°F

PRESSURE = ATMOS.

HUMIDITY = 50%

SUBMERGENCE = NO

RADIATION = $< 1 \times 10^4$ RAD.



Information Concerning Qualification Documents for the Component

Report Number	Report Title / SWEC FILE NO.	Date	Company/Organization Preparing Report		Company/Organization Reviewing Report	
4239	Qualification Report IEEE 05-324-5001B	2-6-85	Target Rock Corp (TRC)		Swec	
2252B Letter dated 4-4-85	Design Report & Seismic Analysis STRS 05-324-5000C	4-18-85				
3575C	Production test Procedure. PROC 05-324-5016F	4-3-84				
76P-034	Project Control Drawings. 5-322-902-072B	4-13-84				
1071240 -1 Sht. 1 Rev. K	Valve DWG. Bill of Material 5-324-902-062A	12-10-82				
1071240-1 Sht. 2 Rev. K	Valve Drawing 5-324-902-063A	12-10-82				
3579	Instruction manual INST 5-324-5000D	1-25-83	↓ SWEC		↓	
12177-DB -381T	ISO DWG - Control Bldg. Cond. & Chilled Water PP-(2HVX) E1-78X16	-				



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
203006	Wiring Schematic 5-322-902-058	10-2-81	TRC	SWEC
1R# N2P304X 0097	QA inspection Report - type B	8-30-82	VARIOUS	SWEC
FSK- 22-12C Rev.2	Flow Diagram Control Bldg Chilled Water	-	SWEC	SWEC
12177- ESK- 7HVK02	AC Elem. Diagram Misc. AC CUTS. CB Chilled Water	-	SWEC	SWEC
Fig. 9.4-1A	FSAR	-	SWEC	SWEC



BOP#16 PVORT

SPEC. NO. P305B

PVORT # 16

NINE MILE POINT NUCLEAR STATION UNIT 2

EQUIPMENT DYNAMIC QUALIFICATION

COMPONENT NAME: MAIN STEAM SAFETY
RELIEF VALVE

MARK NUMBERS: 2SVV * RVV101



STONE & WEBSTER

PUMP AND VALVE
OPERABILITY ASSURANCE REVIEW

I. PLANT INFORMATION

1. Name: Nine Mile Point Unit No. 2 2. Docket No.: 50-410
3. Utility: Niagara Mohawk Power Corporation
4. NSSS: General Electric Co. () PWR (X) BWR
5. A/E: Stone & Webster Engineering Corporation
6. C.P. and/or O. L. SER date 6/24/74

II. GENERAL COMPONENT* INFORMATION

1. Supplier: () NSSS (✓) BOP
2. Location:
 - a. Building/Room PRIMARY CONTAINMENT
 - b. Elevation 254'
 - c. System MAIN STEAM SAFETY / RELIEF VALVES
VENTS & DRAINS
3. Component I.D. No. on P&ID dwg. 2SVV * RVV101
4. If component is a () Pump complete II.5.
If component is a (✓) Valve complete II.6.
5. General Pump Data N / A
 - a. Pump
 - b. Prime-mover

Name _____	Name _____
Mfg. _____	Mfg. _____
Model _____	Model _____
S/N _____	S/N _____
Type _____	Type _____

* The component, whether pump or valve, is considered to be an assembly composed of the body, internals, prime-mover (or actuator) and functional accessories.

a. Pump (Continued)

N/A

Overall Dimensions _____

Weight _____

Mounting Method _____

Required B.H.P. _____

Parameter	Component Design	System Normal/Accident
-----------	------------------	------------------------

Press	_____	_____/_____/_____
-------	-------	-------------------

Temp	_____	_____/_____/_____
------	-------	-------------------

Flow	_____	_____/_____/_____
------	-------	-------------------

Head	_____	_____/_____/_____
------	-------	-------------------

Media	_____	_____/_____/_____
-------	-------	-------------------

Required NPSH at maximum

flow _____

Available NPSH _____

Operating Speed _____

Critical Speed _____

List functional accessories: * _____

b. Prime-mover (Continued)

Overall Dimensions _____

Weight _____

Mounting Method _____

H.P. _____

Prime Mover Requirements: (include normal, maximum and minimum)

Motor (Voltage) _____

Turbine (pressure) _____

If MOTOR list:

Duty cycle _____

Stall current _____

Class of insulation _____

* Functional accessories are those sub-components not supplied by the manufacturer that are required to make the pump assembly operational, (e.g., coupling, lubricating oil system, speed control sys., feedback, etc.)



6. General Valve Data

a. Valve

MAIN STEAM SYSTEM / RELIEF
VALVE DISCHARGE (LSVV) ---
Name VACUUM BREAKER

Mfg. GPE CONTROLS

Model LD244-17

S/N 8211-0289-1

5"/10" DYNAMIC LOAD
Type VACUUM RELIEF VALVE

Size 6"

Weight 185 lbs

Mounting BUTT WELDED TO 10"
Method HORIZ. SECTION OF TEE

Max. Required
Torque N/A

b. Actuator (if not an integral unit) N/A

Name _____

Mfg. _____

Model _____

S/N _____

Type _____

Size _____

Weight _____

Mounting _____
Method _____

Max. Delivered
Torque _____

Parameter	Component Design	System Normal/Accident
-----------	------------------	------------------------

Press (PSIG)	<u>570</u>	<u>14.7 / 570</u>
--------------	------------	-------------------

Temp (°F)	<u>485</u>	<u>135 / 485</u>
-----------	------------	------------------

Flow (SCFM)	<u>1152</u>	<u>0 / 1152</u>
-------------	-------------	-----------------

Media	<u>AIR & STEAM</u>	<u>AIR & STEAM</u>
-------	------------------------	------------------------

Max P across valve @ RATED FLOW	<u>0.5 PSID</u>	
---------------------------------	-----------------	--

Closing time @ max P	<u>N/A</u>	
----------------------	------------	--

Opening time @ max P	<u>0.2 SEC.</u>	
----------------------	-----------------	--

List functional accessories: * N/A

Power Requirements: (include normal, maximum and minimum).

Electrical _____

Other: () Pneumatic () Hydraulic

* Functional accessories are those sub-components not supplied by the manufacturer that are required to make the valve assembly operational, (e.g., limit switches, solenoid valves, accumulators, etc.)



III. FUNCTION

1. Briefly describe components' normal and safety functions (include accident initiating signals.)

Normal: NONE

Safety: PREVENT DRAWING WATER UP INTO THE SRV DISCHARGE LINE DUE TO STEAM CONDENSATION AFTER SRV OPERATION.

2. The components normal state is: () Operating (✓) Standby

3. Safety function:

- a. (✓) Emergency reactor shutdown b. () Containment heat removal
c. () Containment isolation d. () Reactor heat removal
e. () Reactor core cooling f. () Prevent significant release of radioactive material to environment
g. () Does the component function to mitigate the consequences of one or more of the following events? (✓) Yes () No
() LOCA () HELB () MSLB
(✓) Other CLOSURE OF MSN'S & TURBINE/GENERATOR TRIP

WITH COINCIDENT CLOSURE OF TURBINE STEAM BY PASS SYSTEM VALVES.

4. Safety requirements:

- (✓) Intermittent Operation () During postulated event
() Continuous Operation (✓) Following postulated event

If component operation is required following an event, give approximate length of time component must remain operational.

100 DAYS (e.g., hours, days, etc.)

5. For VALVES:

(N/A; NOT APPLICABLE TO CHECK VACUUM BREAKER)
does the component () Fail open () Fail closed () Fail as is N/A

Is this the fail safe position? () Yes () No N/A

Is the valve used for throttling purposes? () Yes (✓) No

What is the maximum acceptable internal and external leakrate?

1 SCFM (INTERNAL) 0 (EXTERNAL)



IV. QUALIFICATION

1. Reference by specific number those applicable sections of the design codes and standards applicable to the component: ASME CODE SECTION III
SUBSECTION NCA-3250, NCA-8000

2. Reference those qualification standards, used as a guide to qualify the component: _____
REG. GUIDES 1.48, 1.61, 1.92

3. Have acceptance criteria been established and documented in the test plan(s) for the component?
☒ Yes ☐ No
4. Are the margins* identified in the qualification documentation? ☒ Yes ☐ No
5. Was the component that was qualified a model or an actual assembly? ACT. ASSEMBLY. If a model, what was its scale? _____. If an actual assembly, was it qualified as an assembly or by sub-assemblies? (i.e., valve, actuator, pump, driver) _____

6. List all component tests performed or to be performed that demonstrate qualification:
HYDROSTATIC TEST
SEAT CLOSURE TEST
SETTING & FUNCTION TEST
FLOW TEST

* Margin is the difference between design basis parameters and the test parameters used for equipment qualification.



7. List all component analyses performed that demonstrate qualification:

STATIC ANALYSIS OF VACUUM RELIEF
VALVE (SEISMIC / HYDRODYNAMIC +
OPERATING LDS.)

8. As a result of any of the tests (or analysis), were any deviations from design requirements identified?
() Yes (✓) No If "Yes", briefly describe any changes made in tests (or analyses) or to the component to correct the deviation.

9. Was the tested component precisely identical (as to model, size, etc.) to the in-plant component? (✓) Yes
() No. If "No", is installed component () oversized or
() undersized?

10. Is component orientation sensitive? (✓) Yes () No
() Unknown If "Yes", does installed orientation coincide with test/analysis orientation? (✓) Yes
() No

List all loads and numerical values used during tests or analysis and indicate whether applied individually or in combination:

1) ANALYSIS: RESULTANT SEISMIC ACCEL.
 $= [16.0^2 + 16.0^2 + (14.0 + 1.0)^2]^{1/2} = 27.15g$; PRESSURE = 570 PSI

2) HYDROSTATIC TEST: PRESSURE = 855 PSI

3) SEAT CLOSURE TEST: PRESSURE = 570 PSI

4) SETTING / FUNCTION TEST: FORCE = 4.4 LBS



11. Does the component have a unique design or utilize unique materials in its construction? (Examples are special gaskets or packings, one of a kind components, limitations on nonferrous materials, special coatings or surfaces, etc.)

(✓) Yes () No If "Yes" identify: _____

HI TEMP POLY PACK SEAL OF EPDM

12. What is the design (qualified) life of the component, exclusive of normal maintenance items such as packings, bearings, seals, diaphragms, gaskets, and other elastomers?

40 YR

13. Which of the components normal maintenance items requires the most frequent replacement? _____

SEALS What is the normal time interval between replacements of this item?

5 YR (MANUFACTURER RECOMMENDATION)

14. What is the harshest (accident/post-accident) external environment that the component could be exposed to during its qualified life? (e.g., temp., press., humidity, submergence, radiation type and dose, etc.)

ZONE PC250620

NORMAL RADIATION: 4.3×10^7 RADS - GAMMA
 2.9×10^5 RADS - BETA
 1.4×10^{13} NTN/CM² NEUTRONS

ACCIDENT RADIATION: 5.1×10^7 RADS GAMMA
 6.3×10^6 RADS BETA

TEMP: NORMAL 150°F MAX
ACCIDENT 310°F MAX

RELATIVE HUMIDITY: ALL STEAM



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
LA241-471 REV. A	DESIGN ANALYSIS FOR 5"/10" VACUUM RELIEF VALVE	4-19-84	GPE CONTROLS	SWEC (SDDF STRS 05.360-5010C) (SDDF STRS 05.360-5010B)
DWG. LD244-17 REV. AB (AS-BUILT)	5"/10" DYNAMIC LOAD VACUUM RELIEF VALVE	7-11-84	GPE CONTROLS	SWEC FILE NO. 05.360-802-300E
LA-241474	INSTRUCTION MANUAL OPERATION; MAINTENANCE INSTRUCTIONS	12-13-83	GPE CONTROLS	SWEC (SDDF INST 05.360-5013D) STATUS AAR
LA 241-466/A	SEAT TEST PROC. & REPORT (10"/5")	12-02-83	GPE CONTROLS	SWEC (SDDF TEST 05.360-505B)
LA241-468/0	WALL THICKNESS EVALUATION PROC. AND RECORDS	12-06-83	GPE CONTROLS	SWEC (SDDF TEST 05.360-5019A)
LA241-467/0	SETTING AND FUNCTION TEST PROCEDURE AND TEST REPORT	10-17-83	GPE CONTROLS	SWEC (SDDF PROC 05.360-5022A)
LA 249-35	FLOW TEST PROCEDURE & SUPPLEMENTS (10"/5")	12-20-83	GPE CONTROLS	SWEC (SDDF TEST 05.360-5013B)
12177-EP-11C-7	MAIN STEAM SAFETY RELIEF VALVES VENTS & DRAINS	1-17-85	SWEC	SWEC



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
12177-EP-11F-7	MAIN STEAM SAFETY & RELIEF VALVES VENTS & DRAINS	1-17-85	SWEC	SWEC
12177-FSK-32-8A REV. 2	FLOW DIAGRAM - MAIN STEAM SAFETY/RELIEF VALVES VENTS AND DRAINS	9-21-84	SWEC	SWEC
FIGURE FSAR 10.1-30	MAIN STEAM SYSTEM P&ID	- (NONE SHOWN)	SWEC	SWEC
MEQ P305B REV. 1	MECHANICAL EQUIP. QUAL. - MAIN STEAM SRV VACUUM BREAKER	3-27-85	SWEC	SWEC
EQEDC-1	EQUIPMENT QUALIFICATION ENVIRONMENTAL DESIGN CRITERIA	5-2-84	SWEC	SWEC
IR NO. N2P305B 3004	QUALITY ASSURANCE INSPECTION REPORT - TYPE B	2-25-84	SWEC	SWEC
SPEC. NMP2-P305B	SPECIFICATION FOR VACUUM BREAKERS ASME III CODE CLASS 3 (INCLUDING ADDENDA 1 & 2)	5-3-83 4-26-83	SWEC	SWEC



SPEC. NO. P304Y
PVORT-#17

NINE MILE POINT NUCLEAR STATION UNIT 2

EQUIPMENT DYNAMIC QUALIFICATION

COMPONENT NAME: 18" - DOUBLE FLANGE STOP VALVE
WITH STAB-O-25/1446C

MARK NUMBERS: 2 RHS * MOV 2A



STONE & WEBSTER



PUMP AND VALVEOPERABILITY ASSURANCE REVIEWI. PLANT INFORMATION

1. Name: Nine Mile Point Unit No. 2 2. Docket No.: 50-410
3. Utility: Niagara Mohawk Power Corporation
4. NSSS: General Electric Co. () PWR (X) BWR
5. A/E: Stone & Webster Engineering Corporation
6. C.P. and/or O. L. SER date 6/24/74

II. GENERAL COMPONENT* INFORMATION

1. Supplier: () NSSS (X) BOP
2. Location: a. Building/Room ABN (AUXILIARY BAY NORTH)
b. Elevation 183'-0" Col. 11.00 Line E
c. System RESIDUAL HEAT REMOVAL (RHS/RHR)
3. Component I.D. No. on P&ID dwg. E12 * F006A (2RHS * 1MOV2A)
4. If component is a () Pump complete II.5.
If component is a (X) Valve complete II.6.
5. General Pump Data (NOT APPLICABLE)
a. Pump b. Prime-mover
Name _____ Name _____
Mfg. _____ Mfg. _____
Model _____ Model _____
S/N _____ S/N _____
Type _____ Type _____

* The component, whether pump or valve, is considered to be an assembly composed of the body, internals, prime-mover (or actuator) and functional accessories.



a. Pump (Continued)

Overall
Dimensions _____

Weight _____

Mounting
Method _____

Required B.H.P. _____

Parameter	Component	System
	Design	Normal/Accident
Press	_____	_____/_____/_____
Temp	_____	_____/_____/_____
Flow	_____	_____/_____/_____
Head	_____	_____/_____/_____
Media	_____	_____/_____/_____

Required NPSH at maximum

flow _____

Available NPSH _____

Operating Speed _____

Critical Speed _____

List functional accessories:*

b. Prime-mover (Continued)

Overall
Dimensions _____

Weight _____

Mounting
Method _____

H.P. _____

Prime Mover Requirements: (include
normal, maximum and minimum)

Motor(Voltage) _____

Turbine (pressure) _____

If MOTOR list:

Duty cycle _____

Stall current _____

Class of insulation _____

* Functional accessories are those sub-components not supplied by the manufacturer that are required to make the pump assembly operational, (e.g., coupling, lubricating oil system, speed control sys., feedback, etc.)



6. General Valve Data

a. Valve

18" DOUBLE FLANGED STOP VALVE
Name WITH SMB-0-25/H4BC

Mfg. CLOW

Model TRICENTRIC

S/N 76-1460 (N)-01

Type MOTOR OPERATED STOP VALVE

Size 18"

Weight 1215 VALVE ONLY

Mounting

Method FLG BOLTED

Max. Required

Torque 2400 ft-lbs

Parameter	Component Design	System Normal/Accident
Press (PSIG)	<u>220</u>	<u>110 / 40</u>
Temp (°F) MEDIA	<u>358</u>	<u>70-358 / 212</u>
Flow (GPM)	<u>7450</u>	<u>7450 / 0</u>
Media	<u>WATER</u>	<u>WATER / WATER</u>
Max ΔP across valve	<u>150 PSIG</u>	

Closing time @ max ΔP 90 SEC @ 150 PSIG

Opening time @ max ΔP 90 SEC @ 150 PSIG

List functional accessories:*

b. Actuator (if not an integral unit)

Name MOTOR OPERATED ACTUATOR

Mfg. LIMITORQUE

Model SMB-0-25/H4BC

MOTOR - 3C5537A1
S/N ACTUATOR - 309999
H4BC - 310000

Type MOTOR OPERATED

Size SMB-0-25

Weight 880 LBS (APPROX)

Mounting

Method BOLTED TO ADAPTER HOUSING

Max. Delivered

Torque 19200 ft-lbs

Power Requirements: (include normal, maximum and minimum).

Electrical

NORMAL 575V / 3Ø / 60Hz

MAX. 633V / 3Ø / 60Hz

MIN. 460V / 3Ø / 60Hz

Other: () Pneumatic () Hydraulic

* Functional accessories are those sub-components not supplied by the manufacturer that are required to make the valve assembly operational, (e.g., limit switches, solenoid valves, accumulators, etc.)



III. FUNCTION

1. Briefly describe components' normal and safety functions (include accident initiating signals.)

Normal: PROVIDES FLOW PATH FOR SHUTDOWN

COOLING VALVE NORMALLY CLOSED.

Safety: ISOLATES SHUTDOWN COOLING FLOW PATH

REQUIRES TO OPERATE IF ACCIDENT OCCURS DURING SHUTDOWN

2. The components normal state is: () Operating () Standby
3. Safety function:
- | | |
|--|---|
| a. () Emergency reactor shutdown | b. () Containment heat removal |
| c. () Containment isolation | d. (X) Reactor heat removal |
| e. (X) Reactor core cooling | f. () Prevent significant release of radioactive material to environment |
| g. () Does the component function to mitigate the consequences of one or more of the following events? (X) Yes () No | |
| (X) LOCA | (X) HELB |
| () Other | (X) MSLB |

4. Safety requirements:

(X) Intermittent Operation (X) During postulated event
() Continuous Operation (X) Following postulated event

If component operation is required following an event, give approximate length of time component must remain operational.
100 DAYS (e.g., hours, days, etc.)

5. For VALVES:

does the component () Fail open () Fail closed (X) Fail as is

Is this the fail safe position? (X) Yes () No

Is the valve used for throttling purposes? () Yes (X) No

What is the maximum acceptable internal and external leakrate?

3 CC/MIN.

0



IV. QUALIFICATION

1. Reference by specific number those applicable sections of the design codes and standards applicable to the component: ASME SECT. III, SECTION NC, 1974 Edition, and

APPENDIX THROUGH 9 INCLUDING WINTER 1976

2. Reference those qualification standards, used as a guide to qualify the component: IEEE 323-1974, 344-1975, 382-1972.

NRC REG. GUIDE 1.48, 1.61, 1.73, 1.89, 1.100, 1.148

3. Have acceptance criteria been established and documented in the test plan(s) for the component?

(X) Yes () No

4. Are the margins* identified in the qualification documentation? () Yes (X) No

5. Was the component that was qualified a model or an actual assembly? Assembly. If a model, what was its scale? . If an actual assembly, was it qualified as an assembly or by sub-assemblies? (i.e., valve, actuator, pump, driver) Assembly for shop tests, static deflection test, Sub-assembly for operator dynamic test.

6. List all component tests performed or to be performed that demonstrate qualification:

1) STATIC DEFLECTION TEST - VALVE ASSEMBLY

2) SEISMIC TYPE TEST - LIMITORQUE ACTUATOR

3) HYDROSTATIC SHELL & SEST TEST - VALVE ASSEMBLY

4) MOTOR TEST - LIMITORQUE MOTOR

a) LOCKED ROTOR

b) DIELECTRIC TEST

5) MOTOR OPERATOR/ACTUATOR PRODUCTION TEST - LIMITORQUE ACTUATOR

a) TORQUE TEST

b) STALLED TORQUE TEST

6) PERFORMANCE/CYCLE TESTS - VALVE ASSEMBLY

7) ENVIRONMENTAL TESTS - LIMITORQUE ACTUATOR

a) RADIATION AGING

b) THERMAL AGING

c) LOCA TEST



7. List all component analyses performed that demonstrate qualification:

STATIC SEISMIC ANALYSIS - VALVE ASSEMBLY
ARRHENIUS TECHNIQUES - TO CALCULATE QUALIFIED LIFE & EXTENDED PAOP (A)

8. As a result of any of the tests (or analysis), were any deviations from design requirements identified?
 (X) Yes () No If "Yes", briefly describe any changes made in tests (or analyses) or to the component to correct the deviation.

DUE TO LIMITORQUE ACTUATOR TESTING LIMIT SWITCH SCREWS & BOLT TORQUES TO BE ADJUSTED & LIMIT SWITCH FINGER ASSEMBLY GAPS TO BE ADJUSTED.

9. Was the tested component precisely identical (as to model, size, etc.) to the in-plant component? () Yes (X) No. If "No", is installed component (X) oversized or () undersized?

10. Is component orientation sensitive? (X) Yes () No () Unknown If "Yes", does installed orientation coincide with test/analysis orientation? (X) Yes () No

List all loads and numerical values used during tests or analysis and indicate whether applied individually or in combination:

1) STATIC SEISMIC ANALYSIS - DYNAMIC LOAD,

2) SEISMIC TYPE TEST - LIMITORQUE ACTUATOR (B)

Ε. ΝΕΥΡΥΠΟΕΣ
ΑΣΥΝΗΤΗΡΕΣ

ΕΛΛΗΝΙΚΗ

ΕΠΙΣΤΗΜΗ

ΕΚΔΟΣΕΙΣ

ΕΚΔΟΣΕΙΣ

ΕΚΔΟΣΕΙΣ

ΕΚΔΟΣΕΙΣ

ΕΚΔΟΣΕΙΣ

ΕΚΔΟΣΕΙΣ

ΕΚΔΟΣΕΙΣ

ΕΚΔΟΣΕΙΣ

ΕΚΔΟΣΕΙΣ

ΕΚΔΟΣΕΙΣ

ΕΚΔΟΣΕΙΣ

ΕΚΔΟΣΕΙΣ

3. STATIC DEFLECTION TEST -

4. HYDROSTATIC SHELL TEST - DISC IN OPEN POSITION WITH
1125 PSI APPLIED & HELD FOR 10 MINUTES.

5. HYDROSTATIC SEAT TEST - VALVE CLOSED & PRESSURE
OF 170 PSI APPLIED TO SWIFT SIDE OF DISC &
HELD FOR 1 MINUTE

6. MOTOR OPERATOR / ACTUATOR PRODUCTION TESTS

a) TORQUE TEST - 75600 IN-LBS @ 460 VOLTS, MAXIMUM SETTINGS

TORQUE SWITCH IN OPEN POSITION
- 84000 IN-LBS @ 460 VOLTS, MAXIMUM SETTINGS

b) STALLED TORQUE TEST - 230400 IN-LBS @ 628V

TORQUE SWITCH IN OPEN POSITION
IN OPEN POSITION
257280 IN-LBS @ 628V
IN CLOSED POSITION

7. MOTOR TEST

a) LOCKED ROTOR - 9.0 AMPS

b) DIELECTRIC TEST - 15 MINUTES

8. PERFORMANCE / CYCLE TEST - OPEN / CLOSE 3 TIMES
1 CYCLE AT 150 PSI AT 460 VOLTS

9. ENVIRONMENTAL TESTS

a) RADIATION AGING - 1.66×10^8 RADS GAMMA - APPLIED INDIVIDUALLY
NORMAL 122°F

* b) THERMAL AGING - ACCIDENT 250°F & 25 PSI G - APPLIED TOGETHER

* c) RH - NORMAL / ACCIDENT 100% - APPLIED WITH b



1944
(6)

1944



1944



11. Does the component have a unique design or utilize unique materials in its construction? (Examples are special gaskets or packings, one of a kind components, limitations on nonferrous materials, special coatings or surfaces, etc.)

() Yes (X) No If "Yes" identify: _____

12. What is the design (qualified) life of the component, exclusive of normal maintenance items such as packings, bearings, seals, diaphragms, gaskets, and other elastomers?

36 YEARS (FOR THE ACTUATOR^(A))

13. Which of the components normal maintenance items requires the most frequent replacement? LIMIT SWITCH GASKETS

& LUBRICANTS What is the normal time interval between replacements of this item?

EVERY 18 MONTHS ^(B)

14. What is the harshest (accident/post-accident) external environment that the component could be exposed to during its qualified life? (e.g., temp., press., humidity, submergence, radiation type and dose, etc.) ^(C)

TEMP - 175°F

PRESSURE - 2.8 PSIG

HUMIDITY - 100% RH

GAMMA (ACCIDENT) - 6.3×10^7

BETA (ACCIDENT) - 1.3×10^7

SPRAY / SUBMERGENCE - NOT APPLICABLE

(A) SWEC CALC. 12177-EQ3-025

(B) L-Torque Rpt. B0058, Appendix A, Lubrication & Maintenance Data (IEEE 05.360.5012A)

(C) EQ EDC-1



1

Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
SPEC. P304Y REV. 3	Specification for Manual & Motor-Operated Rotary, Tague Closed Carbon Steel Valves	5-17-85	SWEC	SWEC
E+DCRS: P13259 P02621		2-13-85 6-18-85		
D0220C REV. C	18" STOP VALVE R.H.	4-17-80	CLOW	SWEC
02-442 0355-4 REV. B	LIMITORQUE VALVE CONTROL	11-14-77	LIMITORQUE CORP.	SWEC
12177-EP 71A-10	RESIDUAL HEAT REMOVAL PIPING - REACTOR BLDG.	2-27-85	SWEC	SWEC
12177-EP 71D-10	RESIDUAL HEAT REMOVAL PIPING - REACTOR BLDG.	2-27-85	SWEC	SWEC
FIG, 5,4-13 (2 OF 2)	RESIDUAL HEAT REMOVAL SYSTEM P & ID		SWEC	SWEC
12177- FSK-27-7F REV. 8	FLOW DIAGRAM RESIDUAL HEAT REMOVAL	10-31-84	SWEC	SWEC



Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
PEI-TR-852300-1	SEIS. QUAL. ANAL. OF CLOW 18" DOUBLE FLANGED STOP VALVES GROUP 1	5-7-85	PATEL ENGINEERS / CLOW	SWEC (STRS 05.360-5041A)
B0058	LIMITORQUE VALVE ACTUATOR QUALIF. FOR NUCLEAR POWER STATION SERVICE	1-11-80	LIMITORQUE CORP.	SWEC (IEEE 05.360-5012A)
B-0115	HYDRODYNAMIC VIBRATION TESTING (NEW LOADS)	6-24-82	LIMITORQUE CORP.	SWEC (TEST 05.360-5039A)
16573-81N REV. 3	REPORT OF TEST FOR DYNAMIC TESTING OF TWO(2) VALVE ASSEMBLIES, 2MSI*MOVIA AND 2CCP*MOV14B, AND TWO ACTUATORS SMB-000-5 AND SMB-0-25	8-04-82	ACTION ENV. TESTING CORP.	SWEC (STRS 05.312-5000B)
548-9291 REV. 2	DYNAMIC TESTING OF LIMITORQUE OPERATORS AND MODIFIED LIMIT SWITCHES	5-25-82	NATIONAL TECHNICAL SYSTEMS	SWEC (NMP2-P801H 6-10-82 T4T, L22)

65-147
MAY 10 1962
FBI - NEW YORK

Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
58941 REV. A	NUCLEAR ENV. QUAL. TEST REPORT ON LIMITORQUE SMB-0-25 H4BL (AC) MOTOR ACTUATOR L371036	1-11-85	WYLE / GE	SWEC (IEEE 016.820-5003C)
	TORQUING OF SCREWS LIMITORQUE ACTUATORS (IOM)	5-30-85	SWEC	SWEC
12177- NM(C)- MS-1942 REV. D	SIMILARITY ANALYSIS FOR DYN. QUAL. OF LIMITORQUE MOTOR OPERATORS	5-31-85	SWEC	SWEC
12177- NM(C)- MS-1939 REV. O	REPORT FOR THE DYN. QUAL. OF GATE & GLOBE VALVE ASSEMBLIES AND LIMITORQUE OPERATORS (SMB-000-5 AND SMB-0-25)	2-21-85	SWEC	SWEC
4-21-81- 01 AND 4-21-81 -02 REV. A	FUNCTIONAL QUALIFICATION PROGRAM FOR POWER OPERATED SAFETY RELATED CLOW- TRICENTRIC NUCLEAR VALVES (WYLE NO. 44852-2 REV. A)	11-18-82	CLOW / WYLE	SWEC

Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
N/A	FUNCTIONAL QUALIFICATION PROGRAM FOR POWER OPERATED SAFETY RELATED CLOW-TRICENTRIC NUCLEAR VALVES	4-21-81	CLOW	SWEC
N/A	ACTUATOR SIZING CALC.		CLOW	SWEC
REV. A	OPERATION INSTRUCT. FOR CLOW TRICENTRIC ELECTRIC STOP VALVE	8-26-80	CLOW	SWEC (INST 05.360-5028A)
D0796G	30" CHECK VALVE ASSEMBLY	10-31-84	CLOW	SWEC (INST 05.360-5019B)
PA89381	90° ROTARY ACTUATOR SYSTEM INSTALL., OP., AND MAINT. MANUAL FOR NMP2	8-84	CLOW	SWEC (INST 05.360-5022A)
REV. A	OPERATION INSTR. FOR CLOW TRICENTRIC CHECK VALVE	8-26-80	CLOW/LIMITORQUE	SWEC (INST 05.360-5027A)
84-2896-01 (N)	OPERATION AND MAINTENANCE MANUAL	12-17-84	CLOW	SWEC (INST. 05.360-5019A)
83-2063-01 (N)	OPERATION AND MAINTENANCE MANUAL CLOW TRICENTRIC STOP VALVE	1-7-85	CLOW	SWEC (INST. 05.360-5018A)

12

(A) 1000-1000-1000 1000-1000-1000		
1000-1000-1000 1000-1000-1000		
1000-1000-1000 1000-1000-1000		
1000-1000-1000 1000-1000-1000	1000-1000-1000 1000-1000-1000	1000-1000-1000 1000-1000-1000

Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
83-2063-02(N)	OPERATION & MAINTENANCE MANUAL FOR CLOW	3-21-85	CLOW CORP.	SWEC (INST 05.360-5021A)
REV. A	OPERATION INSTRUCTIONS FOR CLOW TRICENTRIC ELEC. STOP VALVE	8-26-80	CLOW CORP.	SWEC
REV. B	OPER. INSTR. FOR CLOW TRICENTRIC MANUAL STOP VALVE	8-17-82	CLOW CORP.	SWEC (INST 05.360-5002A)
REV. A	OPER. INSTR. FOR CLOW TRICENTRIC STOP VALVE	6-2-83	CLOW CORP.	SWEC (INST 05.360-5004A)
REV. A	OPER. INSTR. FOR CLOW TRICENTRIC CHECK VALVE	8-26-80	CLOW CORP.	SWEC
REV. F	DOCUMENTATION CHECKLIST	12-12-80	CLOW CORP.	SWEC
EPS 30-49-720 REV. C	PERFORMANCE TEST PROCEDURE	3-28-84	CLOW CORP.	SWEC (TEST 05.360-5032A)
EPS 30-49-721	HYDROSTATIC SEAT TEST	3-21-83	CLOW CORP.	SWEC (TEST 05.360-5025A)
EPS 30-49-733 REV. D	HYDROSTATIC SHELL TEST	1-6-83	CLOW CORP.	SWEC (TEST 05.360-5024A)

[illegible]

Information Concerning Qualification Documents for the Component

Report Number	Report Title	Date	Company/Organization Preparing Report	Company/Organization Reviewing Report
85432 REV. A	ELECTRO-HYDRAULIC ROTARY OPERATOR ACCEPTANCE TEST PROCEDURE	8-2-83	BORG-WARNER / CLOW	SWEC (TEST 05.360-5023A)
N2P304Y 0023	QA INSPECTION REPORT	6-26-80	SWEC	SWEC
EQEDC -1 -	EQUIP. QUAL. ENV. DESIGN CRITERIA	5-2-84	SWEC	SWEC
MEQ P304Y REV. 1	ENV'T. EVALUATION OF NON-METALLICS	3-27-85	SWEC	SWEC
12177- NM(C)- MS-1975 REV. 0	FATIGUE EVALUATION AND GEAR BOX ATTACHMENT CALC. FOR CLOW VALVES 18 INS. GROUP 1	6-18-85	SWEC	SWEC
ED. GENE. 014	ELECTRICAL TEST PROCEDURE, MOTOR OPERATED VALVES	—	SWEC	SWEC

