



Donald W. Gregoire
Columbia Generating Station
P.O. Box 968, PE20
Richland, WA 99352-0968
Ph. 509.377.8616 | F. 509.377.4674
dwgregoire@energy-northwest.com

February 20, 2018

GO2-18-029

10 CFR 50.54(q)

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 205551

Subject: **COLUMBIA GENERATING STATION, DOCKET NO. 50-397;
SUMMARY OF CHANGES AND ANALYSIS FOR REVISION 49 OF PPM 13.1.1
CLASSIFYING THE EMERGENCY, REVISION 33 OF PPM 13.1.1A
CLASSIFYING THE EMERGENCY - TECHNICAL BASES, REVISION 38 OF
PPM 13.8.1 EMERGENCY DOSE PROJECTION SYSTEM OPERATIONS, AND
EMERGENCY RESPONSE DATA SYSTEM**

Dear Sir or Madam:

Enclosed is the summary of changes for the following EPlan Implementing Procedures (EPIP) which were implemented on January 17, 2018:

- Revision 49 of PPM 13.1.1 Classifying The Emergency
- Revision 33 of PPM 13.1.1A Classifying The Emergency – Technical Bases
- Revision 38 of PPM 13.8.1 Emergency Dose Projection System Operations
- Emergency Response Data System (ERDS) data point update.

The changes to these EIPs have been evaluated in accordance with 10 CFR 50.54(q) and 10 CFR 72.44(f). The EIPs, as revised, continue to meet the standards of 10 CFR 50.47(b) and the requirements of 10 CFR 50 Appendix E.


One ERDS data point for the Reactor Building Process Radiation Monitoring has been replaced with a new data point and units updated from counts per second (cps) to $\mu\text{Ci/cc}$. ERDS continues to meet the standards of 10 CFR 50, Appendix E, Section VI.3.

The Enclosure contains a summary of changes. Each change was evaluated in accordance with the station's 10 CFR 50.54(q) evaluation process. These changes do not create a reduction in effectiveness of the approved EPlan and listed EIPs.

This submittal contains no new or revised regulatory commitments. Should you have any questions or desire additional information regarding these matters, please contact Sean E. Clizbe at (509) 377-4398.

Executed on the 20th day of February, 2018.

Respectfully,

A handwritten signature in black ink, appearing to read "D. W. Gregoire". The signature is fluid and cursive, with the first letters of the first and last names being capitalized and prominent.

D. W. Gregoire
Manager, Regulatory Affairs and Performance Improvement

Enclosure: Summary of Changes

cc: NRC Region IV Administrator
NRC NRR Project Manager
NRC Sr. Resident Inspector / 988C
Director – Spent Fuel Storage & Transportation, NMSS
CD Sonoda, BPA / 1399 (email)
WA Horin – Winston & Strawn (email)