



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

Technical Specifications Task Force  
11921 Rockville Pike, Suite 100  
Rockville, MD 20852

SUBJECT: PLANT-SPECIFIC ADOPTION OF TRAVELERS TSTF-51, REVISION 2, "REVISE CONTAINMENT REQUIREMENTS DURING HANDLING IRRADIATED FUEL AND CORE ALTERATIONS," TSTF-286, REVISION 2, "OPERATIONS INVOLVING POSITIVE REACTIVITY ADDITIONS," AND TSTF-471, REVISION 1, "ELIMINATE USE OF TERM CORE ALTERATIONS IN ACTIONS AND NOTES"

Dear Members of the Technical Specifications Task Force:

By letter dated November 7, 2013 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML13246A358), the U.S. Nuclear Regulatory Commission (NRC) staff identified potential operating issues with the continued adoption of the subject travelers related to core monitoring instrumentation and dose consequences. It was suggested in the letter that licensees not submit amendments to adopt these three Travelers until a final resolution was achieved.

After considerable review and analysis, NRC staff concludes that for certain facilities, license amendment requests (LARs) adopting TSTF-51 and TSTF-471 could result in exceeding the bounding licensing basis Fuel Handling Accident (FHA) analysis of record dose for the control room and is therefore considered an unanalyzed condition.

Consistent with the requirements stated in Title 10 of the *Code of Federal Regulations* Part 50 Sections 50.67 and 50.92, along with existing guidance in Regulatory Guides 1.183 and 1.195, Regulatory Issue Summaries 2001-19, 2006-04, and 2001-22, LARs should identify previously evaluated accidents that are affected by the proposed change, describe the radiological and non-radiological impacts including analysis assumptions, inputs, and methods in sufficient detail to support review by the NRC staff and explain why any change in the probability, consequences, or margins of safety is or is not significant.

To minimize the potential for being requested to provide needed information under existing requirements and guidance, licensees adopting TSTF-51 and TSTF-471 are reminded that their application should include the following information to support the NRC staff's review of the requested changes:

- Information describing the licensee's evaluation of "recently" irradiated fuel that demonstrates that after sufficient radioactive decay has occurred (from the time of shutdown) that the onsite and offsite radiological doses resulting from a FHA remain below the regulatory limits and the regulatory guidance limits, and;

- Traditionally, the worst case FHA of record (i.e., the drop of an irradiated fuel assembly and fuel handling tool onto an irradiated fuel assembly) has produced the highest resultant radiological dose at the onsite and offsite boundaries, which bounds the resultant radiological doses from lesser events. Licensees will need to review their plant-specific operating procedures and design basis documents and confirm that the proposed changes in TSTF-51 and/or TSTF-471 will not cause the resultant radiological doses at the onsite and offsite boundaries from dropping a load during core alterations to exceed those recorded in the FHA of record. The licensee's review should take into account only those safety systems required to be operable by the proposed technical specifications. If the resultant radiological doses mentioned above exceed those recorded in the FHA of record, then an additional licensing basis change will be required in order to adopt TSTF-51 and/or TSTF-471, which should be included in the TSTF-51 and/or TSTF-471 license amendment request.

Provided that the above information provided above is satisfactorily addressed, the NRC staff has determined that their initial concerns can be addressed without any changes needed to the travelers.

If you have any questions, please contact Michelle Honcharik at 301-415-1774 or via e-mail at [Michelle.Honcharik@nrc.gov](mailto:Michelle.Honcharik@nrc.gov).

Sincerely,

Victor Cusumano, Chief  
Technical Specifications Branch  
Division of Safety Systems  
Office of Nuclear Reactor Regulation

Project No. 753

Enclosed: As stated

cc: See next page

SUBJECT: PLANT-SPECIFIC ADOPTION OF TRAVELERS TSTF-51, REVISION 2,  
"REVISE CONTAINMENT REQUIREMENTS DURING HANDLING IRRADIATED  
FUEL AND CORE ALTERATIONS," TSTF-286, REVISION 2, "OPERATIONS  
INVOLVING POSITIVE REACTIVITY ADDITIONS," AND TSTF-471,  
REVISION 1, "ELIMINATE USE OF TERM CORE ALTERATIONS IN ACTIONS  
AND NOTES"  
DATED

DISTRIBUTION:

PUBLIC	MChernoff
RidsACRS_MailCTR	Robert Kuntz
RidsNrrDssStsb	RidsNrrDss
RidsNrrOd	RidsNrrDorl
RidsNrrPMMHoncharik	RidsNrrDssSrx
RidsOgcMailCenter	NRR_DORL_BC Distribution
RidsNrrDraArcb	NRR_DORL_PMs Distribution
RidsOpaMail	Mark Blumberg
RidsResOd	Summer Sun
RGrover	Kristy Bucholtz
MHamm	Jerry Dozier

**ADAMS Accession No.: Package: ML17346A598, Letter: ML17346A587, 11/7/2013 letter:  
ML13246A358**

**\*concurrent via e-mail**

**NRR-106**

OFFICE	DRA/ARCB/BC	DSS/SRXB/BC	DORL/BC	OGC	DSS/STSB/PM	DSS/STSB/BC
NAME	KHsueh	JWhitman			MHoncharik	VCusumano
DATE						

**OFFICIAL RECORD COPY**

PLANT-SPECIFIC INFORMATION FROM EACH LICENSEE IN ORDER TO ADOPT THE  
TRAVELERS TSTF-51, TSTF-286, AND TSTF-471

Technical Specifications Task Force

Project No. 753

cc:

Technical Specifications Task Force  
c/o EXCEL Services Corporation  
11921 Rockville Pike, Suite 100  
Rockville, MD 20852  
Attention: Brian D. Mann  
E-mail: [brian.mann@excelservices.com](mailto:brian.mann@excelservices.com)

James P. Miksa  
Entergy Nuclear Operations, Inc.  
Palisades Nuclear Power Plant  
27780 Blue Star Memorial Highway  
Covert, MI 49043  
Email: [jmiksa@entergy.com](mailto:jmiksa@entergy.com)

Jordan L. Vaughan  
Duke Energy  
EC2ZF / P.O. Box 1006  
Charlotte, NC 28202  
Email: [jordan.vaughan@duke-energy.com](mailto:jordan.vaughan@duke-energy.com)

Lisa L. Williams  
Energy Northwest  
Columbia Generating Station  
PO Box 968  
Mail Drop PE20  
Richland, WA 99352-0968  
E-mail: [llwilliams@energy-northwest.com](mailto:llwilliams@energy-northwest.com)

David M. Gullott  
Exelon Generation  
4300 Winfield Road  
Warrenville IL 60555  
Email: [David.Gullott@exeloncorp.com](mailto:David.Gullott@exeloncorp.com)

Wesley Sparkman  
Southern Nuclear Operating Company  
42 Inverness Center Parkway / Bin B237  
Birmingham, AL 35242  
Email: [wasparkm@southernco.com](mailto:wasparkm@southernco.com)