

NRR-DMPSPeM Resource

From: Pulvirenti, April
Sent: Friday, February 16, 2018 10:45 AM
To: Zamber, Maria; HARRIS, ALAN J
Cc: Pascarelli, Robert; Patel, Amrit
Subject: No RAIs for RAPTOR LAR dated November 28, 2017

Maria,

By letter dated November 28, 2017 (ADAMS Accession No. ML17332A898), Waterford Unit 3 submitted a license amendment request (LAR) to revise Section 4.3.3 of the Waterford 3 Updated Final Safety Analysis Report to indicate that the RAPTOR-M3G code is used for reactor vessel fluence calculations. The NRC staff has reviewed the application and has determined that there will be no requests for additional information (RAIs) pertaining to the LAR as it applies to the current operating license.

It should be noted that Attachment 3 of the November 28, 2017 submittal applies to the period of extended operation (PEO) and has been identified, by letter dated December 7, 2017 (ADAMS Accession No. ML17341B295) as a separate supplement to the Waterford 3 license renewal application. RAPTOR as it applies to the PEO is being reviewed separately as part of license renewal.

Thank you,

April

Dr. April L. Pulvirenti
Project Manager, Waterford Unit 3
United States Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
301-415-1390

Hearing Identifier: NRR_DMPS
Email Number: 173

Mail Envelope Properties (April.Pulvirenti@nrc.gov20180216104500)

Subject: No RAIs for RAPTOR LAR dated November 28, 2017
Sent Date: 2/16/2018 10:45:19 AM
Received Date: 2/16/2018 10:45:00 AM
From: Pulvirenti, April

Created By: April.Pulvirenti@nrc.gov

Recipients:

"Pascarelli, Robert" <Robert.Pascarelli@nrc.gov>
Tracking Status: None
"Patel, Amrit" <Amrit.Patel@nrc.gov>
Tracking Status: None
"Zamber, Maria" <mzamber@entergy.com>
Tracking Status: None
"HARRIS, ALAN J" <aharris@entergy.com>
Tracking Status: None

Post Office:

Files	Size	Date & Time
MESSAGE	1073	2/16/2018 10:45:00 AM

Options

Priority:	Standard
Return Notification:	No
Reply Requested:	No
Sensitivity:	Normal
Expiration Date:	
Recipients Received:	