



Public Service Electric and Gas Company 80 Park Plaza Newark, N.J. 07101 Phone 201/430-7000

March 2, 1981

Mr. Boyce Grier, Director
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406



Dear Mr. Grier:

RADIOACTIVE EFFLUENT RELEASE REPORT RERR-9I
SALEM NUCLEAR GENERATING STATION
UNIT NO. 1, DOCKET NO. 50-272
UNIT NO. 2, DOCKET NO. 50-311

As required by Section 5.6.1.2 of Appendix B of the Operating License for the Salem Nuclear Generating Station Unit Nos. 1 & 2, we hereby transmit two copies of the semiannual radioactive effluent release report, RERR-9I.

Additional analyses are being completed and will be submitted in the near future in a revised report.

The report summarizes liquid and gaseous releases and solid waste shipments from the Salem Nuclear Generating Station for the period July - December, 1980.

Very truly yours,

R. L. Mittl
General Manager -
Licensing and Environment

Attachment

CC: Director, Office of Inspection and Enforcement ✓
U.S. Nuclear Regulatory Commission
c/o Distribution Services Branch, DDC, ADM
Washington, D.C. 20555

(6)

*Acc 7
3/11*

R
M P79 43/10
The Energy People
8103060 547



SE&G

e Energy People

1980

SEMIANNUAL RADIOACTIVE
EFFLUENT RELEASE REPORT
RERR-9I

SALEM NUCLEAR GENERATING STATION
SALEM UNIT NOS. 1 & 2

UNIT 1 DOCKET NO. 50-272
UNIT 2 DOCKET NO. 50-311
OPERATING LICENSE NO. DPR-70
OPERATING LICENSE NO. DPR-75

INTERIM REPORT

MARCH 1981

DPR 70
DPR 75

REPORT NO. RERR-9I

UNIT NOS. 1 & 2
RADIOACTIVE EFFLUENT RELEASE REPORT
JULY - DEC 1980*

SALEM NUCLEAR GENERATING STATION
Public Service Electric and Gas Company

*Interim report pending the completion of
additional analyses

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

OFFICIAL BUSINESS

POSTAGE & FEES PAID
U.S. Nuclear Regulatory Commission



SALEM NUCLEAR GENERATING STATION
UNIT 1 50-272
UNIT 2 50-311

UNIT NOS. 1 AND 2
RADIOACTIVE EFFLUENT RELEASE REPORT
July 1, 1980 to December 31, 1980*

Introduction

This report, RERR-9I, summarizes the release of radioactive materials in liquid, gaseous and solid form from the Salem Nuclear Generating Station Units 1 and 2 for the period July 1, 1980 to December 31, 1980. As requested by the United States Nuclear Regulatory Commission (USNRC) this report was prepared in the format specified for all nuclear power plants as defined in USNRC Regulatory Guide 1.21.

Release of radioactive materials from the Salem station during the reporting period were within the limits set forth in the Environmental Technical Specifications. Calculated radiation exposures to off-site individuals were small fractions of the limits set forth in 10CFR20 and within Appendix I to 10CFR50 and 40CFR190 requirements.

Unit 1 generated 1,612,953 megawatts-hour of electrical energy for the period July 1, 1980 to December 31, 1980.

Unit 2 achieved initial criticality on August 2, 1980. The power level of Unit 2 did not exceed 5% of rated power for the report period.

Results of several analyses were not available for inclusion in this report. A revised report will be submitted when this data is available.

*Interim Report

A. SUMMARY INFORMATION

1.0 Regulatory Limits

Symbols utilized in the equations listed below under Sections 1.1 and 1.2 are the same as those used in the Salem Environmental Technical Specifications (ETS). The symbol Q as explained in Section 2.3.3 of the ETS is the release rate of the gaseous activity in units of curies per second. The K, L, M and N terms are actually site dependent dose conversion factors. The equations listed below in Sections 1.1 and 1.2 take into consideration the release point location, building wake effects and physical characteristics of the radionuclides released.

In addition 40CFR190 regulations require that the annual dose equivalent does not exceed 25 mrem to the whole body or any organ (except the thyroid which is limited to 75 mrem).

1.1 Fission and Activation Gases

Gaseous releases from the nuclear units are limited such that at no time will releases of gaseous radioactive materials cause a member of the general public to be exposed to an annual dose rate in excess of 500 mrem to the entire body or 3 rem to the skin in conformance with the requirements of 10CFR20.

Gaseous releases from the units are further restricted such that when releases are averaged over a calendar quarter no member of the general public will be exposed to an annual dose rate in excess of 20 millirads of gamma radiation or 40 millirads of beta radiation.

In addition, it is required that air doses averaged over a twelve month period be less than 40 and 80 millirads for gamma and beta radiation respectively.

At any instant the release rate of radioactive gases must satisfy the following equations whose basis is 10CFR20.

$$2.0 Q_{tv} * K_v \leq 1$$

$$0.33 Q_{tv} * (L_v + 1.1 N_v) \leq 1$$

When averaged over a calendar quarter the release rate for radioactive gases must satisfy the following equation. The basis for these equations is 10CFR50 Appendix I.

$$13 Q_{tv} * N_v \leq 1$$

$$6.3 Q_{tv} * M_v \leq 1$$

The limiting Unit 1 release limit Q is calculated to be 1.24E+5 and 6.53E+4 microcuries/sec for the 3rd and 4th quarters respectively.

The limiting Unit 2 release limit Q is calculated to be 6.04E+4 for both the 3rd and 4th quarters.

When averaged over any twelve consecutive month period, the release rate for radioactive gases must satisfy the following equation. The basis for this equation is 10CFR50 Appendix I.

$$25 Q_{tv} * N_v \leq 1$$

$$13 Q_{tv} * M_v \leq 1$$

The release limits of radioactive gases for the Salem Nuclear Generating Station are not fixed numbers, but depend upon the radioactive isotopes present in the effluent.

1.2 Iodine and Particulates, Half Life > 8 days

The regulatory limits for iodines and particulates are listed below.

The release rates of iodine and particulates are restricted such that no member of the general public will receive a dose at a rate in excess of 1.5 rem/yr. to the thyroid.

Releases of iodines and particulates are further restricted to prevent any member of the general public from receiving a dose rate in excess of 30 mrem in a calendar quarter or 60 mrem in any twelve month period. The equations which govern these conditions are listed below:

At any instant of time the release rate for radioactive iodines and particulates material with a half life greater than 8 days is limited by the equation below. The basis for this equation is 10CFR20.

$$(1.5 \times 10^5) Q_v \leq 1$$

During any calendar quarter the release limit is governed by the equations listed below. The basis for these equations is 10CFR50 Appendix I.

$$\begin{array}{c} 2 \text{ curies of I-131} \\ \text{and} \\ Q_v \times 13 (1.5 \times 10^5) \leq 1 \end{array}$$

During any twelve month period radioactive releases should conform to the following constraints of 10CFR50 Appendix I.

$$\begin{array}{c} 25 \times (1.5 \times 10^5) \times Q_v \leq 1 \\ \text{and} \\ 4 \text{ curies of I-131} \end{array}$$

1.3 Liquid Effluents

The regulatory limits for radioactive liquids released from the plant are governed by 10CFR20, Appendix B, Table II, Column 2.

In addition, the following limits apply:

The cumulative release of radioactive effluents, excluding tritium and dissolved gases, shall be less than 10 Ci in a calendar quarter for each unit.

The cumulative release of radioactive effluents, excluding tritium and dissolved gases, shall be less than 20 Ci in any twelve consecutive months.

2.0 Maximum Permissible Concentrations

Regulatory Guide 1.21 requires that the licensee provide the MPC's used in determining allowable release rates for radioactive releases. We have addressed this question below.

- a. Fission Gases - MPC values were not used to determine the maximum release rates.
- b. Iodines - MPC values were not used to determine the maximum release rates.
- c. Particulates, Half Lives > 8 days - MPC limits were not used to determine the maximum release rates.
- d. Liquid effluents - MPC values as stated in 10CR20, Appendix B, Table 11, Column 2 were used.

3.0 Average Energy

Regulatory Guide 1.21 requires that the licensee provide the average energy of the radionuclide mixture in releases of fission and activation gases, if applicable.

Release limits for the SNGS are not based upon average energy, hence, this section does not apply.

4.0 Measurements and Approximation of Total Radioactivity

4.1 Liquid effluents are monitored in accordance with Table 2.3-3 of the Environmental Technical Specifications. During the period of record, all wastes from the chemical drain tank and the laundry and hot shower tanks were routed to the hold-up tanks for monitoring. Technical Specifications require these tanks to be recirculated the equivalent of two tank volumes to produce uniform mixing and sample extraction and analyzation before any releases are made. Batch releases included releases from the waste monitor tanks, waste monitor hold-up tank, and the chemical and volume control tanks. Continuous releases included releases from intermittent blowdown of the steam generators. The predominate gamma emitting isotopes detected were Co58, Co60, Cs134, and Cs137. At no time did releases exceed limits.

4.2 Gaseous effluent streams are monitored in accordance with Table 2.3-4 of the Environmental Technical Specifications. The plant vent is the final release point of all planned gaseous effluents and is continually monitored by four very sensitive Geiger Mueller tubes. The vent is also continuously sampled for iodine and particulates with a charcoal cartridge and filter paper connected in series to a low volume air sampler. The filter and charcoal are changed weekly, weather permitting, and analyzed on a multichannel analyzer in the laboratory. Sampling is also performed on all gas decay tanks and containment purges prior to release to the environment. The results of these analyses are used as the basis for the cumulative release of gaseous effluents into the environment. All tritium samples were taken by bubbling gas through water and then counting the tritiated water on a liquid scintillation counter.

- 4.3 The estimated total error of the reported continuous gaseous releases is within 50%. This error is due primarily to variability of waste stream flow rates and changes in isotopic distributions of waste streams between sampling periods. The estimated total error of the reported batch gaseous releases is within 10%.

The estimated total error of reported liquid releases is within 25%.

5.0 Batch Releases

Batch releases of gaseous and liquid effluent are provided in Tables 4A-1 and 4B-1 for Unit 1 and 4A-2 and 4B-2 for Unit 2.

6.0 Unplanned Releases

There were no unplanned releases to an unrestricted area during this reporting period.

Part B. Gaseous Effluents

See Summary Tables 1A-1 thru 1C-1 representative of Salem Unit 1 operations.

See Summary Tables 1A-2 thru 1C-2 representative of Salem Unit 2 operations.

Part C. Liquid Effluents

See Summary Tables 2A-1 and 2B-1 representative of Salem Unit 1 operations.

See Summary Tables 2A-2 and 2B-2 representative of Salem Unit 2 operations.

Part D. Solid Waste

See Summary Table 3-1 - Unit 1

See Summary Table 3-2 - Unit 2

Part E. Radiological Impact on Man*

The calculated individual doses in this section are based on actual locations of nearby residents and farms. The population dose impact is based on the projected 1980 population and historical site specific data i.e., food production, milk production, feed for milch animals and seafood production.

The doses were calculated using methods described in Regulatory Guide 1.109 and represent calculations for the six month reporting interval. Doses from batch and continuous releases were calculated using the meteorological dispersion coefficient X/Q for the six month reporting interval.

Liquid Pathways

Doses to individuals in the population from liquid releases are primarily from the seafood ingestion pathway. The total body dose to an individual was calculated to be $1.45\text{E}-2$ mrem. The calculated population total body dose was $2.51\text{E}-1$ person-rem. The highest organ dose from liquid releases was $4.14\text{E}-1$ mrem to the gastrointestinal tract.

Air Pathways

The resulting whole body and skin doses to an individual were calculated to be $2.94\text{E}-3$ mrem and $3.59\text{E}-3$ mrem respectively. The calculated population total body dose was $2.32\text{E}-1$ person-rem. The average total body dose to the population within fifty miles of the site was $4.31\text{E}-5$ mrem/person.

Direct Radiation

Direct radiation may be estimated by TLD measurements. One method for comparing TLD measurements is by comparison with preoperational data. TLD measurements on site near the Service Water pumps (location 11S1) and near the Circulating Water pumps (location 10S1) averaged 9.25 and 6.15 mrad/months, respectively, apparently due to trace activity in the Refueling Water Storage Tank.

TLD's at onsite locations 2S2 and 5S1 which are 0.3 miles and 0.9 miles from the reactor containment, averaged 4.61 and 3.72 mrad/month respectively. The values for stations 2S1 and 5S1 are within the statistical variation associated with the preoperation program results.

* Preliminary Assessment

All offsite monitoring locations remained within preoperational ranges. It should be noted that the nearest resident is 3.5 miles away. It can thus be concluded that there was no measurable dose to any offsite locations from direct radiation.

Part F. Meteorological Data

Cumulative joint wind frequency distribution by atmospheric stability class at the 300 foot elevation is provided for the third and fourth quarters of 1980 as Table 5 and 6.

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

OFFICIAL BUSINESS

POSTAGE & FEES PAID
U.S. Nuclear Regulatory Commission



TABLE 1A-1
EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT (1980)
GASEOUS EFFLUENTS-SUMMARY OF ALL RELEASES
UNIT

	Unit	3rd Quarter	4th Quarter	Est.Total(1) Error %
A. Fission & Activation Gases				
1. Total release	Ci	7.03E+01	4.85E-01	2.50E+01
2. Average release rate for period	uCi/sec.	9.04E+00	6.24E-02	
3. Percent of technical specification limit	%	1.82E-03	9.56E-05	
(See ETS Spec. 2.3.3.b)				
B. Iodines				
1. Total iodine-131	Ci	3.18E-03	6.45E-04	2.50E+01
2. Average release rate for period	uCi/sec.	4.09E-04	8.29E-05	
3. Percent of technical specification limit	%	7.97E-02	1.62E-02	
C. Particulates				
1. Particulates with half-lives > 8 days	Ci	2.09E-01	2.51E-03	2.50E+01
2. Average release rate for period	uCi/sec.	2.69E-02	3.22E-04	
3. Percent of technical specification limit	%	5.24E+00	6.28E-02	
4. Gross alpha radioactivity (2)	Ci	-	-	
D. Tritium				
1. Total release	Ci	*	*	
2. Average release rate for period	uCi/sec.	*	*	
3. Percent of technical specification limit	%	N/A	N/A	

(1) For batch releases the estimated overall error is within 10%.

(2) Analyses indicate no measurable alpha emitting transuranics.

* To be supplied later.

TABLE 1A-2
EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT (1980)
GASEOUS EFFLUENTS-SUMMARY OF ALL RELEASES
UNIT

	Unit	3rd Quarter	4th Quarter	Est.Total(1) Error %
A. Fission & Activation Gases				
1. Total release	Ci	9.09E-06	7.74E+00	2.50E+01
2. Average release rate for period	uCi/sec.	1.16E-06	9.95E-07	
3. Percent of technical specification limit (See ETS Spec. 2.3.3.b)	%	1.92E-09	1.65E-09	
B. Iodines				
1. Total iodine-131	Ci	4.37E-06	5.00E-05	2.50E+01
2. Average release rate for period	uCi/sec.	5.62E-07	6.43E-06	
3. Percent of technical specification limit	%	1.10E-04	1.25E-05	
C. Particulates				
1. Particulates with half-lives > 8 days	Ci	-	-	
2. Average release rate for period	uCi/sec.	-	-	
3. Percent of technical specification limit	%	-	-	
4. Gross alpha radioactivity (2)	Ci	-	-	
D. Tritium				
1. Total release	Ci	*	*	
2. Average release rate for period	uCi/sec.	*	*	
3. Percent of technical specification limit	%	N/A	N/A	

(1) For batch releases the estimated overall error is within 10%.

(2) Analyses indicate no measurable alpha emitting transuranics.

* To be supplied later.

TABLE 1B-1
EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT (1980)
GASEOUS EFFLUENTS-ELEVATED RELEASES

UNIT 1

CONTINUOUS MODE

BATCH MODE

Nuclides Released	Unit	3rd Quarter	4th Quarter	3rd Quarter	4th Quarter
1. Fission gases (1)					
Krypton-85	Ci			1.54E-01	
Krypton-85m	Ci			8.02E-01	2.65E-02
Krypton-87	Ci			1.62E-01	
Krypton-88	Ci			9.52E-01	
Xenon-133	Ci	2.05E-04		5.61E+01	4.59E-01
Xenon-135	Ci	1.14E-03		1.10E-01	
Xenon-135m	Ci			6.56E-01	
Xenon-138	Ci				
Xenon-133m	Ci			4.08E-01	
Argon-41	Ci			6.15E-02	
Fluorine-18	Ci			6.01E-03	1.01E-04
Unidentified	Ci				
Total for period	Ci	1.35E-03		7.03E+01	4.85E-01
2. Iodines (2)					
Iodine-131	Ci	3.18E-03	6.45E-04		
Iodine-133	Ci	8.97E-04			
Iodine-135	Ci				
Total for period	Ci	4.08E-03	6.45E-04		

TABLE 1B-1
EFFLUENT AND WASTE DISPOSAL SYSTEM ANNUAL REPORT (1980)
GASEOUS EFFLUENTS-ESTIMATED RELEASES
(Continued)
UNIT 1

CONTINUOUS MODE			BATCH MODE		
Nuclides Released	Unit 1	3rd Quarter	4th Quarter	3rd Quarter	4th Quarter
3. Particulates					
Chromium-51	Ci				1.21E-04
Manganese-54	Ci			1.15E-01	3.10E-04
Cobalt-58	Ci				1.08E-03
Cobalt-60	Ci				8.69E-04
Iron-59	Ci				3.00E-05
Rubidium-88	Ci			1.27E+00	
Yttrium-88	Ci			6.64E-02	
Strontium-89	Ci				
Strontium-90	Ci				
Niobium-95					4.50E-05
Zirconium-95	Ci				2.13E-05
Tin-117m	Ci			1.84E-02	
Cesium-134	Ci				1.41E-05
Cesium-137	Ci				1.99E-05
Cerium-139	Ci			9.38E-03	
Gross Alpha	Ci				
Total For Period	Ci			1.48E-00	2.51E-03
4. Tritium					
Tritium	Ci	*	*	*	*

(1) Other fission gases were below the detectable level (LLD) Approximately less than 6.67 E-07 uCi/ml).

(2) Iodine was below the minimal detection limit.

* To be supplied later.

TABLE 1B-2
EFFLUENT AND WASTE DISPOSAL SEMI-ANNUAL REPORT (1980)
GASEOUS EFFLUENTS-ELEVATED RELEASES

UNIT 2

CONTINUOUS MODE

BATCH MODE

Nuclides Released	Unit	3rd Quarter	4th Quarter	3rd Quarter	4th Quarter
-------------------	------	----------------	----------------	----------------	----------------

1. Fission gases (1)

Krypton-85	Ci				
Krypton-85m	Ci				
Krypton-87	Ci				
Krypton-88	Ci				
Xenon-133	Ci	1.86E-06	7.74E+00	7.23E-06	
Xenon-135	Ci				
Xenon-135m	Ci				
Xenon-138	Ci				
Xenon-133m	Ci				
Argon-41	Ci				
Fluorine-18	Ci				
Unidentified	Ci				
Total for period	Ci	1.86E-06	7.74E+00	7.23E-06	

2. Iodines (2)

Iodine-131	Ci	4.37E-06	5.00E-05		
Iodine-133	Ci				
Iodine-135	Ci				
Total for period	Ci	4.37E-06	5.00E-05		

TABLE 1B-2
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT (1980)
GASEOUS EFFLUENTS-ENVIRONMENTAL RELEASES
(Continued)
UNIT 2

Nuclides Released	Unit 2	CONTINUOUS MODE		BATCH MODE	
		3rd Quarter	4th Quarter	3rd Quarter	4th Quarter
3. Particulates					
Chromium-51	Ci				
Manganese-54	Ci				
Cobalt-58	Ci				
Cobalt-60	Ci				
Iron-59	Ci				
Rubidium-88	Ci				
Yttrium-88	Ci				
Strontium-89	Ci				
Strontium-90	Ci				
Niobium-95					
Zirconium-95	Ci				
Tin-117m	Ci				
Cesium-134	Ci				
Cesium-137	Ci				
Cerium-139	Ci				
Gross Alpha	Ci				
Total For Period	Ci	-	-	-	-

4. Tritium

Tritium	Ci	*	*	*	*
---------	----	---	---	---	---

- (1) Other fission gases were below the detectable level (LLD) Approximately less than 6.67 E-07 uCi/ml).
- (2) Iodine was below the minimal detection limit.
- * To be supplied later.

TABLE 1C
EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT 1980
UNITS 1 AND 2
GASEOUS EFFLUENTS-GROUND-LEVEL RELEASES

Nuclides Releases	Unit	3rd Quarter	4th Quarter	3rd Quarter	4th Quarter
-------------------	------	-------------	-------------	-------------	-------------

There were no ground level releases for the period of record.

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

OFFICIAL BUSINESS

POSTAGE & FEES PAID
U.S. Nuclear Regulatory Commission



TABLE 2A-1

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT (1980)

UNIT 1

LIQUID EFFLUENTS-SUMMATION OF ALL RELEASES

	Units	3rd Quarter	4th Quarter	Est. Total Error, %
A. Fission and activation products				
1. Total release (not including tritium, gases, alpha)	Ci	6.99E-01	1.29E+00	2.50E+01
2. Average diluted concentration during period	uCi/ml	4.99E-07	1.22E-07	
3. Percent of applicable limits of Technical Specifications	%	6.99E+00	1.29E+01	
B. Tritium				
1. Total release	Ci	*	*	2.50E+01
2. Average diluted concentration during period	uCi/ml	*	*	
3. Percent of applicable limit	%	N/A	N/A	
C. Dissolved and entrained gases				
1. Total release	Ci	2.65E+00	8.65E-02	2.50E+01
2. Average diluted concentration during period	uCi/ml	1.89E-07	8.16E-05	
3. Percent of applicable limit	%	N/A	N/A	
D. Gross alpha radioactivity				
1. Total release	Ci	0.00E+00	0.00E+00	2.50E+01
E. Volume of waste release (prior to dilution - Batch Release)				
	liters	5.77E+06	4.53E+06	1.00E+01
F. Volume of dilution water used during period - Batch Release				
	liters	1.40E+10	1.06E+10	2.50E+01

A - Not Applicable

To be supplied later

TABLE 2A-2

EFFLUENT AND WASTE DISPOSAL SEMI-ANNUAL REPORT (1980)

UNIT 2

LIQUID EFFLUENTS-SUMMATION OF ALL RELEASES

	Units	3rd Quarter	4th Quarter	Est. Total Error, %
Fission and activation products				
1. Total release (not including tritium, gases, alpha)	Ci	4.66E-03	3.84E-01	2.50E+01
2. Average diluted concentration during period	uCi/ml	5.04E-10	1.56E-07	
3. Percent of applicable limits of Technical Specifications	%	4.66E-02	3.84E+00	
Tritium				
1. Total release	Ci	*	*	*
2. Average diluted concentration during period	uCi/ml	*	*	
3. Percent of applicable limit	%	N/A	N/A	
Dissolved and entrained gases				
1. Total release	Ci	2.42E-04	0.00E+00	2.50E+01
2. Average diluted concentration during period	uCi/ml	2.62E-11	0.00E+00	
3. Percent of applicable limit	%	N/A	N/A	
Gross alpha radioactivity				
1. Total release	Ci	0.00E+00	0.00E+00	2.50E+01
Volume of waste release (prior to dilution - Batch Release)				
	liters	2.49E+06	8.45E+05	1.00E+01
Volume of dilution water used during period - Batch Release				
	liters	9.24E+09	2.46E+09	2.50E+01

N/A - Not Applicable

To Be Supplied Later

TABLE 2B-1

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT (1980)

LIQUID EFFLUENTS UNIT 1

Nuclides Released	Unit	CONTINUOUS MODE		BATCH MODE	
		3rd Quarter	4th Quarter	3rd Quarter	4th Quarter
Strontium-89	Ci				
Strontium-90	Ci				
Cesium-134	Ci			1.77E-01	5.66E-03
Cesium-137	Ci			2.31E-01	6.19E-03
Iodine-131	Ci			7.72E-02	1.18E-03
Iodine-133	Ci			3.86E-03	
Cobalt-58	Ci			4.36E-02	7.78E-01
Cobalt-60	Ci			1.41E-01	3.25E-01
Cadmium-109	Ci				
Manganese-54	Ci			8.52E-03	3.43E-02
Chromium-51	Ci			8.86E-03	7.45E-02
Cesium-136	Ci			9.76E-04	
Zirconium-95	Ci			4.78E-04	4.09E-03
Barium-113	Ci				
Barium-140	Ci				
Lanthanum-140	Ci				
Cerium-139	Ci				
Tungsten-187	Ci				
Niobium-95	Ci			2.52E-05	5.27E-03
Antimony-124	Ci				1.05E-02
Antimony-125	Ci			1.40E-04	
Tritium	Ci				
Iron-59	Ci			6.78E-03	4.12E-02
Sodium-24	Ci				1.19E-04
Yttrium-91	Ci				
Total for period (above)					
excluding H3	Ci			6.99E-01	1.29E+00
Xenon-133m	Ci			1.04E-02	
Xenon-133	Ci			2.62E+00	8.63E-02
Xenon-135	Ci	3.27E-03		2.11E-02	1.96E-04
Krypton-88	Ci				
Argon-41	Ci			5.58E-05	

(1) The Lower Limit of Detection (LLD) is approximately 1.00E-08 uCi/ml (Co 60).

TABLE 2B-2

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT (1980)

LIQUID EFFLUENTS UNIT 2

Nuclides Released	Unit	CONTINUOUS MODE		BATCH MODE	
		3rd Quarter	4th Quarter	3rd Quarter	4th Quarter
Strontium-89	Ci				
Strontium-90	Ci				
Cesium-134	Ci				4.22E-03
Cesium-137	Ci				4.93E-03
Iodine-131	Ci				
Iodine-133	Ci				
Cobalt-58	Ci			4.34E-03	2.62E-01
Cobalt-60	Ci				6.77E-02
Cadmium-109	Ci				
Manganese-54	Ci			3.22E-04	1.31E-02
Chromium-51	Ci				1.38E-02
Cesium-136	Ci				
Zirconium-95	Ci				
Tin-113	Ci				1.90E-03
Barium-140	Ci				
Antimony-140	Ci				
Cerium-139	Ci				
Tungsten-187	Ci				
Niobium-95	Ci				2.35E-03
Antimony-124	Ci				5.03E-03
Antimony-125	Ci				4.08E-03
*Tritium	Ci				
Iron-59	Ci				5.05E-03
Sodium-24	Ci				
Yttrium-91	Ci				
Total for period (above)					
excluding H3	Ci			4.66E-03	3.84E-01
Xenon-133m	Ci				
Xenon-133	Ci			2.42E-04	
Xenon-135	Ci				
Krypton-88	Ci				
Argon-41	Ci				

(1) The Lower Limit of Detection (LLD) is approximately 1.00E-08 uCi/ml (Co 60).

* Tritium values were not available at the time the report was tabulated.

TABLE 3

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT 1980

UNITS 1 AND 2

SOLID WASTE AND IRRADIATED FUEL SHIPMENTS

SOLID WASTE SHIPPED OFFSITE FOR BURIAL OR DISPOSAL (Not irradiated fuel)

1. Type of waste	Units	6-month Period	Est. Total Error, %
a. Spent resins, filters sludges, evaporator bottoms	m3 Ci	2.31E+02 3.10E+02	1.50E+01
b. Dry compressible waste, contaminated equip.	m3 Ci	6.61E+02 1.35E+01	1.50E+01
c. Irradiated components, control rods,	m3 Ci	0.00E+00 0.00E+00	
d. Others (describe)	m3 Ci	0.00E+00 0.00E+00	

2. Estimate of major nuclide composition (by type of waste)

a.	Cobalt - 58	80.4%	2.49E+02
	Cobalt - 60	16.3%	5.05E+01
	Manganese - 54	3.3%	1.02E+01
	Others		
b.	Cobalt - 58	50.4%	1.085E+01
	Cobalt - 60	16.3%	2.20E+00
	Manganese - 54	3.3%	0.45E+00
	Others		E
c.			E
d.			E

3. Solid Waste Disposition

<u>Number of Shipments</u>	<u>Mode of Transportation</u>	<u>Destination</u>
65	Truck	Barnwell, South Carolina

IRRADIATED FUEL SHIPMENTS (Disposition)

<u>Number of Shipments</u>	<u>Mode of Transportation</u>	<u>Destination</u>
None	N/A	N/A

TABLE 4A-1

SALEM NUCLEAR GENERATING STATION (1980)
UNIT 1

SUMMARY SHEET FOR RADIOACTIVE EFFLUENTS RELEASED
IN A BATCH MODE

BATCH RELEASES ONLY

1. Dates July 1 - Sept. 30, 1980
2. Type of release (Gas)
3. Number of releases during the 3rd Quarter 1.20E+01
4. Total time duration for all releases of type listed above
3.82E+02
minutes
5. Maximum duration for releases of type listed above 1.53E+03
minutes
6. Average duration for all releases of type listed above
3.19E+02
minutes
7. Minimum duration for release of type listed above 7.60E+01
minutes
8. For liquid batch releases only, provide the average stream
flow (dilution flow) during the period of release. N/A

TABLE 4A-2

SALEM NUCLEAR GENERATING STATION (1980)
UNIT 2

SUMMARY SHEET FOR RADIOACTIVE EFFLUENTS RELEASED
IN A BATCH MODE

BATCH RELEASES ONLY

1. Dates July 1 - Sept. 30, 1980
2. Type of release (Gas)
3. Number of releases during the 3rd Quarter 1.90E+01
4. Total time duration for all releases of type listed above
2.39E+03
minutes
5. Maximum duration for releases of type listed above 1.62E+02
minutes
6. Average duration for all releases of type listed above
1.26E+02
minutes
7. Minimum duration for release of type listed above 8.70E+01
minutes
8. For liquid batch releases only, provide the average stream
flow (dilution flow) during the period of release. N/A

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

OFFICIAL BUSINESS

POSTAGE & FEES PAID
U.S. Nuclear Regulatory Commission



TABLE 4A-1 (Cont'd)

SALEM NUCLEAR GENERATING STATION (1980)
UNIT 1

SUMMARY SHEET FOR RADIOACTIVE EFFLUENTS RELEASED
IN A BATCH MODE

BATCH RELEASES ONLY

1. Dates October 1 - Dec. 31, 1980
2. Type of release (Gas)
3. Number of releases during the 4th Quarter 2.30E+01
4. Total time duration for all releases of type listed above
7.49E+03
minutes
5. Maximum duration for releases of type listed above 1.61E+03
minutes
6. Average duration for all releases of type listed above
3.26E+02
minutes
7. Minimum duration for release of type listed above 7.60E+01
minutes
8. For liquid batch releases only, provide the average stream
flow (dilution flow) during the period of release. N/A

TABLE 4A-2 (Cont'd)

SALEM NUCLEAR GENERATING STATION (1980)
UNIT 2

SUMMARY SHEET FOR RADIOACTIVE EFFLUENTS RELEASED
IN A BATCH MODE

BATCH RELEASES ONLY

1. Dates October 1 - Dec. 31, 1980
2. Type of release (Gas)
3. Number of releases during the 4th Quarter 1.20E+01
4. Total time duration for all releases of type listed above
1.51E+04
minutes
5. Maximum duration for releases of type listed above 1.61E+03
minutes
6. Average duration for all releases of type listed above
1.26E+03
minutes
7. Minimum duration for release of type listed above 9.17E+02
minutes
8. For liquid batch releases only, provide the average stream
flow (dilution flow) during the period of release. N/A

TABLE 4B-1

SALEM NUCLEAR GENERATING STATION (1980)
UNIT 1

SUMMARY SHEET FOR RADIOACTIVE EFFLUENTS RELEASED
IN A BATCH MODE

BATCH RELEASES ONLY

1. Dates July 1 - Sept. 30, 1980
2. Type of release (Liquid)
3. Number of releases during the 3rd Quarter 9.10+01
4. Total time duration for all releases of type listed above
2.00E+04
minutes
5. Maximum duration for releases of type listed above 4.11E+02
minutes
6. Average duration for all releases of type listed above
2.20E+02
minutes
7. Minimum duration for release of type listed above 1.06E+02
minutes
8. For liquid batch releases only, provide the average stream
flow (dilution flow) during the period of release. 1.85E+05
gpm

TABLE 4B-2

SALEM NUCLEAR GENERATING STATION (1980)
UNIT 2

SUMMARY SHEET FOR RADIOACTIVE EFFLUENTS RELEASED
IN A BATCH MODE

BATCH RELEASES ONLY

1. Dates July 1 - Sept. 30, 1980
2. Type of release (Liquid)
3. Number of releases during the 3rd Quarter 3.40+01
4. Total time duration for all releases of type listed above
1.32E+04
minutes
5. Maximum duration for releases of type listed above 5.76E+02
minutes
6. Average duration for all releases of type listed above
3.80E+02
minutes
7. Minimum duration for release of type listed above 3.50E+01
minutes
8. For liquid batch releases only, provide the average stream
flow (dilution flow) during the period of release. 1.85E+05
gpm

TABLE 4B-1 (Cont'd)

SALEM NUCLEAR GENERATING STATION (1980)
UNIT 1

SUMMARY SHEET FOR RADIOACTIVE EFFLUENTS RELEASED
IN A BATCH MODE

BATCH RELEASES ONLY

1. Dates Oct. 1 - Dec. 31, 1980
2. Type of release (Liquid)
3. Number of releases during the 4th Quarter 7.1E+01
4. Total time duration for all releases of type listed above
1.52E+04
minutes
5. Maximum duration for releases of type listed above 4.50E+02
minutes
6. Average duration for all releases of type listed above
2.14E+02
minutes
7. Minimum duration for release of type listed above 1.48E+02
minutes
8. For liquid batch releases only, provide the average stream
flow (dilution flow) during the period of release 1.85E+05
gpm

TABLE 4B-2 (Cont'd)

SALEM NUCLEAR GENERATING STATION (1980)
UNIT 2

SUMMARY SHEET FOR RADIOACTIVE EFFLUENTS RELEASED
IN A BATCH MODE

BATCH RELEASES ONLY

1. Dates Oct. 1 - Dec. 31, 1980
2. Type of release (Liquid)
3. Number of releases during the 4th Quarter 1.2E+01
4. Total time duration for all releases of type listed above
3.51E+03
minutes
5. Maximum duration for releases of type listed above 4.20E+02
minutes
6. Average duration for all releases of type listed above
2.93E+02
minutes
7. Minimum duration for release of type listed above 1.64E+02
minutes
8. For liquid batch releases only, provide the average stream
flow (dilution flow) during the period of release 1.85E+05
gpm

ARTIFICIAL ISLAND
SALEM UNIT 1

PERIOD OF RECORD: 7 180 TO 93080

STABILITY CLASS: EXTREMELY UNSTABLE DELTA T <-1.9 °
LAPSE RATE IN DEG C/100 METERS
EVALUATED USING DELTA T 300-33 FT

ELEVATION: 300 FEET

WINDSPEED (MPH) AT 300 FEET

WIND DIREC- TION	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	1	0	0	1
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
TOTAL	0	0	0	1	0	0	1

PERIODS OF CALM (HOURS): 0
HOURS OF MISSING DATA: 0

ARTIFICIAL ISLAND
SALEM UNIT 1

PERIOD OF RECORD: 7 180 TO 93080

STABILITY CLASS: MODERATELY UNSTABLE DELTA T -1.9 TO -1.7 °
LAPSE RATE IN DEG C/100 METERS
EVALUATED USING DELTA T 300-33 FT

ELEVATION: 300 FEET

WINDSPEED (MPH) AT 300 FEET

WIND DIREC- TION	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	1	0	0	1
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	1	0	0	0	1
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
TOTAL	0	0	1	1	0	0	2

PERIODS OF CALM (HOURS): 0
HOURS OF MISSING DATA: 0

ARTIFICIAL ISLAND
SALEM UNIT 1

PERIOD OF RECORD: 7 180 TO 93080

STABILITY CLASS: SLIGHTLY UNSTABLE DELTA T -1.7 TO -1.5 °
LAPSE RATE IN DEG C/100 METERS
EVALUATED USING DELTA T 300-33 FT

ELEVATION: 300 FEET

WINDSPEED (MPH) AT 300 FEET							
WIND DIREC- TION	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	1	0	0	0	1
SSE	0	0	0	1	1	1	3
S	0	0	0	0	0	0	0
SSW	0	0	1	0	0	0	1
SW	0	1	0	0	0	0	1
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
TOTAL	0	1	2	1	1	1	6

PERIODS OF CALM (HOURS): 0
HOURS OF MISSING DATA: 0

ARTIFICIAL ISLAND
SALEM UNIT 1

PERIOD OF RECORD: 7 180 TO 93080

STABILITY CLASS: NEUTRAL DELTA T -1.5 TO -0.5 °
LAPSE RATE IN DEG C/100 METERS
EVALUATED USING DELTA T 300-33 FT

ELEVATION: 300 FEET

WIND DIREC- TION	WINDSPEED (MPH) AT 300 FEET						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	1	8	26	17	4	0	56
NNE	1	10	11	10	0	0	32
NE	0	4	2	5	0	0	11
ENE	1	3	4	1	0	0	9
E	0	0	4	3	0	0	7
ESE	1	0	0	1	0	0	2
SE	0	1	5	4	15	7	32
SSE	1	4	24	16	15	4	64
S	2	11	9	4	0	0	26
SSW	2	7	9	7	1	4	30
SW	1	20	17	25	1	0	64
WSW	0	7	20	12	0	0	39
W	1	8	14	9	1	0	33
WNW	1	9	5	9	2	8	34
NW	0	5	9	13	0	0	27
NNW	2	13	10	13	4	0	42
TOTAL	14	110	169	149	43	23	508

PERIODS OF CALM (HOURS): 0
HOURS OF MISSING DATA: 78

ARTIFICIAL ISLAND
SALEM UNIT 1

PERIOD OF RECORD: 7 180 TO 93080

STABILITY CLASS: SLIGHTLY STABLE DELTA T -0.5 TO 1.5 °

LAPSE RATE IN DEG C/100 METERS

EVALUATED USING DELTA T 300-33 FT

ELEVATION: 300 FEET

WIND DIREC- TION	WINDSPEED (MPH) AT 300 FEET						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	0	5	24	18	2	0	49
NNE	4	2	18	26	1	0	51
NE	2	6	16	14	2	0	40
ENE	3	6	9	4	2	0	24
E	1	3	13	14	0	0	31
ESE	0	1	6	9	7	0	23
SE	0	6	7	18	16	4	51
SSE	4	7	22	40	14	0	87
S	2	13	32	32	10	2	91
SSW	2	13	37	47	25	2	126
SW	2	19	39	60	17	1	138
WSW	3	8	23	38	9	3	84
W	3	12	30	23	3	1	72
WNW	0	12	17	13	2	1	45
NW	1	8	17	17	14	0	57
NNW	1	9	19	12	2	0	43
TOTAL	28	130	329	385	126	14	1012

PERIODS OF CALM (HOURS): 1

HOURS OF MISSING DATA: 162

ARTIFICIAL ISLAND
SALEM UNIT 1

PERIOD OF RECORD: 7 180 TO 93080

STABILITY CLASS: MODERATELY STABLE DELTA T 1.5 TO 4.0 °
LAPSE RATE IN DEG C/100 METERS
EVALUATED USING DELTA T 300-33 FT

ELEVATION: 300 FEET

WINDSPEED (MPH) AT 300 FEET							
WIND DIREC- TION	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0	4	7	18	3	0	32
NNE	0	0	1	3	1	0	5
NE	0	1	5	4	3	0	13
ENE	0	0	2	3	1	0	6
E	0	1	0	0	0	0	1
ESE	0	0	0	0	0	0	0
SE	0	0	1	1	0	0	2
SSE	0	2	3	6	1	0	12
S	1	1	3	3	0	0	8
SSW	0	1	5	5	4	0	15
SW	0	0	4	6	3	0	13
WSW	0	0	2	5	1	1	9
W	0	1	1	1	0	0	3
WNW	0	1	1	1	1	0	4
NW	0	1	6	1	0	0	8
NNW	0	0	3	16	1	0	20
TOTAL	1	13	44	73	19	1	151

PERIODS OF CALM (HOURS): 0
HOURS OF MISSING DATA: 37

ARTIFICIAL ISLAND
SALEM UNIT 1

PERIOD OF RECORD: 7 180 TO 93080

STABILITY CLASS: EXTREMELY STABLE DELTA T >4.0 °
LAPSE RATE IN DEG C/100 METERS
EVALUATED USING DELTA T 300-33 FT

ELEVATION: 300 FEET

WIND DIREC- TION	WINDSPEED (MPH) AT 300 FEET						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	1	0	0	1
ENE	0	1	0	0	0	0	1
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
TOTAL	0	1	0	1	0	0	2

PERIODS OF CALM (HOURS): 0

HOURS OF MISSING DATA: 2

ARTIFICIAL ISLAND
SALEM UNIT 1

PERIOD OF RECORD: 7 180 TO 93080

STABILITY CLASS: ALL STABILITIES EXCLUDING MISS SPEED/DIR DATA
LAPSE RATE IN DEG C/100 METERS
EVALUATED USING DELTA T 300-33 FT

ELEVATION: 300 FEET

WIND DIREC- TION	WINDSPEED (MPH) AT 300 FEET						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	1	17	57	53	9	0	137
NNE	5	12	30	39	2	0	88
NE	2	11	23	24	5	0	65
ENE	4	10	15	8	3	0	40
E	1	4	17	17	0	0	39
ESE	1	1	6	10	7	0	25
SE	0	7	14	24	31	11	87
SSE	5	13	49	64	31	5	167
S	5	25	44	39	10	2	125
SSW	4	21	52	59	30	6	172
SW	3	40	61	91	21	1	217
WSW	3	15	45	55	10	4	132
W	4	21	45	33	4	1	108
WNW	1	22	23	23	5	9	83
NW	1	14	32	31	14	0	92
NNW	3	22	32	41	7	0	105
TOTAL	43	255	545	611	189	39	1682

PERIODS OF CALM (HOURS): 1
HOURS OF MISSING DATA: 279

ARTIFICIAL ISLAND
SALEM UNIT 1

PERIOD OF RECORD: 10 180 TO 123180

STABILITY CLASS: EXTREMELY UNSTABLE DELTA T <-1.9 °
LAPSE RATE IN DEG C/100 METERS
EVALUATED USING DELTA T 300-33 FT

ELEVATION: 300 FEET

WINDSPEED (MPH) AT 300 FEET							
WIND DIREC- TION	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	0	2	0	0	0	0	2
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	0	0	0	0
NNW	0	0	0	0	0	0	0
TOTAL	0	2	0	0	0	0	2

PERIODS OF CALM (HOURS): 0
HOURS OF MISSING DATA: 0

ARTIFICIAL ISLAND
SALEM UNIT 1

PERIOD OF RECORD: 10 180 TO 123180

STABILITY CLASS: MODERATELY UNSTABLE DELTA T -1.9 TO -1.7 °
LAPSE RATE IN DEG C/100 METERS
EVALUATED USING DELTA T 300-33 FT

ELEVATION: 300 FEET

WIND DIREC- TION	WINDSPEED (MPH) AT 300 FEET						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	1	0	0	0	0	1
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	1	0	0	1
SE	0	0	1	0	1	0	2
SSE	0	0	0	0	0	0	0
S	0	0	0	0	0	0	0
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	0	0	0	0	0	0
WNW	0	0	0	0	0	0	0
NW	0	0	0	1	0	1	2
NNW	0	0	0	0	0	3	3
TOTAL	0	1	1	2	1	4	9

PERIODS OF CALM (HOURS): 0
HOURS OF MISSING DATA: 0

ARTIFICIAL ISLAND
SALEM UNIT 1

PERIOD OF RECORD: 10 180 TO 123180

STABILITY CLASS: SLIGHTLY UNSTABLE DELTA T -1.7 TO -1.5 °
LAPSE RATE IN DEG C/100 METERS
EVALUATED USING DELTA T 300-33 FT

ELEVATION: 300 FEET

WINDSPEED (MPH) AT 300 FEET							
WIND DIREC- TION	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0	0	0	1	0	0	1
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	1	1	1	0	0	3
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	0	0	0	0	0	0
S	0	0	1	0	0	0	1
SSW	0	0	0	0	0	0	0
SW	0	0	0	0	0	0	0
WSW	0	0	0	1	0	0	1
W	0	0	1	3	0	0	4
WNW	0	0	0	1	0	0	1
NW	0	0	0	3	1	1	5
NNW	0	0	0	3	2	2	7
TOTAL	0	1	3	13	3	3	23

PERIODS OF CALM (HOURS): 0
HOURS OF MISSING DATA: 3

ARTIFICIAL ISLAND
SALEM UNIT 1

PERIOD OF RECORD: 10 180 TO 123180

STABILITY CLASS: NEUTRAL DELTA T -1.5 TO -0.5 °
LAPSE RATE IN DEG C/100 METERS
EVALUATED USING DELTA T 300-33 FT

ELEVATION: 300 FEET

WINDSPEED (MPH) AT 300 FEET							
WIND DIREC- TION	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0	5	18	21	7	0	51
NNE	0	3	13	19	5	1	41
NE	0	1	7	21	2	0	31
ENE	0	3	7	5	2	0	17
E	1	5	6	1	0	0	13
ESE	0	2	0	2	0	0	4
SE	0	2	2	4	0	2	10
SSE	0	7	2	2	0	0	11
S	0	5	9	4	0	0	18
SSW	1	8	10	6	0	0	25
SW	1	3	13	19	10	3	49
WSW	1	1	18	9	15	18	62
W	1	11	14	12	8	18	64
WNW	0	4	3	17	12	8	44
NW	0	5	9	29	23	34	100
NNW	1	11	9	25	23	29	98
TOTAL	6	76	140	196	107	113	638

PERIODS OF CALM (HOURS): 0
HOURS OF MISSING DATA: 19

ARTIFICIAL ISLAND
SALEM UNIT 1

PERIOD OF RECORD: 10 180 TO 123180

STABILITY CLASS: SLIGHTLY STABLE DELTA T -0.5 TO 1.5 °
LAPSE RATE IN DEG C/100 METERS
EVALUATED USING DELTA T 300-33 FT

ELEVATION: 300 FEET

WIND DIREC- TION	WINDSPEED (MPH) AT 300 FEET						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	0	9	22	44	14	0	89
NNE	1	3	16	24	10	0	54
NE	2	2	10	27	14	0	55
ENE	2	8	13	21	3	3	50
E	2	6	12	3	0	1	24
ESE	2	6	0	3	0	0	11
SE	1	3	6	1	3	3	17
SSE	2	7	5	9	3	3	29
S	0	12	9	20	17	1	59
SSW	0	3	19	20	22	15	79
SW	1	3	8	32	27	9	80
WSW	1	7	14	19	13	1	55
W	2	3	9	29	14	10	67
WNW	0	2	13	47	30	11	103
NW	5	10	20	53	46	30	164
NNW	0	5	16	40	38	17	116
TOTAL	21	89	192	392	254	104	1052

PERIODS OF CALM (HOURS): 0
HOURS OF MISSING DATA: 28

PERIOD OF RECORD: 10 180 TO 123180

STABILITY CLASS: MODERATELY STABLE DELTA T 1.5 TO 4.0 °
 LAPSE RATE IN DEG C/100 METERS
 EVALUATED USING DELTA T 300-33 FT

ELEVATION: 300 FEET

WIND DIREC- TION	WINDSPEED (MPH) AT 300 FEET						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	0	1	4	9	3	0	17
NNE	0	0	1	5	2	0	8
NE	0	1	4	2	2	0	9
ENE	1	2	2	2	0	0	7
E	0	1	0	0	0	0	1
ESE	0	0	2	0	0	0	2
SE	0	1	4	1	0	0	6
SSE	1	1	1	4	1	4	12
S	1	2	1	7	5	4	20
SSW	0	1	6	3	6	1	17
SW	0	0	2	5	5	2	14
WSW	0	0	1	3	5	2	11
W	1	2	2	1	3	4	13
WNW	0	0	1	1	1	0	3
NW	0	1	1	3	0	1	6
NNW	0	0	0	6	11	0	17
TOTAL	4	13	32	52	44	18	163

PERIODS OF CALM (HOURS): 0
 HOURS OF MISSING DATA: 4

PERIOD OF RECORD: 10 180 TO 123180

STABILITY CLASS: EXTREMELY STABLE DELTA T >4.0 °
LAPSE RATE IN DEG C/100 METERS
EVALUATED USING DELTA T 300-33 FT

ELEVATION: 300 FEET

WIND DIREC- TION	WINDSPEED (MPH) AT 300 FEET						TOTAL
	1-3	4-7	8-12	13-18	19-24	>24	
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0
E	1	0	0	0	0	0	1
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	1	0	0	0	0	1
S	1	2	2	6	1	1	13
SSW	0	0	2	6	3	1	12
SW	0	0	1	1	0	0	2
WSW	0	0	1	7	0	0	8
W	0	0	0	4	0	2	6
WNW	0	0	2	0	0	0	2
NW	0	0	1	0	0	0	1
NNW	0	1	0	0	0	0	1
TOTAL	2	4	9	24	4	4	47

PERIODS OF CALM (HOURS): 0
HOURS OF MISSING DATA: 4

ARTIFICIAL ISLAND
SALEM UNIT 1

PERIOD OF RECORD: 10 180 TO 123180

STABILITY CLASS: ALL STABILITIES EXCLUDING MISS SPEED/DIR DATA
LAPSE RATE IN DEG C/100 METERS
EVALUATED USING DELTA T 300-33 FT

ELEVATION: 300 FEET

		WINDSPEED (MPH) AT 300 FEET					
WIND DIREC- TION	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0	15	44	75	24	0	158
NNE	1	6	30	48	17	1	103
NE	2	5	21	50	18	0	96
ENE	3	14	23	29	5	3	77
E	4	14	18	4	0	1	41
ESE	2	8	2	6	0	0	18
SE	1	6	13	6	4	5	35
SSE	3	16	8	15	4	7	53
S	2	21	22	37	23	6	111
SSW	1	12	37	35	31	17	133
SW	2	6	24	57	42	14	145
WSW	2	8	34	39	33	21	137
W	4	16	26	49	25	34	154
WNW	0	6	19	66	43	19	153
NW	5	16	31	89	70	67	278
NNW	1	17	25	74	74	51	242
TOTAL	33	186	377	679	413	246	1934

PERIODS OF CALM (HOURS): 0
HOURS OF MISSING DATA: 58