

210104/78

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)
DISTRIBUTION FOR INCOMING MATERIAL

50-335

REC: OREILLY J P
NRC

ORG: SCHMIDT A D
FL PWR & LIGHT

DOCDATE: 09/22/78
DATE RCVD: 10/02/78

DOCTYPE: LETTER NOTARIZED: NO
SUBJECT:

COPIES RECEIVED
LTR 1 ENCL 1

FORWARDING LICENSEE EVENT REPT (RO 50-335/78-032) ON 08/30/78 CONCERNING
DAILY CALIBRATION OF NUC AND ^T PWR (TECH SPEC 4.3.1.1.1) WAS INADVERTENTLY
MISSED DURING ONE SURVEILLANCE INTERVAL ENCOMPASSING A SHORT MAINTENANCE
OUTAGE AND SUBSEQUENT STARTUP.

PLANT NAME: ST LUCIE #1

REVIEWER INITIAL: XJM
DISTRIBUTOR INITIAL: DL

***** DISTRIBUTION OF THIS MATERIAL IS AS FOLLOWS *****

INCIDENT REPORTS
(DISTRIBUTION CODE A002)

FOR ACTION: BR CHIEF ~~BRB~~#4 BC**W/4 ENCL

INTERNAL: ~~REG FILE~~**W/ENCL
I & E**W/2 ENCL
I & C SYSTEMS BR**W/ENCL
NOVAK/CHECK**W/ENCL
AD FOR ENG**W/ENCL
HANAUER**W/ENCL
AD FOR SYS & PROJ**W/ENCL
ENGINEERING BR**W/ENCL
KREGER/J. COLLINS**W/ENCL
K SEYFRIT/IE**W/ENCL

NRC PDR**W/ENCL
MIPC**W/3 ENCL
EMERGENCY PLAN BR**W/ENCL
EEB**W/ENCL
PLANT SYSTEMS BR**W/ENCL
AD FOR PLANT SYSTEMS**W/ENCL
REACTOR SAFETY BR**W/ENCL
VOLLMER/BUNCH**W/ENCL
POWER SYS BR**W/ENCL

EXTERNAL: LPDR'S
FT PIERCE, FL**W/ENCL
NSIC**W/ENCL
ACRS CAT B**W/16 ENCL

DISTRIBUTION: LTR 44 ENCL 44
SIZE: 1P+1P


CONTROL NBR: 780680146

THE END

A04 50

2-10-10





September 22, 1978

PRN-LI-78-267

Mr. James P. O'Reilly, Director, Region II
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303


Dear Mr. O'Reilly:

REPORTABLE OCCURRENCE 335-78-32
ST. LUCIE UNIT 1
DATE OF OCCURRENCE: AUGUST 30, 1978

TECHNICAL SPECIFICATION 4.3.1.1.1
NUCLEAR POWER & AT POWER CALIBRATIONS

The attached Licensee Event Report is being submitted in accordance with Technical Specification 6.9 to provide 30-day notification of the subject occurrence.

Very truly yours,


A. D. Schmidt
Vice President
Power Resources

MAS/cpc

Attachment

cc: Harold F. Reis, Esquire
Director, Office of Inspection and Enforcement (30)
✓ Director, Office of Management Information and
Program Control (3)

REGULATORY DOCKET FILE COPY

780680166

A002/s *

CONTROL BLOCK:

						1
--	--	--	--	--	--	---

 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

F I L S I S		L I C E N S E E C O D E		L I C E N S E N U M B E R		L I C E N S E T Y P E		C A T	
0	1	2	0	1	0	-	0	1	0
CON'T		REPORT SOURCE		DOCKET NUMBER		EVENT DATE		REPORT DATE	
0	1	L	6	0	5	0	0	3	3
EVENT DESCRIPTION AND PROBABLE CONSEQUENCES									
The daily calibration of Nuclear and AT Power (T.S. 4.3.1.1.1) was inadvertently missed during one surveillance interval encompassing a short maintenance outage and subsequent startup. The calibration was performed the next day in accordance with the regular schedule. The calibration had been performed on the day before the occurrence. Reactor power did not exceed 75% in the 24 hours during which a calibration was not performed. This was the first missed surveillance of this type in two years of operation.									
SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE		CONP. SUBCODE	
Z	7	A	1	A	1	Z	7	Z	7
VALVE SUBCODE		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.	
Z	7	0	3	2	1	0	3	1	0
LER/RO REPORT NUMBER		EVENT YEAR		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED	
7	8	7	8	Z	7	0	0	0	0
ACTION TAKEN		EFFECT ON PLANT		PRIME COMP. SUPPLIER		NPRD FORM SUB.		COMPONENT MANUFACTURER	
H	1	Z	7	N	7	N	7	Z	7
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS									
Because of the outage and subsequent startup, the operating shift that normally performs the surveillance turned it over to the relieving shift. The relieving operators, however, were not aware that they were required to perform it. Personnel involved were instructed on the importance of performing required surveillances as scheduled and in ensuring a thorough shift turnover.									
FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	
G	7	0	0	0	NA	B	7	Routine Inspection	
ACTIVITY RELEASED		CONTENT OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE			
Z	7	Z	7	NA					
PERSONNEL EXPOSURES		TYPE		DESCRIPTION					
0	0	0	7	NA					
PERSONNEL INJURIES		NUMBER		DESCRIPTION					
0	0	0	7	NA					
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION					
7	7			NA					
PUBLICITY ISSUED		DESCRIPTION							
N	7			NA					
NAME OF PREPARER		M. A. Schoppman		PHONE:		(305) 552-3802			