

1309120178

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)
DISTRIBUTION FOR INCOMING MATERIAL

50-335

REC: 4 OREILLY JP
NRC

ORG: SCHMIDT A.D
FL PWR & LIGHT

DOCDATE: 09/08/78
DATE RCVD: 09/18/78

DOCTYPE: LETTER NOTARIZED: NO

COPIES RECEIVED

SUBJECT:

LTR 1 ENCL 1

FORWARDING LICENSEE EVENT REPT (RO 50-335/78-030) ON 08/10/78 CONCERNING THE
SURVEILLANCE REQUIREMENT OF SPECIFICATION 4.4.8, WHICH REQUIRES AN ISOTOPIC
ANALYSIS FOR IODINE IN THE PRIMARY COOLANT, WAS INADVERTENTLY MISSED.

PLANT NAME: ST LUCIE #1

REVIEWER INITIAL: XJM
DISTRIBUTOR INITIAL: M

***** DISTRIBUTION OF THIS MATERIAL IS AS FOLLOWS *****

INCIDENT REPORTS
(DISTRIBUTION CODE A002)

FOR ACTION: BR CHIEF ORB#4 BC**W/4 ENCL

INTERNAL:

REG FILE**W/ENCL
I & E**W/2 ENCL
I & C SYSTEMS BR**W/ENCL
NOVAK/CHECK**W/ENCL
AD FOR ENG**W/ENCL
HANAUER**W/ENCL
AD FOR SYS & PROJ**W/ENCL
ENGINEERING BR**W/ENCL
KREGER/J. COLLINS**W/ENCL
K SEYFRIT/IE**W/ENCL

NRC PDR**W/ENCL
MIPC**W/3 ENCL
EMERGENCY PLAN BR**W/ENCL
EEB**W/ENCL
PLANT SYSTEMS BR**W/ENCL
AD FOR PLANT SYSTEMS**W/ENCL
REACTOR SAFETY BR**W/ENCL
VOLLMER/BUNCH**W/ENCL
POWER SYS BR**W/ENCL

EXTERNAL:

LPDR'S
FT PIERCE, FL**W/ENCL
NSIC**W/ENCL
ACRS CAT B**W/16 ENCL

DISTRIBUTION: LTR 44 ENCL 44
SIZE: 1P+1P

CONTROL NBR: 780720242

A04 60

***** THE END *****

REGULATORY DOCKET FILE COPY



September 8, 1978

PRN-LI-78-250

Mr. James P. O'Reilly, Director, Region II
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

REPORTABLE OCCURRENCE 335-78-30
ST. LUCIE UNIT 1
DATE OF OCCURRENCE: AUGUST 10, 1978

TECHNICAL SPECIFICATION 4.4.8
ISOTOPIC ANALYSIS

The attached Licensee Event Report is being submitted in accordance with Technical Specification 6.9 to provide 30-day notification of the subject occurrence.

Very truly yours,

J. R. Benzen
for A. D. Schmidt
Vice President
Power Resources

MAS/cpc

Attachment

cc: Harold F. Reis, Esquire
Director, Office of Inspection and Enforcement (30)
Director, Office of Management Information and
Program Control (3)

780720242

1002
7/1

CONTROL BLOCK: [] [] [] [] [] [] [] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

[illegible]

NAME OF PREPARER M. A. Schoppman

PHONE: (305) 552-3802