

LICENSEE EVENT REPORT

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 V A S P S 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5  
8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T  
0 1 REPORT SOURCE L 6 0 5 0 0 0 2 8 0 7 0 8 3 1 8 0 5 0 9 2 6 8 0 9  
8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 Low Flow Alarm indicated for RM-GW-101/102. No discharges via Process Vent System were  
0 3 in progress and AP 5.16 was immediately initiated (system isolation) thus the health  
0 4 and safety of the public were not affected. Tech. Spec 3.4.B.5.b applies, therefore  
0 5 this event is reportable in accordance with Tech. Spec. 6.6.2.b(2).

0 6

0 7

0 8

0 9 SYSTEM CODE M C 11 CAUSE CODE E 12 CAUSE SUBCODE B 13 COMPONENT CODE P U M P X X 14 COMP. SUBCODE H 15 VALVE SUBCODE Z 16  
7 8 9 10 11 12 13 14 15 16 17 18 19 20

17 LER/RO REPORT NUMBER 8 0 EVENT YEAR 8 0 SEQUENTIAL REPORT NO. 0 6 0 OCCURRENCE CODE 0 3 REPORT TYPE L REVISION NO. 0  
21 22 23 24 25 26 27 28 29 30 31 32  
ACTION TAKEN A 18 FUTURE ACTION Z 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 ATTACHMENT SUBMITTED Y 23 NPD-4 FORM SUB. N 24 PRIME COMP. SUPPLIER A 25 COMPONENT MANUFACTURER V 1 1 5 26  
33 34 35 36 37 38 39 40 41 42 43 44 45

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Investigation showed problem to be a broken drive belt. Replaced belt; pump and  
1 1 system returned to service.

1 2

1 3

1 4

1 5 FACILITY STATUS E 28 % POWER 0 8 5 29 OTHER STATUS NA 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION Alarm 32  
7 8 9 10 11 12 13 14 15 16 17 18 19 20

1 6 ACTIVITY CONTENT RELEASED OF RELEASE Z 33 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36  
7 8 9 10 11 12 13 14 15 16 17 18 19 20

1 7 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39  
7 8 9 10 11 12 13 14 15 16 17 18 19 20

1 8 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41  
7 8 9 10 11 12 13 14 15 16 17 18 19 20

1 9 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43  
7 8 9 10 11 12 13 14 15 16 17 18 19 20

2 0 PUBLICITY ISSUED N 44 DESCRIPTION NA 45  
7 8 9 10 11 12 13 14 15 16 17 18 19 20

NRC USE ONLY

8010010580

NAME OF PREPARER J. L. Wilson

PHONE: (804) 357-3184