

SURRY POWER STATION EMERGENCY PLAN IMPLEMENTING PROCEDURES

EPIP-1.01

Enclosed are recently revised pages to the Surry Power Station Emergency Plan Implementing Procedures. Please take the following actions in order to keep your manual updated with the most recent revisions.

EPIP-1.01

Emergency Manager Controlling Procedure

Remove and Destroy

Page 1 of 8 and  
page 5 of 8 dated  
07-29-82

Enter

Page 1 of 8  
and page 5 of  
8 dated 11-18-82

VIRGINIA ELECTRIC AND POWER COMPANY  
SURRY POWER STATION

## EMERGENCY PLAN IMPLEMENTING PROCEDURE

NUMBER	PROCEDURE TITLE	REVISION
EPIP-1.01	EMERGENCY MANAGER CONTROLLING PROCEDURE (With 1 Attachment)	01
		PAGE 1 of 8

## PURPOSE

To initially assess a potential emergency condition and initiate corrective actions.

## USER

Shift Supervisor or Station Emergency Manager

## ENTRY CONDITIONS

Any one of the following :

1. Another station procedure directs initiation of this procedure

OR

2. A potential emergency condition is reported to the Shift Supervisor.

## REVISION RECORD

REV. 00	PAGE(S): ENTIRE PROCEDURE	DATE: JUN 29 1982
REV. 01	PAGE(S): 1 of 8 and 5 of 8	DATE: NOV 18 1982
REV.	PAGE(S):	DATE:
REV.	PAGE(S):	DATE:
REV.	PAGE(S):	DATE:
REV.	PAGE(S):	DATE:
REV.	PAGE(S):	DATE:

## APPROVAL RECOMMENDED

*J. M. Cuf*

## APPROVED

*R. Saunders*  
CHAIRMAN STATION NUCLEAR SAFETY  
AND OPERATING COMMITTEE

## DATE

NOV 18 1982

NUMBER	PROCEDURE TITLE	REVISION
EPIP-1.01	EMERGENCY MANAGER CONTROLLING PROCEDURE	01
		PAGE
		5 of 8

STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
4.	(CONTINUED)	
	2) SRO-On-Call	
	R. Johnson	Attempt contact via beeper
	<u>OR</u>	
	J. Peterson	Attempt contact via beeper
	c) Verify classification	
	d) <u>IF</u> required by Alert, Site Emergency or General Emergency, request initiation of Standing Order 21	
	<u>NOTE:</u> Return to Step 2 of this instruction as necessary during the course of the situation for additional events and reclassification.	
5.	VERIFY EALS EXCEEDED:	
	a) Assure EALS - EXCEEDED	a) <u>IF</u> EALS <u>NOT</u> exceeded, <u>DO NOT</u> declare an emergency classification.
		<u>AND</u>
		1) Continue appropriate corrective action IAW procedures.
		2) <u>GO TO</u> Step <u>7</u> of this procedure.