

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

W. L. STEWART
VICE PRESIDENT
NUCLEAR OPERATIONS

December 29, 1982

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
Attn: Mr. Darrell G. Eisenhut, Director
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Serial No. 227E
SPS,NO/DAC,DWL:acm
Docket Nos. 50-280
50-281
License Nos. DPR-32
DPR-37


Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY
SURRY POWER STATION
SUPPLEMENTAL RESPONSE TO GENERIC LETTER 82-05

In our response to Generic Letter 82-05 dated May 17, 1982 (Serial No. 227), Vepco committed to having operational systems for plant effluent noble gas monitoring, sampling and analysis (NUREG-0737, Items II.F.1.1 and II.F.1.2) by January 1, 1983. Vepco is experiencing support problems with the systems supplier (Kaman Instrumentation, Inc.) in resolving component failures experienced during final startup testing. Accordingly, it is necessary to extend our commitment date to March 1, 1983.

The station has ordered replacement parts for the Vent Stack Accident Range Monitor and is currently waiting for delivery. Despite Vepco's efforts to place this system in service, delays in the delivery of repaired or replacement components has necessitated the commitment extension to March 1, 1983. All interim monitoring systems are still operational.

Very truly yours,


W. L. Stewart

cc: Mr. James P. O'Reilly
Regional Administrator
Region II
U. S. Nuclear Regulatory Commission
Atlanta, Georgia 30303

Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

A046

8301040318 821229
PDR ADDCK 05000280
P PDR

COMMONWEALTH OF VIRGINIA)
)
CITY OF RICHMOND)

The foregoing document was acknowledged before me, in and for the City and Commonwealth aforesaid, today by W. L. Stewart, who is Vice President-Nuclear Operations, of the Virginia Electric and Power Company. He is duly authorized to execute and file the foregoing document in behalf of that Company, and the statements in the document are true to the best of his knowledge and belief.

Acknowledged before me this 29th day of December, 19 82.

My Commission expires: 2-26, 19 85.

Ann C. McSee
Notary Public

(SEAL)

M2/004