

ATTACHMENT 1

PROPOSED TECHNICAL SPECIFICATION CHANGE

8302180448 830214  
PDR ADOCK 05000280  
P PDR

<u>Section</u>	<u>Title</u>	<u>Page</u>
3.15	Containment Vacuum System	TS 3.15-1
3.16	Emergency Power System	TS 3.16-1
3.17	Loop Stop Valve Operation	TS 3.17-1
3.18	Movable Incore Instrumentation	TS 3.18-1
3.19	Main Control Room Ventilation System	TS 3.19-1
3.20	Shock Suppressors (Snubbers)	TS 3.20-1
3.21	Fire Detection and Suppression System	TS 3.21-1
4.0	<u>SURVEILLANCE REQUIREMENTS</u>	TS 4.0-1
4.1	Operational Safety Review	TS 4.1-1
4.2	Reactor Coolant System Component Inspections	TS 4.2-1
4.3	Reactor Coolant System Integrity Testing Following Opening	TS 4.3-1
4.4	Containment Tests	TS 4.4-1
4.5	Spray Systems Tests	TS 4.5-1
4.6	Emergency Power System Periodic Testing	TS 4.6-1
4.7	Main Steam Line Trip Valves	TS 4.7-1
4.8	Auxiliary Feedwater System	TS 4.8-1
4.9	Effluent Sampling and Radiation Monitoring System	TS 4.9-1
4.10	Reactivity Anomalies	TS 4.10-1
4.11	Safety Injection System Tests	TS 4.11-1
4.12	Ventilation Filter Tests	TS 4.12-1
4.13	Deleted.	
4.14	Deleted	
4.15	Augmented Inservice Inspection Program for High Energy Lines Outside of Containment	TS 4.15-1
4.16	Leakage Testing of Miscellaneous Radioactive Materials	TS 4.16-1
4.17	Shock Suppressors (Snubbers)	TS 4.17-1
4.18	Fire Detection and Protection System Surveillance	TS 4.18-1
4.19	Steam Generator Inservice Inspection	TS 4.19-1

continuous exposure to the concentration values listed in Appendix B, Table II of 10 CFR 20, estimates of the likely resultant exposure to individuals and to population groups, and assumptions upon which estimates are based shall be provided.

- (3) If a particular sample or measurements indicate statistically significant levels of radioactivity above established or concurrent backgrounds, the following information shall be provided:

- (a) The type of analysis performed; e.g., alpha, beta, gamma and/or isotopic.
- (b) The minimum sensitivity of the monitoring system.
- (c) The measured radiation level or sample concentration.
- (d) The specific times when samples were taken and measurements were made.
- (e) An estimate of the likely resultant exposure to the public if it exceeds 10 mrem.

ATTACHMENT 2

DISCUSSION OF PROPOSED TECHNICAL SPECIFICATION CHANGE

## DISCUSSION OF PROPOSED TECHNICAL SPECIFICATION CHANGE

This proposed change deletes the non-radiological water quality Technical Specifications 4.13, 4.14, and 6.6.3.d. This change is an administrative action at the request of the NRC. The water quality limits and monitoring program are now under the jurisdiction of the U. S. Environmental Protection Agency as established by the Federal Water Pollution Control Act Amendment of 1972.