

ATTACHMENT 1

PROPOSED TECHNICAL SPECIFICATION CHANGE

8507190309 850712
PDR ADOCK 05000280
P PDR

TABLE 4.1-1 (Continued)

<u>Channel Description</u>	<u>Check</u>	<u>Calibrate</u>	<u>Test</u>	<u>Remarks</u>
10. Rod Position Bank Counters	S(1,2)	N.A.	N.A.	1) Each six inches of rod motion when data logger is out of service 2) With analog rod position
11. Steam Generator Level	S	R	M	
12. Charging Flow	N.A.	R	N.A.	
13. Residual Heat Removal Pump Flow	N.A.	R	N.A.	
14. Boric Acid Tank Level	*D	R	N.A.	
15. Refueling Water Storage Tank Level	S	R	M	
16. (DELETED)				
17. Volume Control Tank Level	N.A.	R	N.A.	
18. Reactor Containment Pressure-CLS	*D	R	M(1)	1) Isolation valve signal and spray signal.
19. Boric Acid Control	N.A.	R	N.A.	
20. Containment Sump Level	N.A.	R	N.A.	
21. Accumulator Level and Pressure	S	R	N.A.	
22. Containment Pressure-Vacuum Pump System	S	R	N.A.	
23. Steam Line Pressure	S	R	M	

ATTACHMENT 2

DISCUSSION OF PROPOSED CHANGE

DISCUSSION OF PROPOSED CHANGE

Technical Specification Amendments Nos. 95 and 94 (dated February 24, 1984) to operating licenses DPR-32 and DPR-37 for the Surry Power Station, Units No. 1 and 2 respectively, removed the surveillance requirements on the boron injection tank level instruments in Table 4.1. Due to an administrative error, surveillance requirements for the boron injection tank level instruments were inadvertently included in Technical Specification Amendments Nos. 97 and 96 on Table 4.1-1 (dated June 19, 1984) for Surry Power Station, Units 1 and 2 respectively.

The proposed change simply deletes the surveillance requirements from the text previously deleted by Amendment Nos. 95/94. The Safety Evaluation, concluding that no unreviewed safety question (as defined in 10CFR50.59) exists, remains unchanged from that supporting Amendment Nos. 95/94.

In a similar manner, no significant hazards consideration as defined in 10CFR50.92 exists because the proposed amendment is administrative in nature and is similar to Example (1) of the examples provided by the Commission (48FR14870) that are considered not likely to involve significant hazards consideration.