

TABLE 4.1-1 (Continued)

<u>CHANNEL DESCRIPTION</u>	<u>CHECK</u>	<u>CALIBRATE</u>	<u>TEST</u>	<u>REMARKS</u>
24. Turbine First Stage Pressure	S	R	M	
25. Emergency Plan Radiation Instr.	*M	R	M	
26. Environmental Radiation Monitors	*M	N.A.	N.A.	TLD Dosimeters
27. Logic Channel Testing	N.A.	N.A.	M	
28. Turbine Overspeed Protection Trip Channel (Electrical)	N.A.	R	R	
29. Turbine Trip Setpoint	N.A.	R	R	Stop valve closure or low EH fluid pressure
30. Seismic Instrumentation	M	R	M	
31. Reactor Trip Breaker	N.A.	N.A.	M	The test shall independently verify operability of the under- voltage and shunt trip attachments
a. Undervoltage Trip Logic	N.A.	N.A.	M	
b. Shunt Trip Logic	N.A.	N.A.	M	
32. Reactor Coolant Pressure	N.A.	R	N.A.	
33. Auxiliary Feedwater				
a. Steam Generator Water Level Low-Low	S	R	M	
b. RCP Undervoltage	S	R	M	
c. S.I.	(All Safety Injection surveillance requirements)			
d. Station Blackout	N.A.	R	N.A.	
e. Main Feedwater Pump Trip	N.A.	N.A.	R	

8510100122 851007
PDR ADDCK 05000280
P PDR