

**Virginia Electric And Power Company  
Surry Power Station  
5570 Hog Island Road  
Surry, Virginia 23883**

August 27, 1999

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D. C. 20555

Serial No.: 99-436  
SPS: BCB  
Docket Nos.: 50-280, 50-281  
License Nos.: DPR-32, DPR-37


Dear Sirs:

Pursuant to Technical Specifications Table 3.7-6, Virginia Electric and Power Company hereby submits the following Special Report applicable to Surry Power Station Units 1 and 2.

Report No. 50-280, 50-281/1999-005-00

This report has been reviewed by the Station Nuclear Safety and Operating Committee and will be forwarded to the Management Safety Review Committee for its review.

Very truly yours,



E. S. Grecheck  
Site Vice President

Enclosure

Commitments contained in this letter:

1. To help minimize the potential for condensation within the system, heat trace is being installed on the radiation monitors' skid and sample discharge line.

9909020017 990827  
PDR ADOCK 05000280  
S PDR

020020

IE22

cc: U. S. Nuclear Regulatory Commission  
Region II  
Atlanta Federal Center  
61 Forsyth Street, SW, Suite 23T85  
Atlanta, Georgia 30303

Mr. R. A. Musser  
NRC Senior Resident Inspector  
Surry Power Station