



$$\text{VALVE BEST POINT NET HEAT RATE} = \frac{17,104,277 (1,188.7 - 427.2)}{1,306,768} = 9,967 \text{ BTU/KW-HR}$$