

	^(b) 1967	1968	1969	1970	1971	1972	1973	1974	^(d) 1975	1976	1977	1978	1979	1980	1981	1982	1983	1984
PEAK DEMAND - MW ^(c)																		
Firm	8276	8798	9234	9756	10970	11688	11975	11732	12474	13149	13940	14705	15475	16289	17144	18050	19145	20175
Interruptible	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total	8276	8798	9234	9756	10970	11688	11975	11732	12474	13149	13940	14705	15475	16289	17144	18050	19145	20175
RESOURCES - MW	10023	10427	11041	11162	11913	13690	14676	14865	14711	14913	15815	16051	16556	17290	19212	20219	21862	23099
SCHEDULED MAINTENANCE - MW ^(e)	0	36	516	458	1257	1558	2790	2730	486	301	1107	522	623	881	1153	739	721	1186
FIRM TRANSFERS - MW ^(f)	-149	-591	-1244	-1815	-1028	-916	-967	-1226	-1411	-1564	-1659	-1699	-1682	-1642	-1437	-1206	-993	-757
NET RESOURCES & FIRM TRANSFERS - MW	10172	10982	11769	12519	11684	13048	12853	13361	15636	16176	16367	17228	17615	18051	19496	20686	22134	22670
MARGIN OVER FIRM LOAD - MW	1896	2184	2535	2763	714	1360	878	1629	3162	3027	2427	2523	2140	1762	2352	2636	2989	2495
MARGIN OVER FIRM LOAD - PERCENT	22.9	24.8	27.5	28.3	6.5	11.6	7.3	13.9	25.3	23.0	17.4	17.2	13.8	10.8	13.7	14.6	15.6	12.4
ENERGY - AVERAGE MW ^(g)																		
Firm	5337	5702	6135	6563	6973	7415	7744	7475	7933	8272	8638	9069	9498	10015	10564	11191	11870	12558
Interruptible	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total	5337	5702	6135	6563	6973	7415	7744	7475	7933	8272	8638	9069	9498	10015	10564	11191	11870	12558
RESOURCES - AVG. MW	8347	8722	9269	+	+	+	+	+	11817	12005	12608	12909	13247	13698	14837	16258	17609	18484
SCHEDULED MAINTENANCE - AVG. MW	747	858	724	+	+	+	+	+	648	778	1039	926	885	803	1135	1268	1263	1393
FIRM TRANSFERS - AVG. MW ^(f)	-52	-140	-565	+	+	+	+	+	-301	-367	-382	-354	-327	-314	-243	-89	152	345
NET RESOURCES & FIRM TRANSFERS - AVG. MW	7652	8003	9110	+	+	+	+	+	11470	11594	11951	12337	12689	13209	13945	15079	16194	16746
MARGIN OVER FIRM LOAD - AVG. MW	2315	2300	2975	+	+	+	+	+	3537	3322	3313	3268	3191	3194	3381	3888	4324	4188
MARGIN OVER FIRM LOAD - PERCENT	43.6	40.5	48.6	+	+	+	+	+	44.6	40.2	38.4	36.0	33.6	31.9	32.0	34.7	36.4	33.3

+ Data Not Available

(a) WSCC Summary of Estimated Loads and Resources - 1968 Report, 1969 Report, 1970 Report, 1971 Report, 1972 Report, 1973 Report, 1974 Report, 1975 Report

(b) Loads and resources data are estimated for 1967

(c) Prior to 1971, the annual peak demand for Subarea "A" of the Pacific Southwest Power Area (PSWA) occurred in December - thus December data have been used for 1967 through 1970. Annual peak demands have occurred, or are estimated to occur, during the Summer (June through September) from 1971 through 1984 - thus Summer data have been used for 1971 through 1984.

(d) Data for 1975 through 1984 are estimates from the WSCC Summary of Estimated Loads and Resources issued April 1975.

(e) Recorded data includes forced outages as well as scheduled maintenance.

(f) A "-" indicates transfers into PSWA-A. Firm Transfers are the net of sales, purchases, and other participants' shares of joint resource projects. Note: The capacity and energy associated with individual generating units included in Firm Transfers have not been reduced to reflect maintenance schedules.

(g) To convert Average Megawatts to Megawatthours, multiply by the number of hours in a year.

Table B1.2-6
LOADS AND RESOURCES SUMMARY
SUBAREA "A" OF THE PACIFIC
SOUTHWEST POWER AREA AS
REPORTED TO WSCC^(a) (1967-1984)