


Washington Public Power Supply System  
A JOINT OPERATING AGENCY

P. O. Box 968 3000 GEO. WASHINGTON WAY RICHLAND, WASHINGTON 99352 PHONE (509) 946-1611

December 9, 1976  
G02-76-540



Nuclear Regulatory Commission  
Region V  
Suite 202, Walnut Creek Plaza  
1900 N. California Boulevard  
Walnut Creek, California 94596

Attention: Mr. R. H. Engelken  
Director

Subject: WPPSS NUCLEAR PROJECT NO. 2  
IE CIRCULAR NO. 76-05  
DOCKET NUMBER 50-397

Reference: Letter, R.H. Engelken to J.J. Stein, same subject,  
dated October 8, 1976

Dear Mr. Engelken:

The Supply System has requested our A/E to review the applicability of the subject circular to Project WNP-2.

Our A/E reports that IE Circular 76-02 does not apply to WNP-2, since shock suppressors of the hydraulic type are not utilized for this project.

Very truly yours,

*D L Renberger*

D. L. RENBERGER  
Assistant Director  
Generation and Technology

DLR:GLC:ho

cc: Mr. D. Roe - Bonneville Power Administration  
NRC - Office of Inspection & Enforcement (Washington, D.C.)

a/b  
2