



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

July 30, 2018

Mr. Bryan C. Hanson  
Senior Vice President  
Exelon Generation Company, LLC  
President and Chief Nuclear Officer (CNO)  
Exelon Nuclear  
4300 Winfield Road  
Warrenville, IL 60555

SUBJECT: BRAIDWOOD STATION, UNITS 1 AND 2; BYRON STATION, UNIT NOS. 1 AND 2; CALVERT CLIFFS NUCLEAR POWER PLANT, UNITS 1 AND 2; CLINTON POWER STATION, UNIT NO. 1; DRESDEN NUCLEAR POWER STATION, UNITS 2 AND 3; JAMES A. FITZPATRICK NUCLEAR POWER PLANT; LASALLE COUNTY STATION, UNITS 1 AND 2; LIMERICK GENERATING STATION, UNITS 1 AND 2; NINE MILE POINT NUCLEAR STATION, UNITS 1 AND 2; PEACH BOTTOM ATOMIC POWER STATION, UNITS 2 AND 3; QUAD CITIES NUCLEAR POWER STATION, UNITS 1 AND 2; R. E. GINNA NUCLEAR POWER PLANT; AND THREE MILE ISLAND NUCLEAR STATION, UNIT 1 — WITHDRAWAL OF REQUEST TO USE ASME CODE CASE N-879 (EPID L-2018-LLR-0076)

Dear Mr. Hanson:

By application dated May 30, 2018 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML18151A023), Exelon Generation Company, LLC (Exelon, the licensee) submitted a request for a proposed alternative to the requirements of Title 10 of the *Code of Federal Regulations* (10 CFR) Section 50.55a, "Codes and standards," and the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code for Braidwood Station, Units 1 and 2; Byron Station, Unit Nos. 1 and 2; Calvert Cliffs Nuclear Power Plant, Units 1 and 2; Clinton Power Station, Unit No. 1; Dresden Nuclear Power Station, Units 2 and 3; James A. FitzPatrick Nuclear Power Plant; LaSalle County Station, Units 1 and 2; Limerick Generating Station, Units 1 and 2; Nine Mile Point Nuclear Station, Units 1 and 2; Peach Bottom Atomic Power Station, Units 2 and 3; Quad Cities Nuclear Power Station, Units 1 and 2; R. E. Ginna Nuclear Power Plant; and Three Mile Island Nuclear Station, Unit 1. The proposed alternative would allow the licensee to use ASME Code Case N-879, "Use of Micro-Alloyed Carbon Steel Bar in Patented Mechanical Joints and Fittings, Classes 1, 2, and 3, Section III, Division 1."

By letter dated July 10, 2018 (ADAMS Accession No. ML18186A545), the U.S. Nuclear Regulatory Commission (NRC) staff informed Exelon that supplemental information was needed for the staff to begin its detailed technical review of the application. By letter dated July 26, 2018 (ADAMS Accession No. ML18208A345), Exelon requested to withdraw the application for the proposed alternative to use ASME Code Case N-879. The staff acknowledges Exelon's request to withdraw the application. The staff's review of the application has ceased and EPID L-2018-LLR-0076 has been closed.

If Exelon decides to resubmit the request for the proposed alternative, the application must provide a plant-specific justification for the proposed alternative that includes the information the NRC requested in its July 10, 2018, letter. Future applications should be limited to a single facility. Prior to resubmitting, Exelon should participate in a pre-application meeting with the NRC staff to discuss its planned application.

Exelon requested the proposed alternative for the lifetime of its facilities. The NRC staff does not generally approve alternatives to 10 CFR 50.55a and the ASME codes beyond the current inservice inspection or testing intervals, unless specific circumstances would justify a longer interval. For example, the NRC staff has approved alternatives for the next inservice inspection or testing interval when it is near the end of the current interval and the ASME code requirements for the next interval are already incorporated in the rule.

If you have any questions, please contact me at (301) 415-1380.

Sincerely,

A handwritten signature in black ink, appearing to read 'BP', is positioned above the typed name.

Blake Purnell, Project Manager  
Plant Licensing Branch III  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket Nos. STN 50-456, STN 50-457,  
STN 50-454, STN 50-455, 50-317,  
50-318, 50-461, 50-237, 50-249,  
50-333, 50-373, 50-374, 50-352,  
50-353, 50-220, 50-410, 50-277,  
50-278, 50-254, 50-265, 50-244,  
and 50-289

cc: Distribution via Listserv

**SUBJECT:** BRAIDWOOD STATION, UNITS 1 AND 2; BYRON STATION, UNIT NOS. 1 AND 2; CALVERT CLIFFS NUCLEAR POWER PLANT, UNITS 1 AND 2; CLINTON POWER STATION, UNIT NO. 1; DRESDEN NUCLEAR POWER STATION, UNITS 2 AND 3; JAMES A. FITZPATRICK NUCLEAR POWER PLANT; LASALLE COUNTY STATION, UNITS 1 AND 2; LIMERICK GENERATING STATION, UNITS 1 AND 2; NINE MILE POINT NUCLEAR STATION, UNITS 1 AND 2; PEACH BOTTOM ATOMIC POWER STATION, UNITS 2 AND 3; QUAD CITIES NUCLEAR POWER STATION, UNITS 1 AND 2; R. E. GINNA NUCLEAR POWER PLANT; AND THREE MILE ISLAND NUCLEAR STATION, UNIT 1 — WITHDRAWAL OF REQUEST TO USE ASME CODE CASE N-879 (EPID L-2018-LLR-0076) DATED JULY 30, 2018

**DISTRIBUTION:****PUBLIC**

RidsAcrs\_MailCTR Resource  
 RidsNrrDorl Resource  
 DidsNrrDmlr Resource  
 RidsNrrDorlLpl1 Resource  
 RidsNrrDorlLpl3 Resource  
 RidsNrrDmlrMphb Resource  
 RidsNrrDe Resource  
 RidsNrrDeEmib Resource  
 RidsNrrLASRohrer Resource  
 RidsNrrLABClayton Resource  
 RidsNrrLAJBurkhardt  
 RidsRgn1MailCenter Resource  
 RidsRgn3MailCenter Resource  
 RidsNrrPMExelon Resource  
 RidsNrrPMBraidwood Resource

RidsNrrPMByron Resource  
 RidsNrrPMCalvertCliffs Resource  
 RidsNrrPMClinton Resource  
 RidsNrrPMDresden Resource  
 RidsNrrPMFitzPatrick Resource  
 RidsNrrPMLaSalle Resource  
 RidsNrrPMLimerick Resource  
 RidsNrrPMNineMilePoint Resource  
 RidsNrrPMPEachBottom Resource  
 RidsNrrPMQuadCities Resource  
 RidsNrrPMREGinna Resource  
 RidsNrrPMThreeMileIsland Resource  
 GCheruvenki, NRR  
 RDavis, NRR  
 CBasavaraju, NRR

**ADAMS Accession No. ML18207A264**

\*by email

|        |              |              |              |
|--------|--------------|--------------|--------------|
| OFFICE | DORL/LPL3/PM | DORL/LPL3/LA | DMLR/MPHB/BC |
| NAME   | BPurnell     | SRohrer      | SRuffin*     |
| DATE   | 7/30/18      | 7/30/18      | 7/30/18      |
| OFFICE | DE/EMIB/BC   | DORL/LPL3/BC | DORL/LPL3/PM |
| NAME   | SBailey*     | DWrona       | BPurnell     |
| DATE   | 7/30/18      | 7/30/18      | 7/30/18      |

**OFFICIAL RECORD COPY**