

Vogle PEmails

From: Hoellman, Jordan
Sent: Thursday, August 2, 2018 6:43 AM
To: Vogle PEmails
Subject: NRC Staff Proposed Revision to License Condition 2.D.(13) for LAR-17-037, dated 7/26/18
Attachments: PROPOSED REVISION TO SNC LICENSE CONDITION 2.D.(13).pdf

From: Hoellman, Jordan
Sent: Thursday, July 26, 2018 2:33 PM
Subject: NRC Staff Proposed Revision to LC 2.D.(13) for LAR-17-037

Hi all –

Please see the attached proposed revision to License Condition 2.D.(13) related to the Tier 2* change process described in LAR 17-037. Please note that we may make changes in formatting (numbering, punctuation at the end of each condition, indentation, etc.) to conform to the rest of the license.

Please let us know if you have any questions or concerns.

We are available to discuss the condition at next week's public meeting, if necessary.

Thanks,
Jordan

Hearing Identifier: Vogtle_COL_Docs_Public
Email Number: 332

Mail Envelope Properties (SN6PR0901MB236690D73ED5987D19A226C5D52C0)

Subject: NRC Staff Proposed Revision to License Condition 2.D.(13) for LAR-17-037,
dated 7/26/18
Sent Date: 8/2/2018 6:43:27 AM
Received Date: 8/2/2018 6:43:31 AM
From: Hoellman, Jordan

Created By: Jordan.Hoellman2@nrc.gov

Recipients:
"Vogtle PEmails" <Vogtle.PEmails@nrc.gov>
Tracking Status: None

Post Office: SN6PR0901MB2366.namprd09.prod.outlook.com

Files	Size	Date & Time	
MESSAGE	658	8/2/2018 6:43:31 AM	
PROPOSED REVISION TO SNC LICENSE CONDITION 2.D.(13).pdf			105262

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

STAFF PROPOSED REVISION TO LICENSE CONDITION 2.D.(13)

(13) Departures from certain plant-specific DCD Tier 2* information

- (a) SNC is exempt from the requirements of 10 CFR Part 52, Appendix D, Paragraphs VIII.B.6 and VIII.B.5.a for prior NRC approval of departures from Tier 2* information and departures from Tier 2 information involving a change to or departure from Tier 2* information, *except* for proposed departures that:
1. Involve design methodology or construction materials that deviate from a code or standard credited in the plant-specific DCD for establishing the criteria for the design or construction of a structure, system, or component (SSC) important to safety,
 2. Result in a change to a design process described in the plant-specific DCD that is material to implementation of an industry standard or endorsed regulatory guidance,
 3.
 - (i) Result in a change to the fuel criteria evaluation process, the fuel principal design requirements, or nuclear design of fuel and reactivity control system that is material to a fuel or reactivity control system design function, or
 - (ii) Result in any change to the maximum fuel rod average burn-up limits or the small break LOCA analysis methodology described in UFSAR Subsections 15.6.5.4B.2.2 or 15.6.5.4B.2.3,
 4. Adversely affect the containment debris limits or debris screen design criteria,
 5. Change the Reactor Coolant Pump (RCP) type from a canned motor to a different type of RCP,
 6. Result in a material change to the test objectives or test performance criteria the Passive Residual Heat Removal Heat Exchanger natural circulation test (first plant test), the Core Makeup Tank Heated Recirculation Tests (first three plants test), or the Automatic Depressurization System Blowdown Test (first three plants test),
 7. Involve structural materials or analytical or design methods, including design codes and analytical assumptions, that deviate from those credited in the plant-specific DCD for critical sections,
 8. Result in a change to the design of the steel faceplates, internal trusses, tie bars, or headed studs of the steel-concrete (SC) module walls in the Nuclear Island or the Shield Building, including SC-to-reinforced concrete (RC) connections,

9. Result in an increase in the demand to capacity (D/C) ratio of a critical section of the structure. SNC shall determine the D/C ratio under this condition for each critical section structural member affected by a departure by:
- (i) Using the Tier 2* information in the UFSAR Section 3.8 or Appendix 3H Table that directly states the D/C ratio or states the area of steel provided and the area of steel required for the affected structural member, or
 - (ii) Providing the same total area of steel across the entire critical section using any combination of rebar sizes and spacing allowed by the design basis codes used in the UFSAR as the total area of steel specified in UFSAR Section 3.8 and Appendix 3H Tables marked Tier 2*;
- (b) For a departure from Tier 2* information that does not require prior NRC approval under the exemption in License Condition 2.D.(13)(a), SNC may take the departure under and in compliance with the Tier 2 change processes in 10 CFR Part 52, Appendix D, Paragraph VIII.B.5, as modified by the exemption in License Condition 2.D.(13)(a). For each departure authorized by this License Condition:
- 1. The departure or change to Tier 2* information shall remain Tier 2* information in the plant-specific DCD.
 - 2. SNC shall prepare and maintain a written evaluation that provides the bases for its determinations regarding the criteria in License Condition 2.D.(13)(a). In the report that 10 CFR Part 52, Appendix D, Section X.B.1 requires SNC to submit, SNC shall include a brief description of each departure and a summary of the evaluation of the departure.