

A07/14/78

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)
DISTRIBUTION FOR INCOMING MATERIAL

50-316

REC: KEPPLER J G
NRC

ORG: SHALLER D V
IN & MI PWR

DOCDATE: 07/11/78
DATE RCVD: 07/14/78

DOCTYPE: LETTER NOTARIZED: NO

COPIES RECEIVED

SUBJECT:

LTR 1 ENCL 1

FORWARDING CORRECTED LICENSEE EVENT REPT (RO 50-316/78-043) ON 06/03/78
CONCERNING WHILE IN MODE 1 OPERATION PRESSURIZER STARTED DECLINING RAPIDLY,
DUE TO ONE OF TWO SPRAY VALVES FAILED ONE HALF OPEN.

PLANT NAME: COOK - UNIT 2

REVIEWER INITIAL: XJM
DISTRIBUTOR INITIAL: *nl*

***** DISTRIBUTION OF THIS MATERIAL IS AS FOLLOWS *****

NOTES:

1. SEND 3 COPIES OF ALL MATERIAL TO I&E
ED REEVES-1 CY ALL MATERIAL

INCIDENT REPORTS
(DISTRIBUTION CODE A002)

FOR ACTION: BR CHIEF LWR#2 BC**W/4 ENCL

INTERNAL:

REG FILE**W/ENCL
I & E**W/2 ENCL
I & C SYSTEMS BR**W/ENCL
NOVAK/CHECK**W/ENCL
AD FOR ENG**W/ENCL
HANAUER**W/ENCL
AD FOR SYS & PROJ**W/ENCL
ENGINEERING BR**W/ENCL
KREGER/J. COLLINS**W/ENCL
K SEYFRIT/IE**W/ENCL

NRC PDR**W/ENCL
MIPC**W/3 ENCL
EMERGENCY PLAN BR**W/ENCL
EEB**W/ENCL
PLANT SYSTEMS BR**W/ENCL
AD FOR PLANT SYSTEMS**W/ENCL
REACTOR SAFETY BR**W/ENCL
VOLLMER/BUNCH**W/ENCL
POWER SYS BR**W/ENCL

EXTERNAL:

LPDR'S
ST. JOSEPH, MI**W/ENCL
TERA**W/ENCL
NSIC**W/ENCL
ACRS CAT B**W/16 ENCL

DISTRIBUTION: LTR 45 ENCL 45
SIZE: 1P+1P

CONTROL NBR: 781950035

***** THE END *****



INDIANA & MICHIGAN POWER COMPANY

DONALD C. COOK NUCLEAR PLANT
P.O. Box 458, Bridgman, Michigan 49106

July 11, 1978

Mr. J.G. Keppler, Regional Director
Office of Inspection and Enforcement
United States Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

Operating License DPR-74
Docket No. 50-316

Dear Mr. Keppler:

Pursuant to the requirements of the Appendix A Technical Specifications
the following report is submitted:

RO 78-043/03L-0.

The attached report is being submitted late because during the reproduction
process of the Condition Report a paper defect in the original reproduced
as a number one in the event date which appeared to be a 13 when, in
actuality, the number should have been a 3.

Sincerely,

D.V. Shaller
Plant Manager

/bab

cc: J.E. Dolan
R.W. Jurgensen
R.F. Kroeger
R. Kilburn
R.J. Vollen BPI
K.R. Baker RO:III
R.C. Callen MPSC
P.W. Steketee, Esq.
R. Walsh, Esq.
G. Charnoff, Esq.

G. Olson
J.M. Hennigan
PNSRC
J.F. Stietzel
R.S. Keith
Dir., IE (30 copies)
Dir., MIPC (3 copies)

JUL 13 1978

A002
5/1

11-11-11

11-11-11

11-11-11

11-11-11

