

**From:** Fosaaen, Carrie <cfosaaen@nuscalepower.com>  
**Sent:** Wednesday, August 22, 2018 1:18 PM  
**To:** Tabatabai, Omid  
**Cc:** Chitty, Mark  
**Subject:** [External\_Sender] 8/22/2018 Clarification Call - FSAR, Tier 2, Section 10.4.11

**Importance:** High

**Attendees:**

Jon Muniga  
Mark Chitty  
Carrie Fosaaen

**Actions:**

- Remove table 10.4-22 and update references to point to correct information in Chapter 10.3, as applicable. This change will be provided with Revision 2 of the DCA.
- Revise sentence to read "Each tank is constructed of corrosion resistant material that is compatible with chemicals used"  
This change will be provided with Revision 2 of the DCA.

Please let me know if there are additions or corrections.



**Carrie Fosaaen**  
**Licensing Specialist 4**

**email:** [cfosaaen@nuscalepower.com](mailto:cfosaaen@nuscalepower.com)

**web:** [www.nuscalepower.com](http://www.nuscalepower.com)

**office:** 541.452.7126

The contents of this email are intended only for the person to whom it is addressed. If you received it by mistake, please inform me by reply email and then delete the message and any attachments. This email may contain proprietary, confidential and/or privileged material, which doesn't change if it is sent to an unintended recipient. Unless you have my consent, please do not copy, forward, or reveal the contents of this email to anyone.

**Confidentiality Notice:** This email message and thread, including any attachments, is for the sole use of the intended recipient(s) and may contain legally privileged and/or confidential information. Any unauthorized review, use, disclosure or distribution is prohibited. If you are not the intended recipient, please contact the sender by reply e-mail and destroy all copies of the original message. By inadvertent disclosure of this communication, NuScale Power, LLC does not waive any attorney-client privilege or attorney work-product privilege with respect hereto.