



August 13, 2018

NG-18-0099

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555-0001

Duane Arnold Energy Center  
Docket No. 50-331  
Renewed Op. License No. DPR-49

References: 1) Letter, Rich Anderson (NextEra Energy Duane Arnold, LLC) to U. S. NRC, NextEra Energy Duane Arnold, LLC Response to Request for Additional Information Regarding NRC Bulletin 2012-01, Design Vulnerability in Electric Power System, NG-14-0032, Date January 30, 2014 (ML14034A107)

Revision to Generic Schedule Provided in NEI 13-12, Open Phase Condition Industry Guidance Document

In Reference 1, NextEra Energy Duane Arnold, LLC (NextEra) stated the Open Phase Condition (OPC) Detection would be addressed in accordance with the Nuclear Energy Institute voluntary initiative. Subsequent to that time, NextEra has announced plans to permanently cease power operations no later than December 31, 2020, subject to certain regulatory reviews and approvals.

This letter is to notify NRC that NextEra will not be installing OPC Detection automatic lockout and its associated trip function during the September 2018 Refueling Outage in accordance with the previously stated schedule. Modifications to install automatic detection and control room alarms are currently being completed as originally scheduled. In addition, NextEra will continue to perform the interim corrective actions specified in Reference 1 throughout the remaining period of power operations.

If material conditions change as a result of the pending regulatory reviews and approvals, a new schedule for installing OPC Detection will be provided. If you have any questions or require additional information, please contact Mike Davis, Licensing Manager at (319) 851-7032.

A handwritten signature in black ink, appearing to read "Dean Curtland".

Dean Curtland  
Site Director, Duane Arnold Energy Center  
NextEra Energy Duane Arnold, LLC

cc: Administrator, Region III, USNRC  
Project Manager, DAEC, USNRC  
Senior Resident Inspector, DAEC, USNRC

IE76  
NRR