

Mailgram to N. C. Moseley from Tennessee Valley Authority dated February 22, 1975.

DISTRIBUTION:

50-260

H. D. Thornburg, IE

IE:HQS (5)

Office of Standards Development

→ Central Files

Division of Reactor Licensing (13)

PDR

Local PDR

NSIC

TIC

STATE

A0
(4)

w

MGHATLT HSB

2-021662E053 02/22/75

ICS IPMBNGZ CSP

2057735226 MGM TDBN HARTSELL AL 100 02-22 0823P EST

ZIP

western union

Mailgram



US ATOMIC ENERGY COMMISSION
REGION TWO DIRECTORATE OF REGULATOR
OPERATIONS 230 PEACHTREE ST NORTHWEST
ATLANTA GA 30303

UNIT TWO-FROM 2200 ON 2-21-75 TO 0215 ON 2-22-75 THE 120 VOLT CONTROL
POWER WAS OFF TO RCIC FLOW CONTROLLER, TORUS LEVEL INDICATOR AND THE
DRYWELL PRESSURE INDICATOR THE REACTOR WAS AT RATED POWER
H J GREEN BROWNS FERRY NUCLEAR PLANT

20:23 EDT

MGHATLT HSB

